

February 15, 2010

CERTIFIED MAIL: RETURN RECEIPT REQUESTED (7002 0860 0007 6826 8934)

Karen Dickinson Georgia-Pacific LLC Crossett Paper Operations 100 Mill Supply Road Crossett, AR 71635

RE: Discharge Permit Number AR0001210, AFIN 02-00013

Dear Ms. Dickinson:

Enclosed is the public notice, Fact Sheet, and a copy of the draft permit which the Arkansas Department of Environmental Quality (ADEQ) has prepared under the authority of the National Pollutant Discharge Elimination System and the Arkansas Water and Air Pollution Control Act. A copy of the final permit will be mailed to you when the Department has made a final permitting decision.

In accordance with Arkansas Pollution Control and Ecology Commission (APCEC) Regulation No. 8, Part 2.1.6, the enclosed public notice will be published by ADEQ in a newspaper of general circulation for one (1) day only. An invoice for the cost of publishing the public notice and proof of publication will be sent to you by the advertising newspaper. The permittee must send proof of publication and payment to the following address as soon as possible but no later than 30 days from the above date. Until this Department receives proof of publication of the public notice, no further action will be taken on the issuance of your discharge permit.

Arkansas Department of Environmental Quality Permits Branch-Water Division 5301 Northshore Drive North Little Rock, AR 72118-5317 501-682-0622 Fax: 501-682-0910

Comments must be received at ADEQ prior to the close of the public comment period as shown in the enclosed public notice. The public comment period will begin on the date of publication and will end no sooner than 30 days from that date. Once a final permit is issued by the Director and becomes effective, the permittee must comply with all terms and conditions of the permit, or be subject to enforcement actions for any instances of noncompliance during the duration of the permit, usually five (5) years. Consequently, it is imperative that you, as the applicant, thoroughly review the enclosed documentation for accuracy, applicability, and your ability to comply with all conditions therein.

Should you have any questions concerning any part of the permit, please contact Loretta Reiber, P.E. at (501) 682-0612.

Sincerely.

Chief, Water Division

SD:lr

Enclosure

PUBLIC NOTICE OF DRAFT DISCHARGE PERMIT PERMIT NUMBER AR0001210, AFIN 02-00013

This is to give notice that the Permits Branch of the Water Division of the Arkansas Department of Environmental Quality (ADEQ), 5301 Northshore Drive, North Little Rock, Arkansas 72118-5317 at telephone number (501) 682-0622, proposes a draft renewal of the permit for which an application was received on 3/2/2009 for the following applicant under the National Pollutant Discharge Elimination System (NPDES) and the Arkansas Water and Air Pollution Control Act.

Applicant: Georgia-Pacific LLC - Crossett Paper Operations, 100 Mill Supply Road, Crossett, AR 71635. Location: west on Hwy 82 from the paper mill, go 1 mile before turning left onto Texas Ave. Go 2 miles then turn right. Proceed until you come to a T in the road, noting where the primary clarifier is located; Latitude: 33° 08' 30"; Longitude: 91° 58' 12" in Ashley County, Arkansas. The discharge is into Mossy Lake, then to Coffee Creek, then to the Ouachita River in Segment 2D of the Ouachita River Basin.

ADEQ's contact person for submitting written comments, requesting information regarding the draft permit, or obtaining copy of the permit and the Fact Sheet is Loretta Reiber, P.E., at the above address and telephone number or by email at <a href="https://www.wienentwo.org/water.gov/wa

http://www.adeq.state.ar.us/water/branch_permits/individual_permits/pn_permits/pnpermits.asp.

The last day of the comment period is 30 days after the publication date. If the last day of the comment period is a Saturday, Sunday or legal holiday, the public comment period shall expire on the next day that is not a Saturday, Sunday or legal holiday. The permit will become effective approximately two weeks after the close of the comment period unless comments are received and/or a public hearing is requested prior to the close of the comment period requiring a delay of the effective date. Comments and public hearing procedures may be found at 40 CFR Parts 124.10 through 124.12 and APCEC Regulation No. 8. All persons, including the permittee, who wish to comment on ADEQ's draft permitting decision must submit written comments to ADEQ, along with their name and mailing address. After the public comment period, and public hearing, if one is held, ADEQ will issue a final permitting decision. A Public Hearing will be held when ADEQ finds a significant degree of public interest. ADEQ will notify the applicant and each person who has submitted written comments or requested notice of the final permitting decision. Any interested person who has submitted comments may appeal a final decision by ADEQ in accordance with the APCEC Regulation No. 8 (Administrative Procedures).

Fact Sheet

This Fact Sheet is for information and justification of the permit limits only and is not enforceable.

For renewal of the draft discharge Permit Number AR0001210 with AFIN 02-00013 to discharge to Waters of the State

1. PERMITTING AUTHORITY.

The issuing office is:

Arkansas Department of Environmental Quality 5301 Northshore Drive North Little Rock, Arkansas 72118-5317

2. APPLICANT.

The applicant's facility and mailing address is:

Georgia-Pacific LLC Crossett Paper Operations 100 Mill Supply Road Crossett, AR 71635

3. PREPARED BY.

The permit was prepared by:

Loretta Reiber, P.E. Staff Engineer Permits Branch, Water Division (501) 682-0612 E-Mail: reiber@adeq.state.ar.us

4. PERMIT ACTIVITY.

Previous Permit Effective Date: 9/01/2004 Previous Permit Expiration Date: 8/31/2009

The permittee submitted a permit renewal application on 3/2/2009. It is proposed that the current discharge permit be reissued for a 5-year term in accordance with regulations promulgated at 40 CFR Part 122.46(a).

Page 2 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

DMR Review:

The Discharge Monitoring Reports (DMR's) from December 2003 through December 2008 were reviewed during the permit renewal process. The only exceedance of a permit limit was the monthly average BOD5 concentration limit at Outfall 001 in December 2006. This exceedance appears due to a typographical error based upon a review of the daily maximum concentration and the loading rates reported for the same month. Therefore, no permit action will be taken.

Legal Order Review:

There are currently no active Consent Administrative Orders (CAOs) or Notice of Violations (NOVs) for this facility.

Use Attainability Analyses (UAAs)

A UAA was performed in the 1980's. As a result of this UAA, the fishable/swimmable uses as well as the drinking water use were removed for Coffee Creek and Mossy Lake. Reg. 2.406 and Chapter 5 of Reg. 2 do not apply to Coffee Creek and Mossy Lake.

EPA Region VI finalized a UAA in 2007. That UAA is under review and has not been incorporated into Reg. 2.

5. FINANCIAL ASSURANCE

The permittee is not required to obtain financial assurance because the City of Crossett, which discharges to Georgia-Pacific upstream of the aeration basin and downstream of all other treatment units, already owns and operates its own wastewater treatment plant.

6. SIGNIFICANT CHANGES FROM THE PREVIOUSLY ISSUED PERMIT.

The permittee is responsible for carefully reading the permit in detail and becoming familiar with all of the changes therein:

- 1. The outfall and the facility coordinates have been corrected.
- 2. The chloroform limits and monitoring requirements have been removed from all of the internal outfalls. These limits have been replaced with the following: minimum pH after the first bleaching stage, maximum Kappa Factor, and maximum total bleach line ClO₂ application rate. These limits are based on the data submitted by the permittee as required under 40 CFR 430.02(f).
- 3. The facility name has been corrected.
- 4. The BOD5 and the TSS concentration limits at Outfall 001 have changed based upon new production data.

Page 3 of Fact Sheet Permit Number: AR0001210 AFIN: 02-00013

- 5. Total Phosphorous and Nitrates monitoring and reporting requirements have been added to the permit at Outfall 001 and Stream Monitoring Station 2. These requirements have been added because the permittee adds a nutrient solution which contains phosphorous and nitrates to the treatment system prior to the aerated lagoon.
- 6. The BOD5 mass limits at Outfall 001 have decreased. These limits are calculated using production based Effluent Limitation Guidelines contained in 40 CFR Part 430, Subpart B. A decrease in the production of fine paper is the cause of the lower BOD5 limits.
- 7. The AOX limits at Outfall 001 have increased. These limits are calculated using production based Effluent Limitation Guidelines contained in 40 CFR Part 430, Subpart B. An increase in the production of unbleached pulp is the cause of the higher AOX limits.
- 8. Parts II, III, and IV have been modified.
- 9. Part II of the permit now specifies that the licensed operator must hold an Advanced Industrial license.
- 10. BMP language has replaced the SWPPP language.
- 11. Several metals and pesticides have been added to the permit at Outfall 001 and SMS2.
- 12. The description of the location of SMS2 has been reworded.

7. RECEIVING STREAM SEGMENT AND DISCHARGE LOCATION.

The outfall is located at the following coordinates based on the May 26, 2009, site visit, Google Earth, and the permit application using NAD83:

Outfall 001: Latitude : 33 ° 06' 25"; Longitude: 92 ° 02' 16"

SMS2: Latitude : 33 ° 01' 58"; Longitude: 92 ° 04' 25"

Internal Outfall 101: Latitude : 33 ° 08' 29.5"; Longitude: 91 ° 58' 25.8"

Internal Outfall 102: Latitude : 33 ° 08' 29.5"; Longitude: 91 ° 58' 25.8"

Latitude : 33 ° 08' 29.5"; Longitude: 91 ° 58' 25.8"

Latitude : 33 ° 08' 29.5"; Longitude: 91 ° 58' 25.8"

The receiving waters named:

Mossy Lake, then to Coffee Creek, then to the Ouachita River in Segment 2D of the Ouachita River Basin. The receiving stream with USGS Hydrologic Unit Code (H.U.C) of 8040202 is a Water of the State classified for primary and secondary contact recreation, raw water source for domestic (public and private), industrial, and agricultural water supplies, propagation of desirable species of fish and other aquatic life, and other compatible uses.

Page 4 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

8. 303(d) LIST AND ENDANGERED SPECIES CONSIDERATIONS.

a. 303(d) List:

Coffee Creek below Mossy Lake is not listed on the 303(d) list. However, Reach #002 of the Ouachita River in HUC 08040202 is on the 303(d) list for Mercury in Category 4a. A numerical limit on Total Recoverable Mercury has been included in the permit.

Coffee Creek enters the Ouachita River in Reach #002, HUC 08040202 of Segment 2D in the Ouachita River Basin. The Ouachita River is on the State's currently approved 303(d) list in Category 5d as impaired due to Total Recoverable Copper and Total Recoverable Zinc. The sources of such pollutants are unknown. In accordance with the requirements of 40 CFR Part 122.4(i) (prohibitions on issuance of a discharge permit for a discharge to impaired waters), information and data provided in the application, or additional information supplied by the applicant indicates that pollutants of concern are present in the effluent at concentrations which are above detection levels. Detection levels, where applicable, are consistent with EPA-defined minimum quantification levels (MQLs). Therefore, the proposed permit establishes end-of pipe (point-of-discharge) limits, based on the most stringent applicable water quality criteria established for the receiving water, to ensure that the discharge will not contribute Total Recoverable Copper or Total Recoverable Zinc to the receiving water at levels which may exacerbate the impairment of the receiving water's designated uses. However, the stream segments listed in Category 5d are those in need of additional data to verify the accuracy of the assessment. The Department therefore reserves the right to remove these requirements at the time of the next permit renewal if the data collected demonstrates that there is not reasonable potential for water quality violations due to the levels of these parameters in the effluent and/or the reach and HUC of the Ouachita River is no longer on the 303(d) list for these parameters.

b. Endangered Species:

No comments on the application were received from the U.S. Fish and Wildlife Service (USF&WS). The draft permit and Fact Sheet will be sent to the USF&WS for their review.

Page 5 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

9. OUTFALL AND TREATMENT PROCESS DESCRIPTION.

The following is a description of the facility described in the application:

Design Flow: 45 MGD.

Type of Treatment: screening followed by primary clarifier, settling for ash removal,

equalization, aerated lagoon with solids settling, and sludge

dewatering.

Discharge Description: process wastewater (Paper Mill, Plywood Plant, and Studmill

operations), sanitary wastewater, landfill leachate, site stormwater, chemical plant, building products, treated effluent from the City of

Crossett, truck wash and backwash wastewater.

The City of Crossett treats sanitary wastewater and some industrial wastewater in a two cell lagoon. This wastewater enters the Georgia-Pacific treatment system upstream of the aerated lagoon and downstream of any other treatment unit located at this facility.

Facility Status: This facility was evaluated using the NPDES Permit Rating Worksheet

(MRAT) to determine the correct permitting status. Since the facility's MRAT score of 130 is greater than 80, this facility is classified as a Major

industrial.

10. APPLICANT ACTIVITY.

Under the Standard Industrial Classification (SIC) code of 2621 or the North American Industry Classification System (NAICS) code of 322121, the applicant's activities are the operation of a paper mill.

11. SLUDGE PRACTICES.

Sludge is placed in the facility's north landfill (Permit No. 292-S3N) as necessary. Sludge is mechanically dewatered. The dewatered sludge may be combined with ash, sand, and grit for use as fill material for the sludge pond closure.

12. PERMIT CONDITIONS.

The Arkansas Department of Environmental Quality has made a determination to issue a draft permit for the discharge described in the application. Permit requirements are based on federal regulations (40 CFR Parts 122, 124, and Subchapter N) and regulations promulgated pursuant to the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended, Ark. Code Ann. 8-4-101 et. seq.).

Page 6 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

a. Final Effluent Limitations

Outfall 001 - process wastewater (Paper Mill, Plywood Plant, and Studmill operations), sanitary wastewater, landfill leachate, site stormwater, chemical plant, building products, treated effluent from the City of Crossett, truck wash and backwash wastewater (Note: Outfall 001 is located immediately downstream of the permittee's aerated lagoon.)

1. Conventional and/or Toxic Pollutants

		Discharge	Monitoring Requirements			
Effluent Characteristics	Ma	SS	Concer	ntration		
Etituent Characteristics	(lbs/day, unle	ss otherwise	(mg/l,	unless		
	specif	ied)	otherwise	specified)	Frequency	Sample Type
	Monthly	Daily Max	Monthly	Daily Max		
	Avg.		Avg.			
Flow (MGD)	N/A	N/A	Report	Report	daily	totalizing meter
Biochemical Oxygen Demand (BOD5)	24155.4	46453.0	64.6	123.8	three/week	24-hr composite
Total Suspended Solids (TSS)	37720	70188	119.6	222.4	three/week	24-hr composite
2,3,7,8-TCDD	Report	Report	Report pg/l	Report pg/l	once/quarter	24-hr composite
Adsorbable Organic Halogens (AOX)	2193.04	3299.97	N/A	N/A	once/day	24-hr composite
Dieldrin	0.00034	0.0011	0.00091µg/l	0.00284 μg/l	once/month	24-hr composite
Total Recoverable Copper	8.42	16.89	22.43 μg/Ι	45.00 μg/l	once/month	24-hr composite
Total Recoverable Mercury	0.026	0.053	0.07 μg/l	0.14 μg/l	once/month	24-hr composite
Total Recoverable Zinc	75.21	150.90	200.40 μg/l	402.09 μg/l	once/month	24-hr composite
Total Phosphorous	Report	Report	Report	Report	three/week	24-hr composite
Nitrates as Nitrogen	Report	Report	Report	Report	three/week	24-hr composite
рН	N/A	N/A	Minimum 6.0 s.u.	Maximum 9.0 s.u.	once/day	grab
Chronic WET Testing	N/A	N/A		em #14 of this Sheet.	once/2 months	24-hr composite

2. Solids, Foam, and Free Oil: There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

Page 7 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

b. Final Effluent Limitations

Stream Monitoring Station (SMS) 002 - At the Transition from Mossy Lake to Coffee Creek

1. Conventional and/or Toxic Pollutants

		Discharge	Monitoring Requirements*			
Effluent Characteristics	Mass (lbs/day, unless otherwise specified)		Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		
Flow (MGD)	N/A	N/A	Report	Report	daily	totalizing meter
Biochemical Oxygen Demand (BOD5)						
(October – July)	8000	12000	Report	Report	three/week	24-hr composite
(August)	7262	10893	Report	Report	three/week	24-hr composite
(September)	5911	8867	Report	Report	three/week	24-hr composite
Total Suspended Solids (TSS)	18000	30000	Report	Report	three/week	24-hr composite
Dieldrin	0.00034	0.0011	0.00091 μg/l	0.00284 μg/l	once/month	24-hr composite
Total Recoverable Copper	8.42	16.89	22.43 μg/l	45.00 μg/l	once/month	24-hr composite
Total Recoverable Mercury	0.026	0.053	0.07 μg/l	0.14 μg/l	once/month	24-hr composite
Total Recoverable Zinc	75.21	150.90	200.40 μg/l	402.09 μg/l	once/month	24-hr composite
Total Phosphorous	Report	Report	Report	Report	three/week	24-hr composite
Nitrates as Nitrogen	Report	Report	Report	Report	three/week	24-hr composite
рН	N/A	N/A	Minimum 6.0 s.u.	Maximum 9.0 s.u.	once/day	grab

^{*} When Mossy Lake is not flooded. A flooded state is defined as the period when the gauge at the Felsenthal Lock and Dam exceeds 62 feet and also for the two weeks following the recession of flood waters below 62 feet.

2. **Solids, Foam, and Free Oil:** There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).



Page 8 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

c. Effluent Limitations

Internal Outfall 101 - Line 1A of Hardwood Effluent

1. Conventional and/or Toxic Pollutants

		Discharge	Monitoring Requirements			
Effluent Characteristics	Mass (lbs/day, unless otherwise specified)		Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		
Flow (MGD)	N/A	N/A	Report	Report	Daily	Instantaneous
2,3,7,8-Tetrachlorodibenzo-p- dioxin (TCDD)	N/A	N/A	N/A	< 10 pg/l	Once/month	24-hr composite
2,3,7,8-Tetrachlorodibenzofuran (TCDF)	N/A	N/A	N/A	31.9 pg/l	Once/month	24-hr composite
Trichlorosyringol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
3,4,5-Trichlorocatechol	N/A	N/A	N/A	< 5.0 μg/l	Once/month	24-hr composite
3,4,6-Trichlorocatechol	N/A	N/A	N/A	< 5.0 μg/l	Once/month	24-hr composite
3,4,5-Trichloroguaiacol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
3,4,6-Trichloroguaiacol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
4,5,6-Trichloroguaiacol	N/A	N/A	N/A	$< 2.5 \mu g/l$	Once/month	24-hr composite
2,4,5-Trichlorophenol	N/A	N/A	N/A	$< 2.5 \mu g/l$	Once/month	24-hr composite
2,4,6-Trichlorophenol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
Tetrachlorocatechol	N/A	N/A	N/A	< 5.0 μg/l	Once/month	24-hr composite
Tetrachloroguaiacol	N/A	N/A	N/A	< 5.0 μg/l	Once/month	24-hr composite
2,3,4,6-Tetrachlorophenol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
Pentachlorophenol	N/A	N/A	N/A	<5.0 μg/l	Once/month	24-hr composite
pH of 1 st ClO ₂ Bleaching Stage	N/A	N/A		minimum	Once/day	Grab
Kappa Factor	N/A	N/A		naximum	Once/day	Grab
Total Bleach Line ClO ₂ Application Rate	N/A	N/A		O ₂ /ton of pulp, imum	Once/day	Totalizing Meter



Page 9 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

d. Effluent Limitations

Internal Outfall 102 – Line 1B of Hardwood Effluent

1. Conventional and/or Toxic Pollutants

		Discharge	Monitoring Requirements			
Effluent Characteristics	Mass (lbs/day, unless otherwise specified)		(mg/l	entration , unless e specified)	Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		
Flow (MGD)	N/A	N/A	Report	Report	Daily	Instantaneous
2,3,7,8-Tetrachlorodibenzo-p- dioxin (TCDD)	N/A	N/A	N/A	< 10 pg/l	Once/month	24-hr composite
2,3,7,8-Tetrachlorodibenzofuran (TCDF)	N/A	N/A	N/A	31.9 pg/l	Once/month	24-hr composite
Trichlorosyringol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
3,4,5-Trichlorocatechol	N/A	N/A	N/A	< 5.0 μg/l	Once/month	24-hr composite
3,4,6-Trichlorocatechol	N/A	N/A	N/A	$< 5.0 \mu g/1$	Once/month	24-hr composite
3,4,5-Trichloroguaiacol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
3,4,6-Trichloroguaiacol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
4,5,6-Trichloroguaiacol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
2,4,5-Trichlorophenol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
2,4,6-Trichlorophenol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
Tetrachlorocatechol	N/A	N/A	N/A	< 5.0 μg/l	Once/month	24-hr composite
Tetrachloroguaiacol	N/A	N/A	N/A	< 5.0 μg/l	Once/month	24-hr composite
2,3,4,6-Tetrachlorophenol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
Pentachlorophenol	N/A	N/A	N/A	<5.0 μg/l	Once/month	24-hr composite
pH of 1 st ClO ₂ Bleaching Stage	N/A	N/A		, minimum	Once/day	Grab
Kappa Factor	N/A	N/A	0.42, n	naximum	Once/day	Grab
Total Bleach Line ClO ₂ Application Rate	N/A	N/A		D_2 /ton of pulp, imum	Once/day	Totalizing Meter



Page 10 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

e. Effluent Limitations

Internal Outfall 103 – Line 2 of Softwood Effluent

1. Conventional and/or Toxic Pollutants

		Discharge	Monitoring Requirements			
Effluent Characteristics	Mass (lbs/day, unless otherwise specified)		Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		
Flow (MGD)	N/A	N/A	Report	Report	Daily	Instantaneous
2,3,7,8-Tetrachlorodibenzo-p- dioxin (TCDD)	N/A	N/A	N/A	< 10 pg/l	Once/month	24-hr composite
2,3,7,8-Tetrachlorodibenzofuran (TCDF)	N/A	N/A	N/A	31.9 pg/l	Once/month	24-hr composite
Trichlorosyringol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
3,4,5-Trichlorocatechol	N/A	N/A	N/A	< 5.0 μg/l	Once/month	24-hr composite
3,4,6-Trichlorocatechol	N/A	N/A	N/A	< 5.0 μg/l	Once/month	24-hr composite
3,4,5-Trichloroguaiacol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
3,4,6-Trichloroguaiacol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
4,5,6-Trichloroguaiacol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
2,4,5-Trichlorophenol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
2,4,6-Trichlorophenol	N/A	N/A	N/A	$< 2.5 \mu g/1$	Once/month	24-hr composite
Tetrachlorocatechol	N/A	N/A	N/A	$< 5.0 \mu g/l$	Once/month	24-hr composite
Tetrachloroguaiacol	N/A	N/A	N/A	$< 5.0 \mu g/1$	Once/month	24-hr composite
2,3,4,6-Tetrachlorophenol	N/A	N/A	N/A	< 2.5 μg/l	Once/month	24-hr composite
Pentachlorophenol	N/A	N/A	N/A	<5.0 μg/l	Once/month	24-hr composite
pH of 1 st ClO ₂ Bleaching Stage	N/A	N/A	1.28 s.u.	, minimum	Once/day	Grab
Kappa Factor	N/A	N/A		naximum	Once/day	Grab
Total Bleach Line ClO ₂ Application Rate	N/A	N/A		D ₂ /ton of pulp, imum	Once/day	Totalizing Meter

13. BASIS FOR PERMIT CONDITIONS.

The following is an explanation of the derivation of the conditions of the draft permit and the reasons for them or, in the case of notices of intent to deny or terminate, reasons suggesting the decisions as required under 40 CFR Part 124.7 (48 FR 1413, April 1, 1983).

Page 11 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

Technology-Based versus Water Quality-Based Effluent Limitations and Conditions

Following regulations promulgated at 40 CFR Part 122.44 (1) (2) (ii), the draft permit limits are based on either technology-based effluent limits pursuant to 40 CFR Part 122.44 (a) or on State water quality standards and requirements pursuant to 40 CFR Part 122.44 (d), whichever are more stringent as follows:

		Water Quality- Technology- Based Based			Previous Permit		Permit	
Parameter	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l
		OUT	FALL 00	1				
BOD5 Concentration Mass (lbs/day) TSS Concentration	N/A N/A	N/A N/A	64.4 24155.4 119.6	123.8 46453.0 222.4	70 26310	135 50617 249	64.4 24155.4 119.6	123.8 46453.0 222.4
40 CFR 430.22, Mass (lbs/day) BPJ limits, Mass (lbs/day)	N/A N/A	N/A N/A	44868.2 37720	83481.1 70188	37720	70188	37720	70188
2,3,7,8-TCDD	N/A	N/A	Report	Report	Report	Report	Report	Report
AOX, lbs/day	N/A	N/A	2193.04	3299.97	2146	3276	2193.04	3299.97
Dieldrin	0.00091 µg/l	0.00284 μg/l	N/A	N/A	N/A	N/A	0.00091 μg/l	0.00284 μg/l
Total Recoverable Copper	22.43 μg/l	45.00 μg/l	N/A	N/A	N/A	N/A	22.43 μg/l	45.00 μg/l
Total Recoverable Mercury	0.07 μg/l	0.14 μg/l	N/A	N/A	N/A	N/A	0.07 μg/l	0.14 μg/l
Total Recoverable Zinc	200.40 μg/l	402.09 μg/l	N/A	N/A	N/A	N/A	200.40 μg/l	402.09 μg/l
Total Phosphorous	N/A	N/A	Report	Report	N/A	N/A	Report	Report
Nitrates as Nitrogen	N/A	N/A	Report	Report	N/A	N/A	Report	Report
pH	6.0 - 9	0.0 s.u.	5.0 - 9	0.0 s.u.	6.0 – 9	.0 s.u.	6.0 - 9).0 s.u.
			SMS2					
BOD5, lb/day						-		
October – July	8000	12000	N/A	N/A	8000	12000	8000	12000
August	7262	10893	N/A	N/A	7262	10893	7262	10893

Page 12 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

	Water (Quality- sed	Technology- Based		Previous Permit		Draft Permit	
Parameter	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l
September	5911	8867	N/A	N/A	5911	8867	5911	8867
TSS, lb/day	18000	30000	N/A	N/A	18000	30000	18000	30000
Dieldrin	0.00091 μg/l	0.00284 μg/l	N/A	N/A	N/A	N/A	0.00091 μg/l	0.00284 μg/l
Total Recoverable Copper	22.43 μg/l	45.00 μg/l	N/A	N/A	N/A	N/A	22.43 μg/l	45.00 μg/l
Total Recoverable Mercury	0.07 μg/l	0.14 μg/l	N/A	N/A	N/A	N/A	0.07 μg/l	0.14 μg/l
Total Recoverable Zinc	200.40 μg/l	402.09 μg/l	N/A	N/A	N/A	N/A	200.40 μg/l	402.09 μg/l
Total Phosphorous	N/A	N/A	Report	Report	N/A	N/A	Report	Report
Nitrates as Nitrogen	N/A	N/A	Report	Report	N/A	N/A	Report	Report
рН	6.0 - 9).0 s.u.	N/	/A	6.0 – 9	.0 s.u.	6.0 - 9	0.0 s.u.
,	ALL INTER	NAL OU	TFALLS (101, 102,	and 103)			
TCDD	N/A	N/A	N/A	<10 pg/l*	N/A	<10 pg/l*	N/A	<10 pg/l*
TCDF	N/A	N/A	N/A	31.9 pg/l*	N/A	31.9 pg/l*	N/A	31.9 pg/l*
Trichlorosyringol	N/A	N/A	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l
3,4,5-Trichlorocatechol	N/A	N/A	N/A	< 5.0 μg/l	N/A	< 5.0 μg/l	N/A	< 5.0 μg/l
3,4,6-Trichlorocatechol	N/A	N/A	N/A	< 5.0 μg/l	N/A	< 5.0 μg/l	N/A	< 5.0 μg/l
3,4,5-Trichloroguaiacol	N/A	N/A	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l
3,4,6-Trichloroguaiacol	N/A	N/A	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l
4,5,6-Trichloroguaiacol	N/A	N/A	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l
2,4,5-Trichlorophenol	N/A	N/A	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l
2,4,6-Trichlorophenol	N/A	N/A	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l

Page 13 of Fact Sheet Permit Number: AR0001210 AFIN: 02-00013

	Water C Bas	-	Techno		Prev Per		Draft I	Permit	
Parameter	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l	Max. Avg. M mg/l mg/l m 5.0 N/A 1g/l N/A 15.0 N/A 1g/l N/A 12.5 N/A 15.0 N/A 15	Daily Max. mg/l	
Tetrachlorocatechol	N/A	N/A	N/A	< 5.0 μg/l	N/A	< 5.0 μg/l	N/A	< 5.0 μg/l	
Tetrachloroguaiacol	N/A	N/A	N/A	< 5.0 μg/l	N/A	< 5.0 μg/l	N/A	< 5.0 μg/l	
2,3,4,6-Tetrachlorophenol	N/A	N/A	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l	N/A	< 2.5 μg/l	
Pentachlorophenol	N/A	N/A	N/A	<5.0 μg/l	N/A	<5.0 μg/l	N/A	<5.0 μg/l	
		Intern	al Outfall 1	.01				-	
pH of 1 st ClO ₂ Bleaching Stage	N/A		1	1.86 s.u., minimum		N/A		1.86 s.u., minimum	
Kappa Factor of 1 st ClO ₂ Bleaching Stage	N/A		0.45, ma	aximum	N/	N/A		aximum	
Total Bleach Line ClO ₂ Application Rate	N/	'A	134.2 lb ClO ₂ /ton of pulp, maximum		N/A		1		
		Intern	al Outfall 1	.02					
pH of 1 st ClO ₂ Bleaching Stage	N/	A	1.76 minii	/	N/	'A		,	
Kappa Factor of 1 st ClO ₂ Bleaching Stage	N/	'A	0.42, ma	aximum	N/A		0.42, maximum		
Total Bleach Line ClO ₂ Application Rate	N/	'A	128.2 lb of pulp, n	ClO ₂ /ton naximum	- N/Δ		128.2 lb ClO ₂ /ton of pulp, maximum		
		Intern	al Outfall 1	03					
pH of 1 st ClO ₂ Bleaching Stage	N/	'A	1.28 minii	,	N/	'A	1.28 minii		
Kappa Factor of 1 st ClO ₂ Bleaching Stage	N/	'A	0.57, ma		N/	'A	0.57, ma	aximum	
Total Bleach Line ClO ₂ Application Rate	N/	'A	185.8 lb of pulp, n	ClO ₂ /ton naximum	N/	'A	185.8 lb of pulp, n	_	

Page 14 of Fact Sheet Permit Number: AR0001210 AFIN: 02-00013

Parameter	Water Quality or Technology	Justification
Outfall 001	or reciniology	ASSOCIATION OF THE PROPERTY OF
BOD5	Technology	40 CFR 430.22(a)
TSS	Technology	40 CFR 430.22(a) and continued from previous permit
2,3,7,8-TCDD	Technology	40 CFR 430.24(a)(1)
AOX	Technology	40 CFR 430.24(a)(1)
Dieldrin	Water Quality	L.A.C. 33:IX:1113
Total Recoverable Copper	Water Quality	Reg. 2.508
Total Recoverable Mercury	Water Quality	Reg. 2.508
Total Recoverable Zinc	Water Quality	Reg. 2.508
Total Phosphorous	Technology	Judgment of permit writer (see further explanation below this table.)
Nitrates as Nitrogen	Technology	Judgment of permit writer (see further explanation below this table.)
pH	Water Quality	Reg. 2.504
SMS2		
BOD5		
October – July	Water Quality	TMDL/WLA report approved by EPA on 01/11/2002
August	Water Quality	TMDL/WLA report approved by EPA on 01/11/2002
September	Water Quality	TMDL/WLA report approved by EPA on 01/11/2002
TSS	Water Quality	TMDL/WLA report approved by EPA on 01/11/2002
Dieldrin	Water Quality	L.A.C. 33:IX:1113
Total Recoverable Copper	Water Quality	Reg. 2.508
Total Recoverable Mercury	Water Quality	Reg. 2.508
Total Recoverable Zinc	Water Quality	Reg. 2.508
Total Phosphorous	Technology	Judgment of permit writer (see further explanation below this table.)
Nitrates as Nitrogen	Technology	Judgment of permit writer (see further explanation below this table.)
pH	Water Quality	Reg. 2.504
All Internal Outfalls		
TCDD	Technology	40 CFR 430.24(a)(1)
TCDF	Technology	40 CFR 430.24(a)(1)
Trichlorosyringol	Technology	40 CFR 430.24(a)(1)
3,4,5-Trichlorocatechol	Technology	40 CFR 430.24(a)(1)
3,4,6-Trichlorocatechol	Technology	40 CFR 430.24(a)(1)
3,4,5-Trichloroguaiacol	Technology	40 CFR 430.24(a)(1)
3,4,6-Trichloroguaiacol	Technology	40 CFR 430.24(a)(1)
4,5,6-Trichloroguaiacol	Technology	40 CFR 430.24(a)(1)
2,4,5-Trichlorophenol	Technology	40 CFR 430.24(a)(1)

Page 15 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

Parameter	Water Quality or Technology	Justification
2,4,6-Trichlorophenol	Technology	40 CFR 430.24(a)(1)
Tetrachlorocatechol	Technology	40 CFR 430.24(a)(1)
Tetrachloroguaiacol	Technology	40 CFR 430.24(a)(1)
2,3,4,6-Tetrachlorophenol	Technology	40 CFR 430.24(a)(1)
Pentachlorophenol	Technology	40 CFR 430.24(a)(1)
pH of 1 st ClO ₂ Bleaching Stage	Technology	40 CFR 430.02(f)
Kappa Factor of 1 st ClO ₂ Bleaching Stage	Technology	40 CFR 430.02(f)
Total Bleach Line ClO ₂ Application Rate	Technology	40 CFR 430.02(f)

The explanation for all technology-based limits may be found below in Item #13.b.iii. The calculations for all water-quality based toxics limits may be found below in Item #13.e.

Limits and Requirements Applicable at Both Outfall 001 and SMS2

The pH limits are remaining unchanged with this permit renewal.

The Department recognizes that Chapter 5 of Reg. No. 2 does not apply to Outfall 001. However, the toxics limits have been included at Outfall 001 in addition to SMS2 because the permittee cannot always monitor at SMS2 due to flooding of Mossy Lake. The limits at Outfall 001 are the numerical limits which were calculated for SMS2. The permittee will be required to monitor at both locations when Mossy Lake is not flooded. This is to ensure that there is a continuity of data at a single location.

Monitoring and reporting requirements for Total Phosphorous and Nitrates as Nitrogen have been included in the permit at Outfall 001 and SMS2 because the permittee adds a nutrient solution just prior to the aerated lagoon to aid in biological activity. Nitrites have not been included in the requirements because the MSDS of the nutrient mix does not indicate that nitrites are present. Numerical limits have not been included in the permit because water quality standards do not apply at Outfall 001 and the effluent passing through SMS2 enters the Ouachita River downstream of the Felsenthal National Wildlife Refuge via a half-mile stretch of Coffee Creek.

a. Anti-backsliding

The draft permit is consistent with the requirements to meet Anti-backsliding provisions of the Clean Water Act (CWA), Section 402(o) [40 CFR 122.44(l)]. The final effluent limitations for reissuance permits must be as stringent as those in the previous permit,

Page 16 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

unless the less stringent limitations can be justified using exceptions listed in 40 CFR 122.44 (l)(2)(i).

The draft permit maintains the requirements of the previous permit with the exception of the removal of chloroform at the internal outfalls. This removal is allowed under 40 CFR 430.02(f) as long as the requirements of the section are met. The permittee has met the certification requirements and the reporting requirements have been included in the permit. (See 40 CFR 122.44(l)(2)(i)(B)(1).)

b. Limits Calculations

i. Mass limits:

The calculation of the loadings (lbs per day) uses a design flow of 45 MGD and the following equation:

lbs/day = Concentration (mg/l) X Flow (MGD) X 8.34

The applicable parts of 40 CFR do not require that the permit contain concentration limits for BOD5 and TSS. Therefore it is not necessary to calculate the mass limits and ratios of wastewaters from various sources to determine concentration limits. The concentration limits for BOD5 and TSS were calculated using the highest average monthly flow and the mass limits calculated for the paper mill discharge.

ii. Daily Maximum Limits:

Daily maximum limits are based on the standards contained in 40 CFR Part 430 and the CPP.

iii. Process wastewater

Outfall 001

Paper Mill

According to the permit renewal application, GP produces 257 tons per day of fine paper (Step 1) and 1512 tons per day Paperboard and Tissue Paper (Step 2).

Effluent limitations guidelines (ELG) for Bleached Paper grade Kraft and Soda Subcategory (40 CFR Part 430.22) cover this industry. Final effluent limitations for BOD5 and TSS are based on 40 CFR Part 430.22 Subpart B (Please see below for calculations).

Page 17 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

Calculations:

Step 1:

Effluent limitations based on production of 257 tons/day are as follows:

	BPT Effluent Limitations								
Pollutant	Daily Maximum (lbs/1000 lb)	Monthly Average (lbs/1000 lb)							
BOD5	10.6	5.5							
TSS	22.15	11.9							
рН	5.0 – 9.0 s.	u. at all times							

Average Daily Production (1000 lbs/day)= 5141

 $^{^{1}}$ ((257 tons/day) X (2000 lbs/ton)) / 1000 = 514

Monthly Average	
-----------------	--

Parameter	Production	X	EG Factor	<u>BPT Limit</u>
	(Klbs/day)	X	(lbs/Klbs)	lbs/day
BOD5	514	X	5.5	2827.0
TSS	514	X	11.9	6116.6

<u>Parameter</u>	Production X EG Factor			<u>BPT Limit</u>	
	(Klbs/day)	X	(lbs/Klbs)	lbs/day	
BOD5	514	X	10.6	5448.4	
TSS	514	X	22.15	11385.1	

Page 18 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

Step 2:

Effluent limitations based on production of 1502 tons/day are as follows:

BPT Effluent Limitations					
Pollutant	Daily Maximum (lbs/1000 lb)	Monthly Average (lbs/1000 lb)			
BOD5	13.65	7.1			
TSS	24	12.9			
pН	5.0 – 9.0 s.u. at all times				

Average Daily Production (1000 lbs/day)= 30041

Monthly Average

Parameter Parameter	Production	X	EG Factor	BPT Limit
	(Klbs/day)	X	(lbs/Klbs)	lbs/day
BOD5	3004	X	7.1	21328.4
TSS	3004	X	12.9	38751.6

Daily	Maximum

Parameter	Production	\mathbf{X}	EG Factor	BPT Limit
	(Klbs/day)	X	(lbs/Klbs)	lbs/day
BOD5	3004	X	13.65	41004.6
TSS	3004	X	24	72096.0

 $\underline{\mathbf{Step 3}} = \mathbf{Step 1} + \mathbf{Step 2}$

<u>Parameter</u>	Monthly Average, lbs/day	Daily Maximum, lbs/day
BOD5	24155.4	46453.0
TSS	44868.2	83481.1

During renewal of the last permit, the technology-based TSS limits at Outfall 001 were reduced to 37720 lbs/day (Monthly Average) and 70188 lbs/day (Daily Maximum) with the agreement of the permittee based on the performance of the treatment system. However, the concentration limits for TSS were based on the above calculated technology limits. This methodology will continue to be used in this permit.

 $^{^{1}}$ ((1502 tons/day) X (2000 lbs/ton)) / 1000 = 3004

Page 19 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

AOX

The Adsorbable Organic Halogen (AOX) limits were calculated based on the annual **unbleached** pulp production and effluent guidelines representing the application of the Best Available Technology (BAT) economically achievable (40 CFR Part 430.24). The Permittee has reported an average unbleached pulp production of 1735 tons per day. Based on 40 CFR 430.24(b)(1), AOX limits must be determined at the end of the pipe. Therefore, production of 1735 tons/day has been used to calculate AOX limits as follows:

40 CFR 430.24, BAT Effluent Limitations			
Pollutant	Daily Max kg/kkg (lbs/1000 lbs)	Monthly Average kg/kkg (lbs/1000 lbs)	
AOX	0.951	0.623	

Calculations

Average Daily Production (1000 lbs/day) = 3470^1 ((1735 ADT/day) x (2000 lbs/ton)) / 1000 = 3470

Monthly Average

<u>Parameter</u>	Production x	ELG Factor	BAT Limit
	(1000 lbs/day) x	(lbs/1000lbs)	lb/day
AOX	3470 x	0.632	2193.04

Daily Max

<u>Parameter</u>	Production x ELC	<u>BAT Limit</u>	
	(1000 lbs/day) x	(lbs/1000lbs)	lb/day
AOX	3470 x	0.951	3299.97

In accordance with 40 CFR 430.01(i), Method 1650 and minimum level (ML) of 20 μ g/l apply to AOX.

40 CFR 430.24(d) states that effluent limitations for pentachlorophenol and trichlorophenol apply to all dischargers subject to this section in accordance with the previous subcategorization scheme unless the discharger certifies to the permitting authority that it is not using these compounds as biocides. Also, for non-continuous dischargers, concentration limitations (mg/l) shall apply. Concentration limitations will only apply to non-continuous dischargers.

Page 20 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

The permittee has certified that pentachlorophenol and trichlorophenol are not used as biocides at this facility. Also, this facility is a continuous discharger. Therefore, the BAT limits set forth in 40 CFR 430.24(d) do not apply to this facility.

Dioxin

In the previous permit, it was determined that the technology based requirement of < 10 pg/l for Dioxin (2,3,7,8-TCDD) at the internal outfalls was more stringent than the Dioxin technology (BPJ) permit limits at Outfall 001. The Dioxin limits at Outfall 001 were changed to monitor and report. The Dioxin monitoring and reporting requirements at Outfall 001 are therefore continued unchanged from the previous permit.

LAC 33:IX:713.C requires a daily maximum 2,3,7,8-TCDD limit of no more than 20 pg/l. As the limits contained for the internal outfalls is less than the Louisiana standard, no additional action (as compared to the previous permit) is necessary to protect the water quality of the State of Louisiana in regards to dioxin.

INTERNAL OUTFALLS

Chloroform

The removal of the chloroform limits at the internal out is allowed under 40 CFR 430.02(f) as long as the requirements of the section are met. The permittee must:

- (i) Demonstrate, based on 104 measurements taken over a period of not less than two years of monitoring conducted in accordance with paragraph (a) of this section, that you are complying with the applicable limitations or standards for chloroform;
- (ii) Certify that they will maintain a record of the maximum value for each of the following process and operating conditions for the fiber line that was recorded during the collection of each of the samples used to make the demonstration required under paragraph (f)(2)(i) of this section.
 - (A) The pH of the first chlorine dioxide bleaching stage;
 - (B) The chlorine (Cl₂) content of chlorine dioxide (ClO₂) used on the bleach line;
 - (C) The kappa factor of the first chlorine dioxide bleaching stage; and
 - (D) The total bleach line chlorine dioxide application rate;

Page 21 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

- (iii) Identify the chlorine-containing compound used for bleaching during the collection of samples used to make the demonstration required under paragraph (f)(2)(i) of this section; and
- (iv) Certify that the fiber line does not use either elemental chlorine or hypochlorite as bleaching agents.

The permittee submitted all of the required information in a permit modification request submitted on 11/28/2007, i.e, compliance with the chloroform limits and the monitoring results for pH after the first bleaching stage, Kappa Factor, and maximum total bleach line ClO₂ application rate. Part II of the permit contains conditions (See Nos. 19 and 20) outlining the requirements contained in 40 CFR 430.02(f)(4), (6), and (7) for the chloroform monitoring exemption to continue.

Other Parameters

In accordance with 40 CFR 430.24(a)(1), the following parameters have been included in the permit for each of the three internal outfalls. With the exception of 2,3,7,8-Tetrachlorodebenzofuran (TCDF), the permit limits are the minimum levels (ML) specified in 40 CFR 430.01(i).

Parameter	Permit Limit
2,3,7,8-Tetrachlorodibenzo-p-dioxin (TCDD)	<10 pg/l
2,3,7,8-Tetrachlorodebenzofuran (TCDF)	31.9 pg/l
Trichlorosyringol	<2.5 μg/l
3,4,5-Trichlorocatechol	<5.0 μg/l
3,4,6-Trichlorocatechol	<5.0 μg/l
3,4,5-Trichloroguaiacol	<2.5 μg/l
3,4,6-Trichloroguaiacol	<2.5 μg/l
4,5,6-Trichloroguaiacol	<2.5 μg/l
2,4,5-Trichlorophenol	<2.5 μg/l
2,4,6-Trichlorophenol	<2.5 μg/l
Tetrachlorocatechol	<5.0 μg/l
Tetrachloroguaiacol	$< 5.0 \mu g/l$
2,3,4,6-Tetrachlorophenol	<2.5 μg/l
Pentachlorophenol	<5.0 μg/l

Plywood Plant and Studmill

In accordance with 40 CFR 429.43, any existing point source subject to this subpart (40 CFR Part 429, Subpart C), must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of best available technology

Page 22 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

economically achievable (BAT): There shall be no discharge of process wastewater pollutants.

In accordance with 40 CFR 429.123, any existing point source subject to this subpart (40 CFR Part 429, Subpart K), must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of best available technology economically achievable (BAT): There shall be no discharge of process wastewater pollutants.

However, the Federal Register, Vol. 39, No. 76 dated Thursday, April 18, 1974, in response to Comment #15 on 40 CFR Part 429, states the following:

"A 'no discharge of process wastewater' limitation does allow a plant to discharge wastewater to an available treatment system which might be present where a number of timber products processing operations are conducted; however, no credit will be given for the wastewater pollutants attributable to the point source categories included in Part 429that have a no dischargee limitation."

The effluent description will reflect that the wastewaters that may be discharged through Outfall 001 include process wastewaters from the plywood plant and studmill.

Chemical Plant

The permittee stated in an e-mail dated 06/10/2009, that, in addition to boiler blowdown and cooling tower blowdown, the following types of wastewater are discharged from the chemical plant:

From the Formaldehyde plant – RCI distillates

From the Resin Manufacturing – Glass Mat distillates, Prepolymer distillates, Vacuum sump discharges, and Red water impoundment discharges

From the Tall Oil plant – API separator discharges

The permittee is not subject to the Best Available Technology Economically Achievable (BAT) requirements of 40 CFR Part 414, Subpart E (Organic Chemicals, Plastics, and Synthetic Fibers, Thermosetting Resins Subpart) or 40 CFR Part 430, Subpart F (Organic Chemicals, Plastics, and Synthetic Fibers, Thermosetting Resins Subpart). The biological treatment associated with this permit occurs after all sources of wastewater (process wastewater from the paper mill, stormwater runoff, City of Crossett's wastewater, etc.) have commingled. Therefore, the biological treatment is not considered to be end-of-pipe.

The permittee is subject to the requirements of 40 CFR Part 414 (Organic Chemicals, Plastics, and Synthetic Fibers), Subpart E (Thermosetting Resins) and Subpart F

Page 23 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

(Commodity Organic Chemicals). The permittee is also subject to the requirements of 40 CFR Part 454 (Gum and Wood Chemicals Manufacturing Point Source Category), Subpart D (Tall Oil Rosin, Pitch and Fatty Acids Subcategory). These subparts contain Effluent Limitation Guidelines for BOD5 and TSS in pounds of the effluent characteristic per 1,000 pounds of product.

The pounds of BOD5 and TSS which could be discharged as a result of the operations at the Chemical Plant would normally be calculated and then added to the BOD5 and TSS limits calculated for the paper mill and other sources of wastewater at this facility. However, the permittee has demonstrated that the limits set based on the paper mill alone are adequate to cover all of the various operations at this facility. Therefore, no additional calculations will be done at this time.

SMS 002

BOD5 and TSS limits as stated in the permit on page 3 of Part IA are based on Waste Load Allocation which was done by the permittee and approved by EPA and ADEQ during the last permit renewal. The loading limits apply when Mossy Lake is not flooded; otherwise the permittee must comply with the BOD5 and TSS limits at Outfall 001.

c. Stormwater runoff

All stormwater runoff discharges which are not routed through Outfall 001 are covered under the general permit for stormwater runoff associated with industrial activity. (See tracking no. ARR00A776.) Therefore, stormwater pollution prevention plan (SWPPP) requirements have not been included in this permit. The permit will continue to contain conditions requiring Best Management Practices (BMPs). This does not violate the anti-backsliding requirements contained in 40 CFR 122.44(1) because the permit has not been relieved of the SWPPP requirements.

d. 208 Plan (Water Quality Management Plan)

No revisions to the 208 Plan are being proposed under this permit renewal.

e. Toxics Pollutants

A. Toxics Pollutants

(1) Post Third Round Policy and Strategy

Section 101 of the Clean Water Act (CWA) states that "...it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited..." To insure

Page 24 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

that the CWA's prohibitions on toxic discharges are met, EPA has issued a "Policy for the Development of Water Quality-Based Permit Limitations by Toxic Pollutants" (49 FR 9016-9019, 3/9/84). In support of the national policy, Region 6 adopted the "Policy for post Third Round NPDES Permitting" and the "Post Third Round NPDES Permit Implementation Strategy" on October 1, 1992. The Regional policy and strategy are designed to insure that no source will be allowed to discharge any wastewater which (1) results in instream aquatic toxicity; (2) causes a violation of an applicable narrative or numerical State water quality standard resulting in non-conformance with the provisions of 40 CFR Part 122.44(d); (3) results in the endangerment of a drinking water supply; or (4) results in aquatic bioaccumulation which threatens human health.

(2) Implementation

The State of Arkansas is currently implementing EPA's Post Third-Round Policy in conformance with the EPA Regional strategy. The 5-year discharge permits contain technology-based effluent limitations reflecting the best controls available. Where these technology-based permit limits do not protect water quality or the designated uses, or where there are no applicable technology-based limits, additional water quality-based effluent limitations and/or conditions are included in the discharge permits. State narrative and numerical water quality standards from Regulation No. 2 are used in conjunction with EPA criteria and other available toxicity information to determine the adequacy of technology-based permit limits and the need for additional water quality-based controls.

(3) Priority Pollutant Scan

In accordance with the regional policy ADEQ has reviewed and evaluated the effluent in evaluating the potential toxicity of each analyzed pollutant:

- a. The results were evaluated and compared to EPA's Minimum Quantification Levels (MQLs) to determine the potential presence of a respective toxic pollutant. Those pollutants which are greater than or equal to the MQLs are determined to be reasonably present in the effluent and an evaluation of their potential toxicity is necessary.
- b. Those pollutants with one datum shown as "non-detect" (ND), providing the level of detection is equal to or lower than MQL are determined to be not potentially present in the effluent and eliminated from further evaluation.
- c. Those pollutants with a detectable value even if below the MQL are determined to be reasonably present in the effluent and an evaluation of their potential toxicity is necessary.

Page 25 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

d. For those pollutants with multiple data values and all values are determined to be non-detect, therefore no further evaluation is necessary. However, where data set includes some detectable concentrations and some values as ND, one-half of the detection level is used for those values below the level of detection to calculate the geometric mean of the data set.

The concentration of each pollutant after mixing with the receiving stream was compared to the applicable water quality standards as established in the Arkansas Water Quality Standards, Reg. No. 2 and with the aquatic toxicity, human health, and drinking water criteria obtained from the "Quality Criteria for Water, 1986 (Gold Book)". The manner in which the Instream Waste Concentrations are calculated may be found on page 2 of each of the attachments.

I. Aquatic Toxicity, Bioaccumulation, and Drinking Water

Arkansas Requirements

As stated on page A-31 of Reg. 2, Chapter 5 of Reg. 2 does not apply to Mossy Lake and Coffee Creek. Therefore, toxics limits based on levels in the effluent at Outfall 001 have not been calculated.

SMS2 is a monitoring point located approximately 2.5 miles upstream of the Arkansas/Louisiana state line. The methods for calculating the background flows based upon the 7Q10, TSS, hardness, etc. are based upon ADEQ's CPP.

Stream Monitoring Station (SMS2)				
Flow	45 MGD = 69.525 cfs	Previous Permit		
7Q10	1200 cfs	EPA*		
TSS	5.5 mg/l	CPP		
Hardness as CaCO ₃	28 mg/l	CPP		
рН	7.01 s.u.	OUA008B		

^{*}Letter dated July 3, 2001.

Louisiana Requirements

The flows (for acute, chronic, and bioaccumulation) are based upon the requirements of Title 33, Part IX, Subpart I, Section 1115, Table 2a.

Stream Monitoring Station (SMS2)				
Flow	45 MGD = 69.525 cfs	Previous Permit		

Page 26 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

Stream Monitoring Station (SMS2)				
7Q10	1200 cfs	EPA*		
TSS	6 mg/l	E-mail**		
Hardness as CaCO ₃	38.4 mg/l	E-mail**		
рН	7.01 s.u.	OUA008B		

^{*}Letter dated July 3, 2001.

(4) Water Quality Standards for Metals and Cyanide

Standards for Chromium (VI), Mercury, Selenium, and Cyanide are expressed as a function of the pollutant's water-effect ratio (WER), while standards for cadmium, chromium (III), copper, lead, nickel, silver, and zinc are expressed as a function of the pollutant's water-effect ratio, and as a function of hardness.

The Water-effect ratio (WER) is assigned a value of 1.0 unless scientifically defensible study clearly demonstrates that a value less than 1.0 is necessary or a value greater than 1.0 is sufficient to fully protect the designated uses of the receiving stream from the toxic effects of the pollutant.

The WER approach compares bioavailability and toxicity of a specific pollutant in receiving water and in laboratory test water. It involves running toxicity tests for at least two species, measuring LC50 for the pollutant using the local receiving water collected from the site where the criterion is being implemented, and laboratory toxicity testing water made comparable to the site water in terms of chemical hardness. The ratio between site water and lab water LC50 is used to adjust the national acute and chronic criteria to site specific values.

(5) Conversion of Dissolved Metals Criteria for Aquatic Life to Total Recoverable Metal

Metals criteria established in Regulation No. 2 for aquatic life protection are based on dissolved metals concentrations and hardness values (See Page 6 of Attachment 1). However, Federal Regulations cited at 40 CFR 122.45(c) require that effluent limitations for metals in discharge permits be expressed as total recoverable (See Attachments 1 and 2). Therefore a dissolved to the total recoverable metal conversion must be implemented. This involves determining a linear partition coefficient for the metal of concern and using this coefficient to determine the fraction of metal dissolved, so that the dissolved metal ambient criteria may be translated to a total effluent limit. The formula for converting dissolved metals to total recoverable metals for streams and lakes are provided in

^{**} These values were received via e-mail from Jeremy "Todd" Franklin of LDEQ on 06/16/2009.

Page 27 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

Section 5.25 of the CPP and Region 6 Implementation Guidance for Arkansas Water Quality Standards promulgated at 40 CFR Part 131.36.

(6) Comparison of the submitted information with the water quality standards and criteria

(a) SMS2

The following pollutants were determined to be present at SMS2 as reported by the permittee.

Arkansas Standards

Pollutant	Concentration Reported**, µg/l	MQL Required by ADEQ's CPP
Total Recoverable Cadmium	0.765	1
Total Recoverable Chromium	5.32	10*
Hexavalent Chromium, Dissolved	5.32	10*
Total Recoverable Copper	7.336	0.5
Total Recoverable Lead	1.769	0.5
Total Recoverable Mercury	0.0052	0.005
Total Recoverable Nickel	8.322	0.5
Total Recoverable Selenium	5.315	5
Total Recoverable Zinc	145.20	20
Bis(2-ethylhexyl) phthalate	2.679	10*
Gamma-BHC (a/k/a Lindane)	0.0492	0.05
Delta-BHC	0.0319	0.05*
Dieldrin	0.0035***	0.02
Alpha-endosulfan	0.0252	0.01

^{*}Actual detection level achieved was lower than what was required.

^{**}Geometric mean of two reported values.

^{***}Geometric mean of five reported values.

Page 28 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

Louisiana Standards

Pollutant	Concentration Reported, µg/l	MQL Required by LDEQ**
Total Recoverable Cadmium	0.765	1
Total Recoverable Chromium	5.32	10*
Hexavalent Chromium, Dissolved	5.32	10*
Total Recoverable Copper	7.336	10
Total Recoverable Lead	1.769	5
Total Recoverable Mercury	0.0052	0.2*
Total Recoverable Nickel	8.322	40
Total Recoverable Zinc	145.20	20
Gamma-BHC (a/k/a Lindane)	0.0492	0.05
Dieldrin	0.0035***	0.1
Alpha-endosulfan	0.0252	0.1*

^{*}Actual detection level achieved was lower than what was required.

As indicated in the above tables, ADEQ has determined from the information submitted by the permittee that reasonable potential for exceedances of water quality standards exists for some of the parameters listed above. Permit action will be taken for the parameters for which the permittee demonstrated reasonable potential for exceedances of the water quality or bioaccumulation standards (See Attachments 1 and 2).

(b) Aquatic Toxicity

(i) Pollutants with numerical water quality standards

a. SMS2

ADEQ has determined from the information submitted by the permittee that there is a reasonable potential for the discharge to cause an instream excursion above the acute and/or chronic numeric standards as specified in the Arkansas Water Quality Standards, Reg.

^{**}Based on Permitting Guidance Document for Implementing Louisiana Surface Water Quality Standards, Water Quality Management Plan, Volume 3. Dated April 16, 2008 (Version 6). Obtained from LDEQ's web site on June 12, 2009.

^{***}Geometric mean of five reported values.

Page 29 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

No. 2 and/or in Louisiana's Water Quality Regulations at L.A.C. 33:IX:1113 (See Attachments 1 and 2).

ADEQ has identified the following toxicants in the discharge in amounts which could potentially have a toxic impact on the receiving stream:

Chronic Aquatic Toxicity Results						
Pollutant C_e , $\mu g/l$ C_e X 2.13 AR IWC, AR WQS, LA IWC, LA WQS, $\mu g/l$ $\mu g/l$ $\mu g/l$						
Total Recoverable Zinc	251	534.63	113.62	109.63	*	*

^{*}Reasonable potential only demonstrated based upon Arkansas' requirements.

Acute Aquatic Toxicity Results						
Pollutant C_e , $\mu g/l$ C_e X 2.13 AR IWC, AR WQS, LA IWC, LA WQS, $\mu g/l$ $\mu g/l$ $\mu g/l$						
Total Recoverable Zinc	251	534.63	282.97	120.05	359.02	159.70

IWC's have been calculated in the manner described on page 2 of the attachments.

b. Permit Action

Under Federal Regulation 40 CFR Part 122.44(d), as adopted by Regulation No. 6, if a discharge poses the reasonable potential to cause or contribute to an exceedance above a water quality standard, the permit must contain an effluent limitation for that pollutant. Effluent limitations for the toxicants listed above have been derived in a manner consistent with the Technical Support Document (TSD) for Water Quality-based Toxics Control (EPA, March 1991), the State's implementations procedures, and 40 CFR Part 122.45(c).

Permit Limit Determination

The Department recognizes that background data exists for the reach of the Ouachita River into which Coffee Creek flows. However, the accuracy of this data is questionable as evidenced by the stream segment's categorization on the 303(d) list. Because no reliable data exists, the Department has used background concentrations of 0 mg/l

Page 30 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

for Total Recoverable Copper and Total Recoverable Zinc when calculating the permit limits for those parameters.

The instream waste load allocation (WLA), which is the level of effluent concentration that would comply with the water quality standard (WQS) of the receiving stream, is calculated for both chronic and acute WLA using the following equations:

$$WLA_c = (WQS \ X \ (Q_d + Q_b) - Q_b \ X \ C_b))/Q_d$$

Where:

 $WLA_c = chronic waste load allocation (\mu g/l)$

 Q_d = discharge flow (cfs)

 $Q_b = 0.25 \text{ X 7Q10 (cfs)}$ @ SMS2 for AR WQS

 $Q_b = 0.33 \text{ X 7Q10 (cfs)}$ @ SMS2 for LA WQS

 C_b = background concentration ($\mu g/l$)

WQS = chronic aquatic toxicity standards (μ g/l)

and;

$$WLA_a = (WQS \ X \ (Q_d + Q_b) - Q_b \ X \ C_b))/Q_d$$

Where:

 $WLA_a = acute waste load allocation (\mu g/l)$

 Q_d = discharge flow (cfs)

 $Q_b = 0.06 \text{ X 7Q10 (cfs)}$ @ SMS2 for AR WQS

 $Q_b = 0.033 \text{ X 7Q10 (cfs)}$ @ SMS2 for LA WQS

 C_b = background concentration ($\mu g/l$)

WQS = acute aquatic toxicity standards ($\mu g/l$)

The long term average (LTA) effluent concentration is then calculated based on the chronic and acute WLA as follows:

$$LTA_c = 0.72 \text{ X WLA}_c$$

 $LTA_a = 0.57 \text{ X WLA}_a$

The lowest of these two (2) values is selected as being the limiting LTA. The limiting LTA is then used to calculate the monthly average (AML) and daily maximum (DML) for the final limits. AML and DML are calculated as follows:

Page 31 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

AML = 1.55 X Limiting LTADML = 3.11 X Limiting LTA

Limits included in the permit are as follows:

SMS2

The reach of the Ouachita River which receives the effluent from this facility (Reach #002 in H.U.C. 08040202) is on the 303(d) due to Zinc. The permittee demonstrated reasonable potential for water quality violations due to the levels of Total Recoverable Zinc. Permit limits were determined using both ADEQ's and LDEQ's permitting procedures. The more stringent limits were those calculated using ADEQ's permitting procedures. Therefore, those limits were placed in the permit.

The permittee did not demonstrate reasonable potential for water quality violations due to Total Recoverable Copper or Total Recoverable Mercury in either Arkansas or Louisiana. However, the reach of the Ouachita River which receives the effluent from this facility is on the 303(d) list due to Copper. Therefore, permit limits based on ADEQ's permitting procedures have been included in the permit.

The Department will reopen the permit to include any TMDLs which are finalized during the term of the permit.

The permittee only demonstrated reasonable potential for exceedances of aquatic toxicity standards for Dieldrin in Arkansas. Therefore, ADEQ's permitting procedures were used to calculate the aquatic toxicity based limits for Dieldrin. The permittee did demonstrate reasonable potential for exceedances of Louisiana's bioaccumulation standards. Those limits are calculated in Item (c) below. The more stringent of the two sets of limits will be included in the permit.

Numerical Aquatic Toxicity Limits					
Parameter AML, μg/l DML, μg/l					
Total Recoverable Copper	22.43	45.00			
Total Recoverable Mercury	0.07	0.14			
Total Recoverable Zinc	200.40	402.09			

Page 32 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

(ii) Pollutants without applicable water quality standards

ADEQ has determined from the information submitted by the permittee that there is not a reasonable potential for the discharge to cause an instream excursion above the acute and/or chronic criteria as specified in the Gold Book (See Attachments 1, 2, and 3).

(c) Human Health (Bioaccumulation) Limits

i. Pollutants with numerical water quality standards

ADEQ has determined from the information submitted by the permittee that there is not a reasonable potential for the discharge to cause an instream excursion above the state numeric bioaccumulation standards as specified in Reg. 2.508. However, ADEQ has determined that there is a reasonable potential for an instream excursion above the State of Louisiana's numeric bioaccumulation standard for Dieldrin.

Bioaccumulation Standard Results					
Pollutant C _e , μg/l C _e X 2.13 IWC, μg/l La WQS, μg/					
Dieldrin	0.113	0.2407	0.01	0.00005	

IWC's have been calculated in the manner described above.

Permit Action

Under Federal Regulation 40 CFR Part 122.44(d), as adopted by Regulation No. 6, if a discharge poses the reasonable potential to cause or contribute to an exceedance above a water quality standard, the permit must contain an effluent limitation for that pollutant. Effluent limitations for the above have been derived in a manner consistent with the Technical Support Document (TSD) for Water Quality based Toxics Control (EPA, March 1991), the Implementation of the Arkansas Water Quality Standards via Permitting, and 40 CFR Part122.45(c) as follows:

$$WLA = (WQS X (Q_d + Q_b) - Q_b X C_b)/Q_d$$

Where:

WLA = waste load allocation ($\mu g/l$)

Page 33 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

 Q_d = discharge flow (cfs)

 $Q_b = long term average flow (cfs)$

 C_b = background concentration ($\mu g/l$)

WQS = bioaccumulation standard (μ g/l)

The instream WLA concentration, which is the level of effluent concentration that would comply with water quality standards (WQS) in the receiving stream, is used to calculate the monthly average (AML) and daily maximum (DML) final limits as follows:

AML = WLA

 $DML = AML \times (DML/AML)$

where the factor DML/AML is found in Table 5-3 of TSD. Limits included in the permit are as follows:

Louisiana Human Hea	Louisiana Human Health (Bioaccumulation) limits				
Pollutant	Pollutant AML, μg/l DML, μg/l				
Dieldrin 0.00091 0.00284					

The Dieldrin limit based upon compliance with Louisiana's bioaccumulation standard is more stringent than the limit based upon compliance with ADEQ's chronic toxicity standard. Therefore, the permit will contain limits of 0.00091 μ g/l for a monthly average and 0.00284 μ g/l for a daily maximum.

ii. Pollutants without applicable water quality standards

ADEQ has determined from the information submitted by the permittee that there is not a reasonable potential for the discharge to cause exceedance of bioaccumulation criterion as specified in the Gold Book (Quality Criteria for Water 1986).

iii. Drinking Water Supply Protection

ADEQ has determined from the information submitted by the permittee that there is not a reasonable potential for the discharge to cause an instream excursion above the drinking water criteria as specified in the Gold Book.

Page 34 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

14. WHOLE EFFLUENT TOXICITY.

Section 101(a)(3) of the Clean Water Act states that "......it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited." In addition, ADEQ is required under 40 CFR Part 122.44(d)(1), adopted by reference in Regulation 6, to include conditions as necessary to achieve water quality standards as established under Section 303 of the Clean Water Act. Arkansas has established a narrative criteria which states "toxic materials shall not be present in receiving waters in such quantities as to be toxic to human, animal, plant or aquatic life or to interfere with the normal propagation, growth and survival of aquatic biota."

Whole effluent toxicity (WET) testing is the most direct measure of potential toxicity which incorporates the effects of synergism of effluent components and receiving stream water quality characteristics. It is the national policy of EPA to use bioassays as a measure of toxicity to allow evaluation of the effects of a discharge upon a receiving water (49 Federal Register 9016-9019, March 9, 1984). EPA Region 6 and the State of Arkansas are now implementing the Post Third Round Policy and Strategy established on September 9, 1992, and EPA Region 6 Post-Third Round Whole Effluent Toxicity Testing Frequencies, revised March 13, 2000. Whole effluent toxicity testing of the effluent is thereby required as a condition of this permit to assess potential toxicity. The whole effluent toxicity testing procedures stipulated as a condition of this permit are as follows:

TOXICITY TESTS

FREQUENCY

Chronic WET Testing

Once/2 months

Requirements for measurement frequency are based on the CPP.

Since 7Q10 is less than 100 cfs (ft³/sec) and dilution ratio is less than 100:1, chronic WET testing requirements will be included in the permit.

The calculations for dilution used for chronic WET testing are continued unchanged from the previous permit.

$$CD = [(2.8 \times D \times 3.14^{\circ}0.5)/y] \times 100$$

D = Diameter of discharge pipe = 4 ft and y = 25 for ZID $CD = [(2.8 \times 4 \times 3.14^{\circ}0.5)/25] \times 100 = 80\%$

Toxicity tests shall be performed in accordance with protocols described in "Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms", EPA/600/4-91/002, July 1994. A minimum of five effluent dilutions in addition to an appropriate control (0%) are to be used in the toxicity tests. These additional effluent concentrations are 25%, 34%, 45%, 60%, and 80% (See Section 6.3 of

Page 35 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

the CPP). The low-flow effluent concentration (critical dilution) is defined as 80% effluent. The requirement for chronic WET tests is based on the magnitude of the facility's discharge with respect to receiving stream flow. The stipulated test species, *Ceriodaphnia dubia* and the Fathead minnow (*Pimephales promelas*) are indigenous to the geographic area of the facility; the use of these is consistent with the requirements of the State water quality standards. The WET testing frequency has been established to provide data representative of the toxic potential of the facility's discharge, in accordance with the regulations promulgated at 40 CFR Part 122.48.

Results of all dilutions as well as the associated chemical monitoring of pH, temperature, hardness, dissolved oxygen conductivity, and alkalinity shall be reported according to EPA/600/4-91/002, July 1994 and shall be submitted as an attachment to the Discharge Monitoring Report (DMR).

This permit may be reopened to require further WET testing studies, Toxicity Reduction Evaluation (TRE) and/or effluent limits if WET testing data submitted to the Department shows toxicity in the permittee's discharge. Modification or revocation of this permit is subject to the provisions of 40 CFR 122.62, as adopted by reference in ADEQ Regulation No. 6. Increased or intensified toxicity testing may also be required in accordance with Section 308 of the Clean Water Act and Section 8-4-201 of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

Administrative Records

The following information summarized toxicity test submitted by the permittee during the term of the current permit at.

WHOLE EFFLUENT TOXICITY TESTING FREQUENCY RECOMMENDATION AND RATIONALE FOR ADDITIONAL REQUIREMENTS

Permit Number: **AR0001210** AFIN: **02-00013**

Facility Name: Crossett Paper Operations

Outfall: 001

Previous Critical Dilution: 80%
Date of Review: 6/3/09

Proposed Critical Dilution: 80%
Name of Reviewer: M. Barnett

Number of tests performed during previous 5 years by species:

Pimephales promelas (Fathead minnow): 24

Ceriodaphnia dubia (water flea): 23



Page 36 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

T 11 1	1			1	
Failed 1	test da	tes durino	previous 5	vears b	v species.
I allou	icsi da	ios auring	, previous s	years	y species.

Pimephales promelas (Fathead minnow):	<u>Lethal</u>	Sub-lethal
	None	06-04
		09-04
		12-05

Ceriodaphnia dubia (water flea):	<u>Lethal</u>	Sub-lethal
	None	04-02
		03-07
		0 4 0 -

06-07 09-07 12-07 06-08 12-08

Previous TRE activities: None

Frequency recommendation by species:

Pimephales promelas (Fathead minnow): once/2 months Ceriodaphnia dubia (water flea): once/2 months

Additional requirements (including WET Limits) rationale/comments concerning permitting:

Rationale: Continuous Planning Process, E.1.c "For permittees with a design flow greater than or equal to 1 MGD and potential toxicity problems (e.g. failed pre-permit test, substantial industrial contribution and no pretreatment) the toxicity testing frequency may be twelve times a year for both species".

However, since the permittee has had no lethal failures, only 3 sub-lethal *P. promelas* test failures, and only 7 sub-lethal *C. dubia* failures during the past 5 years, WET testing shall occur bi-monthly.

15. SAMPLE TYPE AND FREQUENCY.

Outfall 001 and SMS2

Requirements for sample type and sampling frequency at Outfall 001 and SMS2 have been based on the current discharge permit for those parameters carried forth from the previous permit. The only change to sample type or sampling frequency for a parameter carried forth from the previous permit is the WET testing frequency. The WET testing frequency has been increased to once every two months based on the recommendation of the Water Division's Planning Branch.

Page 37 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

The sample type and sampling frequency for the new parameters were based upon the CPP and the judgment of the permit writer. The sample types for metals at SMS2 are grab samples due to the difficulty in obtaining clean samples at this monitoring location.

Internal Outfalls 101, 102, and 103

The monitoring frequencies are based on 40 CFR 430.02(a). The monitoring frequencies and sample types are remaining unchanged from the previous permit.

	Previo	us Permit	Draft	Permit
Parameter	Frequency of Sample	Sample Type	Frequency of Sample	Sample Type
	OUTFA	LL 001		
Flow	Once/day	Totalizing meter	Once/day	Totalizing meter
BOD5	Three/week	24-hr composite	Three/week	24-hr composite
TSS	Three/week	24-hr composite	Three/week	24-hr composite
2,3,7,8-TCDD	Once/quarter	24-hr composite	Once/quarter	24-hr composite
AOX	Once/day	24-hr composite	Once/day	24-hr composite
Total Recoverable Copper	N/A	N/A	Once/month	24-hr composite
Total Recoverable Zinc	N/A	N/A	Once/month	24-hr composite
Dieldrin	N/A	N/A	Once/month	24-hr composite
Total Phosphorous	N/A	N/A	Three/week	24-hr composite
Nitrates as Nitrogen	N/A	N/A	Three/week	24-hr composite
pН	Three/week	Grab	Three/week	Grab
Chronic WET	Once/quarter	24-hr composite	Once/2 months	24-hr composite
	SM	IS2		
Flow	Once/day	Totalizing meter	Once/day	Totalizing meter
BOD5				
October – July	Three/week	24-hr composite	Three/week	24-hr composite
August	Three/week	24-hr composite	Three/week	24-hr composite
September	Three/week	24-hr composite	Three/week	24-hr composite
Total Suspended Solids (TSS)	Three/week	24-hr composite	Three/week	24-hr composite

Page 38 of Fact Sheet Permit Number: AR0001210 AFIN: 02-00013

	Previo	us Permit	Draft	t Permit
Parameter	Frequency of Sample	Sample Type	Frequency of Sample	Sample Type
Total Recoverable Copper	N/A	N/A	Once/month	24-hr composite
Total Recoverable Zinc	N/A	N/A	Once/month	24-hr composite
Dieldrin	N/A	N/A	Once/month	24-hr composite
Total Phosphorous	N/A	N/A	Three/week	24-hr composite
Nitrates as Nitrogen	N/A	N/A	Three/week	24-hr composite
рН	Three/week	Grab	Three/week	Grab
INTER	NAL OUTFAL	LS (101, 102, and	103)	
Flow	Daily	Instantaneous	Daily	Instantaneous
2,3,7,8-Tetrachlorodibenzo-p-dioxin (TCDD)	Once/month	24-hr composite	Once/month	24-hr composite
2,3,7,8-Tetrachlorodebenzofuran (TCDF)	Once/month	24-hr composite	Once/month	24-hr composite
Trichlorosyringol	Once/month	24-hr composite	Once/month	24-hr composite
3,4,5-Trichlorocatechol	Once/month	24-hr composite	Once/month	24-hr composite
3,4,6-Trichlorocatechol	Once/month	24-hr composite	Once/month	24-hr composite
3,4,5-Trichloroguaiacol	Once/month	24-hr composite	Once/month	24-hr composite
3,4,6-Trichloroguaiacol	Once/month	24-hr composite	Once/month	24-hr composite
4,5,6-Trichloroguaiacol	Once/month	24-hr composite	Once/month	24-hr composite
2,4,5-Trichlorophenol	Once/month	24-hr composite	Once/month	24-hr composite
2,4,6-Trichlorophenol	Once/month	24-hr composite	Once/month	24-hr composite
Tetrachlorocatechol	Once/month	24-hr composite	Once/month	24-hr composite
Tetrachloroguaiacol	Once/month	24-hr composite	Once/month	24-hr composite
2,3,4,6-Tetrachlorophenol	Once/month	24-hr composite	Once/month	24-hr composite
Pentachlorophenol	Once/month	24-hr composite	Once/month	24-hr composite
pH of 1 st ClO ₂ Bleaching Stage	N/A	N/A	Once/day	Grab
Kappa Factor of 1 st ClO ₂ Bleaching Stage	N/A	N/A	Once/day	Grab

Page 39 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

	Previou	is Permit	Draft	Permit
Parameter	Frequency of Sample	Sample Type	Frequency of Sample	Sample Type
Total Bleach Line ClO ₂ Application Rate	N/A	N/A	Once/day	Totalizing Meter

16. PERMIT COMPLIANCE.

Compliance with final effluent limitations is required by the following schedule:

Compliance is required on the effective date of the permit except as outlined below in Item #3.

- 1. The report required by Condition No. 12 of Part II of this permit shall be submitted no later than May 31 of each year.
- 2. The permittee must conduct the fish tissue analysis required by Condition No. 14 of Part II of the permit during the third year of the permit cycle. The results must be submitted within 30 days of the completion of the sampling and analyses.

17. MONITORING AND REPORTING.

The applicant is at all times required to monitor the discharge on a regular basis; and report the results monthly. The monitoring results will be available to the public.

18. SOURCES.

The following sources were used to draft the permit:

- a. Application No. AR0001210 received 03/02/2009.
- b. Arkansas Water Quality Management Plan (WQMP).
- c. APCEC Regulation No. 2.
- d. APCEC Regulation No. 3.
- e. APCEC Regulation No. 6.
- f. 40 CFR Parts 122, 125, 414, 429, 430, and 454.
- g. Discharge permit file AR0001210.
- h. Discharge Monitoring Reports (DMRs).
- i. "Arkansas Water Quality Inventory Report 2008 (305B)", ADEQ.
- j. "Identification and Classification of Perennial Streams of Arkansas", Arkansas Geological Commission.
- k. Continuing Planning Process (CPP).
- 1. Technical Support Document For Water Quality-based Toxic Control.

Page 40 of Fact Sheet Permit Number: AR0001210

AFIN: 02-00013

- m. Region 6 Implementation Guidance for Arkansas Water Quality Standards promulgated at 40 CFR Part 131.36.
- n. Inspection Report dated 05/28/2008.
- o. Site Visit on 05/26/2009.
- p. E-mail from Jeremy "Todd" Franklin of LDEQ to Loretta Reiber dated June 16, 2009.
- q. EPA's Consumer Fact Sheet on Nitrates/Nitrites.
- r. E-mail from Rachel Johnson to Loretta Reiber, P.E. dated June 5, 2009.
- s. E-mail from Rachel Johnson to Loretta Reiber, P.E. dated June 10, 2009.
- t. LAC Title 33, Part IX, Subpart 1 (LA WQS).
- u. Permitting Guidance Document for Implementing Louisiana Surface Water Quality Standards, Water Quality Management Plan Volume 3, Version 6 April 16, 2008.
- v. E-mail from Rachel Johnson to Loretta Reiber, P.E. dated July 28, 2009.
- w. E-mail from Jim Wise to Loretta Reiber, P.E. dated July 29, 2009.
- x. E-mail from Rachel Johnson to Loretta Reiber, P.E. dated July 29, 2009.
- y. E-mail from Rachel Johnson to Loretta Reiber, P.E. dated October 26, 2009.
- z. Letter of no objection from EPA Region VI dated December 16, 2009.
- aa. Additional dieldrin test results received January 14, 2010

19. PUBLIC NOTICE.

The public notice describes the procedures for the formulation of final determinations and shall provide for a public comment period of 30 days. During this period, any interested persons may submit written comments on the draft permit and may request a public hearing to clarify issues involved in the permitting decision. A request for a public hearing shall be in writing and shall state the nature of the issue(s) proposed to be raised in the hearing.

A copy of the permit and public notice will be sent via email to the Corps of Engineers, the Regional Director of the U.S. Fish and Wildlife Service, the Department of Arkansas Heritage, the EPA, the Arkansas Department of Health, and the Louisiana Department of Environmental Quality prior to the publication of that notice.

20. POINT OF CONTACT.

For additional information, contact:

Loretta Reiber, P.E.
Permits Branch, Water Division
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118-5317
Telephone: (501) 682-0612

Page 1 of 7

1	- m	_	ш	L	פ		_	~	~		Σ	- -	>	r
				CALCULATI	CALCULATIONS OF ARKANSAS WATER QUALITY-BASED EFFLUENT LIMITATIONS	SAS WATER	QUALITY	BASED EFFL	UENT LIMIT	ATIONS		-		
						For an Arkansas River/Stream	isas River	/Stream						
		4	1			(Reserved)								
STEP 1:	INPUT TWO LETTER CODE FOR ECOREGION (Use Code at Right) Rasin Name	R CODE FOR	ECOREGIO	N (Use Code at	(Right)	GC Orachita River	-							
								U	Codes & TSS	for Ecoreg	Codes & TSS for Ecoregions and Large Rivers	e Rivers		
FACILITY							١	Ouachita Mts. Eco (OM) =	Eco (OM) =	2.0 mg/l	Arkansas (F	Arkansas (Fl. Smith to Dardanelle Dan	danelle Dam	12.0 ma/
Permittee					10	GP Crossett	3	Ozark Highlands Eco (OH) = 2.5 mg/l	ds Eco (OH)	= 2.5 mg/l	Arkansas (D.	Arkansas (Dardanelle Dam to Terry L&	to Terry L&	10.5 mg/l
NPDES Permit No	nt No.					AR0001210		Boston Mts. Eco (BM) =	co (BM) =	1.3 mg/l	Arkansas (T	Arkansas (Terry L&D to L&D No. 5)	D No. 5)	8.3 mg/l
Outfall No.(s)			,			SMS2	-	Ark River Valley Eco (AV) = 3.0 mg/l	ey Eco (AV)	= 3.0 mg/l	Arkansas (L	Arkansas (L&D No. 5 to Mouth)	outh)	9.0 mg/l
Plant Effluent	2 Plant Effluent Flow (MGD)					45.00		Guif Coastal Eco (GC) =	= (OS) es	5.5 mg/l	White (Abov	White (Above Beaver Lake)		2.5 mg/l
3 Plant Effluent Flow (cfs)	(Flow (cfs)					69.53		Delta Ecoregion (DL) =	on (DL) =	1/5m 0.8	White (Belov	White (Below Bull Shoals to Black Riv)	b Black Riv)	3.3 mg/l
											White (From	White (From Black River to Mouth	Mouth)	18.5 mg/
RECEIVING STREAM	STREAM										St. Francis River	iver		18.0 mg/l
								-			Ouachita (At	Ouachita (Above Caddo River)	ver)	2.0 mg/l
this a large	Is this a large river? (see list at right)(enter "1" if y	(enter "1" if yes	s. "0" if no; n	res. "0" if no; make entry as a number)	number)	1					Ouachita (Be	Ouachita (Below Caddo River)	(er)	5.5 mg/l
lame of Rec	8 Name of Receiving Stream.					Ouachita River	e.				Red River			33.0 mg/l
Vaterbody S	Waterbody Segment Code No.					20		,						
this a lake	Is this a lake or reservoir? (enter '1' if yes, '0'	-11	3; make entry	no: make entry as a number)		0			Total Hardness for:	ss for:				
econd Enter	Second Enter Enter 7Q10 in Cell H31					0	0.000		Arkansas River = 125 mg/l	er = 125 mg/l		Red River = 211 mg/l	211 mg/l	
(Reserved)	DO NOT IN	PUT DATA IN	TO CELL HZ.	2. H23 & H24	DO NOT INPUT DATA INTO CELL H22, H23 & H24 LEAVE BLANK= (Reserved)	(Reserved)			Ouachita River = 28 mg/l	er = 28 mg/l		St. Francis River = 103 mg/l	liver = 103 m	1/6
(Reserved)								7	White River = 116 mg/l	116 mg/l				
	(Reserved)	(Reserved)	J)			(Reserved)								
		(Reserved)	E C			(Reserved)		Ÿ	Gulf Coastal = 31 mg/l	= 31 mg/l		Ouachita Mount = 31 mg/l	unt = 31 mg	
		(Reserved)	£			(Reserved)			Ozark Highlands = 148 mg/l	1ds = 148 mg	J/t	Ark River Valley = 25 mg/l	lley = 25 mg	V V
		(Reserved)	3)			(Reserved)			Boston Mount = 25 mg/l	= 25 mg/l		Delta = 81 mg/l	l/6v	
coregion TS	Ecoregion TSS (mg/l) (For Large River, See List	er, See List to	to Right)			5.50		-	Large Rivers					
coregion Ha	Ecoregion Hardness (mg/l)	!				28.00		-	Mississippi Ri	ver, Arkans	Mississippi River, Arkansas River, Red River	River		
Inter 7010 (c	Enter 7010 (cfs) as the Critical Flow	(Reserv	ed) (Reserved)			1200.00 (200.00 (Reserved		White (Below	confluence	White (Below confluence with Black River)	91)		
Long Term Ave / Harmon	Long Term Ave / Harmonic Mean Flow (cfs)					3600.00	Reserved.(3600.00 (Reserved (Reserved)	Duachita (Bel	ow confluence	Ouachita (Below confluence with Little Miss. River)	liss. River)		
pH (Avg)						7.01			For Industrial	and federal	facility, use th	For industrial and federal facility, use the highest monthly average flow	thly average	Now
Percent (%) c	Percent (%) of Critical Flow for Chronic Criteria	nic Criteria				0.25		11	or the past 24	4 months. Fo	or POTWS, us	for the past 24 months. For POTWs, use the design flow.	wc.	
ercent (%) c	Percent (%) of Critical Flow for Acute Criteria	Criteria				90.0								
Valer Effect	Water Effect Ratio (WER)					1.00		15	*VALUE! =>	No violation	#VALUE! => No violation or Not Applicable	able		
we Monthly	Ave Monthly Limit LTA Multiplier (Ref. page 103 T	f: page 103 TS	3D for WQ-B	'SD for WQ-Based Toxics Control)	ntrol)	1.55			= 00.666666	> No EPAJA	9999999.00 => No EPA/ADEO Guideline			
Apy Daily Lin	Max Doily I may 1 TA Att limbio / Doc.													

1/22/2010 12:32 PM

ا ا	0		ш	н	O	Ξ	-	7	ㅗ	7	Σ	z	0	
CALCULA	INPUT AMBIENT AND EFFLUE CALCULATE IN STREAM WAS	INPUT AMBIENT AND EFFLUENT DATA CALCULATE IN STREAM WASTE CONCENTRATIONS	INT DATA	ATIONS										-
DATA INPUT		For less th	an 20 data pi nore data poi	oints enter geor nts in set enter	For less than 20 data points enter geometric mean concentration as micro-gram per liter (ug/l or ppb). For 20 or more data points in set enter highest concentration as micro-gram per liter (ug/l or ppb).	rentration a	s micro-gram	per liter (ug/	or ppb).					
	1-1-1-1	Effluent va Effluent va If a firm val	lue reported lue reported ue is reporte	as "< detection as "< detection d, even less that	Effluent value reported as "< detection level" (DL) but the DL is greater than MQL, the 1/2 DL is used Effluent value reported as "< detection level" (DL) and the DL is smaller than MQL, "0" is used. If a firm value is reported, even less than MQL, the reported value is used.	he DL is gre the DL is sm orted value is	ater than MQ aller than MC s used.	1L, the 1/2 DL	is used.					
	1	The followi (Please ref	The following formulae is used (Please refer to CPP for detail) IWC = [(F*Qa*Cb) + (Qe*2.13*)	llowing formulae is used to calculate the In e refer to CPP for detail) (F*Ga*Cb) + (Ge*2, 13*Ce)] / (F*Ga + Qe)	The following formulae is used to calculate the Instream Waste Concentration (IWC) (Please refer to CPP for detail) WC = (F**Oa**Cb) + (Oe**2.13**Ce) / (F**Oa***Cb)	m Waste Cor	centration (1)	wc)						
		Where: IWC = Inst	ream Waste	Where: IWC = Instream Waste Concentration F = Fraction of stream allowed for mixing	Buix									1
		Ce = Repo Cb = Ambi Qe = Plant	Ce = Reported concentra Cb = Ambient stream cor Qe = Plant effuent flow	ration in effluen	Ce = Reported concentration in effluent Cb = Ambient stream concentration upstream of discharge Qe = Plant effluent flow	acide								
		Ob = Critic Upstream	al low flow or	stream at disci	Qb = Critical low flow of stream at discharge point expressed as the 7Q10 or harmonic mean flow for human health criteria Upstream Flow (Qb)= (% of 7Q10) X 7Q10 for Chronic and Acute	essed as the and Acute	7Q10 or har	rmonic mean	flow for humar	health crite	e.			
The following formulae convert metals reported	ivert metals	reported in to	tal form to dis	ssolved form if	in total form to dissolved form if criteria are in dissolved form	ssolved form								-
65 Kp = Kpo · (TSS**a) 66 C/Ct = 1/ (1 + Kp*TSS* 10^4.6) 67 Total Metal Criteria (Ct) = Cr / (C/Ct)	(-c) Cr / (C/Ct)			Kp = Linear pr TSS = Total sr C/Ct = Fractio	Kp = Linear partition coefficient; Kpo and a can be found in table below. TSS = Total suspended solids concentration found in receiving stream (or in effluent for intermittent stream) C/Ct = Fraction of metal dissolved; and Cr = Dissolved criteria value.	to concentration to the concen	on found in re	eceiving stres criteria value	low am (or in efflue	nt for intermi	Itent stream)			
		*Stream Li	near Partitic	on Coefficient	m Linear Partition Coefficient (Insert "Dissolved" Conc in Column B to convert to Lake Linear Partition Coefficient	red" Conc ir	Column B t	o convert t	Lake Linear P.	artition Coe	fficient			
Dissolved Value in 70 Total Metals Stream		Y Po	alpha (a)	Ş.	C/C	Total Value			8,	alpha (a)	Ą.	C/C	Total Value	
		480000	-0.73	138285.446	0.56799788	0.00			480000.00	-0.73	138285.45	0.5679979		4.4
Cadmium		4000000	-1.13	582706.889	0.237818469	0.00			3520000.00	-0.92	733514.98	0.1986361		
Chromium(3)		3360000	-0.93	688338.365	0.208948818	0.00			2170000.00	-0.27	1369499.28	0.1172024		
		1040000	-0.74	294554.016	0.381672529	0.00			2850000.00	6.0-	614495.12	0.2283249		
		2800000	-0.8	715925.58	0.202527926	0.00			2040000.00	-0.53	826490.64	0.1803199		-
		2900000	-1.14	415321.613	0.30448177	0.00			1970000.00	-1.17	268066.09	0.4041443		-
		490000	-0.57	185433.992	0.495077211	0.00			2210000.00	-0.76	604946.03	0.2310962	0	
		1250000	o o		0.324193117	0.00	-		3340000.00	-0.68	1047851.74	0.1478593		
							-							ļ

1/22/2010 12:32 PM

Д																	1																																			
0	Arkansas	2000	Vôn		4300	1.4	4	#######################################	***************************************	***************************************	***************************************	***************************************	0.45	0.10	4000	***************************************	HHHHHHHHH	6.3	#########	#######################################	220000		1.00E-06		780	9.6	710	3600	44	2.10E+04	340	1.00E+07	1.00E+07	4700	220	#######################################	066	32	#########	1700	29000	*********	4000	16000	110	88.5	2.00E+05	**********	420	##########	810	5250
z	Arkansas Chronic Aquatic	o diameter	√ôn		1600.00	334.51	5.30	1.69	300 34	10.58	20.01	3005	2000	210.0	100.10		-+	#		#	5.2		1.00E+07		21	2600	6666666	#######################################	##########	20	#########	##########	##########	1240		#########	20000	##########	2200	244	**********	#######################################	**********	#######################################	2400	840	#######################################	************	9400	1	21900	*************
Σ	Arkansas Acute Aquatic	5	l/gu		9000.00	633.81	130.00	3.91	925.86	1571	13 44	77 07	10.17	07.0	9/3.00	20.00	1.21	1400.00	120.05	00.666666	22.36		0.01		89	7550	2300	6666666	35200	250	6666666	6666666	6666666	28900	6666666	00.6666666	11800	11600	23000	6060	32000	00.666666	00.666666	00.666666	9320	5280	17500	999999.00	18000	18000		00 666666
٦,	Domestic .A		√6n		************	20	##########	10	20	20	***************************************	20	3 0	7		2 5	2	#########		#######################################	#########		##########		########	#########	2	#########	2	#########	#########	#########	**********	#########	***************************************		വ	##########	#########	*****	*##########	#########	##########	##########	100	##########	#######################################		##########	200	2	
¥	Bioacc	IWC	l/6n		00.0	00.0	00.0	0.03	0.21	0.21	0.50	2000	500	0.00	50.0	17.0	0.00	0.00	5.86	0.00	0.00		0.00		0.00	0.00	00.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	00.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	00.00	0.00	00.0	00.00	0.00	00.0
7	Chronic	IWC	l/6n		0.00	0.00	00.00	0.31	213	213	200	2.04	200	0.00	0.04	2.5	00.0	0.00	58.19	0.00	0.00		0.00		00.00	0.00	00.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	00.00	0.00	0.00	00.0	0.00	00.0	00.0	00.0	00.0	00.0	00.0	0.00	0.00	0.00	00.0
_	Acute	IWC	√ön		0.00	00.0	0.00	0.80	5,57	25.57	200	000	2000	0.00	0.0	0.00	000	0.00	151.93	0.00	0.00		0.00		00'0	00.0	00.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	00'0	00.0	0.00	00.0	00.0	00.0	00.0	00.0	0.00	0.00	0.00	00.0	00.0
I	Domestic	INC.	//ôn		00.00	00.0	0.00	60.0	0.82	0.62	300	0000		0.00	0.90	70.0	0.00	000	16,94	0.00	00.0		0.00		00.0	00.0	00.00	0.00	00.00	0.00	00:00	00:00	00.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	00.0	00.0	0.00	00:00	00.00	00'0	0.00	0.00	00.0	0.00
g	Effluent	Ces	Von		0	0	0	0.765	5.32	5.32	7 236	780	6000	0.005	0.322	0.5.0	0	0	145.2	0	0		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ı.	Background	3	√gu		0	0	0	0	C	0 0	0 0	0 0	0 0	0 0	0 0	0 0	Э .	0	0	0	0		0	+	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0 (0
Е	EPA		Factor		2.13	2.13	2.13	2.13	2.13	2 13	0,0	2.5	2 12	5.50	2.5	2.5	2.13	2.13	2.13	2.13	2.13		2.13	+	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13			2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13
۵	Ō		√gn		09	0.5	0.5	-	10	10		2 0	200	0.00	0.4	0 0	0.1	0.5	20	2	10		0.00001		20	50	10	10	5	0.	0	20	0	10	10	10	10	10	10	10	10	20	20	50	10	10	0	9	2	10	0:5	9
S	Number of Data points				-	-	-	-	-					- •		- ,	-	-	-	-	-		+		-	-	-	-	-	-	-	-		-	-	-	-	*-	-	-	-	-	-	-		-	-	1	-	~	-	_
Ф				YANIDE					-	. 0	1				-	. 0				otal			0	POUNDS					c	e.	omethane		vinyl ether	100	omethane	thane	thane	nylene	ropane,	ropylene		de	je je	loride	chloroetha	ylene		loroethyle	oethane	Delmane	ene	•
٧	132 POLLITANTS			METALS AND CYANIDE	1. Antimony Total	2. Arsenic Total	3. Beryllium Total	4. Cadmium Total	6. Chromium (Tri)	Chromium (hex)	R Copper Total	9 Lead Total	10 Mercino Total	12 Mister T	12 Sologium Tota	S. Seleliulii 101	14. Silver Tolai	15. Thallium Fotal	16. Zinc Total	129. Phenois. Total	17. Cyanide Total	DIOXIN	18. 2-3-7-8-TCDD	VOLATILE COMPOUNDS	19. Acrolein	20. Acrylonitrile	1. Benzene		3. Carbon Tetrach	24. Chlorobenzene	25. Chlorodibromomethane	26. Chloroethane		B. Chloroform	9. Dichlorobromomethane	0. 1-1-Dichloroethane		2. 1-1-Dichlorethylene	33, 1,2 Dichloropropane	4. 1,3 Dichloropi	5. Ethylbenzene	37. Methyl Chloride	36. Methyl bromide	8. Methylene chloride	39. 1-1-2-2-Tetrachloroetha.	 Tetrachiroethylene 	41. Toluene	42. 1.2-trans-dichloroethyler	44, 1-1-2-Trichloroethane	43. 1-1-1-Trichlorgemane	5. Trichloroethylene	187 46. Vinyl Chloride
	132 Pc	-	133	137 M		139 2.	140 3.	14114.	1426	1437	144 8	1450			- kv		D K	200	131	152	153	156 D	157 11	159 V	160 18	161 20	162 21.	163 22	164 23	165 24	166 2:	167.24	168 27	109 28	1/0/29	30	1723	173 32.	174 33	1753	176 35.	177 3,	178 36	179 38.	180 39	181 40.	182 4	183 4.	184 44	185 43	186 45.	Q / 4¢

1/22/2010 12:32 PM

۵																																				1									-																													
0	*********	#######################################	***************************************		2007	2004	***************************************			4600000	65	Himan	Health	Criteria		ngn	#########	**********	110000	5.40E-03	0.31	0.31	0.31	1	0.24	0.0	***************************************	- 1	1.7	29	#########	***********	***************************************		0.24	10.0	0.31	2600	0.77	1.20E+05	2.90E+06	1.20E+04	91	###			370	370	00041	0.003	1 74F+04	80	#########	0.31	0009	#			*****			***************************************	***************************************			0.0014	0.0373	0.46	0.63	#########	0.005	0.0059	0.0059	0.0084
z	***********	#######################################	200	***************************************		450	001	***************************************	27.0	2560	##########	Chronic				logo.	520	***************************************	##########	########	##########	***************************************	************	*************	***************************************		***************************************	**********	##########	#########	#########	***********	***************************************	***************************************	***************************************	***************************************	*********	763	########	#######################################	##########	#######################################	230	***************************************	***************************************	***************************************	***************************************	***************************************	***************************************	03	5.5	540	0.08	#########	##########	620	#######################################	************	***************************************	***************************************	**********	#########			0.00 com a 200 com	#########	0.08	0.08	0.08	0.08	0.0043	0.001	0.001	0.001
Σ	00.6666666	4380	0707	000000000000000000000000000000000000000	00.0000000	000000000000000000000000000000000000000	200	00	9.10	10200	999999.00		Acute Acutation	Criteria	200	l/gu	1700	999999.00	00'6666666	2500	00 666666	00 666666	00.000000	00.000000000000000000000000000000000000	000000000000000000000000000000000000000	000000000000000000000000000000000000000	999999.00	999999900	999999.00	00.6666666	00'6666666	00 666666	1600	0000000	999999.00	999999900	33333300	1120	00'6666666	00'6666666	00.666666	00'666666	330	00 000000	00.0000000	270	3080	3900	000000000000000000000000000000000000000	00	200	980	2	00'6666666	117000	2300	27000	0000000	00.0000000	999999.00	9999999.00	9999999.00	999999.00			3.00	2.00	2.00	2.00	2.00	2.40	1.10	1.10	1.10
		***************************************	***************************************	- 1			***************************************	*********	***************************************		##########		Domestic A		0.00	60	#########	#######################################	###############	#########	***************************************	***************************************								#######################################	#########	1		***************************************			************		#########	#########	#########	1		-			***************************************		3 1 1		***************************************	***************************************	#########	-	1	***************************************	***************************************	***************************************					#########			###############	##########	#########	##########	#########	#########	#########	##########	#########
¥		00.00	000	00.0	000	000	00.0	0.00	0.00	0.00	0.00		Human	Health H	WAND.	IWC	0.00	0.00	00.0	00.0	000	000	000	000	00.0	00.0	0.00	0.00	00.0	0.12	00:00	000	000	800	800	00.0	0.00	0.00	0.00	00.0	00.00	00.0	00:0	200	000	000	000	000	000	00.00	800	000	0000	0.00	0.00	000	000	000	800	00.0	0.00	0.00	0.00			00.00	00.0	0.00	0.00	00.0	00.0	0.00	0.00	0.00
7		000	000	000	000	0 0	000	000	0.00	0.00	0.00		Chronic	Acristic	יאמונים	M	0.00	0.00	00.0	00.0	000	000	000	000	000	00.0	0.00	0.00	0.00	1.15	00.0	000	800	3 6	000	0.00	0.00	0.00	00.0	00.0	0.00	00.0	0000	000	000	000	000	800	000	000	000	000	000	00.0	00.0	000	000	000	000	000	0.00	0.00	0.00			00.0	0.00	00.0	0.02	0.01	00:0	00.00	0.00	0.00
		0.00	00.00	000	800	8	800	0.00	0.00	0.00	00.00		Acrite	Agustic	Odean) A	0.00	0.00	0.00	0.00	000	000	000	000	00.0	0.00	0.00	0.00	0.00	3.00	00.0	000	8 8	000	00.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	000	000	000	000	800	000	00.00	000	000	000	0000	0.00	00.0	00.0	000	000	000	000	0.00	0.00	0.00			0.00	00.0	0.00	0.05	0.03	0.00	00.00	0.00	0.00
I		0000	000	000	0 0	000	000	0.00	0.00	0.00	0.00		Domestic	Supply	Supply of the su	INC	00.0	0.00	00.00	0.00	000	000	000	000	000	0.00	0.00	00.0	00.00	0.33	00.00	000	000	000	000	0.00	00.0	0.00	00.00	00.0	00.0	00.00	000	000	000	000	000	000	8.6	800	000	000	0000	0.00	00.0	00.0	0000	00.0	8 6	00.0	0.00	00.0	0.00			0.00	0.00	00.0	0.01	0.00	00.0	00.0	0.00	0.00
ဟ		0 (> c	0 0		0 0	0 0	> 0	0	0	0		Efflient	Cope	5	9	0	0	0	0	c	· c	o c	0 0	0 0	> 0	> 0	>	0	2.87	0	· c	o c	> <	0 0	> 0	0	0	0	0	0	0	0	o c	0 0	0	0 0	00	0 0	0 0	0 0	00	0	0	0	0	0 0	o c	> 0	0 0	> (0	0			0	0	0	0.0492	0.0319	0	0	0	0
L.		0 0	> <	> 0	> <	> 0	0 0	> (>	0	0	Ambient	Background	Concine	200	3	0	0	0	0			0 0	0 0	0 0	0 0	D (0	0	0	0		o c		> 0	> (0	0	0	0	0	0	0	· c	o c	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0	0	0	0 0	0 0	0	0 0	> (0	0		-	0	0	0	0	0	0	0	0	0
w		2.13	2.13	51.7	5.5	2.5	5.5	2.13	2.13	2.13	2.13					2.13	2.13	2.13	2.13	2.13	213	213	213		3:50	2.13	2.13	2.13	2.13	2.13	2.13	213	2,0	2	2 c	5.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2 43	213	213	213	213	21.5	2.7	213	213	2.13	2.13	2.13	2.13	213	213	2	2.5	2.13	2.13	2.13	:									2.13	2.13
۵		£ 5	2 0	2 9	3 5	2 6	7	2 '	ο.	10	10						10	10	10	20	ır.	ď	, 5	2 6	2	n (2 (2	5	10	10	. 0		2.0	2 4	n - i	o.	10	S	10	10	10	10	2	0.00	20.	2,0	5.5	2 '4	5	2 0	. 02	2	5	10	10	10	2.0	3:6	2.0	2	21	10			0.01	0.05	0.05	0.05	0.05	0.5	0.02	0.1	0.1
O			- •	- •	- •	- ,	- •		-	-	-					SONO	-	-	-	-	-		- •	- +	~ *	- •		_	е -	m	. T	, -		- •	n.	- ,	a) :	- 1		1	,	•												-	_	-						- '	•			-	-	,	-	-	-	-	-	-
В	SONIC	henol	orphenol	inyipherioi	0.50	ioniei io	oneriois Seriois	4 Unioro-3-metnyipheno	raphenol		2-4-6-Trichlorophenol					BASE/NEULKAL COMPOUNDS	hene	ylene	e.		Benzola) anthracene	900000	3 4-benzoflouranthene	on Our an Italiana	Derizo(g,n,i)perylene	benzo(k) moranmene	BIS(Z-chloroethoxy)meth	sroetniy) Ether	Bis(2-Chloroisopropyl) e	Bis(2-ethylhexyl)phthala	4-Bromophenyl phenyl e	Butylhenzy obthalate	2-chloronanihalana	aparate de la constante de la	4-ciliatophienty, pinenty, e		Dibenzo(a,h)anthracene	Dichlorobenzene(1.2	3 Dichlorobenzidine	nthalate	phthalate	Di-n-Butyl phthalate	otoluene	e de lloto	Di-n-ortyl ohthalate	1 2-dinhenvlhvdrazine	חיוויים וויים וויים	ם ס	Hexachlorohenzene	Hexachlorobutadiana	Hexachlorocyclonentadi	roethane	Hexachlorocyclohexane	2,3-cd)pyrene	Je.	ane	ene	98 N-pitrosodimethylamine	t o propordami	IIII isalah ilangan il	100. N-mirrosodiprientylantin	nrene	103. 1.2,4-trichlorobenzene				P	į.	BHC	Ŷ	Je et			
ď	ACID COMPOUNDS	47. 2-Chlorophenol	48 2-4-Dichiorphenol	49. Z-4 Dimemyiphenol		SO CO MITTER DELICATION	Section Numbers	54. 4 UNIORO-	55. Pentachlorophenol	56. Pheno	57. 2-4-6-Tric					BASE/NEUT		Acenapthylene	60. Anthracene	61. Benzidine										70. Bis(2-eth)	71. 4-Bromop						/ b. Dibenzo(a	77-79 Dichlo	80. 3.3 Dichly	81. Diethyl Phthalate				. '						90 Hexachio			Hexachlord	94. Indeno(1,2	95. Isophorone	96 Naphthalene		OS N. pitrosor	OO Al pitroco	SO IN-INITIOSO	No. in-militos	101 Phenanthrene	103. 1.2,4-tm		PESTICIDES	104. Aldrin	105. Alpha-BHC	106. Beta-BHC	107. Gamma-BHC	108. Delta-BHC	109. Chlordane	110, 4,4-DDT	111. 4.4DDE	112. 4.4'-DDD
	T= 1	ᅐ	000					2			199			201	_	707	203	204	205	206	207	30g	200	240	24.0	- k	7 1 7	2	214	215	216	217	21 X	10	1000	778	177	777	223	224	225	226	227	200	229	230	225	939	234	230	235	736	237	238	239	240	241	242	2/2	16	7 6	7 t	740	_		249	250	251	252	253	254	255	10	257

Page 6 of 7

2.13 0 0.0035 0.00041 2.13 0 0.0252 0.00 2.13 0 0 0.00	0.00368	0.00140 0.00014 0.01 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00		0.0019 0.0012 0.056 2 0.056 2 0.056 2 0.056 2 0.0053 0.81 0.0023 0.81 0.0038 0.0021 0.0038 0.0014 0.0014 0.0004
00252	000000000000000000000000000000000000000			0.056 0.056 0.0023 0.0023 0.0023 0.0038 0.0038
	000000000000000000000000000000000000000		0, 0,	0.056 0.056 0.0023 0.0023 0.0038 0.0038
	000000000000000000000000000000000000000		0, 0,	0.056 0.0023 0.0038 0.0038 0.0038
000000	000000000000000000000000000000000000000		0, 0,	0.0023 0.0023 0.0038 0.0038 0.014
00000	000000000000000000000000000000000000000		0, 0,	0.0023 0.0038 0.0038 0.0014
00000	000000000000000000000000000000000000000		24- 24- 24- 24-	0.0038 0.0038 0.014
0000	0.00		31- 31- 31-	0.0038
000	0000000		0, 0,	0.014
00	0000	-	1	0.014
c	0.00			
	0.00		0.6666666 #########	0.014
0	000		0.9999999.00	0.014
0 0	0.00		0 6666666 ########	0.014
0	0.00		00.666666666666666666666666666666666666	0.014
0	0.00		0.6666666 ########	0.014
0	00.0		5 0.73	0.0002
0 0	00.00		#######################################	0.041

A	В	ပ	[Е	ш.	ၯ	Ι	 7	소	L	Σ	z	0	م
STEP 3. A P.	IC A B!	APPLICABLE WATER OHALITY.B	1 41 0 0	≀ ⊲	STIMITO										
:		Permit		Permit	Permit			EPA							
POLLUTANTS		Maximu		rage	Maximum	Average		Status							
		l/gu		/6	lb/day										
Zinc Total		433.22	-	215.91	162.59			N/A							

	2	CALCUI ATIONS OF LOUSIANA WATER OUR! ITY-BASED EFFLUENT LIMITATIONS	SIANA WATER OLIAL	ITY-BASED EFFI	LENT LIMITATIONS			
	5		For an Arkansas River/Stream (Reserved)	River/Stream				
STEP 1: INPUT TWO LETTER CODE FOR ECOREGION (Use Code at Right) Basin Name	OR ECOREGION (US	se Code at Right)	GC Ouachita					
					Codes & TSS for Ecoregions and Large Rivers	egions and Larg	e Rivers	
FACILITY				Ouachita Mts	Ouachita Mts. Eco (OM) = 2.0 mg/l	1	Arkansas (Ft. Smith to Dardanelle Dan	12.0 mg/l
Permittee			GP Crossett	Ozark Highla	Ozark Highlands Eco (OH) = 2.5 mg/l	-	Arkansas (Dardanelle Dam to Terry L&	
NPDES Permit No.			AR0001210	Boston Mts. Eco (BM) =			Arkansas (Terry L&D to L&D No. 5)	8.3 mg/l
Outfall No.(s)			SMS2	Ark River Val	Ark River Valley Eco (AV) = 3.0 mg/l		Arkansas (L&D No. 5 to Mouth)	9.0 mg/l
Plant Effluent Flow (MGD)			45.00	Gulf Coastal Eco (GC) =	n		White (Above Beaver Lake)	2.5 mg/l
Plant Effluent Flow (cfs)		: .	69.53	Delta Ecoregion (DL) =			White (Below Bull Shoals to Black Riv)	
						White (From	White (From Black River to Mouth)	18.5 mg/l
5 RECEIVING STREAM					-	St. Francis River	iver	18.0 mg/l
						Onachita (Ab	Ouachita (Above Caddo River)	2.0 mg/l
Is this a large river? (see list at right)(enter "1" if yes,		"0" if no; make entry as a number)	-			Ouachita (Be	Ouachita (Below Caddo River)	5.5 mg/l
Name of Receiving Stream:			Ouachita River			Red River		33.0 mg/l
Waterbody Segment Code No.		1	20					
yes, '0'	= no; make entry as a number)	number)	0		Total Hardness for:			
ter Enter 701	1		0		Arkansas River = 125 mg/l	ng/l	Red River = 211 mg/l	
	INTO CELL H22, H2	DO NOT INPUT DATA INTO CELL H22, H23 & H24LEAVE BLANK= (Reserved)	K= (Reserved)		Ouachita River = 28 mg/l	1/4	St. Francis River = 103 mg/l	l/gm s
3 (Reserved)					White River = 116 mg/l			
(Reserved) (Reserved)	(pax		(Reserved)					
(Reserved)	ved)		(Reserved)		Gulf Coastal = 31 mg/l		Ouachita Mount = 31 mg/l	l/6c
(Reserved	(pax		(Reserved)		Ozark Highlands = 148 mg/l	mg/l	Ark River Valley = 25 mg/l	mg/l
(Reserved	ved)		(Reserved)		Boston Mount = 25 mg/l		Delta = 81 mg/l	
Ecoregion TSS (mg/l) (For Large River, See List to Right)	to Right)		0009		Large Rivers			
Tecoregion Hardness (mg/l)			38.40		Mississippi River. Arkansas River, Red River	nsas River, Red	River	
Enter 7010 (cfs) as the Critical Flow (Reser	(Reserved) (Reserved)		1200.00 (Reserved	ervedi	White (Below confluence with Black River)	e with Black Rive	(4)	
w (cf				1200.00 (Reserved (Reserved)	Ouachita (Below confluence with Little Miss. River)	ence with Little M	liss. River)	
OH (Avo)			7.01		For industrial and fede	ral facility, use the	For industrial and federal facility, use the highest monthly average flow	ne flow
			0.33		for the past 24 months. For POTWs, use the design flow	For POTWs, use	the design flow.	
36 Percent (%) of Critical Flow for Acute Criteria			0.03					
Water Effect Ratio (WER)		Th. 3- 4	1.00		#VALUE! => No violation or Not Applicable	ion or Not Applica	able	
38 Ave Monthly Limit LTA Multiplier (Ref. page 103 TSD for WQ-Based Toxics Control)	TSD for WO-Based	Toxics Control)	1.55		9999999 00 => No EPA/ADEO Guideline	VADEQ Guideline		

1/22/2010 12:33 PM

4.0 4.1 STEP 2: INPUT AMBIENT AND EFFLUENT DATA 4.2 4.4 4.5 4.5 4.5 4.5 4.5 4.5	FELUENT DATA WASTE CONCENTRATIONS For less than 20 data points enter geometric mean concentration as micro-gram per liter (ugfl or pbb). For 20 or more data points in set enter highest concentration as micro-gram per liter (ugfl or pbb). Effluent value reported as "< detection level" (DL) but the DL is greater than MQL, the 1/2 DL is used. If a firm value is reported, even less than MQL, the reported value is used. The following formulae is used to calculate the Instream Waste Concentration (IWC) INC = I(F*Qa*Cb) + (Qe*Z*13*Ce)] / [F*Qa + Qe) Where: WARRE = Instream Waste Concentration	r geometric renter high ection level ection level ess than M	c mean conce	ntration as								
STEP 2: INPUT AMBIENT AND EFFLUENT CALCULATE IN-STREAM WASTE DATA INPUT Effluent v Efflu	NCENTRATIONS NCENTRATIONS 120 data points enteredata points in selle reported as "< detereported, even 1 formulae is used to 10 CPP for detail) 10 CPP for detail) 10 CPP for detail) 10 CPP for detail) 11 CPP for detail) 12 CPP for detail) 13 CPD for detail) 14 CPC 13 CPC for detail)	rr geometric enter high ection level ection level	mean conce	ntration as								
DATA INPUT For less For 20 or Effluent v Effluent v	NCENTRATIONS 20 data points enter data points enter data points in selle reported as "< det en reported as "	rr geometric enter high ection level ection level	mean conce	ntration as								
DATA INPUT For less For 20 or For 20 or For 20 or For 18	20 data points entered adaptations selected as "< determined as "	enter highe ection level ection level ess than Mi	mean conce	ntration as						-	-	
DATA INPUT For less in the following the following in th	20 data points entere data points in set re data points in set reported as "< det is reported, even is 1s reported, even is 10 CPP for detail) a "Cb" + (Qe"2, 13"C) am Waste Concent	enter high ection level ection level ess than Mi	mean conce	ntration as r								
Effluent V Effluent V It a firm V The follo The follo Where: WC = IN F = Fra C = Reg	re data points in set e reported as "< det e reported as "< det e reported; even i g formulae is used it to CPP for detail) a"Cb) + (Per 2 (3°C) am Waste Concenti	enter highe ection level ection level ess than Mi			nicro-gram	per liter (ug/l	or ppb).					
Effluent v Effluent v It a firm v The follo (Please r WC = [K] Where: WC = IN F = Fra C = Reg	e reported as "< det e reported as "< det e is reported, even i g formulae is used to to CPP for detail) a "Cb" + (Qc"2: 13"C am Waste Concenti	ection level ection level ess than Mi	est concentra	tion as mich	o-gram per	liter (ug/l or p	obp).					
Effluent v The follo The follo Wor = (Please r WC = (N + Pra C = n + Pra C = Reg C = Reg C = Reg	s reported as "< del s s reported, even i y formulae is used it to CPP for detail) a*Cb) + (Qe*2.13*C am Waste Concenti	ection level ess than Mi	" (DL) but the	DL is great	er than MOL	the 1/2 DL	is used.					
	formulae is used to to CPP for detail) a*Cb) + (Qe 2.13*C am Waste Concenti		" (DL) and the	e DL is smal ed value is	ler than MC	N. "0" is used.	9.					
	TO CPP for detail) 3 Cb) + (Qe 2 13 C) am Waste Concenti	total color	ho lastendar	Coto Coto	W. Contraction	1000						
	a*Cb) + (Qe*2.13*C) am Waste Concent	calculate	me instream	waste Conc	u) uonemue	()						
	am Waste Concent	e)] / (F•Qa	+ Qe)									
	200000000000000000000000000000000000000	otic										
	F = Fraction of stream allowed for mixing	for mixing										
	Ce = Reported concentration in effluent	Minent										
De troughe troughe troughe	Cb = Ambient stream concentration upstream of discharge	ion upstream	m of discharg	e ·								
Table Control of the	low flow of etreom	discharge to	Point prior	Toda oc boo	040 05 000	occur olicon	Good day of the	direction district				
	CO = Chinda Ilow Ilow O shearn at discharge point expressed as the CO to that none thear flow for normal nearin chiefa Upstream Flow (Qb)= (% of 7Q10) X 7Q10 for Chronic and Acute	0) X 7Q10 f	or Chronic ar	d Acute	0000	TIONIC IIIEGU	now for numer	nealth chie				
The following formulae convert metals reported in	total form to dissolved form if criteria are in dissolved form	orm if criteri	a are in disso	lved form								
65 Kp = Kpo * (TSS**a)	Ko = Lir	lear partition	Ko = Linear partition coefficient. Koo and a can be found in Table below	Koo and a c	an be found	d in table bel	WC					
	TSS =	otal susper	ded solids o	oncentration	found in re-	ceiving strea	TSS = Total suspended solids concentration found in receiving stream (or in effluent for intermittent stream)	nt for intermi	ttent stream)			
5 / Total Metal Criteria (Ct) = Cr / (C/Ct)	C/C(= 1	raction of r	C/Ct = Fraction of metal dissolved; and Cr = Dissolved criteria value	ed; and Cr =	Dissolved	criteria value						
.Stream	Linear Partition Coefficient (Insert "Dissolved" Conc in Column B to convert to Lake Linear Partition Coefficient	cient (Inse	rt "Dissolved	"Conc in	Column B to	o convert tel	ake Linear Pa	artition Coe	fficient			
Dissolved Value in Stream Koo	(e) edole			Total Value	-		3	(c) cholc	S	č	Total Valley	
										5		
Alsellic		+	0.562224279	0.00			480000.00	-0.73	129//4.94	0.5622243		
			0.2398/48/4	0.00			3520000.00	-0.92	677085.50		0	
CINOTRUCK(S)	Ì		0.207943859	0.00			2170000.00	-0.27	1337700.52			
1040000		-	0.376348023	00.0			2850000.00	6.0	568209.82	0.2267955		
read		-	0.199/31823	00.0			2040000.00	-0.53	789241.67	0.1743542		
Mercury	,		0.307067625	0.00			1970000.00	-1.17	242119.22	0.4077114		
Nickel			0.485727208	0.00			2210000.00	-0.76	566235.80	0.2274063		
Zinc			0.318500517	0.00			3340000.00	-0.68		0.1443854		
80 Silver	-1.03 379066.542		0.305399532	0.00			2400000.00	-1.03	379066.54	0.3053995		

O Z _ X		5.13	250.57 81.28	15.71 10.58	5.01	22.46 CF3 = 1.46203 - [0.145712*In(hardness)]	2.04	629.83 69.95	50.86 46.45	0.67	22.36 5.20	360.00	130.00	5.00	e 1 for mixing zone.
7	Dissolved WQC (ug/l)	8) 90)	688		164) 165)			3.3612) .1645)	1,8604)						he Jet Stream Model for lakes for calculating the Dilution Factor (DF): D • 3.1416/0.5) / X) where DF is % of effluent at distance X. D is the diameter of the outfall pipe and X is aquatic life criteria -25 feet for ZID: 100 feet for mixing zone; human health criteria 200 feet for mixing zone #VALUE! Acute #VALUE! Bloacc.
-	2 of Ark 1949	WER X CF1 X e(1.128[In(hardness)]-3.828) WER X CF2 X e(0.7852[In(hardness)]-3.490)	WER X 0.316 X e(0.819[in(hardness)]+3.688 WER X 0.86 X e(0.819[in(hardness)]+1.561		WER X 0.96 X e(0.9422[in(hardness)]-1.464) WER X 0.96 X e(0.8545[in(hardness)]-1.465)	WER X e(1.273[In(hardness)]-1460)*CF3 WER X e(1.273[In(hardness)]-4.705]*CF3		WER X 0.998 X e(0.8460[in(hardness)]+3.3612) WER X 0.997 X e(0.8460[in(hardness)]+1.1645]	WER X 0.978 X e(0.8473 In(hardness)]+0.8604) WER X 0.986 X e(0.8473 In(hardness)]+0.7614)	WER X 0.85 X e(1.72[in(hardness)]-6.52)					DF): D is the diamet ne: human he Bloacc.
I	No. 2 (Act 47	X e(1.128[In(l X e(0.7852[In	6 X e(0.819 In X e(0.819 In(1	2 X 16 0.962	X e(0.9422[In X e(0.8545[In	73[In(hardnes	X 2.4	8 X e(0.8460	8 X e(0.8473 5 X e(0.8473	X e(1.72[In(ha	(0)				ution Factor (I distance X, I for mixing zo #VALUE
တ	The following formulas are used to calculate water quality criteria based on Regulation No. 2 (Act 472 of Ark 1949)	WER X CF1	WER X 0.31	WER X 0.982 X 16 WER X 11 X 0.962	WER X 0.96 WER X 0.96	WERXe(1.2	WER X 0.85 X 2.4 WER X 0.012	WER X 0.99	WER X 0.97	WER X 0.85	WER X 22.36 WER X 5.2	WER X 360	WER X 130	WER X 20	The following formulas are applicable to the Jet Stream Model for takes for calculating the Dilution Factor (DF): DF = ((2.8 · D · 3.1416 · 0.5) / X) where DF is % of effluent at distance X, D is and X is aquatic life criteria - 25 feet for ZID: 100 feet for mixing zone: DF = #VALUE! Acute #VALUE! Chronic #VALUE!
u.	iteria based c		-1216-9	loc s 19											where DF is eria25 feet fr
Ш	ter quality cr														am Model for v0.5) / X) quatic life crit
۵	calculate wa	Acute	Acute	Acute	Acute	Acute	Acute	Acute	Acute	Acute	Acute	Acute	Acute	Acute	pplicable to the Jet Stream Mode DF = ((2.8 · D · 3.1416·0.5) / X) and X is aquatic life DF = #VALUE! Acute
O	are used to				1 1/4	1-1-1									DF = ((2.8
ω	ig formulas a			ě											g formulas are
∢.	The followin	Cadmium	Chromium Tri	90 Chromum Hex	93 Copper 94 Copper	95 Lead	Mercury	02 Nickel	005 Zinc	08 Silver	Cyanide	3 Arsenic	16 Beryllium	19 Selenium	222 The following 23

1/22/2010 12:33 PM

۵.																																																	
0	Arkansas Bioacc.		√6n		0	1.4	4	10.00	20.00	20.00	1000.00	20.00	2	4600	#########	#######################################	6.3	#########	##########	663.8	-	7.10E-07		780	9.9	0.58	3.9	0.22	2.10E+04	340	1,000=+07	53	220	#	0.36	0.05	########	1700	29000	275000.00 ########	4000	4.4	0.16	0.65	6.10E+03	#########	0.56	28	0
z	Arkansas Chronic Aquatic	o diagram	l/gu		1600.00	337.94	5.30	2.12	390.89	10.58	14.42	4.38	0.012	144.01	2.00	##########	##########	145.83	350.00	4.6		1.00E+07		21	2600	1125	1465.00	1365.00	20		***************************************	1445	***************************************	***************************************	2900	580.00	1		1600.00	275000.00	#########	9650.00	466	645	635.00	##########	900	1950	######### 00.6666666
Σ	Arkansas Domestic Acute Aquatic		√6n		9000.00	640.31	130.00	5.45	1205.00	15.71	19.89	112.47	6.64	1296.68	20.00	2.18	1400.00	159.70	700.00	45.90		0.01		68	7550	2249	2930	2730	250	6666666	6666666	2890	6666666	dagaga no	11800	1160	23000	0909	3200	55000.00	00.666666	19300.00	932	1290	1270	999999.00	1800	3900	999999.00
_	Domestic 1A	3	l/gu		##########	20	#######################################	10	20	20	##########	20	2	#########	10	20	##########	##########	#########	#########		##########		**********	#######################################	2	###############	S	#########		***************************************	***************************************	***********	7	·	***************************************	#######################################	***********	#########	#########	##########	#########	#########	#########		-77	300	3 4	2
¥	Rice	IWC	l/gu		00.0	0.00	0.00	60.0	0.62	0.62	0.86	0.21	0.00	0.97	0.62	0.00	00.0	16.94	00.0	0.00		0.00		0.00	0.00	0.00	0.00	0.00	0.00	0.00	000	000	000	000	000	000	00.00	0.00	00.0	0.00	00.0	00.0	0.00	0.00	0.00	0.00	0.00	000	00.0
ſ	Chronic	IWC	l/gu		0.00	0.00	00.00	0.24	1.69	1.69	2.33	0.56	00.00	2.65	1.69	0.00	0.00	46.19	00.0	00.00		0.00		00:00	00.00	0.00	0.00	00.0	0.00	0.00	0000	000	000	000	000	000	00.0	0.00	00.00	00.0	00.0	00.0	00.0	0.00	0.00	00.0	000	000	0.00
-	Acute	IWC	ng/l		0.00	00.00	0.00	1.04	7.22	7.22	96.6	2.40	0.01	11.29	7.21	00.0	00.0	197.04	0.00	0.00		0.00		0.00	0.00	0.00	0.00	0.00	00.0	0.00	000	000	000	000	000	000	000	00.00	0.00	00.0	0.00	0.00	0.00	0.00	0.00	0.00	000	000	00.0
I	Domestic	IWC.	l/6n		00.0	0.00	0.00	60.0	0.62	0.62	0.86	0.21	0.00	0.97	0.62	00.00	00.00	16.94	0.00	0.00		00.00		00.0	0.00	0.00	0.00	0.00	00:00	0.00	800	00.00	000	000	000	0000	0.00	0.00	0.00	00.0	0.00	0.00	0.00	0.00	0.00	0.00	00.0	000	000
O	Effluent	Ç.	l/gu		0	0	0	0.765	5.32	5.32	7.336	1.769	0.0052	8.322	5.315	0	0	145.2	0	0		0		0	0	0	0	0	0	0 6	.	o c	o c) C	o c) C	0	0	0	0	0	0	0	0	0	0	0 0	> C	, 0
u.	Background	30	√gu		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				0	0	0	0	0	0	0 0	> c	o c	o c) C	o c	0 0	0	0	0	0	0	0	0	0	0	0	o c) C	» o
ш	EPA Statistical		Factor		2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13		2.13		2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.15	2.13	2 13	1.0	1 0	2.13.	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	2.13	21.5	2.13
Ω	Š	M	ng/l		09	0.5	0.5	-	10	. 01	0.5	0.5	0.005	0.5		0.5	0.5	50	2	10		0.00001	-	20	20	10	0,	. 5	10	2 g	0.0	2.5	2:0		2 5		. 0	10	10	20	20	20	10	0	10	9:	5 5	5 . C	2.€
O	Number of	Data politis			-	-	-	-	٢		-	*	-	-	-	-	-	-	-	-		-		-	-	-	-	-	-								-	-	-	_	-	-	-		-				
8				YANIDE											- E				ital			0	POUNDS					f:	e e	omethane	otto luciu	ialia kilik	omethane	thane	thane	Nene	opane	ropylene		Je .	e	loride	chloroetha	ylene	:	loroethyle	oethane	Deu laire	:
∢	SENATI	OLLUIANIS		METALS AND CYANIDE	1. Antimony Total	Arsenic Total	. Beryllium Total	4. Cadmium Total	Chromium (Tri)	. Chromium (hex)	Copper Total	9. Lead Total	10. Mercury Total	12. Nickel Total	13. Selenium Tota	14. Silver Total	15. Thallium Total	16. Zinc Total	129. Phenols, Total	17. Cyanide Total	DIOXIN	18. 2-3-7-8-TCDD	VOLATILE COMPOUNDS	19. Acrolein	20. Acrylonitrile			Carbon Tetrach			o Chloroethare	A Chloroform								7. Methyl Chloride	6. Methyl bromide		39, 1-1-2-2-Tetrachloroethai	40. Tetrachiroethylene		2. 1.2-trans-dichloroethyler	44. 1-1-2-Trichloroethane	45 Trichloroethylene	46. Vinyl Chloride
	132	1351	133	137 M	138 1	139 2	140 3.	141 4	1426	1437.	144 8	145 9	9	147 12	148 1	149 14	150 1	151	152 1.	153 1	156 D	157 1	159 V	160	161 2	1622	163 22	164 2	102	100 25	107	150 24	100	30.5	173	17333	174	175 34	176 35	177	178 36	179 38.	180 3	181	1824	183 42	184 4	282	187

1/22/2010 12:33 PM

Chronic Human Domestic Acute Aquatic Hamilton Segoggg 00 mm (1000 0.00 (1000 0.00 (1000 0.00 0.00 (1000 0.00 0.	Adult House of the control of the co	Name str. (200 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	co. C	Con 000000000000000000000000000000000000
0.00		00000000000000000000000000000000000000	Control Contro	2.13 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Chronic Human Domestic Acute Aquatic Aquatic Health Human Chief and Hamiltonian 1700		0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Control of the part of the par	2.13 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
0.00 0.00		00 00 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Enter 1 Con	2.13 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Chronic Human Domestic Acute Aquatic Health Human Domestic Acute Aquatic Aquatic Health Human Chief Chronic Human Domestic Acute Aquatic Aquatic Health Human Chief Chronic Aquatic Health Human Chief Chronic Aquatic Health Human Chief Chronic Chief Chronic Human Bases of Chronic Chief Chi		2000 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Concession of the part of the	2.13 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Chronic Human Domestic Acute Aquatic Aquatic Health INC 1000 0.00 1111111111111 9999999 0.00 0.00		Sept. 2000 000 000 000 000 000 000 000 000 0	Concerning to the state of the	2.13 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Chronic Human Domestic Acute Aquatic Aquatic Health Criteria Ugil Ugil Ugil Ugil Ugil Ugil Ugil Ugil		No. 10 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Effluent Conf. Con	Amblent Background Conc.
Chronic Human Domestic Acute Aquatic Acute Aquatic Mark Aquatic Mark Health Aquatic Acute Aquatic Acute Aquatic Mark Aquatic Acute Aquatic Acute Aquatic Acute Aquatic Mark Aquatic Acute Aquatic Acute Aquatic Acute Aquatic Mark Aquatic Acute Aquatic Acute Aquatic Acute Aquatic Acute A		Number of the control	Effluent Conf. Co. Co. Co. Co. Co. Co. Co. Co. Co. Co	Background Effluent Conc. Conc
Adultic NVC		5 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	2,0000000000000000000000000000000000000	2.13
0.00			300000000000000000000000000000000000000	2.13 2 2 2 2 3 3 2 2 2 2 3 3 2 2 2 3 3 3 2 2 2 3 3 3 2 2 2 3 3 3 2 2 2 3 3 3 2 2 2 3 3 3 2 2 2 3 3 3 2 2 2 3 3 3 2 2 2 3 3 3 2 2 2 3 3 3 2 2 2 3 3 3 2 2 2 3 3 3 2 2 3
0.00		8 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	2.679	2.13 2.13 2.13 2.13 2.13 2.13 2.13 2.13
0.00	000000000000000000000000000000000000000		2.0000000000000000000000000000000000000	2.13 2.13 2.13 2.13 2.13 2.13 2.13 2.13
0.00			7.000	2.13 2.13 2.13 2.13 2.13 2.13 2.13 2.13
0.00			2.679	2.13 2.13 2.13 2.13 2.13 2.13 2.13 2.13
0.00			2.679	2.13 2.13 2.13 2.13 2.13 2.13 2.13 2.13
0.00 0.00 #############################			2.679	2.13 2.13 2.13 2.13 2.13 2.13 2.13 2.13
0.00			2.679	2.13 2.13 2.13 2.13 2.13 2.13 2.13 2.13
0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.0			2.679	2.13 2.13 2.13 2.13 2.13 2.13 2.13 2.13
0.00 0.00			2.679	2.13 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2
0.65 0.31 ######### 99999900 0.00 0.00 #####################		E 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	2.679	2.13 2.13 2.13 2.13 2.13 2.13 2.13 2.13
0.00 0.00			000000000000000000000000000000000000000	2.13 2.13 2.13 2.13 2.13 2.13 2.13 2.13
0.00 0.00 materialistis 999999.00 0.00 0.00 materialistis 999999.00 0.00 0.00 materialistis 9999999.00 0.00 0.00 0.00 materialistis 99999999.00 0.00 0.00 0.00 materialistis 99999999.00 0.00 0.00 0.00 0.00 0.00 0				2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.
0.00 0.00				2 2 2 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3
0.00 0.00			0000000000	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2
0.00 0.00				
1120 0.00			0000000	000000
0.00 0.00 materialment 9999999.00 0.00 0.00 materialment 999999.00 0.00 0.00 materialment 9999999.00 0.00 0.00 materialment 99999999.00 0.00 0.00 materialment 999999999.00 0.00 0.00 materialment 999999999.00 0.00 0.00 materialment 9999999999.00 0.00 0.00 0.00 materialment 999999999.00 0.00 0.00 0.00 materialment 99999999999.00 0.00 0.00 0.00 materialment 999999999999999999999999999999999999			000000	00000
0.00			00000	0000
0.00 0.00 10.00		000000	0000	0000
0,00		00000	000	2.13 0 0 0 0.00
0.00 0.00 mathematical 9999999.00 0.00 0.00 mathematical 3999999.00 0.00 0.00 mathematical 39999999.00 0.00 0.00 mathematical 39999999.00 0.00 0.00 0.00 mathematical 39999999.00 0.00 0.00 mathematical 39999999.00 0.00 0.00 0.00 mathematical 399999999.00 0.00 0.00 0.00 mathematical 3999999999.00 0.00 0.00 0.00 mathematical 3999999999999999999999999999999999999		0000	00	213
0.00 0.00				
0.00 0.00 minimining 3980 0.00 0.00 minimining 9989999.00 0.00 0.00 minimining 980 0.00 0.00 minimining 999999.00 0.00 0.00 minimining 9999999.00 0.00 0.00 minimining 9999999.00 0.00 0.00 minimining 99999990 0.00 0.00 minimining 99999990 0.00 0.00 minimining 999999990 0.00 0.00 minimining 999999990 0.00 0.00 minimining 999999990 0.00 0.00 minimining 999999990 0.00 0.00 0.00 miniminiming 999999990 0.00 0.00 0.00 miniminiming 999999990 0.00 0.00 0.00 miniminiminiming 9999999990		00	0 0	0 0
0.00 0.00 #############################			. 0	. 0
0.00 0.00 ######### 5.10 0.00 0.00 ########## 980 0.00 0.00 ############################		0.0		000
0.00 0.00 (*****************************		0 0		
0.00 0.00 #############################		0.0	00	13 0 0
0.00 0.00 #############################		0.0	ļ.	13 0 0
0.00 0.00 #############################	+	0.0		133
0.00 0.00 ######### 27000 0.00 0.00 #########################	+	3 0		200
0.00 0.00 ######### 27000 10.00 ##############################	+	0.00	1	13 0
0.00 0.00 m######## 9999999.00 0.00 0.00 m######## 9999999.00 0.00 0.00 m#########################		00.0		13 0 0
0.00 0.00 0.00 ########################	+	00.0	0000	000
0.00 0.00 0.00 ########## 999999.00 0.00 0	+	000	1	200
0.00 0.00 0.00 ########################	ŀ	000		2 5
000 0 000 000	-	000	0000	0 0
0.00 0.00 ######### 3,00				
0000		0		Ç
0.00 0.00 ######## 2.00		000	000	
0.00 0.00 11111111111 2.00				13 0 0
0.02 0.01 ####### 5.30			0.0492	13 0 0.0492
0.01 0.06 **********************************			0.0319	13 0 0.0319
0,00	-	0 0		200
0000	0000	0	000	000
0.00 ######### 0.03		0		13 0 0

Page 6 of 7

_	_			_		_	_	_	_	_	_
Ъ											
0											
z											
Σ											
×											
٦											
r						EPA	Bioac	Status		A/N	N/A
ග											
ш						Permit	Monthly	Average	lb/day	0.00034	83.11
ш	1	SED LIMITS				Permit	Daily	Maximum	lb/day	0.00107	166.76
۵		UALITY-BAS				Permit	Monthly	Average	l/gu	0.00091	221.46
U		E WATER Q				Permit	Daily	Maximum	l/gn	0.00284	444.34
മ		APPLICABLE WATER QUALITY-BASED LIMIT						,,			
Þ		279 STEP 3.						POLLUTANTS		Dieldrin	Zinc Total
	278	279	280	281	282			283	284	285	286

Permit Number: AR0001210

AFIN: 02-00013

AUTHORIZATION TO DISCHARGE WASTEWATER UNDER THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM AND THE ARKANSAS WATER AND AIR POLLUTION CONTROL ACT

In accordance with the provisions of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended, Ark. Code Ann. 8-4-101 et seq.), and the Clean Water Act (33 U.S.C. §1251 et seq.),

The applicant's facility and mailing address is:

Georgia-Pacific LLC Crossett Paper Operations 100 Mill Supply Road Crossett, AR 71635

is authorized to discharge from a facility located as follows: west on Hwy 82 from the paper mill, go 1 mile before turning left onto Texas Ave. Go 2 miles then turn right. Proceed until you come to a T in the road, noting where the primary clarifier is located in Ashley County, Arkansas.

Latitude: 33° 08' 30"; Longitude: 91° 58' 12"

The receiving waters named:

Issue Date:

Outfall 001: Mossy Lake, then into Coffee Creek, then into Ouachita River in Segment 2D of the Ouachita River Basin

SMS 002: At the transition from Mossy Lake to Coffee Creek then into Ouachita River in Segment 2D of the Ouachita River Basin.

The outfalls are located at the following coordinates:

Outfall 001: Latitude: 33° 06' 25"; Longitude: 92° 02' 16"

SMS 002: Latitude: 33° 01' 58"; Longitude: 92° 04' 25"

Internal Outfall 101: Latitude: 33° 08' 29.5"; Longitude: 91° 58' 25.8"

Internal Outfall 102: Latitude: 33° 08' 29.5"; Longitude: 91° 58' 25.8"

Internal Outfall 103: Latitude: 33° 08' 29.5"; Longitude: 91° 58' 25.8"

Discharge shall be in accordance with effluent limitations, monitoring requirements, and other conditions set forth in this permit.

Effective Date:
Expiration Date:

Steven L. Drown
Chief, Water Division
Arkansas Department of Environmental Quality

Permit Number: AR0001210

AFIN: 02-00013 Page 1 of Part IA

PART I PERMIT REQUIREMENTS

SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: OUTFALL 001 – process wastewater (Paper Mill, Plywood Plant, and Studmill operations), sanitary wastewater, landfill leachate, site stormwater¹, chemical plant, building products, treated effluent from the City of Crossett, truck wash and backwash wastewater.

During the period beginning on the effective date and lasting until the date of expiration, the permittee is authorized to discharge from Outfall 001. Such discharges shall be limited and monitored by the permittee as specified below.

		Dischar	ge Limitations		Monitoring	Requirements
Effluent Characteristics	Ma: (lbs/day, otherwise s	unless		ntration unless specified)	Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		
Flow (MGD)	N/A	N/A	Report	Report	Daily	Totalizing Meter
Biochemical Oxygen Demand (BOD5)	24155.4	46453.0	64.4	123.8	Three/week	24-hr composite
Total Suspended Solids (TSS)	37720	70188	119.6	222.4	Three/week	24-hr composite
2,3,7,8-TCDD ⁴	Report	Report	Report pg/l	Report pg/l	Once/quarter	24-hr composite
Adsorbable Organic Halogens (AOX) ²	2193.04	3299.97	N/A	N/A	Once/day	24-hr composite
Dieldrin ⁵	0.00034	0.0011	0.00091 μg/l	0.00284 µg/l	Once/month	24-hr composite
Total Recoverable Copper ⁵	8.42	16.89	22.43 μg/l	45.00 μg/l	Once/month	24-hr composite
Total Recoverable Mercury ⁵	0.026	0.053	0.07 μg/l	0.14 μg/l	Once/month	24-hr composite
Total Recoverable Zinc ⁵	75.21	150.90	200.40 μg/l	402.09 μg/l	Once/month	24-hr composite
Total Phosphorus	Report	Report	Report	Report	Three/week	24-hr composite
Nitrates as Nitrogen	Report	Report	Report	Report	Three/week	24-hr composite
рН	N/A	N/A	Minimum 6.0 s.u.	Maximum 9.0 s.u.	Three/week	Grab
Chronic Whole Effluent Toxicity ³	N/A	N/A	N/A	N/A	Once/2 months	24-hr composite
Pimephales promelas (Chronic) Pass/Fail Lethality (7-day NOEC) TLP6C Pass/Fail Growth (7-day NOEC)TGP6C Survival (7-day NOEC) TOP6C Coefficient of Variation, Growth TQP6C Growth (7-day NOEC) TPP6C Ceriodaphnia dubia (Chronic)			Report (Pas Report (Pas Repo Repo Repo	Average s=0/Fail=1) s=0/Fail=1) ort % ort % ort % Average	once/2 months once/2 months once/2 months once/2 months once/2 months	24-hr composite 24-hr composite 24-hr composite 24-hr composite 24-hr composite
Pass/Fail Lethality (7-day NOEC) TLP3B Pass/Fail production (7-day NOEC)TGP3B Survival (7-day NOEC) TOP3B Coefficient of Variation, Reproduction TQP3B Reproduction (7-day NOEC) TPP3B			Report (Pas Repo Repo	s=0/Fail=1) s=0/Fail=1) ort % ort %	once/2 months once/2 months once/2 months once/2 months	24-hr composite 24-hr composite 24-hr composite 24-hr composite

- 1 See Condition No. 26 of Part II (BMP Requirements).
- 2 See Condition No. 11 of Part II (AOX Test Method).
- 3 See Condition No. 23 of Part II (WET Testing Requirements).
- 4 See Condition No. 10 of Part II (Dioxin Monitoring Requirements).
- 5 See Condition No. 22 of Part II (Metals and Pesticides Test Methods).

Permit Number: AR0001210

AFIN: 02-00013 Page 2 of Part IA

There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks.

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s): at the Outfall 001, following the final treatment unit (aeration basin) at Latitude: 33° 06' 25"; Longitude: 92° 02' 16" before discharge to Mossy Lake.



Permit Number: AR0001210

AFIN: 02-00013 Page 3 of Part IA

PART I PERMIT REQUIREMENTS

SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: Stream Monitoring Station (SMS) 002 – At the Transition from Mossy Lake to Coffee Creek.

During the period beginning on the effective date and lasting until the date of expiration, the permittee is authorized to discharge from serial number SMS 002. Such discharges shall be limited and monitored by the permittee as specified below.

		Dischar	ge Limitations		Monitoring	Requirements ¹
Effluent Characteristics	Ma: (lbs/day, otherwise s	unless	(mg/l,	ntration unless specified)	Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		
Flow (MGD)	N/A	N/A	Report	Report	Daily	Totalizing Meter
Biochemical Oxygen Demand (BOD5)						
October – July	8000	12000	Report	Report	Three/week	24-hr composite
August	7262	10893	Report	Report	Three/week	24-hr composite
September	5911	8867	Report	Report	Three/week	24-hr composite
Total Suspended Solids (TSS)	18000	30000	Report	Report	Three/week	24-hr composite
Dieldrin ²	0.00034	0.0011	0.00091 μg/l	0.00284 μg/l	Once/month	24-hr composite
Total Recoverable Copper ²	8.42	16.89	22.43 μg/l	45.00 μg/l	Once/month	24-hr composite
Total Recoverable Mercury ²	0.026	0.053	0.07 μg/l	0.14 μg/l	Once/month	24-hr composite
Total Recoverable Zinc ²	75.21	150.90	200.40 μg/l	402.09 μg/l	Once/month	24-hr composite
Total Phosphorous	Report	Report	Report	Report	Three/week	24-hr composite
Nitrates as Nitrogen	Report	Report	Report	Report	Three/week	24-hr composite
рН	N/A	N/A	Minimum 6.0 s.u.	Maximum 9.0 s.u.	Three/week	Grab

When Mossy Lake is not flooded. A flooded state is defined as the period when the gauge at the Felsenthal Lock and Dam exceeds 62 feet and also for the two weeks following the recession of flood waters below 62 feet.

2 See Condition No. 22 of Part II (Metals and Pesticides Test Methods).

There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks.

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s): at the SMS 002, after Mossy Lake and prior to Coffee Creek in the general area of the following coordinates: Latitude: 33° 01' 58"; Longitude: 92° 04' 25".



Permit Number: AR0001210

AFIN: 02-00013 Page 4 of Part IA

PART I PERMIT REQUIREMENTS

SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: Internal Outfall 101 – Line 1A of Hardwood Effluent.

During the period beginning on the effective date and lasting until the date of expiration, the permittee is authorized to discharge from internal Outfall 101. Such discharges shall be limited and monitored by the permittee as specified below.

		Discharg	e Limitations		Monitoring	g Requirements
Effluent Characteristics	Mas (lbs/day, otherwise s	unless	Concent (µg/l, u otherwise s	ınless	Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		
Flow (MGD)	N/A	N/A	Report	Report	Daily	Instantaneous
2,3,7,8-Tetrachlorodibenzo-p-dioxin (TCDD)	N/A	N/A	N/A	<10 pg/l	Once/month	24-hr composite
2,3,7,8-Tetrachlorodebenzofuran (TCDF)	N/A	N/A	N/A	31.9 pg/l	Once/month	24-hr composite
Trichlorosyringol ¹	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
3,4,5-Trichlorocatechol	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
3,4,6-Trichlorocatechol	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
3,4,5-Trichloroguaiacol ¹	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
3,4,6-Trichloroguaiacol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
4,5,6-Trichloroguaiacol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
2,4,5-Trichlorophenol ¹	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
2,4,6-Trichlorophenol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
Tetrachlorocatechol	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
Tetrachloroguaiacol	N/A	N/A	N/A	< 5.0	Once/month	24-hr composite
2,3,4,6-Tetrachlorophenol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
Pentachlorophenol 1	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
pH of 1 st ClO ₂ Bleaching Stage	N/A	N/A	1.86 s.u., n		Once/day	Grab ⁴
Kappa Factor of 1 st ClO ₂ Bleaching Stage ²	N/A	N/A	N/A	0.455	Once/day	Grab⁴
Total Bleach Line ClO ₂ Application Rate ³	N/A	N/A	N/A	134.2 lb per ton of pulp	Once/day	Totalizing Meter

- 1 See Condition No. 11 of Part II (Test Method Requirements).
- 2 See Condition No. 17 of Part II (Definition of Kappa Factor).
- 3 See Condition Nos. 18 and 19 of Part II (ClO₂ Application Rate).
- 4 Permittee may monitor these parameters via probe or grab sample.
- 5 Unitless ratio.

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. Samples taken in compliance with monitoring requirements specified above shall be taken at the following location(s): internal outfall 101 (Line 1A – Hardwood) at Latitude: 33° 08' 29.5"; Longitude: 91° 58' 25.8" and prior to commingling with other waste streams.

Permit Number: AR0001210

AFIN: 02-00013 Page 5 of Part IA

PART I PERMIT REQUIREMENTS

SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: Internal Outfall 102 – Line 1B of Hardwood Effluent.

During the period beginning on the effective date and lasting until the date of expiration, the permittee is authorized to discharge from internal Outfall 102. Such discharges shall be limited and monitored by the permittee as specified below.

		Discharg	e Limitations		Monitoring	g Requirements
Effluent Characteristics	Mas (lbs/day, otherwise s	unless	Concen (µg/l, t otherwise s	ınless	Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		. 21
Flow (MGD)+	N/A	N/A	Report	Report	Daily	Instantaneous
2,3,7,8-Tetrachlorodibenzo-p-dioxin (TCDD) ¹	N/A	N/A	N/A	<10 pg/l	Once/month	24-hr composite
2,3,7,8-Tetrachlorodebenzofuran (TCDF)	N/A	N/A	N/A	31.9 pg/l	Once/month	24-hr composite
Trichlorosyringol Trichlorosyringol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
3,4,5-Trichlorocatechol	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
3,4,6-Trichlorocatechol	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
3,4,5-Trichloroguaiacol ¹	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
3,4,6-Trichloroguaiacol ¹	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
4,5,6-Trichloroguaiacol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
2,4,5-Trichlorophenol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
2,4,6-Trichlorophenol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
Tetrachlorocatechol 1	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
Tetrachloroguaiacol ¹	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
2,3,4,6-Tetrachlorophenol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
Pentachlorophenol	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
pH of 1st ClO ₂ Bleaching Stage	N/A	N/A	1.76 s.u., r		Once/day	Grab ⁴
Kappa Factor of 1 st ClO ₂ Bleaching Stage ²	N/A	N/A	N/A	0.425	Once/day	Grab ⁴
Total Bleach Line ClO ₂ Application Rate ³	N/A	N/A	N/A	128.2 lb per ton of pulp	Once/day	Totalizing Meter

- 1 See Condition No. 11 of Part II (Test Method Requirements).
- 2 See Condition No. 17 of Part II (Definition of Kappa Factor).
- 3 See Condition Nos. 18 and 19 of Part II (ClO₂ Application Rate).
- 4 Permittee may monitor these parameters via probe or grab sample.
- 5 Unitless ratio.

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. Samples taken in compliance with monitoring requirements specified above shall be taken at the following location(s): internal outfall 102 (Line 1B – Hardwood) at Latitude: 33° 08' 29.5"; Longitude: 91° 58' 25.8"and prior to commingling with other waste streams.

Permit Number: AR0001210

AFIN: 02-00013 Page 6 of Part IA

PART I PERMIT REQUIREMENTS

SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: Internal Outfall 103 – Line 2 of Softwood Effluent.

During the period beginning on the effective date and lasting until the date of expiration, the permittee is authorized to discharge from internal Outfall 103. Such discharges shall be limited and monitored by the permittee as specified below.

		Discharg	e Limitations		Monitoring	g Requirements
Effluent Characteristics	Mac (lbs/day, otherwise s Monthly Avg.	unless	Concent (µg/l, u otherwise s Monthly	nless	Frequency	Sample Type
Flow (MGD)+	N/A	N/A	Avg. Report	Report	Daily	Instantaneous
2,3,7,8-Tetrachlorodibenzo-p-dioxin (TCDD)	N/A	N/A	N/A	<10 pg/l	Once/month	24-hr composite
2,3,7,8-Tetrachlorodebenzofuran (TCDF)	N/A	N/A	N/A	31.9 pg/l	Once/month	24-hr composite
Trichlorosyringol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
3,4,5-Trichlorocatechol ¹	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
3,4,6-Trichlorocatechol	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
3,4,5-Trichloroguaiacol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
3,4,6-Trichloroguaiacol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
4,5,6-Trichloroguaiacol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
2,4,5-Trichlorophenol ¹	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
2,4,6-Trichlorophenol ¹	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
Tetrachlorocatechol ¹	N/A	N/A	N/A	< 5.0	Once/month	24-hr composite
Tetrachloroguaiacol ¹	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
2,3,4,6-Tetrachlorophenol	N/A	N/A	N/A	<2.5	Once/month	24-hr composite
Pentachlorophenol ¹	N/A	N/A	N/A	<5.0	Once/month	24-hr composite
pH of 1 st ClO ₂ Bleaching Stage	N/A	N/A	1.28 s.u., r		Once/day	Grab⁴
Kappa Factor of 1 st ClO ₂ Bleaching Stage ²	N/A	N/A	N/A	0.575	Once/day	Grab⁴
Total Bleach Line ClO ₂ Application Rate ³	N/A	N/A	N/A	185.8 lb per ton of pulp	Once/day	Totalizing Meter

- See Condition No. 11 of Part II (Test Method Requirements).
- 2 See Condition No. 17 of Part II (Definition of Kappa Factor).
- 3 See Condition Nos. 18 and 19 of Part II (ClO₂ Application Rate).
- 4 Permittee may monitor these parameters via probe or grab sample.
- 5 Unitless ratio.

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. Samples taken in compliance with monitoring requirements specified above shall be taken at the following location(s): internal outfall 103 (Line 2 – Softwood) at Latitude: 33° 08' 29.5"; Longitude: 91° 58' 25.8" and prior to commingling with other waste streams.

Permit Number: AR0001210

AFIN:02-00013 Page 1 of Part IB

SECTION B. PERMIT COMPLIANCE

The permittee shall achieve compliance with the effluent limitations specified for discharges in accordance with the following schedule:

Compliance is required on the effective date of the permit except as outlined below in Item #3.

- 1. The report required by Condition No. 12 of Part II of this permit shall be submitted no later than May 31 of each year.
- 2. The permittee must conduct the fish tissue analysis required by Condition No. 14 of Part II of the permit during the third year of the permit cycle. The results must be submitted within 30 days of the completion of the sampling and analyses.

Permit Number: AR0001210

AFIN: 02-00013 Page 1 of Part II

PART II OTHER CONDITIONS

- 1. The operator of this wastewater treatment facility shall hold an Advanced Industrial license from the State of Arkansas in accordance with Act 1103 of 1991, Act 556 of 1993, Act 211 of 1971, and Regulation No. 3, as amended.
- 2. In accordance with 40 CFR Parts 122.62 (a)(2) and 124.5, this permit may be reopened for modification or revocation and/or reissuance to require additional monitoring and/or effluent limitations when new information is received that actual or potential exceedance of State water quality criteria and/or narrative criteria are determined to be the result of the permittee's discharge(s) to a relevant water body, or a Total Maximum Daily Load (TMDL) is established or revised for the water body that was not available at the time of the permit issuance that would have justified the application of different permit conditions at the time of permit issuance.

3. Other Specified Monitoring Requirements

The permittee may use alternative appropriate monitoring methods and analytical instruments other than as specified in Part I Section A of the permit without a major permit modification under the following conditions:

- The monitoring and analytical instruments are consistent with accepted scientific practices;
- The requests shall be submitted in writing to the Permits Section of the ADEQ Water Division for use of the alternate method or instrument.
- The method and/or instrument is in compliance with 40 CFR Part 136 or approved by the Director; and
- All associated devices are installed, calibrated and maintained to insure the accuracy of the measurements and are consistent with the accepted capability of that type of device. The calibration and maintenance shall be performed as part of the permittee's laboratory Quality Control/Quality Assurance program.

Upon written approval of the alternative monitoring method and/or analytical instruments, these methods or instruments must be consistently utilized throughout the monitoring period. ADEQ must be notified in writing and the permittee must receive written approval from ADEQ if the permittee decides to return to the original permit monitoring requirements.

4. The permittee has certified no chlorophenolic biocides are currently used. Any anticipated use of these biocides will require notification to ADEQ as specified in 40 CFR 122.61(a).

Permit Number: AR0001210 AFIN: 02-00013 Page 2 of Part II

- 5. The Department has an MSDS on file for the nutrient blend (MacroGro GPC-30 Wastewater Nutrient Blend) which lists the Nitrogen content as 15 27% as N by weight and the Phosphorous content as 3 15% as P₂O₅ by weight. The permittee must receive written permission from the Department prior to changing the nutrient blend added to the treatment process for biological activity if the change causes the Nitrogen or Phosphorous to be outside of the listed range.
- 6. In accordance with 40 CFR 429.11(c), the term "process wastewater" specifically excludes non-contact cooling water, material storage yard runoff (either raw material or processed wood storage), boiler blowdown, and wastewater from washout of thermal oxidizers or catalytic oxidizers, wastewater from biofilters, or wastewaters from wet electrostatic precipitators used upstream of thermal oxidizers or catalytic oxidizers installed by facilities covered by subparts B, C, D, or M to comply with the national emissions standards for hazardous air pollutants (NESHAP) for plywood and composite wood products (PCWP) facilities (40 CFR Part 63, subpart DDDD). For the dry process hardboard, veneer, finishing, particleboard, and sawmills and planing mills subcategories, fire control water is excluded from the definition. This condition is applicable only to the plywood and the sawmill facilities.
- 7. The permittee has certified zinc hydrosulfite is not used in the bleaching process. Any anticipated use of zinc hydrosulfite will require notification to ADEQ as specified in 40 CFR 122.61(a).

8. Dioxin Monitoring Requirements

For compliance purposes, the minimum quantification levels (MQLs) listed below or lower detection levels (DL) shall be used for monthly average and daily maximum effluent concentrations, as applicable, for listed pollutants. Test results which are less than the respective MQL or DL may be reported as 'zero'.

Pollutant	EPA Method	ML (μg/l)
2,3,7,8 - TCDD	1613 or latest	0.00001 or lower

9. In accordance with 40 CFR 430.01(i) the following EPA Methods must be utilized when testing bleach plant effluent as specified for Internal Outfalls 101,102, and 103.

Pollutant	EPA Method
2,3,7,8-TCDD	1613
2,3,7,8-TCDF	1613
Trichlorosyringol	1653

Permit Number: AR0001210

AFIN: 02-00013 Page 3 of Part II

Pollutant	EPA Method
3,4,5-Trichlorocatechol	1653
3,4,6-Trichlorocatechol	1653
3,4,6-Trichloroguaiacol	1653
4,5,6-Trichloroguaiacol	1653
2,4,5-Trichlorophenol	1653
Tetrachlorocatechol	1653
Tetarachloroguaiacol	1653
2,3,4,6-Tetrachlorophenol	1653
Pentachlorophenol	1653
AOX	1650

10. Specific Conditions Related to Best Management Practices Conditions

Within 30 days after permit issuance, the Permittee shall submit a report indicating compliance with items having deadlines prior to permit issuance in accordance with 40 CFR 430.03(j).

The Permittee shall make the BMP Plan available at the facility for inspection by a representative of the ADEQ. The BMP Plan must contain all information outlined in 40 CFR 430.03(d).

No later than May 31 of each year, the Permittee shall submit a report to the ADEQ indicating the BMP monitoring results, action level exceedances and corrective actions taken to respond to any exceedances. Exceedances are not violations of the permit. Failure to take appropriate action as soon as practicable is a permit violation. This report must contain all of the information outlined in 40 CFR 430.03(i)(4). The time frame to be covered by the report is the previous calendar year.

The Permittee shall maintain the records specified in 40 CFR 430.03(g) for a minimum of three years.

Permit Number: AR0001210

AFIN: 02-00013 Page 4 of Part II

11. Permit Conditions for Accepting City of Crossett Wastewater

Georgia-Pacific and the City of Crossett must maintain the agreement for the discharge of the City's treated effluent into G-P's wastewater treatment system. The agreement must continue to state that the City will have a Pretreatment Program meeting applicable parts of 40 CFR 403, and the agreement will establish treatment standards for BOD₅ and TSS for the City's treated effluent that are submitted to and approved by the ADEQ. The agreement must also continue to address the notifications that the City must provide to G-P and the ADEQ in the event of potential changes in its discharge due to new significant dischargers, or changes in their wastewater characteristics. The agreement with the City of Crossett must continue to stipulate that monitoring records of the City's flow, BOD₅ and TSS will be maintained by the city for a minimum of three years to ascertain compliance with the Agreement.

12. Fish Tissue Analysis Condition

The permittee shall continue to assess the levels of 2,3,7,8 TCDD in ambient fish tissue in the receiving stream.

A. Stations:

(Outfall) - Between the confluence of Coffee Creek & the Ouachita River and the Louisiana state line

(Background) - Upstream of Felsenthal Lock and Dam

B. Species of fish to collect

The facility shall collect a minimum of three predator species and a minimum of three bottom feeder species from each station. Any combination of the following is acceptable.

Buffalo, Blue catfish, Flathead catfish, Crappie, or Bass

C. Sampling time

Sampling is allowed at any time during the year. Monitoring results shall be submitted on an annual basis to the ADEQ within 30 days of the completion of sampling and analysis.

D. Test Frequency

Testing shall be done once during the permit cycle. This testing must be conducted during the third year of the permit cycle. The Department reserves the right to require more additional tests if the testing yields greater than 5.33 ppt of 2,3,7,8 TCDD. This is required only at the Outfall station.

Permit Number: AR0001210

AFIN: 02-00013 Page 5 of Part II

E. Method of Analysis

Edible fish fillet samples shall be analyzed and reported for 2,3,7,8 TCDD. The method of analysis shall be in accordance with the latest approved procedure of Method 1613.

13. General Condition for Plant Operations

In addition to the normal wastewater discharge, this NPDES permit authorizes discharges associated with or resulting during essential maintenance, regularly scheduled maintenance, during startup and shutdown, spills and release (whether anticipated or unanticipated) from anywhere in the permitted facility, as long as they are amenable to treatment, routed to the plant's wastewater treatment system and effluent limitations are met. In addition, discharges that are necessary to prevent loss of life, personal injury or severe property damage, as long as there are no feasible alternatives available, are also authorized by this permit, so long as effluent limitations are met.

- 14. The permittee must continue to use no elemental chlorine on any of the bleaching lines. This requirement is based on 40 CFR 430.02(f)(4).
- 15. In accordance with 40 CFR 430.02(f)(7)(i), kappa factor is the ratio of available chlorine (total equivalent chlorine, as percent on oven dry pulp) to the kappa number of the pulp. Kappa number is the lignin content of pulp, as measured by a modified permanganate test corrected to 50 percent consumption of the chemical.
- 16. In accordance with 40 CFR 430.02(f)(7)(ii), the total bleach line chlorine dioxide application rate is the mass of chlorine dioxide applied in all stages of the bleach line per mass of unbleached pulp (i.e., lb/ton or kg/kkg).
- 17. In accordance with 40 CFR 430.02(f)(7)(iii), chlorine containing compounds are compounds containing chlorine used in the bleach plant for bleaching, brightening, or whitening, or viscosity control. These compounds include, but are not limited to, chlorine (Cl₂), sodium hypochlorite (NaOCl), chlorine dioxide (ClO₂), and chlorine monoxide (Cl₂O).
- 18. In accordance with 40 CFR 430.02(f)(6)(i), if for any reason (e.g., intentionally or due to process upset) the permittee fails to maintain process and operating conditions at values equal to or less than the maximum value recorded under paragraphs (f)(2)(ii) or (f)(3)(ii)of this section for each condition, the permittee will be in violation of the applicable chloroform limitation or standard unless:
 - a. Within 30 days, the permittee notifies the Department in writing of the exceedance; and
 - b. The permittee demonstrates compliance with the applicable chloroform limitation or standard by immediately monitoring the bleach plant effluent for chloroform at a frequency

Permit Number: AR0001210

AFIN: 02-00013 Page 6 of Part II

similar to that required in paragraph (a) of this section and for a duration determined by the Department. (once per week for four weeks)

- 19. In accordance with 40 CFR 430.02(f)(6)(ii), in order to continue the exemption from the minimum monitoring requirements of this section for chloroform, the permittee must meet the requirements of paragraph (f)(6)(i) (condition no. 19 above) and recertify that the fiber line process and operating conditions do not exceed the maximum value recorded paragraphs (f)(2)(ii) or (f)(3)(ii) of this section for each of the parameters identified in those paragraphs.
- 20. The permittee may use any EPA approved method based on 40 CFR Part 136 provided the MQL for the chosen method is equal to or less than what has been specified in chart below:

Pollutant	MQL (μg/l)
Total Recoverable Copper	0.5
Total Recoverable Mercury	0.005
Total Recoverable Zinc	20
Dieldrin	0.02

The permittee may develop a matrix specific method detection limit (MDL) in accordance with Appendix B of 40 CFR Part 136. For any pollutant for which the permittee determines a site specific MDL, the permittee shall send to ADEQ, NPDES Permits Branch, a report containing QA/QC documentation, analytical results, and calculations necessary to demonstrate that a site specific MDL was correctly calculated. A site specific minimum quantification level (MQL) shall be determined in accordance with the following calculation:

MQL = 3.3 X MDL

Upon written approval by Permits Branch, the site specific MQL may be utilized by the permittee for all future Discharge Monitoring Report (DMR) calculations and reporting requirements.

Permit Number: AR0001210

AFIN: 02-00013 Page 7 of Part II

21. WHOLE EFFLUENT TOXICITY LIMITS (7-DAY CHRONIC NOEC FRESHWATER)

SCOPE AND METHODOLOGY

a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL(S): 001

REPORTED ON DMR AS FINAL OUTFALL: 001

CRITICAL DILUTION (%): 80%

EFFLUENT DILUTION SERIES (%): 25%, 34%, 45%, 60%, & 80%

TESTING FREQUENCY: once/2 months

COMPOSITE SAMPLE TYPE: Defined at PART I

TEST SPECIES/METHODS: 40 CFR Part 136

<u>Ceriodaphnia dubia</u> chronic static renewal survival and reproduction test, Method 1002.0, EPA-821-R-02-013, or the most recent update thereof. This test should be terminated when 60% of the surviving females in the control produce three broods or at the end of eight days, whichever comes first.

<u>Pimephales promelas</u> (Fathead minnow) chronic static renewal 7-day larval survival and growth test, Method 1000.0, EPA-821-R-02-013, or the most recent update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Effect Concentration) is herein defined as the greatest effluent dilution at and below which toxicity (lethal or sub-lethal) that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Chronic lethal test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution. Chronic sub-lethal test failure is defined as a demonstration of a statistically significant sub-lethal effect (i.e., growth or reproduction) at test completion to a test species at or below the critical dilution.
- c. This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.

Permit Number: AR0001210

AFIN: 02-00013 Page 8 of Part II

2. PERSISTENT LETHAL and/or SUB-LETHAL EFFECTS

The requirements of this subsection apply only when a toxicity test demonstrates significant lethal and/or sub-lethal effects at or below the critical dilution. The purpose of additional tests (also referred to as 'retests' or confirmation tests) is to determine the duration of a toxic event. A test that meets all test acceptability criteria and demonstrates significant toxic effects does not need additional confirmation. Such testing cannot confirm or disprove a previous test result.

If any valid test demonstrates significant lethal or sub-lethal effects to a test species at or below the critical dilution, the frequency of testing for that species is automatically increased to once per quarter for the life of the permit. In addition:

a. Part I Testing Frequency Other Than Monthly

- i. The permittee shall conduct a total of three (3) additional tests for any species that demonstrates significant toxic effects at or below the critical dilution. The additional tests shall be conducted monthly during the next three consecutive months. If testing on a quarterly basis, the permittee may substitute one of the additional tests in lieu of one routine toxicity test. A full report shall be prepared for each test required by this section in accordance with procedures outlined in Item 4 of this section and submitted with the period discharge monitoring report (DMR) to the permitting authority for review.
- ii. IF LETHAL EFFECTS HAVE BEEN DEMONSTRATED If any of the additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall initiate Toxicity Reduction Evaluation (TRE) requirements as specified in Item 5 of this section. The permittee shall notify ADEQ in writing within 5 days of the failure of any retest, and the TRE initiation date will be the test completion date of the first failed retest. A TRE may also be required due to a demonstration of-intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests. A TRE required based on lethal effects should consider any sub-lethal effects as well.
- iii. IF SUB-LETHAL EFFECTS ONLY HAVE BEEN DEMONSTRATED If any two of the three additional tests demonstrates significant sub-lethal effects at 75% effluent or lower, the permittee shall initiate the Sub-Lethal Toxicity Reduction Evaluation (TRE_{SL}) requirements as specified in Item 5 of this section. The permittee shall notify ADEQ in writing within 5 days of the failure of any retest, and the Sub-Lethal Effects TRE initiation date will be the test completion date of the first failed retest. A TRE may be also be required for failure to perform the required retests.

Permit Number: AR0001210 AFIN: 02-00013 Page 9 of Part II

iv. The provisions of Item 2.a.i. are suspended upon submittal of the TRE Action Plan.

b. Part I Testing Frequency of Monthly

The permittee shall initiate the Toxicity Reduction Evaluation (TRE) requirements as specified in Item 5 of this section when any two of three consecutive monthly toxicity tests exhibit significant toxic effects at or below the critical dilution. A TRE may also be required due to a demonstration of intermittent lethal and/or sub-lethal effects at or below the critical dilution, or for failure to perform the required retests.

3. REQUIRED TOXICITY TESTING CONDITIONS

a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- i. The toxicity test control (0% effluent) must have survival equal to or greater than 80%.
- ii. The mean number of <u>Ceriodaphnia dubia</u> neonates produced per surviving female in the control (0% effluent) must be 15 or more.
- iii. 60% of the surviving control females must produce three broods. The mean dry weight of surviving Fathead minnow larvae at the end of the 7 days in the control (0% effluent) must be 0.25 mg per larva or greater.
- iv. The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for: the young of surviving females in the <u>Ceriodaphnia dubia</u> reproduction test; the growth and survival endpoints of the Fathead minnow test.
- v. The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, <u>unless</u> significant lethal or sub-lethal effects are exhibited for: the young of surviving females in the <u>Ceriodaphnia dubia</u> reproduction test; the growth and survival endpoints of the Fathead minnow test.
- vi. If a test passes, yet the percent coefficient of variation between replicates is greater than 40% in the control (0% effluent) and/or in the critical dilution for: the young of surviving females in the <u>Ceriodaphnia dubia</u> reproduction test; the growth and survival endpoints of the Fathead minnow test, the test is determined to be invalid. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.

Permit Number: AR0001210 AFIN: 02-00013 Page 10 of Part II

- vii. If a test fails, test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%.
- viii. A Percent Minimum Significant Difference (PMSD) range of 13 47 for Ceriodaphnia dubia reproduction;
- ix. A PMSD range of 12 30 for Fathead minnow growth.

b. Statistical Interpretation

- i. For the <u>Ceriodaphnia dubia</u> survival test, the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be Fisher's Exact Test as described in EPA/821/R-02-013 or the most recent update thereof.
- ii. For the <u>Ceriodaphnia dubia</u> reproduction test and the Fathead minnow larval survival and growth test, the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA/821/R-02-013 or the most recent update thereof.
- iii. If the conditions of Test Acceptability are met in Item 3.a above and the percent survival of the test organism is equal to or greater than 80% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report a survival NOEC of not less than the critical dilution for the DMR reporting requirements found in Item 4 below.

c. Dilution Water

- i. Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness, and alkalinity to the closest downstream perennial water for:
 - (A)toxicity tests conducted on effluent discharges to receiving water classified as intermittent streams; and
 - (B) toxicity tests conducted on effluent discharges where no receiving water is available due to zero flow conditions.

Permit Number: AR0001210

AFIN: 02-00013 Page 11 of Part II

ii. If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 3.a), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:

- (A) a synthetic dilution water control which fulfills the test acceptance requirements of Item 3.a was run concurrently with the receiving water control;
- (B) the test indicating receiving water toxicity has been carried out to completion (i.e., 7 days);
- (C) the permittee includes all test results indicating receiving water toxicity with the full report and information required by Item 4 below; and
- (D) the synthetic dilution water shall have a pH, hardness, and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

- i. The permittee shall collect a minimum of three flow-weighted composite samples from the outfall(s) listed at Item 1.a above. Unless otherwise stated in this section, a composite sample for WET shall consist of 12 subsamples gathered at equal time intervals during a 24-hour period.
- ii. The permittee shall collect second and third composite samples for use during 24-hour renewals of each dilution concentration for each test. The permittee must collect the composite samples such that the effluent samples, on use, are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on a regular or intermittent basis.
- iii. The permittee must collect all three flow-weighted composite samples within the monitoring period. Second and/or third composite samples shall not be collected into the next monitoring period; such tests will be determined to be invalid. Monitoring period definitions are listed in Part IV.
- iv. The permittee must collect the composite samples so that the maximum holding time for any effluent sample shall not exceed 72 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first composite sample. Samples shall be chilled to 6 degrees Centigrade during collection, shipping, and/or storage.

Permit Number: AR0001210

AFIN: 02-00013 Page 12 of Part II

v. If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must have collected an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days if the discharge occurs over multiple days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 4 of this section.

- vi. <u>MULTIPLE OUTFALLS:</u> If the provisions of this section are applicable to multiple outfalls, the permittee shall combine the composite effluent samples in proportion to the average flow from the outfalls listed in item 1.a. above for the day the sample was collected. The permittee shall perform the toxicity test on the flow-weighted composite of the outfall samples.
- vii. The permittee shall not allow the sample to be dechlorinated at the laboratory. At the time of sample collection the permittee shall measure the TRC of the effluent. The measured concentration of TRC for each sample shall be included in the lab report submitted by the permittee.

4. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this section in accordance with the Report Preparation Section of EPA/821/R-02-013, or the most current publication, for every valid or invalid toxicity test initiated whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of PART III.C.7 of this permit. The permittee shall submit full reports. For any test which fails, is considered invalid or which is terminated early for any reason, the full report must be submitted for agency review.
- b. A valid test for each species must be reported on the DMR during each reporting period specified in PART I of this permit unless the permittee is performing a TRE which may increase the frequency of testing and reporting. Only <u>ONE</u> set of WET test data for each species is to be recorded on the DMR for each reporting period. The data submitted should reflect the <u>LOWEST</u> lethal and sub-lethal effects results for each species during the reporting period. The full reports for all invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached to the DMR for Agency review.

Permit Number: AR0001210 AFIN: 02-00013 Page 13 of Part II

c. The permittee shall submit the results of each valid toxicity test on the subsequent monthly DMR for that reporting period in accordance with PART III.D.4 of this permit, as follows below. Submit retest information clearly marked as such with the following month's DMR. Only results of valid tests are to be reported on the DMR.

- i. Pimephales promelas (Fathead minnow)
 - (A) If the No Observed Effect Concentration (NOEC) for survival is less than the critical dilution, enter a '1'; otherwise, enter a '0' for Parameter No. TLP6C
 - (B) Report the NOEC value for survival, Parameter No. TOP6C
 - (C) Report the NOEC value for growth, Parameter No. TPP6C
 - (D) If the NOEC for growth is less than the critical dilution, enter a '1'; otherwise, enter a '0' for Parameter No. TGP6C
 - (E) Report the highest (critical dilution or control) Coefficient of Variation for growth, Parameter No. TQP6C

ii. Ceriodaphnia dubia

- (A) If the NOEC for survival is less than the critical dilution, enter a '1'; otherwise, enter a '0'c for Parameter No. TLP3B
- (B) Report the NOEC value for survival, Parameter No. TOP3B
- (C) Report the NOEC value for reproduction, Parameter No. TPP3B
- (D) If the NOEC for reproduction is less than the critical dilution, enter a '1'; otherwise, enter a '0' for Parameter No. TGP3B
- (E) Report the higher (critical dilution or control) Coefficient of Variation for reproduction, Parameter No. TQP3B

5. TOXICITY REDUCTION EVALUATIONS (TREs)

TREs for lethal and sub-lethal effects are performed in a very similar manner. EPA Region 6 is currently addressing TREs as follows: a sub-lethal TRE (TRE_{SL}) is triggered based on three sub-lethal test failures while a lethal effects TRE (TRE_L) is triggered based on only two test failures for lethality. In addition, EPA Region 6 will consider the magnitude of toxicity and use flexibility when considering a TRE_{SL} where there are no effects at effluent dilutions of less than 76% effluent.

Permit Number: AR0001210 AFIN: 02-00013

Page 14 of Part II

a. Within ninety (90) days of confirming persistent toxicity, the permittee shall submit a Toxicity Reduction Evaluation (TRE) Action Plan and Schedule for conducting a TRE. The TRE Action Plan shall specify the approach and methodology to be used in performing the TRE. A Toxicity Reduction Evaluation is an investigation intended to determine those actions necessary to achieve compliance with water quality-based effluent limits by reducing an effluent's toxicity to an acceptable level. A TRE is defined as a step-wise process which combines toxicity testing and analyses of the physical and chemical characteristics of a toxic effluent to identify the constituents causing effluent toxicity and/or treatment methods which will reduce the effluent toxicity. The goal of the TRE is to maximally reduce the toxic effects of effluent at the critical dilution and includes the following:

i. Specific Activities. The plan shall detail the specific approach the permittee intends to utilize in conducting the TRE. The approach may include toxicity characterizations, identifications and confirmation activities, source evaluation, treatability studies, or alternative approaches. When the permittee conducts Toxicity Characterization Procedures the permittee shall perform multiple characterizations and follow the procedures specified in the documents 'Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures' (EPA-600/6-91/003) and 'Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I' (EPA-600/6-91/005F), or alternate procedures. When the permittee conducts Toxicity Identification Evaluations and Confirmations, the permittee shall perform multiple identifications and follow the methods specified in the documents 'Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity'c (EPA/600/R-92/080) and 'Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity' (EPA/600/R-92/081), as appropriate.

The documents referenced above may be obtained through the <u>National Technical Information Service</u> (NTIS) by phone at (703) 487-4650, or by writing:

U.S. Department of Commerce National Technical Information Service 5285 Port Royal Road Springfield, VA 22161

ii. Sampling Plan (e.g., locations, methods, holding times, chain of custody, preservation, etc.). The effluent sample volume collected for all tests shall be adequate to perform the toxicity test, toxicity characterization, identification and

Permit Number: AR0001210

AFIN: 02-00013 Page 15 of Part II

confirmation procedures, and conduct chemical specific analyses when a probable toxicant has been identified;

Where the permittee has identified or suspects specific pollutant(s) and/or source(s) of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical specific analyses for the identified and/or suspected pollutant(s) and/or source(s) of effluent toxicity. Where lethality was demonstrated within 48 hours of test initiation, each composite sample shall be analyzed independently. Otherwise the permittee may substitute a composite sample, comprised of equal portions of the individual composite samples, for the chemical specific analysis;

- iii. Quality Assurance Plan (e.g., QA/QC implementation, corrective actions, etc.); and
- iv. Project Organization (e.g., project staff, project manager, consulting services, etc.).
- c. The permittee shall initiate the TRE Action Plan within thirty (30) days of plan and schedule submittal. The permittee shall assume all risks for failure to achieve the required toxicity reduction.
- d. The permittee shall submit a quarterly TRE Activities Report, with the Discharge Monitoring Report in the months of January, April, July and October, containing information on toxicity reduction evaluation activities including:
 - i. any data and/or substantiating documentation which identifies the pollutant(s) and/or source(s) of effluent toxicity;
 - ii. any studies/evaluations and results on the treatability of the facility's effluent toxicity; and
 - iii. any data which identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant toxicity at the critical dilution.

A copy of the TRE Activities Report shall also be submitted to the state agency.

e. The permittee shall submit a Final Report on Toxicity Reduction Evaluation Activities no later than twenty-eight (28) months from confirming toxicity in the retests, which provides information pertaining to the specific control mechanism selected that will, when implemented, result in reduction of effluent toxicity to no significant toxicity at the critical dilution. The report will also provide a specific corrective action schedule for implementing the selected control mechanism.

Permit Number: AR0001210

AFIN: 02-00013 Page 16 of Part II

A copy of the Final Report on Toxicity Reduction Evaluation Activities shall also be submitted to the state agency.

f. Quarterly testing during the TRE is a minimum monitoring requirement. EPA recommends that permittees required to perform a TRE not rely on quarterly testing alone to ensure success in the TRE, and that additional screening tests be performed to capture toxic samples for identification of toxicants. Failure to identify the specific chemical compound causing toxicity test failure will normally result in a permit limit for whole effluent toxicity limits per federal regulations at 40 CFR 122.44(d)(1)(v).

6. MONITORING FREQUENCY REDUCTION

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first four consecutive quarters or first twelve consecutive months (in accordance with Item 1.a.) of testing for one or both test species, with no lethal or sublethal effects demonstrated at or below the critical dilution. If granted, the monitoring frequency for that test species may be reduced to not less than once per year for the less sensitive species (usually the Fathead minnow) and not less than twice per year for the more sensitive test species (usually the Ceriodaphnia dubia).
- b. CERTIFICATION The permittee must certify in writing that no test failures have occurred and that all tests meet all test acceptability criteria in item 3.a. above. In addition the permittee must provide a list with each test performed including test initiation date, species, NOECs for lethal and sub-lethal effects and the maximum coefficient of variation for the controls. Upon review and acceptance of this information the agency will issue a letter of confirmation of the monitoring frequency reduction. A copy of the letter will be forwarded to the agency's Permit Compliance System section to update the permit reporting requirements.
- c. SUB-LETHAL OR SURVIVAL FAILURES If any test fails the survival or sub-lethal endpoint at any time during the life of this permit, three monthly retests are required and the monitoring frequency for the affected test species shall be increased to once per quarter until the permit is re-issued. Monthly retesting is not required if the permittee is performing a TRE.

Any monitoring frequency reduction granted applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to once per quarter until the permit is re-issued.

24. The NPDES permit is issued to the Consumer Products and Paper (CP&P) mill. Should company divestitures split the CP&P mill from the Building Products (BP) facilities in the complex (Chemical plant, Stud mill and Plywood plant) then the NPDES permit will remain with the CP&P mill. The CP&P mill, as permit holder, will enter into and maintain an

Permit Number: AR0001210 AFIN: 02-00013

Page 17 of Part II

agreement with the BP facilities for the discharge of the BP facilities' effluent into the wastewater treatment system. The agreement will state that the Chemical plant, the Stud mill and Plywood plant will meet the applicable wastewater requirements of Arkansas DEQ regulations. The agreement will also establish monitoring requirements for parameters in the BP facilities' effluent. The agreement will also address the notifications that the BP facilities must provide to CP&P and the ADEQ in the event of potential changes in its discharge due to new significant dischargers, or changes in their wastewater characteristics.

- 25. The Agreement with the BP facilities will stipulate that monitoring records will be maintained for a minimum of three years to ascertain compliance with the Agreement.
- 26. Stormwater runoff commingling with other process waster discharged from Outfall 001 shall be managed in accordance with the Best Management Practices (BMPs) in the form of a stormwater pollution prevention plan (SWPPP) to control the quality of stormwater discharges associated with industrial activity that are authorized by this permit. Use of BMPs in lieu of numeric effluent limitations in NPDES permits is authorized under 40 CFR 122.44(k) when the Permitting Authority finds numeric effluent limitations to be infeasible to carry out the purposes of the Clean Water Act.
- 27. If the permittee can demonstrate through more sensitive analyses that the discharge does not have the potential to exceed state water quality standards-based effluent limits, the more stringent state water quality numerical standard-based effluent limit(s), monitoring requirements, and the schedule of compliance will be deleted in the final permit. Such new information must be submitted prior to the end of the public comment period. This condition applies only to Dieldrin.



Permit Number: AR0001210

AFIN: 02-00013 Page 1 of Part III

PART III STANDARD CONDITIONS

SECTION A - GENERAL CONDITIONS

1. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the federal Clean Water Act and the Arkansas Water and Air Pollution Control Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; and/or for denial of a permit renewal application. Any values reported in the required Discharge Monitoring Report (DMR) which are in excess of an effluent limitation specified in Part I shall constitute evidence of violation of such effluent limitation and of this permit.

2. Penalties for Violations of Permit Conditions

The Arkansas Water and Air Pollution Control Act provides that any person who violates any provisions of a permit issued under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year, or a fine of not more than twenty-five thousand dollars (\$25,000) or by both such fine and imprisonment for each day of such violation. Any person who violates any provision of a permit issued under the Act may also be subject to civil penalty in such amount as the court shall find appropriate, not to exceed ten thousand dollars (\$10,000) for each day of such violation. The fact that any such violation may constitute a misdemeanor shall not be a bar to the maintenance of such civil action.

3. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause including, but not limited to the following:

- a. Violation of any terms or conditions of this permit; or
- b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
- c. A change in any conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- d. A determination that the permitted activity endangers human health or the environment and can only be regulated to acceptable levels by permit modification or termination.
- e. Failure of the permittee to comply with the provisions of APCEC Regulation No. 9 (Permit fees) as required by Part III.A.10. herein.

Permit Number: AR0001210

AFIN: 02-00013 Page 2 of Part III

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

4. Toxic Pollutants

Notwithstanding Part III.A.3., if any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under APCEC Regulation No. 2, as amended, or Section 307(a) of the Clean Water Act for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitations on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standards or prohibition and the permittee so notified.

The permittee shall comply with effluent standards, narrative criteria, or prohibitions established under APCEC Regulation No. 2, as amended, or Section 307 (a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Civil and Criminal Liability

Except as provided in permit conditions on "Bypassing" (Part III.B.4.a.), and "Upsets" (Part III.B.5.b), nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. Any false or materially misleading representation or concealment of information required to be reported by the provisions of this permit or applicable state and federal statues or regulations which defeats the regulatory purposes of the permit may subject the permittee to criminal enforcement pursuant to the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

6. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject to under Section 311 of the Clean Water Act.

7. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law or regulation under authority preserved by Section 510 of the Clean Water Act.

Permit Number: AR0001210

AFIN: 02-00013 Page 3 of Part III

8. Property Rights

The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State, or local laws or regulations.

9. Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provisions of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

10. Permit Fees

The permittee shall comply with all applicable permit fee requirements for wastewater discharge permits as described in APCEC Regulation No. 9 (Regulation for the Fee System for Environmental Permits). Failure to promptly remit all required fees shall be grounds for the Director to initiate action to terminate this permit under the provisions of 40 CFR Parts 122.64 and 124.5 (d), as adopted in APCEC Regulation No. 6 and the provisions of APCEC Regulation No. 8.

SECTION B – OPERATION AND MAINTENANCE OF POLLUTION CONTROLS

1. Proper Operation and Maintenance

- a. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
- b. The permittee shall provide an adequate operating staff which is duly qualified to carryout operation, maintenance, and testing functions required to insure compliance with the conditions of this permit.

Permit Number: AR0001210 AFIN: 02-00013

Page 4 of Part III

2. Need to Halt or Reduce not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. Upon reduction, loss, or failure of the treatment facility, the permittee shall, to the extent necessary to maintain compliance with its permit, control production or discharges or both until the facility is restored or an alternative method of treatment is provided. This requirement applies, for example, when the primary source of power for the treatment facility is reduced, is lost, or alternate power supply fails.

3. <u>Duty to Mitigate</u>

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment or the water receiving the discharge.

4. Bypass of Treatment Facilities

a. Bypass not exceeding limitation

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts II.B.4.b. and 4.c.

b. Notice

- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
- (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Part III.D.6. (24-hour notice).

c. Prohibition of bypass

- (1) Bypass is prohibited and the Director may take enforcement action against a permittee for bypass, unless:
 - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if the permittee could have installed adequate backup equipment to prevent a bypass which occurred during normal or preventive maintenance; and

Permit Number: AR0001210

AFIN: 02-00013 Page 5 of Part III

- (c) The permittee submitted notices as required by Part III.B.4.b.
- (2) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in Part III.B.4.c.(1).

5. Upset Conditions

- a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Part III.B.5.b. of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- b. Conditions necessary for demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the permittee can identify the specific cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated.
 - (3) The permittee submitted notice of the upset as required by Part III.D.6.; and
 - (4) The permittee complied with any remedial measures required by Part III.B.3.
- c. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

6. Removed Substances

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of waste waters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering the waters of the State. Written approval must be obtained from the ADEQ for land application only.

7. Power Failure

The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failure either by means of alternate power sources, standby generators, or retention of inadequately treated effluent.



Permit Number: AR0001210

AFIN: 02-00013 Page 6 of Part III

SECTION C – MONITORING AND RECORDS

1. Representative Sampling

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points shall not be changed without notification to and the approval of the Director. Intermittent discharges shall be monitored.

2. Flow Measurement

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to insure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure the accuracy of the measurements are consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than +/- 10% from true discharge rates throughout the range of expected discharge volumes and shall be installed at the monitoring point of the discharge.

3. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals frequent enough to insure accuracy of measurements and shall insure that both calibration and maintenance activities will be conducted. An adequate analytical quality control program, including the analysis of sufficient standards, spikes, and duplicate samples to insure the accuracy of all required analytical results shall be maintained by the permittee or designated commercial laboratory. At a minimum, spikes and duplicate samples are to be analyzed on 10% of the samples.

4. Penalties for Tampering

The Arkansas Water and Air Pollution Control Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year or a fine of not more than ten thousand dollars (\$10,000) or by both such fine and imprisonment.

Permit Number: AR0001210

AFIN: 02-00013 Page 7 of Part III

5. Reporting of Monitoring Results

Monitoring results must be reported on a Discharge Monitoring Report (DMR) form (EPA No. 3320-1 or other approved Form by ADEQ). Permittees are required to use preprinted DMR forms provided by ADEQ, unless specific written authorization to use other reporting forms is obtained from ADEQ. Monitoring results obtained during the previous calendar month shall be summarized and reported on a DMR form postmarked no later than the 25th day of the month following the completed reporting period to begin on the effective date of the permit. Duplicate copies of DMR forms signed and certified as required by Part III.D.11. and all other reports required by Part III.D., shall be submitted to the Director at the following address:

Permits Enforcement Branch Water Division Arkansas Department of Environmental Quality 5301 Northshore Drive North Little Rock, AR 72118-5317

If permittee uses outside laboratory facilities for sampling and/or analysis, the name and address of the contract laboratory shall be included on the DMR.

6. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR. Such increased frequency shall also be indicated on the DMR.

7. Retention of Records

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of the Director at any time.

8. Record Contents

Records and monitoring information shall include:

- a. The date, exact place, time and methods of sampling or measurements, and preservatives used, if any;
- b. The individuals(s) who performed the sampling or measurements;

Permit Number: AR0001210

AFIN: 02-00013 Page 8 of Part III

- c. The date(s) and time analyses were performed;
- d. The individual(s) who performed the analyses;
- e. The analytical techniques or methods used; and
- f. The measurements and results of such analyses.

9. Inspection and Entry

The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, and
- d. Sample, inspect, or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

SECTION D – REPORTING REQUIREMENTS

1. Planned Changes

The permittee shall give notice and provide plans and specification to the Director for review and approval prior to any planned physical alterations or additions to the permitted facility. Notice is required only when:

- a. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR Part 122.29(b).
- b. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR Part 122.42 (a)(1).

2. Anticipated Noncompliance

The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

Permit Number: AR0001210

AFIN: 02-00013 Page 9 of Part III

3. Transfers

The permit is nontransferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act.

4. Monitoring Reports

Monitoring results shall be reported at the intervals and in the form specified in Part III.C.5. Discharge Monitoring Reports must be submitted even when no discharge occurs during the reporting period.

5. Compliance Schedule

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date. Any reports of noncompliance shall include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirement.

6. Twenty-four Hour Report

- a. The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain the following information:
 - (1) a description of the noncompliance and its cause;
 - (2) the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and
 - (3) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
- b. The following shall be included as information which must be reported within 24 hours:
 - (1) Any unanticipated bypass which exceeds any effluent limitation in the permit;
 - (2) Any upset which exceeds any effluent limitation in the permit and
 - (3) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in Part I of the permit to be reported within 24 hours to the Enforcement Section of the Water Division of the ADEQ.
- c. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours to the Enforcement Section of the Water Division of the ADEQ.

Permit Number: AR0001210

AFIN: 02-00013 Page 10 of Part III

7. Other Noncompliance

The permittee shall report all instances of noncompliance not reported under Parts II.D.4., 5., and 6., at the time monitoring reports are submitted. The reports shall contain the information listed at Part III.D.6.

8. Changes in Discharge of Toxic Substances for Industrial Dischargers

The permittee shall notify the Director as soon as he/she knows or has reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" described in 40 CFR Part 122.42(a)(1); or
- b. That any activity has occurred or will occur which would result in any discharge on a non-routine or infrequent basis of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" described in 40 CFR Part 122.42(a)(2).

9. Duty to Provide Information

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit. Information shall be submitted in the form, manner and time frame requested by the Director.

10. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The complete application shall be submitted at least 180 days before the expiration date of this permit. The Director may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date. Continuation of expiring permits shall be governed by regulations promulgated in APCEC Regulation No. 6.

Permit Number: AR0001210 AFIN: 02-00013

Page 11 of Part III

11. Signatory Requirements

All applications, reports, or information submitted to the Director shall be signed and certified as follows:

a. All **permit applications** shall be signed as follows:

- (1) For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
 - (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or
 - (ii) The manager of one or more manufacturing, production, or operation facilities, provided: the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
- (2) For a partnership or sole proprietorship: by a general partner or proprietor, respectively; or
- (3) For a municipality, State, Federal, or other public agency, by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes:
 - (i) The chief executive officer of the agency, or
 - (ii) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.
- b. All **reports** required by the permit and **other information** requested by the Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - (1) The authorization is made in writing by a person described above.
 - (2) The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility. (A duly authorized representative may thus be either a named individual or any individual occupying a named position); and
 - (3) The written authorization is submitted to the Director.
- c. Certification. Any person signing a document under this section shall make the following certification:



Permit Number: AR0001210

AFIN: 02-00013 Page 12 of Part III

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

12. Availability of Reports

Except for data determined to be confidential under 40 CFR Part 2 and APCEC Regulation No. 6, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department of Environmental Quality. As required by the Regulations, the name and address of any permit applicant or permittee, permit applications, permits, and effluent data shall not be considered confidential.

13. Penalties for Falsification of Reports

The Arkansas Air and Water Pollution Control Act provides that any person who knowingly makes any false statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under this permit shall be subject to civil penalties specified in Part III.A.2. and/or criminal penalties under the authority of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

Permit Number: AR0001210

AFIN: 02-00013 Page 1 of Part IV

PART IV DEFINITIONS

All definitions contained in Section 502 of the Clean Water Act shall apply to this permit and are incorporated herein by reference. Additional definitions of words or phrases used in this permit are as follows:

- 1. "Act" means the Clean Water Act, Public Law 95-217 (33.U.S.C. 1251 et seq.) as amended.
- 2. "Administrator" means the Administrator of the U.S. Environmental Protection Agency.
- 3. "Applicable effluent standards and limitations" means all State and Federal effluent standards and limitations to which a discharge is subject under the Act, including, but not limited to, effluent limitations, standards of performance, toxic effluent standards and prohibitions, and pretreatment standards.
- 4. "Applicable water quality standards" means all water quality standards to which a discharge is subject under the federal Clean Water Act and which has been (a) approved or permitted to remain in effect by the Administrator following submission to the Administrator pursuant to Section 303(a) of the Act, or (b) promulgated by the Director pursuant to Section 303(b) or 303(c) of the Act, and standards promulgated under (APCEC) Regulation No. 2, as amended.
- 5. **"Bypass"** means the intentional diversion of waste streams from any portion of a treatment facility.
- 6. **"Daily Discharge"** means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. *Mass Calculations:* For pollutants with limitations expressed in terms of mass, the "daily discharge" is calculated as the total mass of pollutant discharged over the sampling day. *Concentration Calculations:* For pollutants with limitations expressed in other units of measurement, determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the "daily discharge" determination of concentration shall be the arithmetic average (weighted by flow value) of all the samples collected during that sampling day by using the following formula: where C= daily concentration, F=daily flow and n=number of daily samples

$$\frac{C_1F_1 + C_2F_2 + \cdots + C_nF_n}{F_1 + F_2 + \cdots + F_n}$$

7. "Monthly average" means the highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month. For Fecal Coliform Bacteria (FCB) report the monthly average (see 30-day average below).

Permit Number: AR0001210

AFIN: 02-00013 Page 2 of Part IV

- 8. "Daily Maximum" discharge limitation means the highest allowable "daily discharge" during the calendar month. The daily average for Fecal Coliform Bacteria (FCB) is the geometric mean of the values of all effluent samples collected during the day in colonies per 100 ml.
- 9. "Department" means the Arkansas Department of Environmental Quality (ADEQ).
- 10. "Director" means the Administrator of the U.S. Environmental Protection Agency and/or the Director of the Arkansas Department of Environmental Quality.
- 11. "Grab sample" means an individual sample collected in less than 15 minutes in conjunction with an instantaneous flow measurement.
- 12. "Industrial User" means a nondomestic discharger, as identified in 40 CFR Part 403, introducing pollutants to a POTW.
- 13. "National Pollutant Discharge Elimination System" means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements under Sections 307, 402, 318, and 405 of the Clean Water Act.
- 14. "POTW" means a Publicly Owned Treatment Works.
- 15. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in products.
- 16. "APCEC" means the Arkansas Pollution Control and Ecology Commission.
- 17. "Sewage sludge" means the solids, residues, and precipitate separated from or created in sewage by the unit processes at a POTW. Sewage as used in this definition means any wastes, including wastes from humans, households, commercial establishments, industries, and stormwater runoff that are discharged to or otherwise enter a POTW.
- 18. "7-day average" discharge limitation, other than for Fecal Coliform Bacteria (FCB), is the highest allowable arithmetic mean of the values for all effluent samples collected during the calendar week. The 7-day average for Fecal Coliform Bacteria (FCB) is the geometric mean of the values of all effluent samples collected during the calendar week in colonies/100 ml. The Discharge Monitoring Report should report the highest 7-day average obtained during the calendar month. For reporting purposes, the 7-day average values should be reported as occurring in the month in which the Saturday of the calendar week falls in.
- 19. "30-day average", other than for Fecal Coliform Bacteria (FCB), is the arithmetic mean of the daily values for all effluent samples collected during a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. The 30-day average for Fecal Coliform Bacteria (FCB) is the geometric mean of the values for all effluent samples collected during a calendar month. For Fecal Coliform Bacteria (FCB), report the monthly average as a 30-day geometric mean in colonies per 100 ml.

Permit Number: AR0001210

AFIN: 02-00013 Page 3 of Part IV

- 20. **"24-hour composite sample"** consists of a minimum of 12 effluent portions collected at equal time intervals over the 24-hour period and combined proportional to flow or a sample collected at frequent intervals proportional to flow over the 24-hour period.
- 21. **"12-hour composite sample"** consists of 12 effluent portions, collected no closer together than one hour and composited according to flow or a sample collected at frequent intervals proportional to flow over the 12-hour period.
- 22. **"6-hour composite sample"** consists of six effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow or a sample collected at frequent intervals proportional to flow over the 6-hour period.
- 23. "3-hour composite sample" consists of three effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow or a sample collected at frequent intervals proportional to flow over the 3-hour period.
- 24. "Treatment works" means any devices and systems used in storage, treatment, recycling, and reclamation of municipal sewage and industrial wastes, of a liquid nature to implement section 201 of the Act, or necessary to recycle reuse water at the most economic cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and alterations thereof; elements essential to provide a reliable recycled supply such as standby treatment units and clear well facilities, and any works, including site acquisition of the land that will be an integral part of the treatment process or is used for ultimate disposal of residues resulting from such treatment.
- 25. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. Any upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, lack of preventive maintenance, or careless of improper operations.
- 26. "For Fecal Coliform Bacteria (FCB)", a sample consists of one effluent grab portion collected during a 24-hour period at peak loads. For Fecal Coliform Bacteria (FCB) report the monthly average as a 30-day geometric mean in colonies per 100 ml.
- 27. "Dissolved oxygen limit", shall be defined as follows:
 - a. When limited in the permit as a monthly average minimum, shall mean the lowest acceptable monthly average value, determined by averaging all samples taken during the calendar month;
 - b. When limited in the permit as an instantaneous minimum value, shall mean that no value measured during the reporting period may fall below the stated value.
- 28. **The term "MGD"** shall mean million gallons per day.
- 29. The term "mg/l "shall mean milligrams per liter or parts per million (ppm).
- 30. The term "ug/l" shall mean micrograms per liter or parts per billion (ppb).
- 31. The term "cfs" shall mean cubic feet per second.
- 32. The term "ppm" shall mean parts per million.
- 33. **The term "s.u."** shall mean standard units.

Permit Number: AR0001210

AFIN: 02-00013 Page 4 of Part IV

34. The term "Instantaneous Maximum" when limited in the permit as an instantaneous maximum value, shall mean that no value measured during the reporting period may fall above the stated value.

35. Monitoring and Reporting:

When a permit becomes effective, monitoring requirements are of the immediate period of the permit effective date. Where the monitoring requirement for an effluent characteristic is monthly or more frequently, the Discharge Monitoring Report (DMR) shall be submitted by the 25th of the month following the sampling. Where the monitoring requirement for an effluent characteristic is Quarterly, Semi-Annual, Annual, or Yearly, the DMR shall be submitted by the 25th of the month following the monitoring period end date.

MONTHLY:

is defined as a calendar month or any portion of a calendar month for monitoring requirement frequency of once/month or more frequently.

QUARTERLY:

- (1) is defined as a fixed calendar quarter or any part of the fixed calendar quarter for a non-seasonal effluent characteristic with a measurement frequency of once/quarter. Fixed calendar quarters are: January through March, April through June, July through September, and October through December; or
- (2) is defined as a fixed three month period (or any part of the fixed three month period) of or dependent upon the seasons specified in the permit for a seasonal effluent characteristic with a monitoring requirement frequency of once/quarter that does not coincide with the fixed calendar quarter. Seasonal calendar quarters are: May through July, August through October, November through January, and February through April.

SEMI-ANNUAL:

is defined as the fixed time periods January through June, and July through December (or any portion thereof) for an effluent characteristic with a measurement frequency of once/6 months or twice/year.

ANNUAL or YEARLY:

is defined as a fixed calendar year or any portion of the fixed calendar year for an effluent characteristic or parameter with a measurement frequency of once/year. A calendar year is January through December, or any portion thereof.

36. **The term "Weekday"** means Monday – Friday.