

A R K A N S A S Department of Environmental Quality

JAN 4 2013

CERTIFIED MAIL: RETURN RECEIPT REQUESTED (91 7199 9991 7030 4905 3593)

Mr. Don O'Neal, General Manager City of Wynne 121 East Merriman Avenue Wynne, AR 72396

RE: Discharge Permit Number AR0021903 – AFIN 19-00071

Dear Mr. O'Neal:

Enclosed are the public notice, a copy of the draft permit and Fact Sheet which the Arkansas Department of Environmental Quality (ADEQ) has prepared and mailed to you on the above date under the authority of the National Pollutant Discharge Elimination System (NPDES) and the Arkansas Water and Air Pollution Control Act. A copy of the final permit will be mailed to you when the Department has made a final permitting decision.

In accordance with Reg. 8.207, the enclosed public notice will be or has been published by <u>ADEQ</u> in a newspaper of general circulation of your facility for one (1) day only. An invoice for the cost of publishing the public notice and proof of publication will be sent to you by the advertising newspaper. The permittee <u>must</u> send proof of publication and proof of payment to the address at the bottom of this letter as soon as possible but no later than 30 days from the above date. Until this Department receives proof of publication of the public notice and payment of all permit fees, no further action will be taken on the issuance of your discharge permit.

The following is a list of the major changes to the previously issued permit:

- 1. Total Recoverable Arsenic reporting requirements have been removed.
- 2. Part II has been revised to remove language for the development of an approvable Pretreatment Program.
- 3. Sewage sludge practices for land application have been removed due to an issuance of a land application permit.
- 4. Monitoring frequency for CBOD5, TSS, NH3-N, FCB, pH and DO have been reduced from three/week to once/week.
- 5. Monitoring and reporting requirements for Nitrate + Nitrite Nitrogen (NO3 + NO2-N) have been included.
- 6. Monitoring and reporting requirements for Total Phosphorus (TP) have been included.
- 7. Monitoring and reporting requirements for Total Dissolved Solids (TDS) have been included.
- 8. Monitoring and reporting requirements for Chloride (Cl) have been included.

For a list of changes, please see Section 5 of the enclosed Fact Sheet.

Comments must be received at ADEQ prior to the close of the public comment period as described in the enclosed public notice. Once a final permit is issued by the Director and becomes effective, the permittee must comply with all terms and conditions of the permit, or be subject to enforcement actions for any instances of noncompliance during the duration of the permit, usually five (5) years. Consequently, it is imperative that you, as the applicant, thoroughly review the enclosed documentation for accuracy, applicability, and your ability to comply with all conditions therein.

Should you have any questions concerning any part of the draft permit, please contact Christopher Randall at (501) 682-0617.

Sincerely,

Steven L. Drown
Chief, Water Division

SD:cr

Enclosure

PUBLIC NOTICE OF DRAFT DISCHARGE PERMIT AND 208 Plan PERMIT NUMBER AR0021903, AFIN 19-00071

This is to give notice that the Permits Branch of the Water Division of the Arkansas Department of Environmental Quality (ADEQ), 5301 Northshore Drive, North Little Rock, Arkansas 72118-5317 at telephone number (501) 682-0622, proposes a draft renewal of the permit for which an application was received on 3/28/2012 for the following applicant under the National Pollutant Discharge Elimination System (NPDES) and the Arkansas Water and Air Pollution Control Act.

Applicant: City of Wynne, 545 Bowden Road, Wynne, AR 72396. Location: approximately 1.5 miles west of Wynne on Hwy 284 to Bowden Road, thence south on Bowden Road approximately 0.25 mile.; Latitude: 35° 13′ 8.81"; Longitude: 90° 49′ 41.25" in Cross County, Arkansas. The discharge of treated municipal wastewater is into a drainage ditch, thence to Caney Creek, thence to the L'Anguille River, thence to the St. Francis River in Segment 5B of the St. Francis River Basin.

The 208 Plan, developed by the ADEQ under provisions of Section 208 of the federal Clean Water Act, is a comprehensive program to work toward achieving federal water goals in Arkansas. The initial 208 Plan, adopted in 1979, provides for annual updates, but can be revised more often if necessary. The 208 Plan is being updated to revise the monthly average NH3-N limit for May-October from 3.0 mg/l to 2.1 mg/l.

ADEQ's contact person for submitting written comments, requesting information regarding the draft permit, or obtaining a copy of the permit and the Fact Sheet is Christopher Randall, at the above address and telephone number or by email at Water-Draft-Permit-Comment@adeq.state.ar.us. For those with Internet access, a copy of the proposed draft permit as well as the publication date may be found on the ADEQ's website at: http://www.adeq.state.ar.us/water/branch_permits/individual_permits/pn_permits/pnpermits.asp.

The last day of the comment period is 30 days after the publication date. If the last day of the comment period is a Saturday, Sunday or legal holiday, the public comment period shall expire on the next day that is not a Saturday, Sunday or legal holiday. For information regarding the actual publication date along with the actual date and time the comment period will end, please contact Christopher Randall at the above address and telephone number or by email at Water-Draft-Permit-Comment@adeq.state.ar.us. Public notice, comments, and hearings will be conducted in accordance with Regulation 6.104(A)(5) [40 CFR Parts 124.10 through 124.12 by reference] and Regulation 8.209 and 8.210 (Administrative Procedures). All persons, including the permittee, who wish to comment on ADEQ's draft permitting decision must submit written comments to ADEQ, along with their name and mailing address. A Public Hearing will be held when ADEQ finds a significant degree of public interest. After the public comment period, ADEQ will issue a final permitting decision. ADEQ will notify the applicant and each person who has submitted written comments or request notice of the final permitting decision. Any interested person who has submitted comments may appeal a final decision by ADEQ in accordance with the APCEC Regulation No. 8.603.

Fact Sheet

This Fact Sheet is for information and justification of the permit limits only. Please note that it is not enforceable. This draft permitting decision is for renewal of the discharge Permit Number AR0021903 with Arkansas Department of Environmental Quality (ADEQ) Facility Identification Number (AFIN) 19-00071 to discharge to Waters of the State.

1. PERMITTING AUTHORITY.

The issuing office is:

Arkansas Department of Environmental Quality 5301 Northshore Drive North Little Rock, Arkansas 72118-5317

2. APPLICANT.

The applicant's mailing address is:

City of Wynne 121 East Merriman Avenue Wynne, AR 72396

The facility address is:

City of Wynne 545 Bowden Road Wynne, AR 72396

3. PREPARED BY.

The permit was prepared by:

Christopher Randall
Staff Engineer
Discharge Permits Section, Water Division (501) 682-0617
E-mail: randall@adeq.state.ar.us

4. PERMIT ACTIVITY.

Previous Permit Effective Date: 12/1/2007 Previous Permit Expiration Date: 11/30/2012

Page 2 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

The permittee submitted a permit renewal application on 3/28/2012 with additional information received on 12/11/2012. It is proposed that the current discharge permit be reissued for a 5-year term in accordance with regulations promulgated at 40 CFR Part 122.46(a).

DOCUMENT ABBREVIATIONS

In the document that follows, various abbreviations are used. They are as follows:

- BAT best available technology economically achievable
- BCT best conventional pollutant control technology
- BMP best management practices
- BOD₅ five-day biochemical oxygen demand
- BPJ best professional judgment
- BPT best practicable control technology currently available
- CBOD₅ carbonaceous biochemical oxygen demand
- CD critical dilution
- CFR Code of Federal Regulations
- cfs cubic feet per second
- Cl Chloride
- COD chemical oxygen demand
- COE United States Corp of Engineers
- CPP continuing planning process
- CWA Clean Water Act
- DMR discharge monitoring report
- DO dissolved oxygen
- ELG effluent limitation guidelines
- EPA United States Environmental Protection Agency
- ESA Endangered Species Act
- FCB fecal coliform bacteria
- gpm gallons per minute
- MGD million gallons per day
- MQL minimum quantification level
- NAICS North American Industry Classification System
- NH3-N ammonia nitrogen
- $NO_3 + NO_2 N$ nitrate + nitrite nitrogen
- NPDES National Pollutant Discharge Elimination System
- O&G oil and grease
- Reg. 2 APCEC Regulation No. 2
- Reg. 6 APCEC Regulation No. 6

Page 3 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

Reg. 8 - APCEC Regulation No. 8

Reg. 9 - APCEC Regulation No. 9

RP - reasonable potential

SIC - standard industrial classification

TDS - total dissolved solids

TMDL - total maximum daily load

TP - total phosphorus

TRC - total residual chlorine

TSS - total suspended solids

UAA - use attainability analysis

USF&WS - United States Fish and Wildlife Service

WET - Whole effluent toxicity

WQMP - water quality management plan

WQS - Water Quality standards

WWTP - wastewater treatment plant

DMR Review:

The Discharge Monitoring Reports (DMR's) for the last three years were reviewed during the permit renewal process. There were no violations noted during the review of permit data.

Legal Order Review:

There are currently no active Consent Administrative Orders (CAOs) or Notice of Violations (NOVs) for this facility.

Site Visits/Inspections

A routine compliance inspection was performed at the facility on 2/16/2011 by a Water Division Inspector. At the time of inspection the facility appeared to be in compliance with the applicable regulations.

A site visit was made on 9/06/2012 by Water Division Engineers to discuss permit renewal changes including the new land application permit 5155-W. Discussions with the Responsible Official (RO) included: 1) new permit monitoring and reporting requirements for TDS, TP, and Nitrate + Nitrite Nitrogen. 2) Monitoring frequency reduction for CBOD5, TSS, NH3-N, FCB, pH, and DO. 3) Changes associated with the new 5155-W land application permit.

Page 4 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

5. SIGNIFICANT CHANGES FROM THE PREVIOUSLY ISSUED PERMIT.

The permittee is responsible for carefully reading the permit in detail and becoming familiar with all of the changes therein:

- 1. Parts II, III, and IV have been revised.
- 2. The description of the monitoring location has been included.
- 3. The required operator license Class III for the facility has been stated in condition 1 in Part II of the permit.
- 4. Total Recoverable Arsenic has been removed based on the results of the most recent Priority Pollutant Scan (PPS) and DMR data from the previous 3 years.
- 5. Part II has been revised to remove language for the development of an approvable Pretreatment Program.
- 6. Sewage sludge practices for land application have been removed due to an issuance of a land application permit, tracking number 5155-W.
- 7. Nitrate + Nitrite Nitrogen (NO3 + NO2-N) reporting requirements have been added.
- 8. Monitoring and reporting requirements for Total Phosphorus (TP) have been added.
- 9. Monitoring and reporting requirements for Chloride (Cl) have been added.
- 10. Monitoring frequency for CBOD5, TSS, NH3-N, FCB, pH and DO have been reduced from three/week to once/week.
- 11. Monitoring sample type requirements for Total Recoverable Copper and Chronic WET Testing have changed from 24-hr composite to composite and CBOD5, TSS, and NH3-N have changed from 6-hr composite to composite and is defined in No. 8 of Part IV.
- 12. Chronic Biomonitoring has been renamed Chronic WET Testing. Requirements for Chronic WET Testing have been updated based on the previous 5 years of sampling results.
- 13. Monitoring and Reporting requirements for Total Dissolved Solids have been added.

6. RECEIVING STREAM SEGMENT AND DISCHARGE LOCATION.

The outfall is located at the following coordinates based on Google Earth using WGS84:

Latitude: 35° 13' 07" Longitude: 90° 49' 52"

The receiving waters named:

a drainage ditch, thence to Caney Creek, thence to the L'Anguille River, thence to the St. Francis River in Segment 5B of the St. Francis River Basin. The receiving stream with USGS Hydrologic Unit Code (H.U.C) of 08020205 and reach # 901 is a Water of the State classified for secondary contact recreation, raw water source for domestic (public and

Page 5 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

private), industrial, and agricultural water supplies, propagation of desirable species of fish and other aquatic life, and other compatible uses.

7. 303(d) LIST, ENDANGERED SPECIES, AND ANTI-DEGRADATION CONSIDERATIONS.

A. 303(d) List:

The receiving stream is not listed on the 2008 303(d) list. However, Caney Creek, one (1) mile downstream of the facility is listed as impaired for TDS and the L'Anguille River approximately 4.68 miles downstream is listed as impaired for TDS, Chloride, and Dissolved Oxygen. The permittee submitted TDS effluent data and receiving stream background TDS data on December 5, 2012. A reasonable potential analysis was done using the submitted TDS data in accordance with the CPP. The results showed that the discharge showed no reasonable potential to exceed water quality standards in the receiving stream or reasonable potential to exceed EPA's secondary drinking water standards. Therefore, monitoring and reporting requirements for TDS have been included for the duration of the permit until a TMDL is established. Since there is no database for Chloride levels in the effluent from the facility, data must be established to determine if the facility is a contributor to the Chloride impairment in the L'Anguille River. Therefore, monitoring and reporting requirements for Chlorides have been included. The Dissolved Oxygen limits for the City of Wynne are more stringent than the WQS for the impaired stream. Therefore, based on the judgment of the permit writer, no additional permit action is needed at this time for DO.

There is a report entitled "TMDLs for Turbidity and Fecal Coliform for L'Anguille River, AR" dated Oct. 2001. On page 5-6 of this report it states, "...implementation of the fecal coliform TMDL should be based on bacterial counts (i.e. concentration) or percent reduction of fecal coliforms rather than loads of fecal coliform calculated for a single flow during each season." This TMDL also states "...there is no clear connection between point source discharges of fecal coliforms and fecal coliform measurement in the L' Anguille River. Also, ADEQ has set most of the point sources permit limits for fecal coliform at the water quality standard (i.e., the dischargers are required to meet the water quality standard at end of the pipe). Therefore, the wasteload allocations for point sources were calculated based on existing permit limits..." Based on these statements and the inclusion of FCB limits equal to WQS, no additional permit action for FCB is needed at this time.

Page 6 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

This same report identifies inorganic suspended solids from surface erosion as the source of the impairment for turbidity. The report states, "The suspended solids discharged by point sources in the L' Anguille River basin are assumed to consist primarily of organic solids rather than inorganic solids. Discharges of organic suspended solids from point sources are already addressed by ADEQ through their permitting of point sources to maintain water quality standards for dissolved oxygen. Field data collected during May-June 2000 showed that point source discharges appeared to be having little impact on turbidity in the L' Anguille River." Based on these statements and the inclusion of TSS limits, no additional permit action for turbidity is needed at this time.

B. Endangered Species:

No comments on the application were received from the U.S. Fish and Wildlife Service (USF&WS). The draft permit and Fact Sheet will be sent to the USF&WS for their review.

C. Anti-Degradation:

The limitations and requirements set forth in this permit for discharge into waters of the State are consistent with the Anti-degradation Policy and all other applicable water quality standards found in APC&EC Regulation No. 2.

8. OUTFALL, TREATMENT PROCESS DESCRIPTION, AND FACILITY CONSTRUCTION.

The following is a description of the facility described in the application:

- A. Design Flow: 2.76 MGD
- B. Type of Treatment: <u>Wastewater</u>: coarse screening, grit removal, aeration, clarification, UV disinfection, post aeration. <u>Sludge</u>: oxidation ditch, aerobic digester/thickener, land application of sludge.
- C. Discharge Description: treated municipal wastewater
- D. Facility Status: This facility is classified as a Major municipal since the design flow of the facility listed above is greater than 1.0 MGD.

Page 7 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

E. Facility Construction: This permit does not authorize or approve the construction or modification of any part of the treatment system or facilities. Approval for such construction must be by permit issued under Reg. 6.202.

9. ACTIVITY.

Under the Standard Industrial Classification (SIC) code of 4952 or North American Industry Classification System (NAICS) code of 221320, the applicant's activities are the operation of a sewage treatment plant.

10. INDUSTRIAL WASTEWATER CONTRIBUTIONS.

INDUSTRIAL USERS

This facility receives industrial wastewater from one (1) significant industrial user. This Categorical industry is being tracked for compliance with its federal effluent guideline semi-annually. ADEQ is inspected and sampling the industry for compliance assurance. The Department has made the decision based on several criteria that the POTW will not be required to develop an approved pretreatment program at this time. Standard boilerplate Pretreatment Prohibitions (40 CFR 403.5[b]) are deemed appropriate at this time.

11. SEWAGE SLUDGE PRACTICES.

Sludge is land applied. Regulations can be found in the land application of bio-solids permit under permit number 5155-W.

12. PERMIT CONDITIONS.

The Arkansas Department of Environmental Quality has made a determination to issue a draft permit for the discharge described in the application. Permit requirements are based on federal regulations (40 CFR Parts 122, 124, and Subchapter N), the National Pretreatment Regulation in 40 CFR Part 403 and regulations promulgated pursuant to the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. 8-4-101 et. seq.).

A. Effluent Limitations

Outfall 001- treated municipal wastewater

1. Conventional and/or Toxic Pollutants

Page 8 of Fact Sheet Permit Number: AR0021903 AFIN: 19-00071

Effluent Characteristics	Dis	charge Limita	ations	Monitoring R	Requirements
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Monthly Avg.	7-Day Avg.		
Flow	N/A	Report, MGD	Report, MGD (Daily Max.)	once/day	totalizing meter
Overflows	SSOs	Monthly Totals (occurrences/	month)	See Conditio	n 5 of Part II
Overflow Volume	Volume	Monthly Total Volume of SSOs (gallons/month)		See Condition 5 of Part II	
Carbonaceous Biochemical Oxygen Demand (CBOD5)	276	12	18	once/week	composite
Total Suspended Solids (TSS)	345	15	22.5	once/week	composite
Ammonia Nitrogen (NH3-N)					
(April)	48	2.1	5.2	once/week	composite
(May-Oct)	48	2.1	4.5	once/week	composite
(Nov-March)	115	5	7.5	once/week	composite
Dissolved Oxygen (DO)					
(May-Oct)	N/A	7.0 (In	st. Min.)	once/week	grab
(Nov-Apr)	N/A	6.0 (In	st. Min.)	once/week	grab
		(colonie	es/100 ml)		
Fecal Coliform Bacteria (FCB)	N/A	1000	2000	once/week	grab
Copper, Total Recoverable	0.68	29.5 μg/l	59.1 μg/l	once/month	composite
Nitrate + Nitrite Nitrogen (NO3+NO2-N)	Report	Report	Report	once/month	composite
Total Phosphorus (TP)	Report	Report	Report	once/month	composite
Total Dissolved Solids (TDS)	Report	Report	Report	once/month	composite
Chloride (Cl)	Report	Report	Report	once/month	composite
рН	N/A	Minimum 6.0 s.u.	Maximum 9.0 s.u.	once/week	grab
Chronic WET Testing	N/A	N/A	N/A	once/quarter	composite

Page 9 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

Effluent Characteristics	<u>Discharge Limitations</u>			Monitoring Requirements		
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type	
	Monthly Avg.	Monthly Avg.	7-Day Avg.			
Pimephales promelas (Chronic) Pass/Fail Lethality (7-day NOEC) TLP6C Pass/Fail Growth (7-day NOEC)TGP6C Survival (7-day NOEC) TOP6C Coefficient of Variation (Growth) TQP6C Growth (7-day NOEC) TPP6C		Report (Pa Report (Pa Rep Rep	Average ss=0/Fail=1) ss=0/Fail=1) ort % ort % ort %	once/quarter once/quarter once/quarter once/quarter once/quarter	composite composite composite composite	
Ceriodaphnia dubia (Chronic) Pass/Fail Lethality (7-day NOEC) TLP3B Pass/Fail production (7-day NOEC) TGP3B		Report (Pa	Average ss=0/Fail=1) ss=0/Fail=1)	once/quarter once/quarter	composite composite	
Survival (7-day NOEC) TOP3B Coefficient of Variation (Reproduction) TOP3B			ort % ort %	once/quarter once/quarter	composite composite	
Reproduction (7-day NOEC) TPP3B		Rep	ort %	once/quarter	composite	

2. **Solids, Foam, and Free Oil:** There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

13. BASIS FOR PERMIT CONDITIONS.

The following is an explanation of the derivation of the conditions of the draft permit and the reasons for them or, in the case of notices of intent to deny or terminate, reasons suggesting the decisions as required under 40 CFR Part 124.7.

Technology-Based Versus Water Quality-Based Effluent Limitations And Conditions

Following regulations promulgated at 40 CFR Part 122.44, the draft permit limits are based on either technology-based effluent limits pursuant to 40 CFR Part 122.44 (a) or on State water quality standards and requirements pursuant to 40 CFR Part 122.44 (d), whichever are more stringent as follows:

Page 10 of Fact Sheet Permit Number: AR0021903 AFIN: 19-00071

Parameter	Water (Quality-	Techno		Prev	ious	Permit	Limit
	Bas	sed	Based	/BPJ	Pen	nit		
	Monthly	7-day	Monthly	7-day	Monthly	7-day	Monthly	7-day
	Avg.	Avg.	Avg.	Avg.	Avg.	Avg.	Avg.	Avg.
	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l
CBOD5	12	18	25	40	12	18	12	18
TSS	N/A	N/A	30	45	15	22.5	15	22.5
NH3-N				_				
(April)	2.1	5.2	N/A	N/A	2.1	5.2	2.1	5.2
(May-Oct)	2.1	4.5	N/A	N/A	2.1	4.5	2.1	4.5
(Nov-March)	5	7.5	N/A	N/A	5	7.5	5	7.5
DO	_							
(May-Oct)	7.0 (Ins	t. Min.)	N/	A	7.0 (Month	nly Avg.)	7.0 (Inst	. Min.)
(Nov-Apr)	6.0 (Ins	t. Min.)	N/	A	6.0 (Mont	hly Avg.)	6.0 (Inst	. Min.)
FCB (col/100 ml)	1000	2000	N/A	N/A	1000	2000	1000	2000
Copper, Total	29.5	59.1	N/A	N/A	29.5	59.1	29.5	59.1
Recoverable								
Nitrate + Nitrite	N/A	N/A	Report	Report	N/A	N/A	Report	Report
Nitrogen								
TP	N/A	N/A	Report	Report	N/A	N/A	Report	Report
TDS	N/A	N/A	Report	Report	N/A	N/A	Report	Report
Chloride	N/A	N/A	Report	Report	N/A	N/A	Report	Report
рН	6.0-9.	0 s.u.	N/	A	6.0-9.	0 s.u.	6.0-9.0	0 s.u.

A. Justification for Limitations and Conditions of the draft permit:

Parameter	Water Quality or Technology	Justification
CBOD5	Water Quality	MultiSMP Model dated 9/5/2012, 40 CFR 122. 44(1), and previous permit
TSS	Technology	MultiSMP Model dated 9/5/2012, 40 CFR 122. 44(1), and previous permit
NH3-N	Water Quality	Reg. 2.512, MultiSMP Model dated 9/5/2012, 40 CFR 122. 44(1), CPP, and previous permit,
DO	Water Quality	MultiSMP Model dated 9/5/2012, 40 CFR 122. 44(l), and previous permit

Page 11 of Fact Sheet Permit Number: AR0021903 AFIN: 19-00071

Parameter	Water Quality or Technology	Justification
Fecal Coliform Bacteria	Water Quality	Reg. 2.507
Copper, Total Recoverable	Water Quality	Reg. 2.508
Nitrate + Nitrite Nitrogen ²	Technology	СРР
Total Phosphorus ²	Technology	СРР
Chloride ³	Technology	303(d) Listing
TDS ⁴	Technology	303(d) Listing
рН	Water Quality	Reg. 2.504

The minimum required DO level is now expressed as an instantaneous minimum. Reg. 2.501 states that the specific standards set forth in Chapter 5 of Regulation 2 shall apply to all surface waters at all times except during periods when flows are less than the applicable critical flow. Since the dissolved oxygen standards apply at all times, not on an average basis, the dissolved oxygen standards are considered to be instantaneous standards.

Nitrate and Nitrite Nitrogen (NO3+NO2-N) and Total Phosphorus (TP)

In order to establish a database of point source loadings of nutrients to waters of the state of Arkansas, a requirement for monitoring and reporting of this parameter has been included based on the CPP.

³ Chlorides (Cl)

The 2008 303(d) list in Category 5b lists L'Anguille River in Reach 004 as impaired for Chlorides. The confluence of the L'Anguille River is approximately 4.68 miles downstream from the facility. The source of the impairment is listed as from agricultural use, although since there is currently no data for Chloride levels from the facility, it is still necessary to determine if the facility is a contributor to the impairment. In order to establish a database of point source loadings of minerals to waters of the state of Arkansas, a requirement for monitoring and reporting of this parameter has been included.

⁴ Total Dissolved Solids (TDS)

The permittee submitted TDS effluent data and receiving stream background TDS data received on December 11, 2012. A reasonable potential analysis was done using the submitted TDS data in accordance with the CPP. The results showed that the discharge from

Page 12 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

the facility had no reasonable potential to exceed water quality standards in the receiving stream or reasonable potential to exceed EPA's secondary drinking water standards. The permittee discharges to a drainage ditch and must travel approximately (1) stream mile before entering Caney Creek, which is impaired for TDS. Therefore, monitoring and reporting requirements for TDS have been included for the duration of the permit or until a TMDL is established.

B. Anti-backsliding

The draft permit is consistent with the requirements to meet Anti-backsliding provisions of the Clean Water Act (CWA), Section 402(o) [40 CFR 122.44(l)]. The final effluent limitations for reissuance permits must be as stringent as those in the previous permit, unless the less stringent limitations can be justified using exceptions listed in 40 CFR 122.44 (l)(2)(i).

The draft permit maintains the requirements of the current permit with the exceptions of the removal of the monitoring and reporting requirements for Arsenic and the monitoring frequency reduction of CBOD5, TSS, NH3-N, FCB, pH and DO from three/week to once/week.

The removal of monitoring and reporting requirements for Arsenic is allowed in accordance with regulation 40 CFR 122.44(l)(i)(B)(1). The facility submitted a letter dated December 30, 2010, requesting that monitoring and reporting requirements for Arsenic be removed from the permit. Condition No. 8 of Part II of the current permit allowed for the removal of Arsenic if four consecutive monthly samples are below the level of concern, i.e., 2.0 mg/l. The Department reviewed the test results submitted and agreed to no longer require the Arsenic levels in the effluent to be monitored for the remainder of the term of the current permit. The most recent Priority Pollutant Scan (PPS) results submitted with the renewal application and DMR data from the previous 3 years showed no reasonable potential for requiring monitoring and reporting of Arsenic levels in the effluent. Therefore, monitoring and reporting requirements for Arsenic have been removed from the proposed permit.

The monitoring frequency reduction of CBOD5, TSS, NH3-N, FCB, pH and DO from three/week to once/week is due to the result from an evaluation using the EPA's *Interim Guidance for Performance-Based Reductions of NPDES Permit Monitoring Frequencies*. This decrease in monitoring frequency does not constitute backsliding based on 40 CFR 122.44(1)(i)(B)(1).

Page 13 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

C. Limits Calculations

1. Mass limits:

In accordance with 40 CFR 122.45(f)(1), all pollutants limited in permits shall have limitations expressed in terms of mass if feasible. 40 CFR 122.45(f)(2) allows for pollutants which are limited in terms of mass to also be limited in terms of other units of measurement.

The calculation of the loadings (lbs per day) uses a design flow of 2.76 MGD and the following equation:

lbs/day = Concentration (mg/l) X Flow (MGD) X 8.34

2. 7-Day Average Limits:

The 7-Day Average limits for NH3-N (November through March) as well as CBOD5, TDS, and TSS are based on Section 5.4.2 of the Technical Support Document for Water Quality-Based Toxics Control.

7-Day Average limits = Monthly average limits X 1.5

The 7-Day Average NH3-N limits for the months of April through October are based on the requirements of Reg. 2.512.

The 7-Day Average limits for FCB are based on Regs. 2.507.

3. Ammonia-Nitrogen (NH3-N):

The water quality effluent limitations for Ammonia are based either on DO-based effluent limits or on toxicity-based standards, whichever are more stringent. The toxicity-based effluent limitations are based on Reg. 2.512 and the CPP.

4. Minerals

ADEQ has reviewed the information submitted by the permittee indicating the amounts of minerals present in the effluent. The concentration of each mineral after mixing with the receiving stream (IWC) was compared to the applicable water quality standards as established in the Arkansas Water Quality Standards (WQS), Regulation No. 2 and the US EPA's Secondary Drinking Water Standards. Both of these can be found in Section 2.511 of Arkansas Regulation No. 2.

From these standards, total dissolved solids (TDS) have specific numerical criteria.

Page 14 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

The following information was used in calculating the In-stream Waste Concentrations for TDS:

Parameter	Value	Source
Effluent Flow (MGD)	2.76	Submitted Data
Harmonic Mean Flow (cfs)	4.0	CPP
7Q10 (cfs)	0.0	USGS
TDS Background Concentration (mg/L)	385 ²	Submitted Data ¹
Reported TDS Concentration (mg/L)	296	Submitted Data ¹

Permittee submitted outfall and stream sampling data on December 11, 2012.

The permittee submitted one sample analysis for the effluent TDS concentration at outfall 001 and receiving stream TDS concentration just upstream of outfall 001. Since the permittee submitted site-specific data for the background concentration of the receiving stream, the site-specific data was used in the place of the general small stream ecoregion standards used in the CPP for the reasonable potential analysis as a worst-case mean background concentration for that specific stream.

The concentration of TDS after mixing with the receiving stream was compared to the applicable water quality standard as established in Reg. 2.511. Reg. 2.511 contains secondary drinking water standards as well as the ecoregion stream standards. Calculations were done in accordance with the CPP. The following table represents the comparison of IWCs to WQS.

Pollutant	WQS IWC, mg/l	Water Quality Mineral Standards, mg/l	Secondary Drinking Water IWC, mg/l	Secondary Drinking Water Standards, mg/l
Total Dissolved Solids	339	411.3	296	500

Results of mineral IWC's comparisons to Water Quality Standards:

In the case of TDS, neither the WQS for the ECOREGION or EPA's Secondary Drinking Water Standards were exceeded or showed the potential to be exceeded. Therefore, no limitations for TDS will be required. Since only one data point was submitted for effluent concentration, monitoring and reporting requirements have been included to gather more data before a TMDL is established.

TDS background concentration was derived from a sample collected by premittee just upstream of the discharge point.

Page 15 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

D. 208 Plan (Water Quality Management Plan)

The 208 Plan, developed by the ADEQ under provisions of Section 208 of the federal Clean Water Act, is a comprehensive program to work toward achieving federal water goals in Arkansas. The initial 208 Plan, adopted in 1979, provides for annual updates, but can be revised more often if necessary. The 208 Plan is being updated to revise the monthly average NH3-N limit for May-October from 3.0 mg/l to 2.1 mg/l based on toxicity. The current permit already included the 2.1 mg/l NH3-N limit for May-October, but the 208 Plan listed the oxygen-based limit instead of the more stringent toxicity-based limit.

E. Priority Pollutant Scan (PPS)

ADEQ has reviewed and evaluated the effluent in accordance with the potential toxicity of each analyzed pollutant using the procedures outlined in the Continuing Planning Process (CPP).

The concentration of each pollutant after mixing with the receiving stream was compared to the applicable water quality standards as established in the Arkansas Water Quality Standards (AWQS), Regulation No. 2 (Reg. 2.508) and criteria obtained from the "Quality Criteria for Water, 1986 (Gold Book)".

Under Federal Regulation 40 CFR Part 122.44(d), as adopted by Regulation No. 6, if a discharge poses the reasonable potential to cause or contribute to an exceedance above a water quality standard, the permit must contain an effluent limitation for that pollutant. Effluent limitations for the toxicants listed below have been derived in a manner consistent with the Technical Support Document (TSD) for Water Quality-based Toxics Control (EPA, March 1991), the CPP, and 40 CFR Part 122.45(c).

The following items were used in calculations:

Parameter	Value	Source
Flow = Q	2.76 MGD = 4.26 cfs	Application
7Q10	0.0 cfs	U.S.G.S.
TSS	8 mg/l	CPP
Hardness as CaCo3	81 mg/l	CPP
рН	7.03 s.u.	UWLGR01

Page 16 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

The following pollutants were reported above the required MQL:

Pollutant	Concentration Reported, µg/l	MQL, μg/l
Arsenic, Total Recoverable	11.3*	0.5
Copper, Total Recoverable	41.6*	0.5
Lead, Total Recoverable	1.39	0.5
Nickel, Total Recoverable	2.12	0.5
Zinc, Total Recoverable	52.5	20

* Concentration reported for Arsenic and Copper were based on the highest concentration reported in the DMR report for the previous 5 years. There were two outliers for Copper not considered for the highest concentration in the DMR report dating 3/31/2008 with a concentration reported at $140.76~\mu g/l$ and 6/20/2008 with a concentration reported at $245.886~\mu g/l$. These outliers were not representative of the samples reported and while noted were not considered for any limit calculations.

ADEQ has determined from the submitted information that the discharge poses the reasonable potential to cause or contribute to an exceedance above a water quality standard as follows:

(a) Aquatic Toxicity

Substance	Concentration	IWC	Water Quality Standards		
, ;	(C_e)	μg/l	(W	QS)	
,	μg/l		Acute, μg/l	Chronic, µg/l	
Copper	41.6	41.6	38.87	26.41	

In-stream Waste Concentrations (IWC's) have been calculated in the manner described in the CPP.

As can be seen in the table above, the calculated level for the following pollutants are sufficiently higher than the water quality standards. Therefore, the limits for those pollutants are calculated in the manner described in the CPP and are included in the permit as follows:

Fir	nal Limits	
Substance	AML, μg/l	DML, μg/l
Copper, Total Recoverable	29.5	59.1

Page 17 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

14. TOTAL RESIDUAL CHLORINE (TRC) REQUIREMENTS.

No action is necessary. TRC requirements are not included in the permit because UV disinfection is used.

15. WHOLE EFFLUENT TOXICITY.

Section 101(a)(3) of the Clean Water Act states that ".....it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited." In addition, ADEQ is required under 40 CFR Part 122.44(d)(1), adopted by reference in Regulation 6, to include conditions as necessary to achieve water quality standards as established under Section 303 of the Clean Water Act. Arkansas has established a narrative criteria which states "toxic materials shall not be present in receiving waters in such quantities as to be toxic to human, animal, plant or aquatic life or to interfere with the normal propagation, growth and survival of aquatic biota."

Whole effluent toxicity (WET) testing is the most direct measure of potential toxicity which incorporates the effects of synergism of effluent components and receiving stream water quality characteristics. It is the national policy of EPA to use bioassays as a measure of toxicity to allow evaluation of the effects of a discharge upon a receiving water (49 Federal Register 9016-9019, March 9, 1984). EPA Region 6 and the State of Arkansas are now implementing the Post Third Round Policy and Strategy established on September 9, 1992, and EPA Region 6 Post-Third Round Whole Effluent Toxicity Testing Frequencies, revised March 13, 2000. Whole effluent toxicity testing of the effluent is thereby required as a condition of this permit to assess potential toxicity. The whole effluent toxicity testing procedures stipulated as a condition of this permit are as follows:

TOXICITY TESTS

FREQUENCY

Chronic WET Testing

once/quarter

Requirements for measurement frequency are based on the CPP.

Since 7Q10 is less than 100 cfs (ft³/sec) and dilution ratio is less than 100:1, chronic WET testing requirements will be included in the permit.

The calculations for dilution used for chronic WET testing are as follows:

Critical dilution (CD) = $(Qd/(Qd + Qb)) \times 100$

Qd = Design flow = 2.76 MGD = 4.26 cfs

7010 = 0.0 cfs

Qb = Background flow = (0.67) X 7Q10 = 0.0 cfs

CD = (4.26) / (4.26 + 0.0) X 100 = 100%

Page 18 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

Toxicity tests shall be performed in accordance with protocols described in "Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms", EPA/600/4-91/002, July 1994. A minimum of five effluent dilutions in addition to an appropriate control (0%) are to be used in the toxicity tests. These additional effluent concentrations are 32%, 42%, 56%, 75%, and 100% (See the CPP). The low-flow effluent concentration (critical dilution) is defined as 100% effluent. The requirement for chronic WET tests is based on the magnitude of the facility's discharge with respect to receiving stream flow. The stipulated test species, *Ceriodaphnia dubia* and the Fathead minnow (*Pimephales promelas*) are representative of organisms indigenous to the geographic area of the facility; the use of these is consistent with the requirements of the State water quality standards. The WET testing frequency has been established to provide data representative of the toxic potential of the facility's discharge, in accordance with the regulations promulgated at 40 CFR Part 122.48.

Results of all dilutions as well as the associated chemical monitoring of pH, temperature, hardness, dissolved oxygen conductivity, and alkalinity shall be reported according to EPA-821-R-02-013, October 2002 and shall be submitted as an attachment to the Discharge Monitoring Report (DMR).

This permit may be reopened to require further WET testing studies, Toxicity Reduction Evaluation (TRE) and/or effluent limits if WET testing data submitted to the Department shows toxicity in the permittee's discharge. Modification or revocation of this permit is subject to the provisions of 40 CFR 122.62, as adopted by reference in ADEQ Regulation No. 6. Increased or intensified toxicity testing may also be required in accordance with Section 308 of the Clean Water Act and Section 8-4-201 of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

Administrative Records

The following information summarized toxicity test submitted by the permittee during the term of the current permit at outfall **001**

Page 19 of Fact Sheet Permit Number: AR0021903 AFIN: 19-00071

Permit Number:	AR0021903	AFIN: 19-00071	Outfall Number:	001
Date of Review:	8/30/2012	Reviewer: M. Barnett		
Facility Name:	Wynne			

Previous Dilution series: 32, 42, 56, 75, 100 Proposed Dilution Series: 32, 42, 56, 75, 100 Proposed Critical Dilution: 100 Proposed Critical Dilution: 100

Previous TRE activities: None

Frequency recommendation by species

Pimephales promelas (Fathead minnow): once per quarter
Ceriodaphnia dubia (water flea): once per quarter

TEST DATA SUMMARY

Ye II Chumu mer'et all a x x x x x x x x x x x x x x x x x	Vertebrate		Invertebrate	
TEST DATE	Lethal	Sub-Lethal	Lethal	Sub-Lethal
	NOEC	NOEC	NOEC	NOEC
12/4/2007	100	100	100	100
3/4/2008	100	100	100	100
6/4/2008	100	100	100	100
9/4/2008	100	100	100	100
12/4/2008	100	100	100	100
6/4/2009	100	100	100	100
12/31/2009	100	100	100	100
6/30/2010	100	100	100	100
12/30/2010	100	100	100	100
6/30/2011	100	100	100	100
12/31/2011	100	100	100	100
6/30/2012	100	100	100	100

REASONABLE POTENTIAL CALCULATIONS

	Vertebrate Lethal	Vertebrate Sub-Lethal	Invertebrate Lethal	Invertebrate Sub-Letha
Min NOEC Observed	100	100	100	100
TU at Min Observed	1.00	1.00	1.00	1.00
Count	13	12	12	12
Failure Count	0	0	0	0
M ean	1.000	1.000	1.000	1.000
Std. Dev.	0.000	0.000	0.000	0.000
CV	0	0	0	0
RPMF	0	0	0	0
Reasonable Potential	0.000	0.000	0.000	0.000
100/Critical dilution	1.000	1.000	1.000	1.000
Does Reasonable				
Potential Exist	No	No	No	No

PERMIT ACTION

- P. promelas lethal monitoring
- P. promelas sub-lethal monitoring
- C. dubia lethal moniroring
- C. dubia sub-lethal monitoring

Page 20 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

16. SAMPLE TYPE AND FREQUENCY.

Regulations require permits to establish monitoring requirements to yield data representative of the monitored activity [40 CFR Part 122.48(b)] and to ensure compliance with permit limitations [40 CFR Part 122.44(i)(l)].

Requirements for sampling frequency for Flow and Total Recoverable Copper have been based on the current discharge permit. Also, the sample types for Flow, Dissolved Oxygen, Fecal Coliform Bacteria, and pH have been continued. Sample type for Carbonaceous Biochemical Oxygen Demand, Total Suspended Solids, Ammonia Nitrogen, Chronic WET Testing, and Total Recoverable Copper have been replaced with composite sampling to allow the flexibility in how samples are taken. Sample frequency and sample type for Nitrate and Nitrite Nitrogen, Total Phosphorus, Chlorides and Total Dissolved Solids are once per month with composite sampling. This frequency is assumed sufficient for establishing a database of point source loadings for these parameters to waters of the state.

The monitoring frequencies for Total Suspended Solids, Ammonia Nitrogen, Dissolved Oxygen, Fecal Coliform Bacteria, Carbonaceous Biochemical Oxygen Demand, and pH have been reduced using EPA's *Interim Guidance for Performance - Based Reductions of NPDES Permit Monitoring Frequencies*. This decrease in monitoring frequency does not constitute backsliding based on 40 CFR 122.44 (l)(2)(i)(B)(1).

	Previous Permit		Draft 1	Permit
Parameter	Frequency of Sample	Sample Type	Frequency of Sample	Sample Type
Flow	once/day	totalizing meter	once/day	totalizing meter
CBOD5	three/week	6-hr composite	once/week	composite
TSS	three/week	6-hr composite	once/week	composite
NH3-N	three/week	6-hr composite	once/week	composite
DO	three/week	grab	once/week	grab
FCB	three/week	grab	once/week	grab
NO3 + NO2-N	N/A	N/A	once/month	composite
TP	N/A	N/A	once/month	composite
TDS	N/A	N/A	once/month	composite
Chloride	N/A	N/A	once/month	composite
Copper, Total Recoverable	once/month	24-hr composite	once/month	composite
рН	three/week	grab	once/week	grab
Chronic WET Testing	once/quarter	24-hr composite	once/quarter	composite

Page 21 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

17. STORMWATER REQUIREMENTS

Facility has applied for and received a certification for a Stormwater No Exposure General Permit. The tracking number for the stormwater permit is ARR000293. No further action is required at this time.

18. PERMIT COMPLIANCE.

A Schedule of Compliance has not been included in this permit. Compliance with all permit requirements is required on the effective date of the permit.

19. MONITORING AND REPORTING.

The applicant is at all times required to monitor the discharge on a regular basis and report the results monthly. The monitoring results will be available to the public.

20. SOURCES.

The following sources were used to draft the permit:

- A. Application No. AR0021903 received 3/28/2012 with additional information received on 12/11/2012.
- B. Arkansas Water Quality Management Plan (WQMP).
- C. APCEC Regulation No. 2.
- D. APCEC Regulation No. 3.
- E. APCEC Regulation No. 6.
- F. 40 CFR Parts 122, 125, 133 and 403.
- G. Discharge permit file AR0021903.
- H. Discharge Monitoring Reports (DMRs).
- I. "Arkansas Water Quality Inventory Report 2008 (305b)", ADEQ.
- J. "Identification and Classification of Perennial Streams of Arkansas", Arkansas Geological Commission.
- K. Continuing Planning Process (CPP).
- L. Technical Support Document For Water Quality-based Toxic Control.
- M. Inspection Report dated 02/16/2011.
- N. Letter dated December 30, 2010, from Don O'Neal to Kim Fuller.
- O. Letter dated January 28, 2011, from Mo Shafii to Don O'Neal.
- P. TMDLs for Turbidity and Fecal Coliforms for L'Anguille River, AR dated 8/1/2001.
- Q. "Interim Guidance for Performance-Based Reductions of NPDES Permit Monitoring Frequencies." Prepared by EPA dated 4/16/1996.
- R. Site visit on September 6, 2012.
- S. Letter dated December 5, 2012 from Don O'Neal to Steve Drown.

Page 22 of Fact Sheet Permit Number: AR0021903

AFIN: 19-00071

21. PUBLIC NOTICE.

The public notice describes the procedures for the formulation of final determinations and shall provide for a public comment period of 30 days. During this period, any interested persons may submit written comments on the permit and may request a public hearing to clarify issues involved in the permitting decision. A request for a public hearing shall be in writing and shall state the nature of the issue(s) proposed to be raised in the hearing.

A copy of the permit and public notice will be sent via email to the Corps of Engineers, the Regional Director of the U.S. Fish and Wildlife Service, the Department of Arkansas Heritage, the EPA, and the Arkansas Department of Health.

22. POINT OF CONTACT.

For additional information, contact:

Christopher Randall
Permits Branch, Water Division
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118-5317
Telephone: (501) 682-0617

Permit Number: AR0021903

AFIN: 19-00071

AUTHORIZATION TO DISCHARGE WASTEWATER UNDER THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM AND THE ARKANSAS WATER AND AIR POLLUTION CONTROL ACT

In accordance with the provisions of the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. 8-4-10 et seq.), and the Clean Water Act (33 U.S.C. § 1251 et seq.),
The applicant's facility address is:
City of Wynne Wastewater Treatment Plant 545 Bowden Road Wynne, AR 72396
is authorized to discharge treated Municipal Wastewater from a facility located as follows: approximately 1.1 miles West of Wynne on Hwy 284 to Bowden Road, thence south on Bowden Road approximately 0.25 mile in Cross County, Arkansas. The applicant's mailing address is: 121 East Merriman Avenue, Wynne, AR 72396.
Facility Coordinates: Latitude: 35° 13' 8.81"; Longitude: 90° 49' 41.25"
Receiving stream: a drainage ditch, thence to Caney Creek, thence to the L'Anguille River, thence to the St Francis River in Segment 5B of the St. Francis River Basin.
The permitted outfall is located at the following coordinates:
Outfall 001: Latitude: 35° 13' 07"; Longitude: 90° 49' 52"
Discharge shall be in accordance with effluent limitations, monitoring requirements, and other conditions set forting in this permit. Per Part III.D.10, the permittee must re-apply on or before 180 days prior to the expiration date of the permit for permit coverage past the expiration date.
Effective Date: Expiration Date:
Steven L. Drown Issue Date Chief, Water Division Arkansas Department of Environmental Quality



Permit Number: AR0021903

AFIN: 19-00071 Page 1 of Part IB

PART I PERMIT REQUIREMENTS

SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: Outfall 001 - treated municipal wastewater.

During the period beginning on the effective date and lasting the expiration date of the permit the permittee is authorized to discharge from Outfall 001. Such discharges shall be limited and monitored by the permittee as specified below as well as Parts II and III. See Part IV for all definitions and calculations.

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass Concentration (lbs/day, (mg/l, unless unless otherwise specified) otherwise specified)		Frequency	Sample Type	
	Monthly Avg.	Monthly Avg.	7-Day Avg.		
Flow	N/A	Report, MGD	Report, MGD (Daily Maximum)	once/day	totalizing meter
Overflows	Monthly Total SSOs (occurrences/month)		See Comments ¹		
Overflow Volume	1	Monthly Total Volume of SSOs (gallons/month)		See Comments ¹	
Carbonaceous Biochemical Oxygen Demand (CBOD5)	276	12	18	once/week	composite ⁴
Total Suspended Solids (TSS)	345	15	22.5	once/week	composite ⁴
Ammonia Nitrogen (NH3-N)					
(April)	48	2.1	5.2	once/week	composite ⁴
(May-Oct)	48	2.1	4.5	once/week	composite ⁴
(Nov-March)	115	5	7.5	once/week	composite ⁴
Dissolved Oxygen (DO)					
(May-Oct)	N/A	7.0, (lr	nst. Min.)	once/week	grab
(Nov-Apr)	N/A		nst. Min.)	once/week	grab
		(coloni	es/100ml)		
Fecal Coliform Bacteria (FCB)	N/A	1000	2000	once/week	grab
Copper, Total Recoverable ²	0.68	29.5 μg/l	59.1 μg/l	once/month	composite ⁴
Nitrate + Nitrite Nitrogen (NO3 + NO2-N)	Report	Report	Report	once/month	composite ⁴
Total Phosphorus (TP)	Report	Report	Report	once/month	composite ⁴
Total Dissolved Solids (TDS)	Report	Report	Report	once/month	composite ⁴
Chloride	Report	Report	Report	once/month	composite ⁴
рН	N/A	Minimum 6.0 s.u.	Maximum 9.0 s.u.	once/week	grab
Chronic WET Testing ³	N/A	N/A	N/A	once/quarter	composite ⁴

Permit Number: AR0021903 AFIN: 19-00071 Page 2 of Part IB

Effluent Characteristics	ent Characteristics <u>Discharge Limitations</u>		Monitoring Requirements		
	Mass	Conce	entration		
	(lbs/day,	(mg/l, unless		Frequency	Sample Type
	unless	otherwise specified)			
	otherwise				
	specified)				
	Monthly	Monthly	7-Day Avg.		
2	Avg.	Avg.			
Pimephales promelas (Chronic) ³		7-Day Average			,
Pass/Fail Lethality (7-day NOEC) TLP6C		Report (Pass=0/Fail=1)		once/quarter	composite ⁴
Pass/Fail Growth (7-day NOEC)TGP6C		Report (Pass=0/Fail=1)		once/quarter	composite ⁴
Survival (7-day NOEC) TOP6C		Report %		once/quarter	composite ⁴
Coefficient of Variation (Growth) TQP6C		Report %		once/quarter	composite ⁴
Growth (7-day NOEC) TPP6C		Report %		once/quarter	composite ⁴
Ceriodaphnia dubia (Chronic) ³		7-Day	Average		
Pass/Fail Lethality (7-day NOEC) TLP3B		Report (Pa	ss=0/Fail=1)	once/quarter	composite ⁴
Pass/Fail production (7-day NOEC)TGP3B		Report (Pa	ss=0/Fail=1)	once/quarter	composite ⁴
Survival (7-day NOEC) TOP3B		Rep	ort %	once/quarter	composite ⁴
Coefficient of Variation (Reproduction)		Rep	ort %	once/quarter	composite ⁴
TQP3B				-	
Reproduction (7-day NOEC) TPP3B		Rep	ort %	once/quarter_	composite ⁴

- 1 See Condition No. 5 of Part II (SSO Condition). If there are no overflows during the entire month, report "zero" (0).
- 2 See Condition No. 8 of Part II (Metals Condition).
- 3 See Condition No. 9 of Part II (WET Testing Condition).
- 4 See Definition No. 8 of Part IV

There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen as defined in Part IV of this permit.

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. Samples shall be taken at the discharge from the final treatment unit except for the flow measurement, which shall be taken after the UV system and prior to post aeration.

Permit Number: AR0021903

AFIN: 19-00071 Page 1 of Part IB

SECTION B. PERMIT COMPLIANCE

The permittee shall achieve compliance with the effluent limitations specified for discharges in accordance with the following schedule:

Compliance is required on the effective date of the permit.

Permit Number: AR0021903

AFIN: 19-00071 Page 1 of Part II

PART II OTHER CONDITIONS

- 1. The operator of this wastewater treatment facility shall be licensed as Class III by the State of Arkansas in accordance with APCEC Regulation No. 3.
- 2. For publicly owned treatment works, the 30-day average percent removal for Carbonaceous Biochemical Oxygen Demand (CBOD5) and Total Suspended Solids (TSS) shall not be less than 85 percent unless otherwise authorized by the permitting authority in accordance with 40 CFR Part 133.102, as adopted by reference in APCEC Regulation No. 6. The permittee must monitor the influent and effluent CBOD5 and TSS at least once per year and calculate the percent removal to ensure compliance with the required 85 percent removal. This information must be maintained on site and provided to Department personnel upon request.
- 3. In accordance with 40 CFR Parts 122.62 (a)(2) and 124.5, this permit may be reopened for modification or revocation and/or reissuance to require additional monitoring and/or effluent limitations when new information is received that actual or potential exceedance of State water quality criteria and/or narrative criteria are determined to be the result of the permittee's discharge(s) to a relevant water body or a Total Maximum Daily Load (TMDL) is established or revised for the water body that was not available at the time of the permit issuance that would have justified the application of different permit conditions at the time of permit issuance.

4. Other Specified Monitoring Requirements

The permittee may use alternative appropriate monitoring methods and analytical instruments other than as specified in Part I Section A of the permit without a major permit modification under the following conditions:

- The monitoring and analytical instruments are consistent with accepted scientific practices;
- The requests shall be submitted in writing to the Permits Section of the Water Division of the ADEQ for use of the alternate method or instrument.
- The method and/or instrument is in compliance with 40 CFR Part 136 or approved in accordance with 40 CFR Part 136.5; and
- All associated devices are installed, calibrated, and maintained to insure the accuracy of the measurements and are consistent with the accepted capability of that type of device. The calibration and maintenance shall be performed as part of the permittee's laboratory Quality Control/Quality Assurance program.

Upon written approval of the alternative monitoring method and/or analytical instruments, these methods or instruments must be consistently utilized throughout the monitoring period. ADEQ must be notified in writing and the permittee must receive written approval from ADEQ if the permittee decides to return to the original permit monitoring requirements.

Permit Number: AR0021903 AFIN: 19-00071 Page 2 of Part II

5. Sanitary Sewer Overflow (SSO) Reporting Requirements:

All SSOs are prohibited.

- A. A sanitary sewer overflow is any spill, release or diversion of wastewater from a sanitary sewer collection system including:
 - 1. Any overflow, whether it discharges to the waters of the state or not; or
 - 2. An overflow of wastewater, including a wastewater backup into a building (other than a backup caused solely by a blockage or other malfunction in a privately owned sewer or building lateral), even if that overflow does not reach waters of the state.

B. Immediate Reporting

Overflows that <u>endanger health or the environment</u> shall be orally reported to the Enforcement Branch of the Water Division by telephone (501-682-0638) or by email <u>waterenfsso@adeq.state.ar.us</u> within 24 hours from the time the permittee becomes aware of the circumstance.

C. Follow-Up Written Reports/email:

A written report of overflows that endanger health or the environment shall be provided to ADEQ within 5 days of the time the permittee becomes aware of the circumstance.

At a minimum, the report shall identify:

- 1. The location(s) of overflow;
- 2. The receiving water (If there is one);
- 3. The duration of overflow;
- 4. Cause of overflow; and
- 5. The estimated volume of overflow (gal).

A 24-hr and 5-day follow-up written report can be filled-in or downloaded from the ADEQ /Water Division/Enforcement Branch Web page at

http://www.adeq.state.ar.us/water/branch_enforcement/forms/sso_report.asp

D. Reporting for All SSOs on DMR

At the end of the month, total the daily <u>occurrences</u> and <u>volumes</u> from all locations on your system and report this number on the DMR. For counting occurrences, each location on the sanitary sewer system where there is an overflow, spill, release, or diversion of wastewater on a given day is counted as one occurrence. For example, if on

Permit Number: AR0021903 AFIN: 19-00071 Page 3 of Part II

a given day overflows occur from a manhole at one location and from a damaged pipe at another location then you should record two occurrences for that day.

- 6. Best Management Practices (BMPs), as defined in Part IV.6, must be implemented for the facility along with the collection system to prevent or reduce the pollution of waters of the State from stormwater runoff, spills or leaks, sludge or waste disposal, or drainage from raw sewage. The permittee must amend the BMPs whenever there is a change in the facility or a change in the operation of the facility.
- 7. Contributing Industries and Pretreatment Requirements
 - A. The following pollutants may not be introduced into the treatment facility:
 - (1) pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, waste streams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21;
 - (2) pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0, unless the works are specifically designed to accommodate such discharges;
 - (3) solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, resulting in Interference* or Pass Through**;
 - (4) any pollutant, including oxygen demanding pollutants (e.g., BOD), released in a discharge at a flow rate and/or pollutant concentration which will cause Pass Through** or Interference* with the POTW;
 - (5) heat in amounts which will inhibit biological activity in the POTW resulting in Interference*, but in no case heat in such quantities that the temperature at the POTW treatment plant exceeds 40 deg. C (104 deg. F) unless the Approval Authority, upon request of the POTW, approves alternate temperature limits;
 - (6) Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause Interference* or Pass Through**;
 - (7) Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems;
 - (8) Any trucked or hauled pollutants, except at discharge points designated by the POTW.

Permit Number: AR0021903 AFIN: 19-00071 Page 4 of Part II

- B. The permittee shall require any indirect discharger to the treatment works to comply with the reporting requirements of Sections 204(b), 307, and 308 of the Act, including any requirements established under 40 CFR Part 403.
- C. The permittee shall provide adequate notice to the Department of the following:
 - (1) any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 or 306 of the Act if it were directly discharging those pollutants; and
 - (2) any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.

Any notice shall include information on (i) the quality and quantity of effluent to be introduced into the treatment works, and (ii) any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.

- * According to 40 CFR Part 403.3(k) the term *Interference* means a Discharge which, alone or in conjunction with a discharge or discharges from other sources, both:
 - (1) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and
 - (2) Therefore is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.
- ** According to 40 CFR 403.3(p) the term *Pass Through* means a Discharge which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation).

Permit Number: AR0021903

AFIN: 19-00071 Page 5 of Part II

8. The permittee may use any EPA approved method based on 40 CFR Part 136 provided the MQL for the chosen method is equal to or less than what has been specified in chart below:

Pollutant	EPA Method	MQL (µg/l)
Copper (Cu)	220.2	0.5

The permittee may develop a matrix specific method detection limit (MDL) in accordance with Appendix B of 40 CFR Part 136. For any pollutant for which the permittee determines a site specific MDL, the permittee shall send to ADEQ, NPDES Permits Branch, a report containing QA/QC documentation, analytical results, and calculations necessary to demonstrate that a site specific MDL was correctly calculated. A site specific minimum quantification level (MQL) shall be determined in accordance with the following calculation:

$$MQL = 3.3 X MDL$$

Upon written approval by Permits Branch, the site specific MQL may be utilized by the permittee for all future Discharge Monitoring Report (DMR) calculations and reporting requirements.

9. WHOLE EFFLUENT TOXICITY TESTING (7-DAY CHRONIC NOEC FRESHWATER)

1. SCOPE AND METHODOLOGY

a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL(S):

001

REPORTED ON DMR AS FINAL OUTFALL:

{OUTFALL 001}

CRITICAL DILUTION (%):

100

EFFLUENT DILUTION SERIES (%):

32, 42, 56, 75, 100

TESTING FREQUENCY:

once/quarter

COMPOSITE SAMPLE TYPE:

Defined at PART I

TEST SPECIES/METHODS:

40 CFR Part 136

Ceriodaphnia dubia chronic static renewal survival and reproduction test, Method 1002.0, EPA-821-R-02-013, or the most recent update thereof. This test should be

Permit Number: AR0021903 AFIN: 19-00071

Page 6 of Part II

terminated when 60% of the surviving females in the control produce three broods or at the end of eight days, whichever comes first.

<u>Pimephales promelas</u> (Fathead minnow) chronic static renewal 7-day larval survival and growth test, Method 1000.0, EPA-821-R-02-013, or the most recent update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Effect Concentration) is herein defined as the greatest effluent dilution at and below which toxicity (lethal or sub-lethal) that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Chronic lethal test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution. Chronic sub-lethal test failure is defined as a demonstration of a statistically significant sub-lethal effect (i.e., growth or reproduction) at test completion to a test species at or below the critical dilution.
- c. This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.

2. PERSISTENT LETHAL and/or SUB-LETHAL EFFECTS

The requirements of this subsection apply only when a toxicity test demonstrates significant lethal and/or sub-lethal effects at or below the critical dilution. The purpose of additional tests (also referred to as 'retests' or confirmation tests) is to determine the duration of a toxic event. A test that meets all test acceptability criteria and demonstrates significant toxic effects does not need additional confirmation. Such testing cannot confirm or disprove a previous test result.

If a frequency reduction, as specified in Item 6, has been granted and any subsequent valid test demonstrates significant lethal or sub-lethal effects to a test species at or below the critical dilution, the frequency of testing for that species is automatically increased to once per quarter for the life of the permit. In addition:

a. Part I Testing Frequency Other Than Monthly

i. The permittee shall conduct a total of three (3) additional tests for any species that demonstrates significant toxic effects at or below the critical dilution. The additional tests shall be conducted monthly during the next three consecutive months. If testing on a quarterly basis, the permittee may substitute one of the additional tests in lieu of one routine toxicity test. A full report shall be prepared for each test required by this section in accordance with procedures outlined in Item 4 of this section and submitted with the period discharge monitoring report (DMR) to the permitting authority for review.

Permit Number: AR0021903

AFIN: 19-00071 Page 7 of Part II

- ii. IF LETHAL EFFECTS HAVE BEEN DEMONSTRATED If any of the additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall initiate Toxicity Reduction Evaluation (TRE) requirements as specified in Item 5 of this section. The permittee shall notify ADEQ in writing within 5 days of the failure of any retest, and the TRE initiation date will be the test completion date of the first failed retest. A TRE may also be required due to a demonstration of intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests. A TRE required based on lethal effects should consider any sub-lethal effects as well.
- iii. IF SUB-LETHAL EFFECTS ONLY HAVE BEEN DEMONSTRATED If any two of the three additional tests demonstrates significant sub-lethal effects at 75% effluent or lower, the permittee shall initiate the Sub-Lethal Toxicity Reduction Evaluation (TRESL) requirements as specified in Item 5 of this section. The permittee shall notify ADEQ in writing within 5 days of the failure of any retest, and the Sub-Lethal Effects TRE initiation date will be the test completion date of the first failed retest. A TRE may be also be required for failure to perform the required retests.
- iv. The provisions of Item 2.a.i. are suspended upon submittal of the TRE Action Plan.

b. Part I Testing Frequency of Monthly

The permittee shall initiate the Toxicity Reduction Evaluation (TRE) requirements as specified in Item 5 of this section when any two of three consecutive monthly toxicity tests exhibit significant toxic effects at or below the critical dilution. A TRE may also be required due to a demonstration of intermittent lethal and/or sub-lethal effects at or below the critical dilution, or for failure to perform the required retests.

3. REQUIRED TOXICITY TESTING CONDITIONS

a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- i. The toxicity test control (0% effluent) must have survival equal to or greater than 80%.
- ii. The mean number of <u>Ceriodaphnia dubia</u> neonates produced per surviving female in the control (0% effluent) must be 15 or more.

Permit Number: AR0021903 AFIN: 19-00071 Page 8 of Part II

- iii. 60% of the surviving control females must produce three broods. The mean dry weight of surviving Fathead minnow larvae at the end of the 7 days in the control (0% effluent) must be 0.25 mg per larva or greater.
- iv. The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for: the young of surviving females in the <u>Ceriodaphnia dubia</u> reproduction test; the growth and survival endpoints of the Fathead minnow test.
- v. The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, <u>unless</u> significant lethal or sub-lethal effects are exhibited for: the young of surviving females in the <u>Ceriodaphnia dubia</u> reproduction test; the growth and survival endpoints of the Fathead minnow test.
- vi. If a test passes, yet the percent coefficient of variation between replicates is greater than 40% in the control (0% effluent) and/or in the critical dilution for: the young of surviving females in the <u>Ceriodaphnia dubia</u> reproduction test; the growth and survival endpoints of the Fathead minnow test, the test is determined to be invalid. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.
- vii. If a test fails, test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%.
- viii. A Percent Minimum Significant Difference (PMSD) range of 13 47 for Ceriodaphnia dubia reproduction;
- ix. A PMSD range of 12 30 for Fathead minnow growth.

b. Statistical Interpretation

- For the <u>Ceriodaphnia dubia</u> survival test, the statistical analyses used to determine
 if there is a significant difference between the control and the critical dilution
 shall be Fisher's Exact Test as described in EPA/821/R-02-013 or the most recent
 update thereof.
- ii. For the <u>Ceriodaphnia dubia</u> reproduction test and the Fathead minnow larval survival and growth test, the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA/821/R-02-013 or the most recent update thereof.

Permit Number: AR0021903 AFIN: 19-00071 Page 9 of Part II

iii. If the conditions of Test Acceptability are met in Item 3.a above and the percent survival of the test organism is equal to or greater than 80% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report a survival NOEC of not less than the critical dilution for the DMR reporting requirements found in Item 4 below.

c. Dilution Water

- i. Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness, and alkalinity to the closest downstream perennial water for;
 - (A) toxicity tests conducted on effluent discharges to receiving water classified as intermittent streams; and
 - (B) toxicity tests conducted on effluent discharges where no receiving water is available due to zero flow conditions.
- ii. If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 3.a), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
 - (A) a synthetic dilution water control which fulfills the test acceptance requirements of Item 3.a was run concurrently with the receiving water control;
 - (B) the test indicating receiving water toxicity has been carried out to completion (i.e., 7 days);
 - (C) the permittee includes all test results indicating receiving water toxicity with the full report and information required by Item 4 below; and
 - (D) the synthetic dilution water shall have a pH, hardness, and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

i. The permittee shall collect a minimum of three flow-weighted composite samples from the outfall(s) listed at Item 1.a above. Unless otherwise stated in this section, a composite sample for WET shall consist of a minimum of 12 subsamples gathered at equal time intervals during a 24-hour period.

Permit Number: AR0021903 AFIN: 19-00071 Page 10 of Part II

- ii. The permittee shall collect second and third composite samples for use during 24-hour renewals of each dilution concentration for each test. The permittee must collect the composite samples such that the effluent samples, on use, are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on a regular or intermittent basis.
- iii. The permittee must collect all three flow-weighted composite samples within the monitoring period. Second and/or third composite samples shall not be collected into the next monitoring period; such tests will be determined to be invalid. Monitoring period definitions are listed in Part IV.
- iv. The permittee must collect the composite samples so that the maximum holding time for any effluent sample shall not exceed 72 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first composite sample. Samples shall be chilled to between 0 and 6 degrees Centigrade during collection, shipping, and/or storage.
- v. If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must have collected an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days if the discharge occurs over multiple days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 4 of this section.
- vi. <u>MULTIPLE OUTFALLS</u>: If the provisions of this section are applicable to multiple outfalls, the permittee shall combine the composite effluent samples in proportion to the average flow from the outfalls listed in item 1.a. above for the day the sample was collected. The permittee shall perform the toxicity test on the flow-weighted composite of the outfall samples.
- vii. If chlorination is part of the treatment process, the permittee shall not allow the sample to be dechlorinated at the laboratory. At the time of sample collection the permittee shall measure the TRC of the effluent. The measured concentration of TRC for each sample shall be included in the lab report submitted by the permittee.

Permit Number: AR0021903 AFIN: 19-00071 Page 11 of Part II

4. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this section in accordance with the Report Preparation Section of EPA/821/R-02-013, or the most current publication, for every valid or invalid toxicity test initiated whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of PART III.C.7 of this permit. The permittee shall submit full reports. For any test which fails, is considered invalid or which is terminated early for any reason, the full report must be submitted for agency review.
- b. A valid test for each species must be reported on the DMR during each reporting period specified in PART I of this permit unless the permittee is performing a TRE which may increase the frequency of testing and reporting. Only <u>ONE</u> set of WET test data for each species is to be recorded on the DMR for each reporting period. The data submitted should reflect the <u>LOWEST</u> lethal and sub-lethal effects results for each species during the reporting period. The full reports for all invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached to the DMR for Agency review.
- c. The permittee shall submit the results of each valid toxicity test on the subsequent monthly DMR for that reporting period in accordance with PART III.D.4 of this permit, as follows below. Submit retest information clearly marked as such with the following month's DMR. Only results of valid tests are to be reported on the DMR.
 - i. Pimephales promelas (Fathead minnow)
 - (A) If the No Observed Effect Concentration (NOEC) for survival is less than the critical dilution, enter a '1'; otherwise, enter a '0' for Parameter No. TLP6C
 - (B) Report the NOEC value for survival, Parameter No. TOP6C
 - (C) Report the NOEC value for growth, Parameter No. TPP6C
 - (D) If the NOEC for growth is less than the critical dilution, enter a '1'; otherwise, enter a '0' for Parameter No. TGP6C
 - (E) Report the highest (critical dilution or control) Coefficient of Variation for growth, Parameter No. TQP6C

ii. Ceriodaphnia dubia

(A) If the NOEC for survival is less than the critical dilution, enter a '1'; otherwise, enter a '0'C for Parameter No. TLP3B

Permit Number: AR0021903

AFIN: 19-00071 Page 12 of Part II

- (B) Report the NOEC value for survival, Parameter No. TOP3B
- (C) Report the NOEC value for reproduction, Parameter No. TPP3B
- (D) If the NOEC for reproduction is less than the critical dilution, enter a '1'; otherwise, enter a '0' for Parameter No. TGP3B
- (E) Report the higher (critical dilution or control) Coefficient of Variation for reproduction, Parameter No. TQP3B

5. TOXICITY REDUCTION EVALUATIONS (TREs)

TREs for lethal and sub-lethal effects are performed in a very similar manner. EPA Region 6 is currently addressing TREs as follows: a sub-lethal TRE (TRE_{SL}) is triggered based on three sub-lethal test failures while a lethal effects TRE (TRE_L) is triggered based on only two test failures for lethality. In addition, EPA Region 6 will consider the magnitude of toxicity and use flexibility when considering a TRE_{SL} where there are no effects at effluent dilutions of 75% or lower.

- a. Within ninety (90) days of confirming persistent toxicity, the permittee shall submit a Toxicity Reduction Evaluation (TRE) Action Plan and Schedule for conducting a TRE. The TRE Action Plan shall specify the approach and methodology to be used in performing the TRE. A Toxicity Reduction Evaluation is an investigation intended to determine those actions necessary to achieve compliance with water quality-based effluent limits by reducing an effluent's toxicity to an acceptable level. A TRE is defined as a step-wise process which combines toxicity testing and analyses of the physical and chemical characteristics of a toxic effluent to identify the constituents causing effluent toxicity and/or treatment methods which will reduce the effluent toxicity. The goal of the TRE is to maximally reduce the toxic effects of effluent at the critical dilution and includes the following:
 - i. Specific Activities. The plan shall detail the specific approach the permittee intends to utilize in conducting the TRE. The approach may include toxicity characterizations, identifications and confirmation activities, source evaluation, treatability studies, or alternative approaches. When the permittee conducts Toxicity Characterization Procedures the permittee shall perform multiple characterizations and follow the procedures specified in the documents 'Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures' (EPA-600/6-91/003) and 'Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I' (EPA-600/6-91/005F), or alternate procedures. When the permittee conducts Toxicity Identification Evaluations and Confirmations, the permittee shall perform multiple identifications and follow the methods specified in the documents 'Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity' (EPA/600/R-

Permit Number: AR0021903 AFIN: 19-00071

Page 13 of Part II

92/080) and 'Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity' (EPA/600/R-92/081), as appropriate.

The documents referenced above may be obtained through the <u>National Technical Information Service</u> (NTIS) by phone at (703) 487-4650, or by writing:

U.S. Department of Commerce National Technical Information Service 5285 Port Royal Road Springfield, VA 22161

ii. Sampling Plan (e.g., locations, methods, holding times, chain of custody, preservation, etc.). The effluent sample volume collected for all tests shall be adequate to perform the toxicity test, toxicity characterization, identification and confirmation procedures, and conduct chemical specific analyses when a probable toxicant has been identified;

Where the permittee has identified or suspects specific pollutant(s) and/or source(s) of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical specific analyses for the identified and/or suspected pollutant(s) and/or source(s) of effluent toxicity. Where lethality was demonstrated within 48 hours of test initiation, each composite sample shall be analyzed independently. Otherwise the permittee may substitute a composite sample, comprised of equal portions of the individual composite samples, for the chemical specific analysis;

- iii. Quality Assurance Plan (e.g., QA/QC implementation, corrective actions, etc.); and
- iv. Project Organization (e.g., project staff, project manager, consulting services, etc.).
- b. The permittee shall initiate the TRE Action Plan within thirty (30) days of plan and schedule submittal. The permittee shall assume all risks for failure to achieve the required toxicity reduction.
- c. The permittee shall submit a quarterly TRE Activities Report, with the Discharge Monitoring Report in the months of January, April, July and October, containing information on toxicity reduction evaluation activities including:

any data and/or substantiating documentation which identifies the pollutant(s) and/or source(s) of effluent toxicity;

any studies/evaluations and results on the treatability of the facility's effluent toxicity; and

Permit Number: AR0021903 AFIN: 19-00071

Page 14 of Part II

any data which identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant toxicity at the critical dilution.

- d. The permittee shall submit a Final Report on Toxicity Reduction Evaluation Activities no later than twenty-eight (28) months from confirming toxicity in the retests, which provides information pertaining to the specific control mechanism selected that will, when implemented, result in reduction of effluent toxicity to no significant toxicity at the critical dilution. The report will also provide a specific corrective action schedule for implementing the selected control mechanism.
- e. Quarterly testing during the TRE is a minimum monitoring requirement. EPA recommends that permittees required to perform a TRE not rely on quarterly testing alone to ensure success in the TRE, and that additional screening tests be performed to capture toxic samples for identification of toxicants. Failure to identify the specific chemical compound causing toxicity test failure will normally result in a permit limit for whole effluent toxicity limits per federal regulations at 40 CFR 122.44(d)(1)(v).

6. MONITORING FREQUENCY REDUCTION

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first four consecutive quarters or first twelve consecutive months (in accordance with Item 1.a.) of testing for one or both test species, with no lethal or sub-lethal effects demonstrated at or below the critical dilution. If granted, the monitoring frequency for that test species may be reduced to not less than once per year for the less sensitive species (usually the Fathead minnow) and not less than twice per year for the more sensitive test species (usually the Ceriodaphnia dubia).
- b. CERTIFICATION The permittee must certify in writing that no test failures have occurred and that all tests meet all test acceptability criteria in item 3.a. above. In addition the permittee must provide a list with each test performed including test initiation date, species, NOECs for lethal and sub-lethal effects and the maximum coefficient of variation for the controls. Upon review and acceptance of this information the agency will issue a letter of confirmation of the monitoring frequency reduction. A copy of the letter will be forwarded to the agency's Permit Compliance System section to update the permit reporting requirements.
- c. SUB-LETHAL OR SURVIVAL FAILURES If any test fails the survival or sublethal endpoint at any time during the life of this permit, three monthly retests are required and the monitoring frequency for the affected test species shall be increased to once per quarter until the permit is re-issued. Monthly retesting is not required if the permittee is performing a TRE.

Any monitoring frequency reduction granted applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to once per quarter until the permit is re-issued.



Permit Number: AR0021903

AFIN: 19-00071 Page 1 of Part III

PART III STANDARD CONDITIONS

SECTION A – GENERAL CONDITIONS

1. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the federal Clean Water Act and the Arkansas Water and Air Pollution Control Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; and/or for denial of a permit renewal application. Any values reported in the required Discharge Monitoring Report (DMR) which are in excess of an effluent limitation specified in Part I shall constitute evidence of violation of such effluent limitation and of this permit.

2. Penalties for Violations of Permit Conditions

The Arkansas Water and Air Pollution Control Act provides that any person who violates any provisions of a permit issued under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year, or a fine of not more than twenty-five thousand dollars (\$25,000) or by both such fine and imprisonment for each day of such violation. Any person who violates any provision of a permit issued under the Act may also be subject to civil penalty in such amount as the court shall find appropriate, not to exceed ten thousand dollars (\$10,000) for each day of such violation. The fact that any such violation may constitute a misdemeanor shall not be a bar to the maintenance of such civil action.

3. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause including, but not limited to the following:

- A. Violation of any terms or conditions of this permit; or
- **B.** Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
- C. A change in any conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- **D.** A determination that the permitted activity endangers human health or the environment and can only be regulated to acceptable levels by permit modification or termination.
- **E.** Failure of the permittee to comply with the provisions of APCEC Regulation No. 9 (Permit fees) as required by Part III.A.11 herein.

Permit Number: AR0021903

AFIN: 19-00071 Page 2 of Part III

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

4. Toxic Pollutants

Notwithstanding Part III.A.3, if any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under APCEC Regulation No. 2, as amended, or Section 307(a) of the Clean Water Act for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitations on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standards or prohibition and the permittee so notified.

The permittee shall comply with effluent standards, narrative criteria, or prohibitions established under APCEC Regulation No. 2, as amended, or Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Civil and Criminal Liability

Except as provided in permit conditions for "Bypass of Treatment Facilities" (Part III.B.4), and "Upset" (Part III.B.5), nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. Any false or materially misleading representation or concealment of information required to be reported by the provisions of this permit or applicable state and federal statues or regulations which defeats the regulatory purposes of the permit may subject the permittee to criminal enforcement pursuant to the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. § 8-4-101 et seq.).

6. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject to under Section 311 of the Clean Water Act.

7. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law or regulation under authority preserved by Section 510 of the Clean Water Act.

Permit Number: AR0021903 AFIN: 19-00071

Page 3 of Part III

8. Property Rights

The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State, or local laws or regulations.

9. Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provisions of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

10. Applicable Federal, State or Local Requirements

Permittees are responsible for compliance with all applicable terms and conditions of this permit. Receipt of this permit does not relieve any operator of the responsibility to comply with any other applicable federal such as endangered species, state or local statute, ordinance or regulation.

11. Permit Fees

The permittee shall comply with all applicable permit fee requirements (i.e., including annual permit fees following the initial permit fee that will be invoiced every year the permit is active) for wastewater discharge permits as described in APCEC Regulation No. 9 (Regulation for the Fee System for Environmental Permits). Failure to promptly remit all required fees shall be grounds for the Director to initiate action to terminate this permit under the provisions of 40 CFR Parts 122.64 and 124.5(d), as adopted in APCEC Regulation No. 6 and the provisions of APCEC Regulation No. 8.

SECTION B - OPERATION AND MAINTENANCE OF POLLUTION CONTROLS

1. Proper Operation and Maintenance

A. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

Permit Number: AR0021903 AFIN: 19-00071 Page 4 of Part III

B. The permittee shall provide an adequate operating staff which is duly qualified to carryout operation, maintenance, and testing functions required to insure compliance with the conditions of this permit.

2. Need to Halt or Reduce not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. Upon reduction, loss, or failure of the treatment facility, the permittee shall, to the extent necessary to maintain compliance with its permit, control production or discharges or both until the facility is restored or an alternative method of treatment is provided. This requirement applies, for example, when the primary source of power for the treatment facility is reduced, is lost, or alternate power supply fails.

3. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment or the water receiving the discharge.

4. Bypass of Treatment Facilities

A. Bypass not exceeding limitation

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts III.B.4.b and 4.c.

B. Notice

- 1. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
- 2. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Part III.D.6 (24-hour notice).

C. Prohibition of bypass

- 1. Bypass is prohibited and the Director may take enforcement action against a permittee for bypass, unless:
 - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;

Permit Number: AR0021903 AFIN: 19-00071 Page 5 of Part III

- (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if the permittee could have installed adequate backup equipment to prevent a bypass which occurred during normal or preventive maintenance; and
- (c) The permittee submitted notices as required by Part III.B.4.b.
- 2. The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in Part III.B.4.c.(1).

5. Upset Conditions

- A. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Part III.B.5.b of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- B. Conditions necessary for demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - 1. An upset occurred and that the permittee can identify the specific cause(s) of the upset;
 - 2. The permitted facility was at the time being properly operated.
 - 3. The permittee submitted notice of the upset as required by Part III.D.6; and
 - 4. The permittee complied with any remedial measures required by Part III.B.3.
- C. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

6. Removed Substances

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering the waters of the State. The permittee shall give at least 180 days prior notice to the Director of any change planned in the permittee's disposal practices. Produced sludge shall be disposed of by land application only when allowed through a separate land application permit issued in accordance with the applicable provisions of 40 CFR Part 503.

Permit Number: AR0021903 AFIN: 19-00071 Page 6 of Part III

7. Power Failure

The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failure either by means of alternate power sources, standby generators, or retention of inadequately treated effluent.

SECTION C – MONITORING AND RECORDS

1. Representative Sampling

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points shall not be changed without notification to and the approval of the Director. Intermittent discharge shall be monitored.

2. Flow Measurement

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to insure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure the accuracy of the measurements are consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than +/- 10% from true discharge rates throughout the range of expected discharge volumes and shall be installed at the monitoring point of the discharge.

Calculated Flow Measurement

For calculated flow measurements that are performed in accordance with either the permit requirements or a Department approved method (i.e., as allowed under Part II.3), the +/- 10% accuracy requirement described above is waived. This waiver is only applicable when the method used for calculation of the flow has been reviewed and approved by the Department.

Permit Number: AR0021903

AFIN: 19-00071 Page 7 of Part III

3. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals frequent enough to insure accuracy of measurements and shall insure that both calibration and maintenance activities will be conducted. An adequate analytical quality control program, including the analysis of sufficient standards, spikes, and duplicate samples to insure the accuracy of all required analytical results shall be maintained by the permittee or designated commercial laboratory. At a minimum, spikes and duplicate samples are to be analyzed on 10% of the samples.

4. Penalties for Tampering

The Arkansas Water and Air Pollution Control Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year or a fine of not more than ten thousand dollars (\$10,000) or by both such fine and imprisonment.

5. Reporting of Monitoring Results

Monitoring results must be reported on a Discharge Monitoring Report (DMR) form provided by the Department or other form/method approved in writing by the Department (e.g., electronic submittal of DMR once approved). Monitoring results obtained during the previous monitoring period shall be summarized and reported on a DMR form postmarked no later than the 25th day of the month or submitted electronically by 6:00 p.m. of the 25th (after NETDMR is approved), following the completed reporting period beginning on the effective date of the permit. When mailing the DMRs, duplicate copies of the forms signed and certified as required by Part III.D.11 and all other reports required by Part III.D, shall be submitted to the Director at the following address:

Enforcement Branch Water Division Arkansas Department of Environmental Quality 5301 Northshore Drive North Little Rock, AR 72118-5317

If permittee uses outside laboratory facilities for sampling and/or analysis, the name and address of the contract laboratory shall be included on the DMR.

Permit Number: AR0021903 AFIN: 19-00071

Page 8 of Part III

6. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR. Such increased frequency shall also be indicated on the DMR.

7. Retention of Records

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of the Director at any time.

8. Record Contents

Records and monitoring information shall include:

- A. The date, exact place, time and methods of sampling or measurements, and preservatives used, if any;
- B. The individuals(s) who performed the sampling or measurements;
- C. The date(s) and time analyses were performed;
- D. The individual(s) who performed the analyses;
- E. The analytical techniques or methods used; and
- F. The measurements and results of such analyses.

9. Inspection and Entry

The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

- A. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- B. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- C. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, and
- D. Sample, inspect, or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.



Permit Number: AR0021903

AFIN: 19-00071 Page 9 of Part III

SECTION D – REPORTING REQUIREMENTS

1. Planned Changes

The permittee shall give notice within 180 days and provide plans and specification (if applicable) to the Director for review and approval prior to any planned physical alterations or additions to the permitted facility. In no case are any new connections, increased flows, removal of substances, or significant changes in influent quality permitted that cause violation of the effluent limitations specified herein.

2. Anticipated Noncompliance

The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

3. Transfers

The permit is nontransferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act.

4. Monitoring Reports

Monitoring results shall be reported at the intervals and in the form specified in Part III.C.5. Discharge Monitoring Reports must be submitted even when no discharge occurs during the reporting period.

5. Compliance Schedule

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date. Any reports of noncompliance shall include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirement.

6. Twenty-four Hour Report

A. The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain the following information:

Permit Number: AR0021903 AFIN: 19-00071 Page 10 of Part III

- 1. A description of the noncompliance and its cause;
- 2. The period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and
- 3. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
- B. The following shall be included as information which must be reported within 24 hours:
 - 1. Any unanticipated bypass which exceeds any effluent limitation in the permit;
 - 2. Any upset which exceeds any effluent limitation in the permit and
 - 3. Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in Part I of the permit to be reported within 24 hours to the Enforcement Section of the Water Division of the ADEQ.
- C. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours to the Enforcement Section of the Water Division of the ADEO.

7. Other Noncompliance

The permittee shall report all instances of noncompliance not reported under Parts III.D.4, 5, and 6, at the time monitoring reports are submitted. The reports shall contain the information listed at Part III.D.6.

8. Changes in Discharge of Toxic Substances for Industrial Dischargers

The permittee shall notify the Director as soon as he/she knows or has reason to believe:

- A. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" described in 40 CFR Part 122.42(a)(1); or
- B. That any activity has occurred or will occur which would result in any discharge on a non-routine or infrequent basis of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" described in 40 CFR Part 122.42(a)(2).

Permit Number: AR0021903 AFIN: 19-00071 Page 11 of Part III

9. Duty to Provide Information

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit. Information shall be submitted in the form, manner and time frame requested by the Director.

10. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The complete application shall be submitted at least 180 days before the expiration date of this permit. The Director may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date. Continuation of expiring permits shall be governed by regulations promulgated in APCEC Regulation No. 6.

11. Signatory Requirements

All applications, reports, or information submitted to the Director shall be signed and certified as follows:

A. All **permit applications** shall be signed as follows:

- 1. For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
 - (a) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or
 - (b) The manager of one or more manufacturing, production, or operation facilities, provided: the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

Permit Number: AR0021903 AFIN: 19-00071 Page 12 of Part III

- 2. For a partnership or sole proprietorship: by a general partner or proprietor, respectively; or
- 3. For a municipality, State, Federal, or other public agency, by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes:
 - (a) The chief executive officer of the agency, or
 - (b) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.
- B. All **reports** required by the permit and **other information** requested by the Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - 1. The authorization is made in writing by a person described above.
 - 2. The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility. (A duly authorized representative may thus be either a named individual or any individual occupying a named position); and
 - 3. The written authorization is submitted to the Director.
- C. Certification. Any person signing a document under this section shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

12. Availability of Reports

Except for data determined to be confidential under 40 CFR Part 2 and APCEC Regulation No. 6, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department of Environmental Quality. As required by the Regulations, the name and address of any permit applicant or permittee, permit applications, permits, and effluent data shall not be considered confidential.



Permit Number: AR0021903 AFIN: 19-00071 Page 13 of Part III

13. Penalties for Falsification of Reports

The Arkansas Air and Water Pollution Control Act provides that any person who knowingly makes any false statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under this permit shall be subject to civil penalties specified in Part III.A.2. and/or criminal penalties under the authority of the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. § 8-4-101 et seq.).

14. Applicable Federal, State or Local Requirements

Permittees are responsible for compliance with all applicable terms and conditions of this permit. Receipt of this permit does not relieve any operator of the responsibility to comply with any other applicable federal, state, or local statute, ordinance, policy, or regulation.

Permit Number: AR0021903

AFIN: 19-00071 Page 1 of Part IV

PART IV DEFINITIONS

All definitions contained in Section 502 of the Clean Water Act and 40 CFR 122.2 shall apply to this permit and are incorporated herein by reference. Additional definitions of words or phrases used in this permit are as follows:

- 1. "Act" means the Clean Water Act, Public Law 95-217 (33.U.S.C. 1251 et seq.) as amended.
- 2. "Administrator" means the Administrator of the U.S. Environmental Protection Agency.
- 3. "APCEC" means the Arkansas Pollution Control and Ecology Commission.
- 4. "Applicable effluent standards and limitations" means all State and Federal effluent standards and limitations to which a discharge is subject under the Act, including, but not limited to, effluent limitations, standards of performance, toxic effluent standards and prohibitions, and pretreatment standards.
- 5. "Applicable water quality standards" means all water quality standards to which a discharge is subject under the federal Clean Water Act and which has been (a) approved or permitted to remain in effect by the Administrator following submission to the Administrator pursuant to Section 303(a) of the Act, or (b) promulgated by the Director pursuant to Section 303(b) or 303(c) of the Act, and standards promulgated under (APCEC) Regulation No. 2, as amended.
- 6. "Best Management Practices (BMPs)" are activities, practices, maintenance procedures, and other management practices designed to prevent or reduce the pollution of waters of the State. BMPs also include treatment technologies, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw sewage. BMPs may include structural devices or nonstructural practices.
- 7. "Bypass" As defined at 122.41(m).
- 8. "Composite sample" is a mixture of grab samples collected at the same sampling point at different times, formed either by continuous sampling or by mixing a minimum of 4 effluent portions collected at equal time intervals (but not closer than one hour apart) during operational hours, within the 24-hour period, and combined proportional to flow or a sample collected at more frequent intervals proportional to flow over the 24-hour period.
- 9. **Daily Discharge**" means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling.
 - A. Mass Calculations: For pollutants with limitations expressed in terms of mass, the "daily discharge" is calculated as the total mass of pollutant discharged over the sampling day.
 - B. Concentration Calculations: For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the day.
- 10. **Daily Maximum**" discharge limitation means the highest allowable "daily discharge" during the calendar month. The 7-day average for Fecal Coliform Bacteria (FCB) or E-Coli is the geometric mean of the values of all effluent samples collected during the calendar week in colonies per 100 ml.

Permit Number: AR0021903 AFIN: 19-00071 Page 2 of Part IV

- 11. "Department" means the Arkansas Department of Environmental Quality (ADEQ).
- 12. "Director" means the Director of the Arkansas Department of Environmental Quality.
- 13. "Dissolved oxygen limit", shall be defined as follows:
 - A. When limited in the permit as a minimum monthly average, shall mean the lowest acceptable monthly average value, determined by averaging all samples taken during the calendar month;
 - B. When limited in the permit as an instantaneous minimum value, shall mean that no value measured during the reporting period may fall below the stated value.
- 14. **"E-Coli"** a sample consists of one effluent grab portion collected during a 24-hour period at peak loads. For E-Coli, report the monthly average as a 30-day geometric mean in colonies per 100 ml.
- 15. "Fecal Coliform Bacteria (FCB)" a sample consists of one effluent grab portion collected during a 24-hour period at peak loads. For Fecal Coliform Bacteria (FCB) report the monthly average as a 30-day geometric mean in colonies per 100 ml.
- 16. "Grab sample" means an individual sample collected in less than 15 minutes in conjunction with an instantaneous flow measurement.
- 17. "Industrial User" means a nondomestic discharger, as identified in 40 CFR Part 403, introducing pollutants to a POTW.
- 18. "Instantaneous Maximum" when limited in the permit as an instantaneous maximum value, shall mean that no value measured during the reporting period may fall above the stated value.
- 19. "Instantaneous Minimum" an instantaneous minimum value, shall mean that no value measured during the reporting period may fall below the stated value.
- 20. "Monthly average" means the highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month. For Fecal Coliform Bacteria (FCB) or E-Coli, report the monthly average.
- 21. "National Pollutant Discharge Elimination System" means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements under Sections 307, 402, 318, and 405 of the Clean Water Act.
- 22. "POTW" means a Publicly Owned Treatment Works.
- 23. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in products.
- 24. "Sewage sludge" means the solids, residues, and precipitate separated from or created in sewage by the unit processes at a POTW. Sewage as used in this definition means any wastes, including wastes from humans, households, commercial establishments, industries, and stormwater runoff that are discharged to or otherwise enter a POTW.
- 25. "7-day average" Also known as Average weekly. means the highest allowable average of "daily discharges" over a calendar week, calculated as the sum of all "daily discharges"

Permit Number: AR0021903

AFIN: 19-00071 Page 3 of Part IV

measured during a calendar week divided by the number of "daily discharges" measured during that week.

- 26. "Treatment works" means any devices and systems used in storage, treatment, recycling, and reclamation of municipal sewage and industrial wastes, of a liquid nature to implement section 201 of the Act, or necessary to recycle reuse water at the most economic cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and alterations thereof; elements essential to provide a reliable recycled supply such as standby treatment units and clear well facilities, and any works, including site acquisition of the land that will be an integral part of the treatment process or is used for ultimate disposal of residues resulting from such treatment.
- 27. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. Any upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, lack of preventive maintenance, or careless of improper operations.
- 28. "Visible sheen" means the presence of a film or sheen upon or a discoloration of the surface of the discharge. A sheen can also be from a thin glistening layer of oil on the surface of the discharge.
- 29. "MGD" shall mean million gallons per day.
- 30. "mg/l "shall mean milligrams per liter or parts per million (ppm).
- 31. "µg/l" shall mean micrograms per liter or parts per billion (ppb).
- 32. "cfs" shall mean cubic feet per second.
- 33. "ppm" shall mean parts per million.
- 34. "s.u." shall mean standard units.
- 35. "Weekday" means Monday Friday.
- 36. Monitoring and Reporting:
- 37. When a permit becomes effective, monitoring requirements are of the immediate period of the permit effective date. Where the monitoring requirement for an effluent characteristic is monthly or more frequently, the Discharge Monitoring Report (DMR) shall be submitted by the 25th of the month following the sampling. Where the monitoring requirement for an effluent characteristic is Quarterly, Semi-Annual, Annual, or Yearly, the DMR shall be submitted by the 25th of the month following the monitoring period end date.

A. MONTHLY:

is defined as a calendar month or any portion of a calendar month for monitoring requirement frequency of once/month or more frequently.

B. BI-MONTHLY:

is defined as two (2) calendar months or any portion of 2 calendar months for monitoring requirement frequency of once/2 months or more frequently.

Permit Number: AR0021903 AFIN: 19-00071 Page 4 of Part IV

C. QUARTERLY:

 is defined as a fixed calendar quarter or any part of the fixed calendar quarter for a non-seasonal effluent characteristic with a measurement frequency of once/quarter. Fixed calendar quarters are: January through March, April through June, July through September, and October through December; or

2. is defined as a **fixed three month period** (or any part of the fixed three month period) of or dependent upon the seasons specified in the permit for a seasonal effluent characteristic with a monitoring requirement frequency of once/quarter that does not coincide with the fixed calendar quarter. Seasonal calendar quarters are: May through July, August through October, November through January, and February through April.

D. SEMI-ANNUAL:

is defined as the fixed time periods January through June, and July through December (or any portion thereof) for an effluent characteristic with a measurement frequency of once/6 months or twice/year.

E. ANNUAL or YEARLY:

is defined as a fixed calendar year or any portion of the fixed calendar year for an effluent characteristic or parameter with a measurement frequency of once/year. A calendar year is January through December, or any portion thereof.