

# ADEQ

ARKANSAS  
Department of Environmental Quality

September 14, 2007

CERTIFIED MAIL: RETURN RECEIPT REQUESTED (7005 1160 0000 3832 4682)

Mr. Don O'Neal  
City of Wynne  
121 East Merriman  
Wynne, AR 72396

RE: Application to Discharge to Waters of the State Permit Number AR0021903

Dear Mr. O'Neal:

Enclosed is the public notice, Fact Sheet, and a copy of the draft permit which the Arkansas Department of Environmental Quality (ADEQ) has prepared under the authority of the National Pollutant Discharge Elimination System and the Arkansas Water and Air Pollution Control Act. A copy of the final permit will be mailed to you when the Department has made a final permitting decision.


In accordance with Arkansas Pollution Control and Ecology Commission (APCEC) Regulation No. 8, Part 2.1.6, the enclosed public notice will be published by ADEQ in a newspaper of general circulation for one (1) day only. An invoice for the cost of publishing the public notice and proof of publication will be sent to you by the advertising newspaper. The permittee must send proof of publication and payment to the following address as soon as possible but no later than 30 days from the above date. Until this Department receives proof of publication of the public notice, no further action will be taken on the issuance of your NPDES discharge permit.

Arkansas Department of Environmental Quality  
NPDES-Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118-5317  
501-682-0622 Fax: 501-682-0910

Comments must be received at ADEQ prior to the close of the public comment period as shown in the enclosed public notice. The public comment period will begin on the date of publication and will end no sooner than 30 days from that date. Once a final permit is issued by the Director and becomes effective, the permittee must comply with all terms and conditions of the permit, or be subject to enforcement actions for any instances of noncompliance during the duration of the permit, usually five (5) years. Consequently, it is imperative that you, as the applicant, thoroughly review the enclosed documentation for accuracy, applicability, and your ability to comply with all conditions therein.

Should you have any questions concerning any part of the draft permit, please contact the NPDES Branch at (501) 682-0622.

Sincerely,



Steven L. Drown  
Chief, Water Division

SD:kf

Enclosure

NPDES PERMIT FILE  
NPDES # AR002903  
AFIN # 11-00071  
Permit PN  
 Correspondence  
 Technical Backup  
9-12-07 Date Scanned  
mit



**PUBLIC NOTICE OF DRAFT NPDES PERMIT  
PERMIT NUMBER AR0021903**

September 14, 2007

This is to give notice that the Arkansas Department of Environmental Quality, 5301 Northshore Drive, North Little Rock, Arkansas 72118-5317 proposes a draft renewal of the permit for which an application was received on March 2, 2007 with additional information submitted on April 4, 2007 and April 16, 2007 for the following applicant under the National Pollutant Discharge Elimination System and the Arkansas Water and Air Pollution Control Act.

The applicant's mailing address is:

City of Wynne  
121 East Merriman Ave  
Wynne, AR 72396

The facility address is:

City of Wynne  
545 Bowden Road  
Wynne, AR 72396

This is a renewal of the existing NPDES discharge permit.

The proposed draft permit was publicly noticed on July 13, 2007. The Department, after receiving comments during the public comment period, made substantial revisions in the permit which require this second public notice.

**208 PLAN (WATER QUALITY MANAGEMENT PLAN):** The 208 Plan, developed by the ADEQ under provisions of Section 208 of the federal Clean Water Act, is a comprehensive program to work toward achieving federal water goals in Arkansas. The initial 208 Plan, adopted in 1979, provides for annual updates, but can be revised more often if necessary. Updates to the 208 Plan have been proposed to include the following updates to the existing water quality limitations for CBOD5, DO, and NH3-N:

May-October:           CBOD5/TSS/NH3-N/DO = 12/15/3/7 mg/l  
November-April:       CBOD5/TSS/NH3-N/DO = 12/15/5/6 mg/l  
Design flow (Q):       2.76 MGD  
Background Flow of the receiving stream (7Q10):       0cfs

**FACILITY LOCATION:** The facility is located as follows: 545 Bowden Road; approximately 1.5 miles West of Wynne on Hwy 284 to Bowden Road; Latitude: 35° 13' 9"; Longitude: 90° 49' 41" in Section 24, Township 7 North, Range 2 East in Cross County, Arkansas.

**DISCHARGE LOCATION:** The discharge from this existing facility is made into a drainage ditch, thence to Caney Creek, thence to the L'Angeuille River, thence to the St. Francis River in Segment 5B of the St. Francis River Basin. The receiving stream with USGS Hydrologic Unit Code (H.U.C) of 08020205 and reach #901 is a Water of the State classified for secondary contact recreation, raw water source for public, industrial, and agricultural water supplies, propagation of desirable species of fish and other aquatic life, and other compatible uses.

**OUTFALL LOCATION:** The outfall is located at the following coordinates: Latitude: 35° 13' 07" Longitude: 90° 49' 52".

**303(d) LIST CONSIDERATION:** Caney Creek is listed on the 303(d) list in Category 5d for Total Dissolved Solids from agricultural activities. The discharge from the City of Wynne is into an un-named drainage ditch and must travel approximately one (1) stream mile before entering Caney Creek. Due to the travel distance to the impaired stream and since additional data verification must be conducted before a Total Maximum Daily Load (TMDL) is scheduled, the discharge from the City of Wynne should not adversely affect Caney Creek. Therefore based on the judgment of the permit writer, no additional permit action is needed at this time.

**ENDANGERED SPECIES CONSIDERATION:** No comments on the application were received from the U.S. Fish and Wildlife Service (USF&WS). The draft permit and Fact Sheet will be sent to the USF&WS for their review.

**TYPE OF TREATMENT:** Extended aeration activated sludge with ultraviolet disinfection, post aeration and aerobic sludge digestion with a design flow of 2.76 MGD.

**SLUDGE CONDITION:** Sludge is land applied to the following sites:

<u>Field No.</u>	<u>Section</u>	<u>Township</u>	<u>Range</u>	<u>Total Acres</u>
1	24	7 North	2 East	30
2	24	7 North	2 East	10

**ACTIVITY:** Under the standard industrial classification (SIC) code 4952 or North American Industry Classification System (NAICS) code of 22132, the applicant's activities are the operation of a sewage treatment plant.

**CHANGES:** Significant changes from the previously issued permit are listed below. The permittee is responsible for carefully reading the permit in detail and becoming familiar with all of the changes therein:

1. Parts II, III, and IV have been revised.
2. The facility's location coordinates have been corrected to match the most recent field data.
3. The effluent limitations for pH have been corrected from 6-9 s.u. to 6.0 to 9.0 s.u. to ensure the required accuracy in reporting.
4. The Ammonia Nitrogen (NH<sub>3</sub>-N) limits have been changed based upon the toxicity criteria contained in Section 2.512 of APCEC Regulation No. 2 for the months of April through October.
5. The NH<sub>3</sub>-N monthly average effluent limit for the months of November through March and the daily max effluent limit for the months of May through October have been changed based upon a new desk top model performed by staff on August 21, 2007.
6. The monthly average effluent limit for Carbonaceous Biochemical Oxygen Demand (5 day) (CBOD<sub>5</sub>) has been changed based upon a new desk top model performed by staff on August 21, 2007.
7. The Dissolved Oxygen limit has been changed to a monthly average minimum of 6.0 mg/l for the months of November through April and a monthly average minimum of 7.0 mg/l for the months of May through October in accordance with the current Dissolved Oxygen standard.
8. The Whole Effluent Toxicity (WET) limit has been removed from the permit and replaced with quarterly Chronic Biomonitoring requirements based on the previous 5 years of sampling results and the inclusion of NH<sub>3</sub>-N toxicity limits.
9. Interim and final effluent limitations for Total Recoverable Copper and Total Recoverable Arsenic along with a schedule of compliance has been included based on the results of the most recent Priority Pollutant Scan (PPS).
10. The 7-day average effluent limit for Total Suspended Solids (TSS) has been corrected to show the actual numeric limitation prior to rounding.
11. The required operator license Class III for the facility has been stated in Part III of the permit.
12. The biosolids monitoring requirements have been changed to once per year.

13. A statement has been added to Part I of the permit to allow for effluent flow measurement prior to the final treatment unit.
14. A requirement to develop a Pretreatment Program in accordance with 40 CFR 403 has been included in the draft permit based on the fact that the permittee receives significant industrial process wastewater.

**PUBLIC NOTICE:** In accordance with Arkansas Pollution Control and Ecology Commission (APCEC) Regulation No. 8, the public notice will be published by ADEQ in a newspaper of general circulation for one (1) day only. The public comment period will begin on the date of publication and will end no sooner than 30 days from that date. Comments must be received at ADEQ prior to the close of the public comment period.

A draft permit and draft public notice will be sent to the District Engineer, Corps of Engineers, and to the Regional Director of the USF&WS on a case-by-case basis, and the EPA and Arkansas Department of Health prior to the publication of that notice.

**ISSUANCE OF THE FINAL PERMIT:** The permit will become effective no sooner than 30 days after the close of the comment period unless comments are received and/or a public hearing is requested prior to October 15, 2007 requiring a delay of the effective date.

**COMMENTS AND PUBLIC HEARING:** NPDES comments and public hearing procedures may be found at 40 CFR Parts 124.10 through 124.12 and APCEC Regulation No. 8. All persons, including the permittee, who wish to comment on ADEQ's draft permitting decision must submit written comments to ADEQ, along with their name and mailing address. During the comment period, any interested person may request a public hearing by filing a written request which must state the technical issues to be raised. A public hearing will be held if ADEQ finds a significant degree of public interest. If a public hearing is held, ADEQ will issue a public notice of the hearing at least 30 days prior to the scheduled hearing.

After the public comment period, and public hearing, if one is held, ADEQ will issue a final permitting decision. ADEQ will notify the applicant and each person who has submitted written comments or requested notice of the final permitting decision. A final permitting decision means a final decision to issue, deny, modify, revoke and reissue, or terminate a permit. Any interested person who has submitted comments may appeal a final decision by ADEQ in accordance with the APCEC Regulation No. 8 (Administrative Procedures).

Submitting written comments to ADEQ or making oral statements on the record at the public hearing on the proposed permitting decision provides individuals with legal standing to appeal a final Department permitting decision. Comments supporting or opposing the proposed decision will provide legal standing. Only parties with legal standing may appeal a permitting decision.

**PERMIT APPLICATION RECORD:** The permit application and the administrative record is available for review and copying in the ADEQ Central Records Section at 5301 Northshore Drive, North Little Rock, Arkansas.

**WEB SITE INFORMATION:** For those with Internet access, a copy of the proposed draft permit may be found on the Arkansas Department of Environmental Quality's website at:

[http://www.adeq.state.ar.us/water/branch\\_npdes/pn\\_permits/pnpermits.asp](http://www.adeq.state.ar.us/water/branch_npdes/pn_permits/pnpermits.asp).

**CONTACT PERSON:** The ADEQ contact person for submitting written comments, requesting information, or obtaining copies of the application, permit, and the Fact Sheet is:

Kimberly A. Fuller, E.I., CPESC  
NPDES Branch, Water Division  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, Arkansas 72118-5317  
(501) 682-0622

# DRAFT

## Fact Sheet

for renewal of the draft NPDES Permit Number AR0021903 to discharge to Waters of the State

### 1. PERMITTING AUTHORITY.

The issuing office is:

Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, Arkansas 72118-5317

### 2. APPLICANT.

The applicant's mailing address is:

City of Wynne  
121 East Merriman Ave  
Wynne, AR 72396

The facility address is:

City of Wynne  
545 Bowden Road  
Wynne, AR 72396

### 3. PREPARED BY.

The permit was prepared by:

Kimberly A. Fuller  
Staff Engineer  
NPDES Branch, Water Division  
Telephone: (501) 682-0621

### 4. DATE PREPARED.

The permit was prepared on May 7, 2007.

### 5. PREVIOUS PERMIT ACTIVITY.

Effective Date: September 1, 2002  
Expiration Date: August 31, 2007

# DRAFT

Page 2 of Fact Sheet  
Permit Number: AR0021903

The permit application was received on March 2, 2007 and was deemed administratively complete on March 26, 2007. It is proposed that the current NPDES permit be reissued for a 5-year term in accordance with regulations promulgated at 40 CFR Part 122.46(a).

The draft permit was prepared and publicly noticed on July 13, 2007. The following comments were received on the draft permit in a letter from Wynne Water Utilities to Kimberly A. Fuller received August 9, 2007.

1. The permittee requested a copy of the model print-out, including the various model in-put values, and an opportunity to review and comment on the model results before the draft permit becomes final.

A copy of the desk-top model was provided to Larry Gaddis with Crist Engineers (consultant engineer for Wynne Water Utilities) on July 25, 2007. Due to comments received, the Department re-evaluated the model using different inputs. With this revised permit, the Department is proposing new limits generated from the new model.

2. The permittee requested that the quarterly chronic biomonitoring testing requirement be removed from the permit conditions as being obviously unnecessary based on the previous years whole effluent toxicity test results.

The Department's Continuing Planning Process (CPP) requires that all major facilities conduct biomonitoring at a minimum of once per quarter. All major NPDES permits contain this requirement. As allowed in Part III.11.6.a, the permittee may request a monitoring frequency reduction after "successful completion of the first four consecutive quarters of testing for one or both test species, with no lethal or sub-lethal effects demonstrated at or below the critical dilution without a major modification". If allowed, the frequency may be reduced to once per year for the fathead minnow and twice per year for the Ceriodaphnia dubia.

3. The permittee requested that a condition be included allowing the removal of the arsenic reporting requirement after four consecutive monthly samples confirm the absence of arsenic at concentrations of concern.

The following condition has been added to Part III.8 to allow the removal of the monthly Arsenic sampling.

"The permittee may request the removal of the monthly Arsenic sampling requirement after four (4) consecutive monthly samples confirm that the concentrations of Arsenic are below levels of concern, i.e., 0.65 µg/l."

4. The permittee requested that the footnote in regard to flow measurement be corrected.

The note on Pages 2 and 4 of Part IA has been changed as follows.



“Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit except for the flow measurement which shall be taken after the UV system and prior to post-aeration at the monitoring location of 35° 13' 7" Latitude and 90° 49' 48" Longitude.”

5. The permittee requested that the requirement to develop a pretreatment program be removed from the permit.

The Department requires that all major municipal facilities conduct an industrial user survey at a minimum of once per permit term.

6. The permittee submitted a “No Exposure Exclusion” application form with their permit comments; therefore, the Stormwater Pollution Prevention Plan (SWPPP) requirements were removed.

In response to these comments and after thorough review of the draft permit, the Department made a determination that several changes/revisions/corrections to the draft permit were necessary. This is a public notice of the revised draft permit.

## 6. RECEIVING STREAM SEGMENT AND DISCHARGE LOCATION.

The outfall is located at the following coordinates:

Latitude: 35° 13' 07" Longitude: 90° 49' 52"

The receiving waters named:

a drainage ditch, thence to Caney Creek, thence to the L'Anguille River, thence to the St. Francis River in Segment 5B of the St. Francis River Basin. The receiving stream with USGS Hydrologic Unit Code (H.U.C) of 08020205 and reach #901 is a Water of the State classified for secondary contact recreation, raw water source for public, industrial, and agricultural water supplies, propagation of desirable species of fish and other aquatic life, and other compatible uses.

### a. 303(d) LIST AND ENDANGERED SPECIES CONSIDERATIONS.

#### i. 303(d) List:

Caney Creek is listed on the 303(d) list in Category 5d for Total Dissolved Solids from agricultural activities. The discharge from the City of Wynne is into an unnamed drainage ditch and must travel approximately one (1) stream mile before entering Caney Creek. Due to the travel distance to the impaired stream and since additional data verification must be conducted before a Total Maximum Daily Load

# DRAFT

Page 4 of Fact Sheet  
Permit Number: AR0021903

(TMDL) is scheduled, the discharge from the City of Wynne should not adversely affect Caney Creek. Therefore based on the judgment of the permit writer, no additional permit action is needed at this time.

## ii. Endangered Species:

No comments on the application were received from the U.S. Fish and Wildlife Service (USF&WS). The draft permit and Fact Sheet will be sent to the USF&WS for their review.

## 7. OUTFALL AND TREATMENT PROCESS DESCRIPTION.

The following is a description of the facility described in the application:

- a. Design Flow: 2.76 MGD
- b. Type of Treatment: Extended aeration activated sludge with ultraviolet disinfection, post aeration, and aerobic sludge digestion.
- c. Discharge Description: Treated Municipal Wastewater

## 8. ACTIVITY.

Under the standard industrial classification (SIC) code 4952 or North American Industry Classification System (NAICS) code of 22132, the applicant's activities are the operation of a sewage treatment plant.

## 9. INDUSTRIAL WASTEWATER CONTRIBUTIONS.

### INDUSTRIAL USERS

This facility receives significant industrial process wastewater. Based on the applicant's type of industrial contributions, requirements to develop a Pretreatment Program are deemed necessary at this time. The Department may decide to waive this requirement after subsequent information from the applicant is received and reviewed.

## 10. SEWAGE SLUDGE PRACTICES.

Sludge is land applied to the following sites:

Field No.	Section	Township	Range	Total Acres
1	24	7 North	2 East	30
2	24	7 North	2 East	10

## 11. PERMIT CONDITIONS.

The Arkansas Department of Environmental Quality has made a tentative determination to issue a permit for the discharge described in the application. Permit requirements are based on NPDES regulations (40 CFR Parts 122, 124, and Subchapter N), the National Pretreatment Regulation in 40 CFR Part 403 and regulations promulgated pursuant to the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended, Ark. Code Ann. 8-4-101 et. seq.).

### a. Interim Effluent Limitations

Outfall 001- Treated Municipal Wastewater

#### i. Conventional and/or Toxic Pollutants

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow (MGD)	N/A	Report	Report	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)	276	12	18	three/week	6-hr composite
Total Suspended Solids (TSS)	345	15	22.5	three/week	6-hr composite
Ammonia Nitrogen (NH3-N)					
(Apr)	48	2.1	5.2	three/week	6-hr composite
(May-Oct)	48	2.1	4.5	three/week	6-hr composite
(Nov-Mar)	115	5	7.5	three/week	6-hr composite
Dissolved Oxygen					
(May-Oct)	N/A	7.0 (Monthly Avg. Min.)		three/week	grab
(Nov-Apr)	N/A	6.0 (Monthly Avg. Min.)		three/week	grab

# DRAFT

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Fecal Coliform Bacteria (FCB)		(colonies/100 ml)			
	N/A	1000	2000	three/week	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	three/week	grab
Arsenic, Total Recoverable	Report	Report, µg/l	Report, µg/l	once/month	24-hr composite
Copper, Total Recoverable	Report	Report, µg/l	Report, µg/l	once/month	24-hr composite
Chronic Biomonitoring	N/A	See Page #16 below		once/quarter	24-hr composite

- ii. **Solids, Foam, and Free Oil:** There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

a. **Final Effluent Limitations**

Outfall 001- Treated Municipal Wastewater

i. **Conventional and/or Toxic Pollutants**

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow (MGD)	N/A	Report	Report	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)	276	12	18	three/week	6-hr composite
Total Suspended Solids (TSS)	345	15	22.5	three/week	6-hr composite
Ammonia Nitrogen (NH3-N)					
(Apr)	48	2.1	5.2	three/week	6-hr composite
(May-Oct)	48	2.1	4.5	three/week	6-hr composite
(Nov-Mar)	115	5	7.5	three/week	6-hr composite

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Dissolved Oxygen					
(May-Oct)	N/A	7.0 (Monthly Avg. Min.)		three/week	grab
(Nov-Apr)	N/A	6.0 (Monthly Avg. Min.)		three/week	grab
Fecal Coliform Bacteria (FCB)		(colonies/100 ml)			
	N/A	1000	2000	three/week	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	three/week	grab
Arsenic, Total Recoverable	Report	Report, µg/l	Report, µg/l	once/month	24-hr composite
Copper, Total Recoverable	0.68	29.5, µg/l	59.1, µg/l	once/month	24-hr composite
Chronic Biomonitoring	N/A	See Page #16 below		once/quarter	24-hr composite

- ii. **Solids, Foam, and Free Oil:** There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

## 12. BASIS FOR PERMIT CONDITIONS.

The following is an explanation of the derivation of the conditions of the draft permit and the reasons for them or, in the case of notices of intent to deny or terminate, reasons suggesting the tentative decisions as required under 40 CFR Part 124.7 (48 FR 1413, April 1, 1983).

### Technology-Based Versus Water Quality-Based Effluent Limitations And Conditions

Following regulations promulgated at 40 CFR Part 122.44(1)(2)(ii), the draft permit limits are based on either technology-based effluent limits pursuant to 40 CFR Part 122.44(a) or on State water quality standards and requirements pursuant to 40 CFR Part 122.44(d), whichever are more stringent.

#### a. Anti-backsliding

The permit is consistent with the requirements to meet Anti-backsliding provisions of the Clean Water Act (CWA), Section 402(o) [40 CFR 122.44(l)(i)(A)], which state in part that final effluent limitations for reissuance permits must be as stringent as those in the previous permit, unless material and substantial alternations or additions to the permitted

# DRAFT

facility occurred after permit issuance which justify the application of a less stringent effluent limitations.

The permit maintains the requirements of the previous permit with the exception of a revised limitation identified for Whole Effluent Toxicity (WET). Due to the City of Wynne's sampling history over the past 5 years (i.e., no WET testing failures in 17 tests for each species) and the inclusion of more stringent toxicity based ammonia limits for the months of April through October, the WET limit from the previous permit has been removed. This revision is allowed in accordance with the federal regulations at 40 CFR 122.44(l)(2)(i)(B)(1).

b. **Technology-Based Effluent Limitations And/Or Conditions**

The permit must at least comply with 40 CFR Part 133 (Secondary Treatment Regulation) when applicable.

c. **State Water Quality Numerical Standards Based Limitations**

The monthly average effluent limits for CBOD5, TSS, DO, and NH3-N are based on a desk top model performed by staff on April 5, 2007. These limitations were included in the updated Arkansas Water Quality Management Plan (WQMP). The calculation of the loadings (lbs per day) uses a design flow of 2.76 MGD and the following equation (See below). Fecal Coliform Bacteria and pH limitations are based on Chapter 5, Sections 2.507 and 2.504 of APCEC Regulation No. 2 as amended, respectively.

$$\text{Daily Maximum limits} = \text{Monthly average limits} \times 1.5$$

$$\text{lbs/day} = \text{Concentration (mg/l)} \times \text{Flow (MGD)} \times 8.34$$

Ammonia-Nitrogen (NH3-N):

The water quality effluent limitations for Ammonia are based on either DO-based effluent limits or on toxicity-based standards, whichever are more stringent.

The toxicity-based effluent limitations are based on Chapter 5, Section 2.512 of APCEC Regulation No. 2 and an ADEQ internal memo dated March 28, 2005. The following formula has been used to calculate toxicity based Ammonia limits:

$$Cd = (IWC(Qd + Qb) - CbQb)/Qd,$$

Where:

Cd = effluent limit concentration (mg/l)  
IWC = Ammonia toxicity standard for Ecoregion



# DRAFT

Qd = design flow = 2.76 MGD = 4.26 cfs

The 7Q10 of 0 cfs is based on the fact that the receiving stream is a drainage ditch.

Qb = Critical flow of the receiving stream = 0 cfs.

Cb = background concentration = 0 mg/l

The following pH and temperature were used for Delta Ecoregion:

Month	pH s.u.	Temperature °C	IWC (Monthly Avg)	IWC (Daily Max)
April-October	7.1	30	2.1 mg/l	5.2 mg/l
November-March	7.1	14	5.9 mg/l	14.7 mg/l

Notes:

- Daily Max = 4-day Average in APCEC Regulation No. 2
- Monthly Average = 30-day Average in APCEC Regulation No. 2

### Calculations of Toxicity-Based Limits:

Since background flow of the receiving stream is 0 cfs then Cd = IWC

### Calculated Toxicity Limits

Month	Monthly Avg (30-day Average) (mg/l)	Daily Max (4-day Average) (mg/l)
April-October	2.1	5.2
November-March	5.9	14.7

Comparison between Arkansas Water Quality Standard DO based limits and calculated toxicity limits for Ammonia Nitrogen (NH<sub>3</sub>-N):

Month	DO Based Limits		Calculated Toxicity Limits		Final Water Quality Limits	
	Monthly Avg. (mg/l)	Daily Max (mg/l)	Monthly Avg. (mg/l)	Daily Max (mg/l)	Monthly Avg. (mg/l)	Daily Max (mg/l)
(April)	5	7.5	2.1	5.2	2.1	5.2
(May-October)	3	4.5	2.1	5.2	2.1	4.5
(November-March)	5	7.5	5.9	14.7	5	7.5

d. **208 Plan (Water Quality Management Plan)**

The 208 Plan, developed by the ADEQ under provisions of Section 208 of the federal Clean Water Act, is a comprehensive program to work toward achieving federal water goals in Arkansas. The initial 208 Plan, adopted in 1979, provides for annual updates, but can be revised more often if necessary. Updates to the 208 Plan have been proposed to include the following updates to the existing water quality limitations for CBOD5, DO, and NH3-N:

May-October:           CBOD5/TSS/NH3-N/DO = 12/15/3/7 mg/l  
November-April:       CBOD5/TSS/NH3-N/DO = 12/15/5/6 mg/l  
Design flow (Q):       2.76 MGD  
Background Flow of the receiving stream (7Q10):       0cfs

e. **Toxics Pollutants**

i. Post Third Round Policy and Strategy

Section 101 of the Clean Water Act(CWA) states that "...it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited...". To insure that the CWA's prohibitions on toxic discharges are met, EPA has issued a "Policy for the Development of Water Quality-Based Permit Limitations by Toxic Pollutants"(49 FR 9016-9019,3/9/84). In support of the national policy, Region 6 adopted the "Policy for post Third Round NPDES Permitting" and the "Post Third Round NPDES Permit Implementation Strategy" on October 1, 1992. The Regional policy and strategy are designed to insure that no source will be allowed to discharge any wastewater which (1) results in instream aquatic toxicity; (2) causes a violation of an applicable narrative or numerical State water quality standard resulting in non-conformance with the provisions of 40 CFR Part 122.44(d); (3) results in the endangerment of a drinking water supply; or (4) results in aquatic bioaccumulation which threatens human health.

ii. Implementation

The State of Arkansas is currently implementing EPA's Post Third-Round Policy in conformance with the EPA Regional strategy. The 5-year NPDES permits contain technology-based effluent limitations reflecting the best controls available. Where these technology-based permit limits do not protect water quality or the designated uses, or where there are no applicable technology-based limits, additional water quality-based effluent limitations and/or conditions are included in the NPDES permits. State narrative and numerical water quality standards from Regulation No. 2 are used in conjunction with EPA criteria and other available toxicity information to



determine the adequacy of technology-based permit limits and the need for additional water quality-based controls.

iii. Priority Pollutant Scan (PPS)

In accordance with the regional policy ADEQ has reviewed and evaluated the effluent in evaluating the potential toxicity of each analyzed pollutant:

- (a) The results were evaluated and compared to EPA's Minimum Quantification Levels (MQLs) to determine the potential presence of a respective toxic pollutant. Those pollutants which are greater than or equal to the MQLs are determined to be reasonably present in the effluent and an evaluation of their potential toxicity is necessary.
- (b) Those pollutants with one datum shown as "non-detect" (ND), providing the level of detection is equal to or lower than MQL are determined to be not potentially present in the effluent and eliminated from further evaluation.
- (c) Those pollutants with a detectable value even if below the MQL are determined to be reasonably present in the effluent and an evaluation of their potential toxicity is necessary.
- (d) For those pollutants with multiple data values and all values are determined to be non-detect, therefore no further evaluation is necessary. However, where data set includes some detectable concentrations and some values as ND, one-half of the detection level is used for those values below the level of detection to calculate the geometric mean of the data set.

The concentration of each pollutant after mixing with the receiving stream was compared to the applicable water quality standards as established in the Arkansas Water Quality Standards, Reg. No. 2 and with the aquatic toxicity, human health, and drinking water criteria obtained from the "Quality Criteria for Water, 1986 (Gold Book)". The following expression was used to calculate the pollutant instream waste concentration(IWC):

$$IWC = ((C_e \times Q_e) + (C_b \times Q_b)) / (Q_e + Q_b)$$

where:

IWC = instream concentration of pollutant after mixing with receiving stream ( $\mu\text{g/l}$ )

$C_e$  = pollutant concentration in effluent ( $\mu\text{g/l}$ )

$Q_e$  = effluent flow of facility (cfs)

$C_b$  = background concentration of pollutant in receiving stream ( $\mu\text{g/l}$ )

$Q_b$  = background flow of receiving stream (cfs)

The following values were used in the IWC calculations:

$C_e$  = varies with pollutant. A single value from the Priority Pollutant Screen (PPS) submitted by the permittee as part of the NPDES permit application or the geometric mean of a group of data points (less than 20 data points) is multiplied by a factor of 2.13. This factor is based on EPA's Region VI procedure (See attachment IV of Continuing Planning Process (CPP)) to extrapolate limited data sets to better evaluate the potential toxicity for higher effluent concentrations to exceed water quality standards. This procedure employs a statistical approach which yields an estimate of a selected upper percentile value (the 95th percentile) of an effluent data set which would be expected to exceed 95% of effluent concentrations in a discharge. If 20 or more data points during the last two years are available, do not multiply by 2.13, but instead use the maximum reported values.

$Q_e$  = 2.76 MGD = 4.26 cfs

$C_b$  = 0  $\mu\text{g/l}$

$Q_b$  = (See below):

## I. Aquatic Toxicity

Chronic Toxicity: Flow = 0 cfs, for comparison with chronic aquatic toxicity. This flow is 67 percent of the 7-day, 10-year low-flow (7Q10) for the receiving stream. The 7Q10 of 0 cfs is based on "Identification and Classification of Perennial Stream of Arkansas", Arkansas Geological Commission Map.

Acute Toxicity: Flow = 0 cfs, for comparison with acute aquatic toxicity. This flow is 33 percent of the 7Q10 for the receiving stream.

## II. Bioaccumulation

Flow = 0 cfs, for comparison with bioaccumulation criteria. This flow is the long term average (LTA) of the receiving stream which is based on "Identification and Classification of Perennial Stream of Arkansas", Arkansas Geological Commission Map.]

## III. Drinking Water

Flow = 0 cfs, for comparison with drinking water criteria. This flow is the 7Q10 for the receiving stream.

The following values were used to determine limits for the pollutants:

Hardness = 81 mg/l, based on attachment VI of CPP.

TSS = 8 mg/l, based on attachment V of CPP

pH = 7.52 s.u., based on compliance data from "Arkansas Water Quality Inventory Report" 305(b) for Station FRA0010.

iv. Water Quality Standards for Metals and Cyanide

Standards for Chromium (VI), Mercury, Selenium, and Cyanide are expressed as a function of the pollutant's water-effect ratio (WER), while standards for cadmium, chromium (III), copper, lead, nickel, silver, and zinc are expressed as a function of the pollutant's water-effect ratio, and as a function of hardness.

The Water-effect ratio (WER) is assigned a value of 1.0 unless scientifically defensible study clearly demonstrates that a value less than 1.0 is necessary or a value greater than 1.0 is sufficient to fully protect the designated uses of the receiving stream from the toxic effects of the pollutant.

The WER approach compares bioavailability and toxicity of a specific pollutant in receiving water and in laboratory test water. It involves running toxicity tests for at least two species, measuring LC50 for the pollutant using the local receiving water collected from the site where the criterion is being implemented, and laboratory toxicity testing water made comparable to the site water in terms of chemical hardness. The ratio between site water and lab water LC50 is used to adjust the national acute and chronic criteria to site specific values.

v. Conversion of Dissolved Metals Criteria for Aquatic Life to Total Recoverable Metal

Metals criteria established in APCEC Regulation No. 2, Section 2.508 for aquatic life protection are based on dissolved metals concentrations and hardness values. However, Federal Regulations cited at 40 CFR Part 122.45(c) require that effluent limitations for metals in NPDES permits be expressed as total recoverable based on Attachment V of CPP. Therefore a dissolved to the total recoverable metal conversion must be implemented. This involves determining a linear partition coefficient for the metal of concern and using this coefficient to determine the fraction of metal dissolved, so that the dissolved metal ambient criteria may be translated to a total effluent limit. The formula for converting dissolved metals to total recoverable metals for streams and lakes are provided in Attachment V of CPP and Region 6 Implementation Guidance for Arkansas Water Quality Standards promulgated at 40 CFR Part 131.36.

# DRAFT

- vi. Comparison of the submitted information with the water quality standards and criteria

The following pollutants were determined to be present in the effluent for each pollutant as reported by the permittee.

Pollutant	Concentration Reported, $\mu\text{g/l}$	MQL, $\mu\text{g/l}$
Arsenic, Total Recoverable	2	2
Copper, Total Recoverable	13	10

However, ADEQ has determined from the information submitted by the permittee that no water quality standards or Gold Book criteria are exceeded except for total recoverable copper and arsenic. Therefore, no permit action is necessary to maintain these standards or criteria (See Attachment 1).

(a) Aquatic Toxicity

(i) Pollutants with numerical water quality standards

ADEQ has determined from the information submitted by the permittee that there is a reasonable potential for copper in the discharge to cause an instream excursion above the chronic numeric standards as specified in the Arkansas Water Quality Standards, Reg. No. 2 (See Attachment 1).

ADEQ has identified the following toxicants in the discharge in amounts which could potentially have a toxic impact on the receiving stream:

Chronic Aquatic Toxicity Results				
Pollutant	$C_c$ , $\mu\text{g/l}$	$C_c \times 2.13$	IWC, $\mu\text{g/l}$	AWQS, $\mu\text{g/l}$
Copper, Total Recoverable	13	27.69	27.69	26.41

IWC's have been calculated in the manner described above.

Permit Action

Under Federal Regulation 40 CFR Part 122.44(d), as adopted by Regulation No. 6, if a discharge poses the reasonable potential to cause or contribute to an exceedance above a water quality standard, the permit must contain an effluent limitation for that pollutant. Effluent limitations for the toxicants listed above have been derived in a manner consistent with the Technical Support Document (TSD) for Water Quality-based Toxics Control (EPA,

March 1991), the State's implementations procedures, and 40 CFR Part 122.45(c).

### Permit Limit Determination

The instream waste load allocation (WLA), which is the level of effluent concentration that would comply with the water quality standard (WQS) of the receiving stream, is calculated for both chronic and acute WLA using the following equations:

$$WLA_c = (WQS \times (Q_d + Q_b) - Q_b \times C_b) / Q_d$$

where:

$$\begin{aligned} WLA_c &= \text{chronic waste load allocation } (\mu\text{g/l}) \\ Q_d &= \text{discharge flow (cfs)} \\ Q_b &= 0.67 \times 7Q_{10} \text{ (cfs)} \\ C_b &= \text{background concentration } (\mu\text{g/l}) \\ WQS &= \text{chronic aquatic toxicity standards } (\mu\text{g/l}) \end{aligned}$$

and;

$$WLA_a = (WQS \times (Q_d + Q_b) - Q_b \times C_b) / Q_d$$

where:

$$\begin{aligned} WLA_a &= \text{acute waste load allocation } (\mu\text{g/l}) \\ Q_d &= \text{discharge flow (cfs)} \\ Q_b &= 0.33 \times 7Q_{10} \text{ (cfs)} \\ C_b &= \text{background concentration } (\mu\text{g/l}) \\ WQS &= \text{acute aquatic toxicity standards } (\mu\text{g/l}) \end{aligned}$$

The long term average (LTA) effluent concentration is then calculated based on the chronic and acute WLA as follows:

$$\begin{aligned} LTA_c &= 0.72 \times WLA_c \\ LTA_a &= 0.57 \times WLA_a \end{aligned}$$

The lowest of these two (2) values is selected as being the limiting LTA. The limiting LTA is then used to calculate the monthly average (AML) and daily maximum (DML) for the final limits. AML and DML are calculated as follows:

$$AML = 1.55 \times \text{Limiting LTA}$$

DML = 3.11 X Limiting LTA

Limits included in the permit are as follows:

Arkansas Numerical Aquatic Toxicity Limits		
Parameter	AML*, µg/l	DML*, µg/l
Copper, Total Recoverable	29.5	59.1
*See Attachment 2 for calculations		

(b) Human Health (Bioaccumulation) Limits

(i) Pollutants without applicable water quality standards

ADEQ has determined from the information submitted by the permittee that there is reasonable potential for the discharge to cause exceedence of bioaccumulation criterion for arsenic as specified in the Gold Book (Quality Criteria for Water 1986) for the following parameters (Please see below). The results of the analysis are as follows:

Bioaccumulation Criterion Results				
Pollutant	C <sub>e</sub> , µg/l	C <sub>e</sub> X 2.13	IWC, µg/l	GB, µg/l
Arsenic, Total Recoverable	2	4.26	4.26	1.4

IWC's have been calculated in the manner described above.

Since the Arkansas Water Quality Standards have not been established for arsenic, no permit limitations have been placed in the permit. However, monthly monitoring and reporting is required to confirm that the pollutant is present at the levels reported by the permittee. The permit may be reopened to require effluent limitations, additional testing, and/or other appropriate actions.

(c) Drinking Water Supply Protection

ADEQ has determined from the information submitted by the permittee that there is not a reasonable potential for the discharge to cause an instream excursion above the drinking water criteria as specified in the Gold Book. ADEQ has identified the following toxicants in the discharge in amounts which may have the potential to cause toxic conditions in the receiving stream.

# DRAFT

## 13. FINAL LIMITATIONS.

The following effluent limitation requirements were placed in the permit based on the more stringent of the technology-based, water quality-based, or previous NPDES permit limitations:

Parameter	Water Quality-Based		Technology-Based/BPJ		Previous NPDES Permit		Permit Limit	
	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l
CBOD5	12	18	25	40	15	23	12	18
TSS	15	22.5	30	45	15	23	15	22.5
NH3-N								
(Apr)	2.1	5.2	N/A	N/A	4	6	2.1	5.2
(May-Oct)	2.1	4.5	N/A	N/A	4	6	2.1	4.5
(Nov-Mar)	5	7.5	N/A	N/A	9	14	5	7.5
Dissolved Oxygen								
(Apr & Nov)	6.0 (Monthly Avg. Min.)		N/A		7.0 (Inst. Min.)		6.0 (Monthly Avg. Min.)	
(May-Oct)	7.0 (Monthly Avg. Min.)		N/A		7.0 (Inst. Min.)		7.0 (Monthly Avg. Min.)	
(Dec-Mar)	6.0 (Monthly Avg. Min.)		N/A		6.0 (Inst. Min.)		6.0 (Monthly Avg. Min.)	
FCB (col/100 ml)	1000	2000	N/A	N/A	1000	2000	1000	2000
pH	6.0-9.0 s.u.		6.0-9.0 s.u.		6-9 s.u.		6.0-9.0 s.u.	
Arsenic, Total Recoverable	Report, µg/l	Report, µg/l	N/A	N/A	N/A	N/A	Report, µg/l	Report, µg/l
Copper, Total Recoverable	29.5 µg/l	59.1 µg/l	N/A	N/A	N/A	N/A	29.5 µg/l	59.1 µg/l

## 14. BIOMONITORING.

Section 101(a)(3) of the Clean Water Act states that ".....it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited." In addition, ADEQ is required



# DRAFT

under 40 CFR Part 122.44(d)(1), adopted by reference in Regulation 6, to include conditions as necessary to achieve water quality standards as established under Section 303 of the Clean Water Act. Arkansas has established a narrative criteria which states "toxic materials shall not be present in receiving waters in such quantities as to be toxic to human, animal, plant or aquatic life or to interfere with the normal propagation, growth and survival of aquatic biota."

Whole effluent biomonitoring is the most direct measure of potential toxicity which incorporates the effects of synergism of effluent components and receiving stream water quality characteristics. It is the national policy of EPA to use bioassays as a measure of toxicity to allow evaluation of the effects of a discharge upon a receiving water (49 Federal Register 9016-9019, March 9, 1984). EPA Region 6 and the State of Arkansas are now implementing the Post Third Round Policy and Strategy established on September 9, 1992, and EPA Region 6 Post-Third Round Whole Effluent Toxicity Testing Frequencies, revised March 13, 2000. Biomonitoring of the effluent is thereby required as a condition of this permit to assess potential toxicity. The biomonitoring procedures stipulated as a condition of this permit are as follows:

TOXICITY TESTS	FREQUENCY
Chronic Biomonitoring	Once/quarter

Requirements for measurement frequency are based on appendix D of CPP.

Since 7Q10 is less than 100 cfs (ft<sup>3</sup>/sec) and dilution ratio is less than 100:1, chronic biomonitoring requirements will be included in the permit.

The calculations for dilution used for chronic biomonitoring are as follows:

$$\text{Critical dilution (CD)} = (Q_d / (Q_d + Q_b)) \times 100$$

$$Q_d = \text{Design flow} = 2.76 \text{ MGD} = 4.26 \text{ cfs}$$

$$7Q_{10} = 0 \text{ Cfs}$$

$$Q_b = \text{Background flow} = (0.67) \times 7Q_{10} = 0 \text{ cfs}$$

$$\text{Since } 7Q_{10} = 0 \text{ cfs then } CD = 100\%$$

Toxicity tests shall be performed in accordance with protocols described in "Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms", EPA/600/4-91/002, July 1994. A minimum of five effluent dilutions in addition to an appropriate control (0%) are to be used in the toxicity tests. These additional effluent concentrations are **32%, 42%, 56%, 75%, and 100%** (See **Attachment I** of CPP). The low-flow effluent concentration (critical dilution) is defined as **100%** effluent. The requirement for chronic biomonitoring tests is based on the magnitude of the facility's discharge with respect to receiving stream flow. The stipulated test species, *Ceriodaphnia*



*dubia* and the Fathead Minnow (*Pimephales promelas*) are indigenous to the geographic area of the facility; the use of these is consistent with the requirements of the State water quality standards. The biomonitoring frequency has been established to provide data representative of the toxic potential of the facility's discharge, in accordance with the regulations promulgated at 40 CFR Part 122.48.

Results of all dilutions as well as the associated chemical monitoring of pH, temperature, hardness, dissolved oxygen conductivity, and alkalinity shall be reported according to EPA/600/4-91/002, July 1994 and shall be submitted as an attachment to the Discharge Monitoring Report (DMR).

This permit may be reopened to require further biomonitoring studies, Toxicity Reduction Evaluation (TRE) and/or effluent limits if biomonitoring data submitted to the Department shows toxicity in the permittee's discharge. Modification or revocation of this permit is subject to the provisions of 40 CFR 122.62, as adopted by reference in ADEQ Regulation No. 6. Increased or intensified toxicity testing may also be required in accordance with Section 308 of the Clean Water Act and Section 8-4-201 of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

### Administrative Records

The following information summarized toxicity test submitted by the permittee during the term of the current permit at outfall 001:

### **BIOMONITORING FREQUENCY RECOMMENDATION AND RATIONALE FOR ADDITIONAL REQUIREMENTS**

Permit Number: AR0021903  
Facility Name: City of Wynne  
Previous Critical Dilution: **100%** Proposed Critical Dilution: **100%**  
Date of Review: **3-12-07** Name of Reviewer: **Clem**

Number of Test Performed during previous 5 years by Species:

***Pimephales promelas* (Fathead minnow) : 17**  
***Ceriodaphnia dubia* (water flea): 17**

Failed Test Dates during previous 5 years by Species:

***Pimephales promelas* (Fathead minnow) : None**  
***Ceriodaphnia dubia* (water flea): None**

Previous TRE Activities: None

Frequency Recommendation by Species:

***Pimephales promelas* (Fathead minnow) : four/year**

# DRAFT

*Ceriodaphnia dubia* (water flea): four/year

Additional Requirements (including WET Limits) Rationale/Comments Concerning Permitting:

Limitations can be removed, considering the new data from the past five years supports no toxicity.

Rationale: According to the EPA Region 6 Post-Third Round Whole Effluent Toxicity Testing Frequencies: "All major dischargers, and those minor dischargers specifically identified by EPA or the State permitting authority (based on available information on a case-by case basis) as posing a significant unaddressed toxic risk, will be required to perform Whole Effluent Toxicity testing at a frequency of once per quarter for the vertebrate and invertebrate tests species for the first year of a new or reissued permit."

## 15. SAMPLE TYPE AND FREQUENCY.

Regulations require permits to establish monitoring requirements to yield data representative of the monitored activity [40 CFR Part 122.48(b)] and to ensure compliance with permit limitations [40 CFR Part 122.44(i)(1)].

Requirements for sample type and sampling frequency have been based on the current NPDES permit.

## 16. SIGNIFICANT CHANGES FROM THE PREVIOUSLY ISSUED PERMIT.

The permittee is responsible for carefully reading the permit in detail and becoming familiar with all of the changes therein:

1. Parts II, III, and IV have been revised.
2. The facility's location coordinates have been corrected to match the most recent field data.
3. The effluent limitations for pH have been corrected from 6-9 s.u. to 6.0 to 9.0 s.u. to ensure the required accuracy in reporting.
4. The Ammonia Nitrogen (NH<sub>3</sub>-N) limits have been changed based upon the toxicity criteria contained in Section 2.512 of APCEC Regulation No. 2 for the months of April through October.
5. The NH<sub>3</sub>-N monthly average effluent limit for the months of November through March and the daily max effluent limit for the months of May through October have been changed based upon a new desk top model performed by staff on August 21, 2007.
6. The monthly average effluent limit for Carbonaceous Biochemical Oxygen Demand (5 day) (CBOD<sub>5</sub>) has been changed based upon a new desk top model performed by staff on August 21, 2007.

7. The Dissolved Oxygen limit has been changed to a monthly average minimum of 6.0 mg/l for the months of November through April and a monthly average minimum of 7.0 mg/l for the months of May through October in accordance with the current Dissolved Oxygen standard.
8. The Whole Effluent Toxicity (WET) limit has been removed from the permit and replaced with quarterly Chronic Biomonitoring requirements based on the previous 5 years of sampling results and the inclusion of NH<sub>3</sub>-N toxicity limits.
9. Interim and final effluent limitations for Total Recoverable Copper and Total Recoverable Arsenic along with a schedule of compliance has been included based on the results of the most recent Priority Pollutant Scan (PPS).
10. The 7-day average effluent limit for Total Suspended Solids (TSS) has been corrected to show the actual numeric limitation prior to rounding.
11. The required operator license Class III for the facility has been stated in Part III of the permit.
12. The biosolids monitoring requirements have been changed to once per year.
13. A statement has been added to Part I of the permit to allow for effluent flow measurement prior to the final treatment unit.
14. A requirement to develop a Pretreatment Program in accordance with 40 CFR 403 has been included in the draft permit based on the fact that the permittee receives significant industrial process wastewater.

## 17. STORMWATER POLLUTION PREVENTION PLAN REQUIREMENTS.

In lieu of stormwater pollution prevention plan requirements, a No Exposure Certification (Tracking #ARR000293) was submitted. Under the no exposure certification, any discharge of stormwater not in compliance with the No Exposure Certification requirements is a violation of the permit.

## 18. PERMIT COMPLIANCE.

Compliance with final effluent limitations is required by the following schedule:

The permittee shall achieve compliance with the effluent limitations specified for discharges in accordance with the following schedule:

1. Compliance with the interim limits is required on the effective date of the permit.
2. The permittee shall submit progress reports addressing the progress towards attaining the final effluent limits for Total Recoverable Copper according to the following schedule:

# DRAFT

## ACTIVITY

## DUE DATE

Progress Report	One (1) year from effective date
Progress Report	Two (2) years from effective date
Achieve Final Limits	Three (3) years from effective date

The permittee has the option to undertake any study deemed necessary to meet the final limitations during the interim period. Any additional treatment must be approved and construction approval granted prior to final installation.

3. Compliance with the new Pretreatment Program requirements in Condition No. 9 of Part III is required on the effective date of the permit. The initial submittal requirement in Part III.9.B.1 for the Pretreatment Program is due two (2) months from the effective date of the permit.

## 19. MONITORING AND REPORTING.

The applicant is at all times required to monitor the discharge on a regular basis and report the results monthly. The monitoring results will be available to the public.

## 20. SOURCES.

The following sources were used to draft the permit:

- a. NPDES application No. AR0021903 received March 2, 2007.
- b. Arkansas Water Quality Management Plan (WQMP).
- c. APCEC Regulation No. 2.
- d. APCEC Regulation No. 6.
- e. 40 CFR Parts 122, 125, 133 and 403.
- f. NPDES permit file AR0021903.
- g. Discharge Monitoring Reports (DMRs).
- h. "Arkansas Water Quality Inventory Report 2004 (305B)", ADEQ.
- i. Memo from Mo Shafii to NPDES Engineers dated March 28, 2005
- j. "Identification and Classification of Perennial Streams of Arkansas", Arkansas Geological Commission.
- k. Continuing Planning Process (CPP).
- l. Technical Support Document For Water Quality-based Toxic Control.
- m. Region 6 Implementation Guidance for Arkansas Water Quality Standards promulgated at 40 CFR Part 131.36.
- n. Inspection Report dated November 28, 2006.
- o. Email from Sarah Clem to Kim Fuller dated April 12, 2007.
- p. Email from Henry Insua to Kim Fuller dated April 9, 2007.

# DRAFT

Page 23 of Fact Sheet  
Permit Number: AR0021903

## 21. PUBLIC NOTICE.

The public notice describes the procedures for the formulation of final determinations and shall provide for a public comment period of 30 days. During this period, any interested persons may submit written comments on the permit and may request a public hearing to clarify issues involved in the permitting decision. A request for a public hearing shall be in writing and shall state the nature of the issue(s) proposed to be raised in the hearing.

A copy of the permit and public notice will be sent to the District Engineer, Corps of Engineers, and to the Regional Director of the U.S. Fish and Wildlife Service on a case-by-case basis, and the EPA and Arkansas Department of Health prior to the publication of that notice.

## 22. NPDES POINT OF CONTACT.

For additional information, contact:

Kimberly A. Fuller, E.I., CPESC  
NPDES Branch, Water Division  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, Arkansas 72118-5317  
Telephone: (501) 682-0622



**DRAFT**

Permit Number: AR0021903

**AUTHORIZATION TO DISCHARGE WASTEWATER UNDER  
THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM AND  
THE ARKANSAS WATER AND AIR POLLUTION CONTROL ACT**

In accordance with the provisions of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended, Ark. Code Ann. 8-4-101 et seq.), and the Clean Water Act (33 U.S.C. § 1251 et seq.),

The applicant's mailing address is:

City of Wynne  
121 East Merriman Ave  
Wynne, AR 72396

The facility address is:

City of Wynne Wastewater Treatment Plant  
545 Bowden Road  
Wynne, AR 72396

is authorized to discharge from a facility located as follows: Approximately 1.5 miles West of Wynne on Hwy 284 to Bowden Road, in Section 24, Township 7 North, Range 2 East in Cross County, Arkansas.

Latitude: 35° 13' 9"; Longitude: 90° 49' 41"

to receiving waters named:

a drainage ditch, thence to Caney Creek, thence to the L'Anguille River, thence to the St. Francis River in Segment 5B of the St. Francis River Basin.

The outfall is located at the following coordinates:

Outfall 001: Latitude: 35° 13' 07"; Longitude: 90° 49' 52"

Discharge shall be in accordance with effluent limitations, monitoring requirements, and other conditions set forth in Parts I, II, III, and IV hereof.

Issue Date:

Effective Date:

Expiration Date:

---

Steven L. Drown  
Chief, Water Division  
Arkansas Department of Environmental Quality

# DRAFT

## PART I PERMIT REQUIREMENTS

### SECTION A. INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: OUTFALL 001 - Treated Municipal Wastewater.

During the period beginning on the effective date and lasting until three years from the effective date, the permittee is authorized to discharge from Outfall 001. Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow <sup>1</sup>	N/A	Report	Report	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)	276	12	18	three/week	6-hr composite
Total Suspended Solids (TSS)	345	15	22.5	three/week	6-hr composite
Ammonia Nitrogen (NH3-N)					
(Apr)	48	2.1	5.2	three/week	6-hr composite
(May-Oct)	48	2.1	4.5	three/week	6-hr composite
(Nov-Mar)	115	5	7.5	three/week	6-hr composite
Dissolved Oxygen <sup>2</sup>					
(May-Oct)	N/A	7.0 (Monthly Avg. Min.)		three/week	grab
(Nov-Apr)	N/A	6.0 (Monthly Avg. Min.)		three/week	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
	N/A	1000	2000	three/week	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	three/week	grab
Arsenic, Total Recoverable <sup>3,4</sup>	Report	Report, µg/l	Report, µg/l	once/month	24-hr composite
Copper, Total Recoverable <sup>4</sup>	Report	Report, µg/l	Report, µg/l	once/month	24-hr composite
Chronic Biomonitoring <sup>5</sup>	N/A	N/A	N/A	once/quarter	24-hr composite



Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
<b><u>Pimephales promelas (Chronic)</u></b> <sup>4</sup> Pass/Fail Lethality (7-day NOEC) TLP6C Pass/Fail Growth (7-day NOEC) TGP6C Survival (7-day NOEC) TOP6C Coefficient of Variation TQP6C Growth (7-day NOEC) TPP6C  <b><u>Ceriodaphnia dubia (Chronic)</u></b> <sup>4</sup> Pass/Fail Lethality (7-day NOEC) TLP3B Pass/Fail production (7-day NOEC) TGP3B Survival (7-day NOEC) TOP3B Coefficient of Variation TQP3B Reproduction (7-day NOEC) TPP3B			7-Day Average Report (Pass=0/Fail=1) Report (Pass=0/Fail=1) Report % Report % Report %	once/quarter once/quarter once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite 24-hr composite 24-hr composite
			7-Day Average Report (Pass=0/Fail=1) Report (Pass=0/Fail=1) Report % Report % Report %	once/quarter once/quarter once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite 24-hr composite 24-hr composite

- 1 Report monthly average and daily maximum as MGD.
- 2 See item #27(a) of Part IV (Dissolved Oxygen).
- 3 See Condition No. 8 of Part III.
- 4 See Condition No. 12 of Part III (Metals Condition)
- 5 See Condition No. 11 of Part III (Biomonitoring Condition).

There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit except for the flow measurement which shall be taken after the UV system and prior to post-aeration at the monitoring location of 35° 13' 7" Latitude and 90° 49' 48" Longitude.

## PART I PERMIT REQUIREMENTS

### SECTION A. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: OUTFALL 001 - Treated Municipal Wastewater.

During the period beginning on three years from the effective date and lasting until the date of expiration, the permittee is authorized to discharge from Outfall 001. Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow <sup>1</sup>	N/A	Report	Report	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)	276	12	18	three/week	6-hr composite
Total Suspended Solids (TSS)	345	15	22.5	three/week	6-hr composite
Ammonia Nitrogen (NH3-N)					
(Apr)	48	2.1	5.2	three/week	6-hr composite
(May-Oct)	48	2.1	4.5	three/week	6-hr composite
(Nov-Mar)	115	5	7.5	three/week	6-hr composite
Dissolved Oxygen <sup>2</sup>					
(May-Oct)	N/A	7.0 (Monthly Avg. Min.)		three/week	grab
(Nov-Apr)	N/A	6.0 (Monthly Avg. Min.)		three/week	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
	N/A	1000	2000	three/week	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	three/week	grab
Arsenic, Total Recoverable <sup>3, 4</sup>	Report	Report, µg/l	Report, µg/l	once/month	24-hr composite
Copper, Total Recoverable <sup>4</sup>	0.68	29.5 µg/l	59.1 µg/l	once/month	24-hr composite
Chronic Biomonitoring <sup>5</sup>	N/A	N/A	N/A	once/quarter	24-hr composite

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
<b><u>Pimephales promelas (Chronic)</u></b> <sup>4</sup> Pass/Fail Lethality (7-day NOEC) TLP6C Pass/Fail Growth (7-day NOEC) TGP6C Survival (7-day NOEC) TOP6C Coefficient of Variation TQP6C Growth (7-day NOEC) TPP6C  <b><u>Ceriodaphnia dubia (Chronic)</u></b> <sup>4</sup> Pass/Fail Lethality (7-day NOEC) TLP3B Pass/Fail production (7-day NOEC) TGP3B Survival (7-day NOEC) TOP3B Coefficient of Variation TQP3B Reproduction (7-day NOEC) TPP3B			7-Day Average Report (Pass=0/Fail=1) Report (Pass=0/Fail=1) Report % Report % Report %	once/quarter once/quarter once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite 24-hr composite 24-hr composite

- 1 Report monthly average and daily maximum as MGD.
- 2 See item #27(a) of Part IV (Dissolved Oxygen).
- 3 See Condition No. 8 of Part III.
- 4 See Condition No. 12 of Part III (Metal Condition).
- 5 See Condition No. 11 of Part III (Biomonitoring Condition).

There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit except for the flow measurement which shall be taken after the UV system and prior to post-aeration at the monitoring location of 35° 13' 7" Latitude and 90° 49' 48" Longitude.

# DRAFT

## SECTION B. PERMIT COMPLIANCE

The permittee shall achieve compliance with the effluent limitations specified for discharges in accordance with the following schedule:

1. Compliance with the interim limits is required on the effective date of the permit.
2. The permittee shall submit progress reports addressing the progress towards attaining the final effluent limits for Total Recoverable Copper according to the following schedule:

<u>ACTIVITY</u>	<u>DUE DATE</u>
Progress Report	One (1) year from effective date
Progress Report	Two (2) years from effective date
Achieve Final Limits	Three (3) years from effective date

The permittee has the option to undertake any study deemed necessary to meet the final limitations during the interim period. Any additional treatment must be approved and construction approval granted prior to final installation.

3. Compliance with the new Pretreatment Program requirements in Condition No. 9 of Part III is required on the effective date of the permit. The initial submittal requirement in Part III.9.B.1 for the Pretreatment Program is due two (2) months from the effective date of the permit.

## PART II STANDARD CONDITIONS

### SECTION A – GENERAL CONDITIONS

#### 1. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the federal Clean Water Act and the Arkansas Water and Air Pollution Control Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; and/or for denial of a permit renewal application. **Any values reported in the required Discharge Monitoring Report (DMR) which are in excess of an effluent limitation specified in Part I shall constitute evidence of violation of such effluent limitation and of this permit.**

#### 2. Penalties for Violations of Permit Conditions

The Arkansas Water and Air Pollution Control Act provides that any person who violates any provisions of a permit issued under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year, or a fine of not more than ten thousand dollars (\$10,000) or by both such fine and imprisonment for each day of such violation. Any person who violates any provision of a permit issued under the Act may also be subject to civil penalty in such amount as the court shall find appropriate, not to exceed ten thousand dollars (\$10,000) for each day of such violation. The fact that any such violation may constitute a misdemeanor shall not be a bar to the maintenance of such civil action.

#### 3. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause including, but not limited to the following:

- a. Violation of any terms or conditions of this permit; or
- b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
- c. A change in any conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- d. A determination that the permitted activity endangers human health or the environment and can only be regulated to acceptable levels by permit modification or termination.
- e. Failure of the permittee to comply with the provisions of APCEC Regulation No. 9 (Permit fees) as required by Part II.A.10 herein.

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

# DRAFT

Permit Number: AR0021903

Page 2 of Part II

## 4. Toxic Pollutants

Notwithstanding Part II.A.3, if any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under APCEC Regulation No. 2, as amended, or Section 307(a) of the Clean Water Act for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitations on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standards or prohibition and the permittee so notified.

The permittee shall comply with effluent standards, narrative criteria, or prohibitions established under APCEC Regulation No. 2, as amended, or Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

## 5. Civil and Criminal Liability

Except as provided in permit conditions on “Bypassing” (Part II.B.4.a), and “Upsets” (Part II.B.5.b), nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. Any false or materially misleading representation or concealment of information required to be reported by the provisions of this permit or applicable state and federal statutes or regulations which defeats the regulatory purposes of the permit may subject the permittee to criminal enforcement pursuant to the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

## 6. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject to under Section 311 of the Clean Water Act.

## 7. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law or regulation under authority preserved by Section 510 of the Clean Water Act.

# DRAFT

Permit Number: AR0021903

Page 3 of Part II

## 8. Property Rights

The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State, or local laws or regulations.

## 9. Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provisions of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

## 10. Permit Fees

The permittee shall comply with all applicable permit fee requirements for wastewater discharge permits as described in APCEC Regulation No. 9 (Regulation for the Fee System for Environmental Permits). Failure to promptly remit all required fees shall be grounds for the Director to initiate action to terminate this permit under the provisions of 40 CFR Parts 122.64 and 124.5(d), as adopted in APCEC Regulation No. 6 and the provisions of APCEC Regulation No. 8.

## SECTION B – OPERATION AND MAINTENANCE OF POLLUTION CONTROLS

### 1. Proper Operation and Maintenance

- a. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
- b. The permittee shall provide an adequate operating staff which is duly qualified to carryout operation, maintenance, and testing functions required to insure compliance with the conditions of this permit.

### 2. Need to Halt or Reduce not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the



# DRAFT

Permit Number: AR0021903

Page 4 of Part II

conditions of this permit. Upon reduction, loss, or failure of the treatment facility, the permittee shall, to the extent necessary to maintain compliance with its permit, control production or discharges or both until the facility is restored or an alternative method of treatment is provided. This requirement applies, for example, when the primary source of power for the treatment facility is reduced, is lost, or alternate power supply fails.

### 3. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment or the water receiving the discharge.

### 4. Bypass of Treatment Facilities

#### a. Bypass not exceeding limitation

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts II.B.4.b and 4.c.

#### b. Notice

- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
- (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Part II.D.6 (24-hour notice).

#### c. Prohibition of bypass

- (1) Bypass is prohibited and the Director may take enforcement action against a permittee for bypass, unless:
  - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
  - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if the permittee could have installed adequate backup equipment to prevent a bypass which occurred during normal or preventive maintenance; and
  - (c) The permittee submitted notices as required by Part II.B.4.b.
- (2) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in Part II.B.4.c.(1).



## 5. Upset Conditions

- a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Part II.B.5.b of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- b. Conditions necessary for demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (1) An upset occurred and that the permittee can identify the specific cause(s) of the upset;
  - (2) The permitted facility was at the time being properly operated.
  - (3) The permittee submitted notice of the upset as required by Part II.D.6; and
  - (4) The permittee complied with any remedial measures required by Part II.B.3.
- c. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

## 6. Removed Substances

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of waste waters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering the waters of the State. Written approval must be obtained from the ADEQ for land application only.

## 7. Power Failure

The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failure either by means of alternate power sources, standby generators, or retention of inadequately treated effluent.

## SECTION C – MONITORING AND RECORDS

### 1. Representative Sampling

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points shall not be changed without notification to and the approval of the Director. Intermittent discharges shall be monitored.

## 2. Flow Measurement

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to insure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure the accuracy of the measurements are consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than +/-10% from true discharge rates throughout the range of expected discharge volumes and shall be installed at the monitoring point of the discharge.

## 3. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals frequent enough to insure accuracy of measurements and shall insure that both calibration and maintenance activities will be conducted. An adequate analytical quality control program, including the analysis of sufficient standards, spikes, and duplicate samples to insure the accuracy of all required analytical results shall be maintained by the permittee or designated commercial laboratory. At a minimum, spikes and duplicate samples are to be analyzed on 10% of the samples.

## 4. Penalties for Tampering

The Arkansas Water and Air Pollution Control Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year or a fine of not more than ten thousand dollars (\$10,000) or by both such fine and imprisonment.

## 5. Reporting of Monitoring Results

Monitoring results must be reported on a Discharge Monitoring Report (DMR) form (EPA No. 3320-1). Permittees are required to use preprinted DMR forms provided by ADEQ, unless specific written authorization to use other reporting forms is obtained from ADEQ. Monitoring results obtained during the previous calendar month shall be summarized and reported on a DMR form postmarked no later than the 25<sup>th</sup> day of the month following the completed reporting period to begin on the effective date of the permit. Duplicate copies of DMR forms signed and certified as required by Part II.D.11 and all other reports required by Part II.D, shall be submitted to the Director at the following address:

# DRAFT

Permit Number: AR0021903  
Page 7 of Part II

NPDES Enforcement Section  
Water Division  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

If permittee uses outside laboratory facilities for sampling and/or analysis, the name and address of the contract laboratory shall be included on the DMR.

## 6. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR. Such increased frequency shall also be indicated on the DMR.

## 7. Retention of Records

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of the Director at any time.

## 8. Record Contents

Records and monitoring information shall include:

- a. The date, exact place, time and methods of sampling or measurements, and preservatives used, if any;
- b. The individuals(s) who performed the sampling or measurements;
- c. The date(s) and time analyses were performed;
- d. The individual(s) who performed the analyses;
- e. The analytical techniques or methods used; and
- f. The measurements and results of such analyses.

## 9. Inspection and Entry

The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;

# DRAFT

Permit Number: AR0021903

Page 8 of Part II

- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, and
- d. Sample, inspect, or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

## SECTION D – REPORTING REQUIREMENTS

### 1. Planned Changes

The permittee shall give notice and provide plans and specification to the Director for review and approval prior to any planned physical alterations or additions to the permitted facility. Notice is required only when:

#### *For Industrial Dischargers*

- a. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR Part 122.29(b).
- b. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR Part 122.42(a)(1).

#### *For POTW Dischargers:*

Any change in the facility discharge (including the introduction of any new source or significant discharge or significant changes in the quantity or quality of existing discharges of pollutants) must be reported to the permitting authority. In no case are any new connections, increased flows, or significant changes in influent quality permitted that cause violation of the effluent limitations specified herein.

### 2. Anticipated Noncompliance

The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

### 3. Transfers

The permit is nontransferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act.

#### 4. Monitoring Reports

Monitoring results shall be reported at the intervals and in the form specified in Part II.C.5. **Discharge Monitoring Reports must be submitted even when no discharge occurs during the reporting period.**

#### 5. Compliance Schedule

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date. Any reports of noncompliance shall include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirement.

#### 6. Twenty-four Hour Report

- a. The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain the following information:
  - (1) a description of the noncompliance and its cause;
  - (2) the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and
  - (3) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
- b. The following shall be included as information which must be reported within 24 hours:
  - (1) Any unanticipated bypass which exceeds any effluent limitation in the permit;
  - (2) Any upset which exceeds any effluent limitation in the permit; and
  - (3) Any violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in Part I of the permit to be reported within 24 hours to the Enforcement Section of the Water Division of the ADEQ.
- c. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours to the Enforcement Section of the Water Division of the ADEQ.

#### 7. Other Noncompliance

The permittee shall report all instances of noncompliance not reported under Parts II.D.4, 5, and 6, at the time monitoring reports are submitted. The reports shall contain the information listed at Part II.D.6.

## **8. Changes in Discharge of Toxic Substances for Industrial Dischargers**

The permittee shall notify the Director as soon as he/she knows or has reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the “notification levels” described in 40 CFR Part 122.42(a)(1); or
- b. That any activity has occurred or will occur which would result in any discharge on a non-routine or infrequent basis of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the “notification levels” described in 40 CFR Part 122.42(a)(2).

## **9. Duty to Provide Information**

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit. Information shall be submitted in the form, manner and time frame requested by the Director.

## **10. Duty to reapply**

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The complete application shall be submitted at least 180 days before the expiration date of this permit. The Director may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date. Continuation of expiring permits shall be governed by regulations promulgated in APCEC Regulation No. 6.

## **11. Signatory Requirements**

All applications, reports, or information submitted to the Director shall be signed and certified as follows:

- a. All **permit applications** shall be signed as follows:
  - (1) For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
    - (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or

- (ii) The manager of one or more manufacturing, production, or operation facilities, provided: The manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
- (2) For a partnership or sole proprietorship: By a general partner or proprietor, respectively; or
- (3) For a municipality, State, Federal, or other public agency, by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes:
  - (i) The chief executive officer of the agency, or
  - (ii) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.
- b. All **reports** required by the permit and **other information** requested by the Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - (1) The authorization is made in writing by a person described above.
  - (2) The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility. (A duly authorized representative may thus be either a named individual or any individual occupying a named position); and
  - (3) The written authorization is submitted to the Director.
- c. Certification. Any person signing a document under this section shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

## 12. Availability of Reports

Except for data determined to be confidential under 40 CFR Part 2 and APCEC Regulation No. 6, all reports prepared in accordance with the terms of this permit shall be available for

# DRAFT

Permit Number: AR0021903

Page 12 of Part II

public inspection at the offices of the Department of Environmental Quality. As required by the Regulations, the name and address of any permit applicant or permittee, permit applications, permits, and effluent data shall not be considered confidential.

### **13. Penalties for Falsification of Reports**

The Arkansas Air and Water Pollution Control Act provides that any person who knowingly makes any false statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under this permit shall be subject to civil penalties specified in Part II.A.2 and/or criminal penalties under the authority of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).



## PART III OTHER CONDITIONS

1. The operator of this wastewater treatment facility shall be licensed as Class III by the State of Arkansas in accordance with Act 211 of 1971, Act 1103 of 1991, Act 556 of 1993, and APCEC Regulation No. 3, as amended.
2. For publicly owned treatment works, the 30-day average percent removal for Carbonaceous Biochemical Oxygen Demand (CBOD5) and Total Suspended Solids shall not be less than 85 percent unless otherwise authorized by the permitting authority in accordance with 40 CFR Part 133.102, as adopted by reference in APCEC Regulation No. 6.
3. Produced sludge shall be disposed of by land application only when meeting the following criteria:
  - a. Sewage sludge from treatment works treating domestic sewage (TWTDS) must meet the applicable provisions of 40 CFR Part 503; and
  - b. The sewage sludge has not been classified as a hazardous waste under state or federal regulations.
4. The permittee shall give at least 120 days prior notice to the Director of any change planned in the permittee's sludge disposal practice or land use applications, including types of crops grown (if applicable).
5. The permittee shall report all overflows with the Discharge Monitoring Report (DMR) submittal. These reports shall be summarized and reported in tabular format. The summaries shall include: The date, time, duration, location, estimated volume, and cause of overflow; observed environmental impacts from the overflow; action taken to address the overflow; and ultimate discharge location if not contained (e.g., storm sewer system, ditch, tributary). All overflows which endanger health or the environment shall be orally reported to this department (Enforcement Section of the Water Division), within 24 hours from the time the permittee becomes aware of the circumstance. A written report of overflows which endanger health or the environment, shall be provided within 5 days of the time the permittee becomes aware of the circumstance.
6. In accordance with 40 CFR Parts 122.62(a)(2) and 124.5, this permit may be reopened for modification or revocation and/or reissuance to require additional monitoring and/or effluent limitations when new information is received that actual or potential exceedance of State water quality criteria and/or narrative criteria are determined to be the result of the permittee's discharge(s) to a relevant water body or a Total Maximum Daily Load (TMDL) is established or revised for the water body that was not available at the time of

# DRAFT

Permit Number: AR0021903

Page 2 of Part III

the permit issuance that would have justified the application of different permit conditions at the time of permit issuance.

## 7. Other Specified Monitoring Requirements

The permittee may use alternative appropriate monitoring methods and analytical instruments other than as specified in Part I Section A of the permit without a major permit modification under the following conditions:

- The monitoring and analytical instruments are consistent with accepted scientific practices;
- The requests shall be submitted in writing to the NPDES Section of the Water Division of the ADEQ for use of the alternate method or instrument.
- The method and/or instrument is in compliance with 40 CFR Part 136 or acceptable to the Director; and
- All associated devices are installed, calibrated, and maintained to insure the accuracy of the measurements and are consistent with the accepted capability of that type of device. The calibration and maintenance shall be performed as part of the permittee's laboratory Quality Control/Quality Assurance program.

Upon written approval of the alternative monitoring method and/or analytical instruments, these methods or instruments must be consistently utilized throughout the monitoring period. ADEQ must be notified in writing and the permittee must receive written approval from ADEQ if the permittee decides to return to the original permit monitoring requirements.

8. The permittee may request the removal of the monthly Arsenic sampling requirement after four (4) consecutive monthly samples confirm that the concentrations of Arsenic are below levels of concern, i.e., 0.65 µg/l.

## 9. Contributing Industries and Pretreatment Requirements

A. The following pollutants may not be introduced into the treatment facility:

1. Pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, waste streams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21;
2. Pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0, unless the works are specifically designed to accommodate such discharges;

# DRAFT

Permit Number: AR0021903

Page 3 of Part III

3. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, resulting in Interference;
  4. Any pollutant, including oxygen demanding pollutants (BOD, etc.), released in a discharge at a flow rate and/or pollutant concentration which will cause interference with the POTW;
  5. Heat in amounts which will inhibit biological activity in the POTW resulting in Interference, but in no case heat in such quantities that the temperature at the POTW treatment plant exceeds 40 degrees Centigrade (104 degrees Fahrenheit) unless the Department, upon request of the POTW, approves the alternate temperature limit;
  6. Petroleum oil, non-biodegradable cutting oil, or products of mineral origin in amounts that will cause interference or pass through;
  7. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems; and,
  8. Any trucked or hauled pollutants, except at discharge points designated by the POTW.
- B. The permittee shall comply with the pretreatment requirements in 40 CFR 403, as specified in the following schedule of compliance. The final approvable package is due 12 months from the effective date of the permit.

ACTIVITY  
NUMBER

ACTIVITY

DATE

- |    |   |  |
|----|---|--|
| 1. | Submit to the Department results of an industrial user survey which consists of a qualitative analysis of pollutants being contributed by all industrial sources in its entire municipal system (including all treatment plants). The industrial users should be asked to provide information on the type and approximate quantity of pollutants discharged into the system. This information may be derived from knowledge of the facility's process, and should not require any sampling at the source. | 2 months from the effective date of the permit |
|----|---|--|

(Unless the Department notifies the permittee otherwise within 30 days after receipt of this survey, the permittee will be required to continue the program past Activity No. 1. If notified that a pretreatment program is not necessary, the permittee will submit to the Department an update of its industrial user survey,

# DRAFT

Permit Number: AR0021903  
Page 4 of Part III

<u>ACTIVITY NUMBER</u>	<u>ACTIVITY</u>	<u>DATE</u>
	documenting changes in industrial flow and/or characteristics and new contributing industries when next reapplying for this NPDES permit.)	
2.	Submit to the Department a design of a sampling, inspection and reporting program which will implement the requirements of 40 CFR 403.8 and 403.12, and in particular those requirements referenced in 40 CFR 403.8(f)(1)(iv-v), 403.8(f)(2)(iv-vi) and 403.12(g-j and l-p).	4 months from the effective date of the permit
3.	Submit to the Department an evaluation of the financial programs, revenue sources, equipment and staffing, which will be employed to implement the pretreatment program (as required by 40 CFR Parts 403.8(f)(3) and 403.9(b)(3)).	6 months from the effective date of the permit
4.	Submit to the Department the results of an influent pollutant scan of a 24-hour composite sample to determine all pollutants being contributed to the system. The type of scan to be performed is the basic priority pollutant scan of the 126 "priority pollutants" plus any other additional pollutants designated in your State Water Quality Standards. All sampling, analyses, and method detection limits must be done in accordance with 40 CFR Part 136. This scan will also serve as the initial scan necessary for developing technically based local limits (Activity 5 as follows).  a) From the qualitative information supplied by the industrial users in Activity 1 and the quantitative information collected in the pollutant scan, the permittee shall determine which industrial users may be discharging pollutants which may affect the operation of the POTW(s) or pass through untreated.  b) Sampling and analysis to quantify the pollutants discharged by the industrial users, identified in the investigation of (a) above, shall be completed.	6 months from the effective date of the permit

# DRAFT

<u>ACTIVITY NUMBER</u>	<u>ACTIVITY</u>	<u>DATE</u>
5.	Submit to the Department an approvable technically based local limits submission package as required by 40 CFR 403.8(f)(4). Technically based local limits should be developed in accordance with <i>EPA Region 6 Technically Based Local Limits Development Guidance</i> .	9 months from the effective date of the permit
6.	40 CFR 403.8(f)(1) requires POTWs to apply and enforce the requirements of Sections 307(b) and (c), and 402(b)(8) of the Act and any regulations implementing those sections. Submit to the Department:  a) a statement from the city solicitor, a city official acting in a comparable capacity, or the city's independent counsel, that the POTW has the authority to carry out the program;  b) a copy of any statute, ordinance, regulation, contract, agreement, or other authority that will be relied on by the POTW to administer the program;  c) a statement reflecting the endorsement of or approval by the local boards or bodies responsible for supervising and/or funding the program;  d) any additional documents required in multi-jurisdictional situations for administration of the program; and,  e) an enforcement response plan that shall contain detailed procedures indicating how the POTW will investigate and respond to instances of industrial user noncompliance. The plan shall contain, at a minimum, the aspects defined at 40 CFR 403.8(f)(5).	10 months from the effective date of the permit
7.	Submit to the Department an approvable pretreatment program (and removal credit approval, if desired and appropriate) as required by 40 CFR 403.9. The approvable pretreatment program shall include a compilation of all previously submitted pretreatment program activities as finally amended and supplemented (i.e. Activities 1-6).	12 months from the effective date of the permit

Upon notification by the Department of approvability of the submitted program, the permittee is required to submit an official

# DRAFT

Permit Number: AR0021903  
Page 6 of Part III

ACTIVITY  
NUMBER

ACTIVITY

DATE

request for program approval, including three (3) copies of the program deemed to be approvable.

- C. If the permittee does not comply with any of the increments of the progress in the above schedule, the permittee shall submit to Department within 14 days of the activity due date a report, including, at a minimum, the date on which the required activity will be submitted, the reason for the delay, and the steps taken to return to the established schedule.
- D. Upon approval of a local pretreatment program by the Department, this permit will be modified, or, alternatively, revoked and reissued to incorporate that pretreatment program.
- E. The permittee may develop and submit an approvable pretreatment program at any time before the deadline established in Activity 7.
- F. The permittee may apply for authority to revise categorical pretreatment standards to reflect POTW removal of pollutants in accordance with the requirements of 40 CFR 403.7 at any time.
- G. The permittee shall require any indirect discharger to the treatment works to comply with the reporting requirements of Sections 204(b), 307, and 308 of the Act, including any requirements established under 40 CFR Part 403.
- H. The permittee shall provide adequate notice to the Department of the following:
  - 1. Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 and 306 of the Act if it were directly discharging those pollutants; and
  - 2. Any substantial change in the volume or character of pollutants being introduced into the treatment works.

Adequate notice shall include information on (i) the quality and quantity of effluent to be introduced into the treatment works, and (ii) any anticipated impact of such change in the quality or quantity of effluent to be discharged from the publicly owned treatment works.

## 10. ADDITIONAL CONDITIONS FOR LAND APPLICATION OF BIOSOLIDS

The sludge produced at the treatment plant will be disposed at the following location(s):

Field No.	Section	Township	Range	Total Acres
1	24	7 North	2 East	30
2	24	7 North	2 East	10

### A. GENERAL REQUIREMENTS:

1. Only biosolids which are not classified as a hazardous waste under state or federal regulations may be land applied.
2. Plant Available Nitrogen (PAN) will not be applied at a rate exceeding the annual nitrogen uptake of the crop. At no time will the nitrogen application rate (PAN/acre-year) be allowed to exceed the site specific rate approved by the Department.
3. Biosolids with Polychlorinated Biphenyls (PCB's) concentrations equal or greater than 50 mg/kg (dry basis) will not be land applied at any time.
4. CEILING CONCENTRATIONS (milligrams per kilogram, dry weight basis): If the biosolids to be land applied exceed any of the pollutant concentrations listed in **Table 1** below, the biosolids shall not be land applied.

Element	Concentration (mg/kg)
Arsenic	75
Cadmium	85
Chromium	*
Copper	4,300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
Selenium	100
Zinc	7,500

\* This value is being reevaluated by US EPA

5. **POLLUTANTS LIMITS:** When bulk biosolids are applied to agricultural land, forest, a public contact site, or reclamation site, the permittee shall not exceed the Cumulative Pollutant Loading Rate values listed in **Table 2**, or the Pollutant Concentration values listed in **Table 3**.

<b>TABLE 2</b>		
<b>Element</b>	<b>Cumulative Pollutant Loading Rate</b>	
	<b>Kg/ha</b>	<b>lbs/ac</b>
Arsenic	41	37
Cadmium	39	35
Chromium	*	*
Copper	1,500	1,350
Lead	300	270
Mercury	17	15
Molybdenum	*	*
Nickel	420	378
Selenium	100	90
Zinc	2,800	2,520

\*These values are being reevaluated by US EPA.

<b>TABLE 3</b>	
<b>Element</b>	<b>Monthly Average Concentration (mg/kg)</b>
<b>Arsenic</b>	41
Cadmium	39
Chromium	*
Copper	1,500
Lead	300
Mercury	17
Molybdenum	*
Nickel	420
Selenium	36
Zinc	2,800

\*These values are being reevaluated by US EPA.

6. The biosolids generator must issue a signed certification stating that the Pathogen Reduction, Vector Attraction Reduction, and Pollutant Concentration Limits have been met. The State requirements on Pathogen



Reduction, Vector Attraction Reduction, and Pollutant Concentration Limits are the same as those listed in 40 CFR Part 503. All the above information must be made available to the land-applicator before the biosolids materials are delivered. Concurrently, a signed copy of each certification must be also submitted to the ADEQ Water Division.

7. Biosolids can only be stored in accordance with the permit and the approved waste management plan, if provisions are made in the plan for that purpose. The utilization of improvised field storage sites or any other site not approved by the Department is strictly prohibited.
8. Transportation of the biosolids must be such that will prevent the attraction, harborage or breeding of insects or rodents. It must not produce conditions harmful to public health, the environment, odors, unsightliness, nuisances, or safety hazards.
9. The containers used for the transportation of the biosolids must be of the closed type. Transportation equipment must be leak-proof and kept in a top sanitary condition at all times. Biosolids must be enclosed or covered as to prevent littering, vector attraction, or any other nuisances.
10. The permittee will be responsible for assuring that the land owner, of any land application site not owned by the permittee, and the waste applicator, if different from the permittee, abide by the conditions of this permit.
11. Biosolids will be spread evenly over the application area and in no way biosolids will be allowed to enter the waters of the State.
12. Biosolids will not be applied to slopes with a gradient greater than 15%; or to soils that are saturated, frozen or covered with snow, during rain, or when precipitation is imminent.
13. The permittee will not cause any underground drinking water source to exceed the limitations in 40 CFR Part 257, Appendix I.
14. The permittee will not cause or contribute to the taking of life or the destruction or adverse modification of the critical habitat of any known endangered or threatened species of plant, fish or wildlife.
15. The permittee will take all necessary measures to reduce obnoxious and offensive odors. Equipment will be maintained and operated to prevent spillage and leakage.

16. Disposal of wastewater biosolids in a flood plain will not restrict the flow of the base flood, reduce the temporary storage capacity of the flood plain, or result in a washout of solid waste, so as to pose a hazard to human life, wildlife or land and water uses.
17. Biosolids will not be spread within 50 feet of rock outcrops and property lines; 100 feet of lakes, ponds, springs, streams, wetlands and sinkholes; 200 feet of drinking water wells; 300 feet of occupied buildings and streams classified as an "extraordinary resource water body."
18. All new land application sites must have a waste management plan approved by the Department prior to land application of wastewater biosolids. This change normally requires a permit modification.

**B. MONITORING AND REPORTING REQUIREMENTS:**

1. The permittee will be responsible for the biosolids analyses, soil analyses, and a reporting schedule that must include the following:

a. Biosolids Analysis

- (1) Biosolids samples collected must be representative of the treated biosolids to be land applied. The samples are to be stored in appropriate containers and kept refrigerated or frozen to prevent any change in composition.
- (2) An annual representative sample of the land-applied biosolids will be analyzed and results expressed in dry basis in mg/kg, except as otherwise indicated:

Volatile Solids(%)	Total Kjeldahl Nitrogen
Total Solids(%)	Total Phosphorus
Nitrate +Nitrate Nitrogen	Total Potassium
Ammonia Nitrogen	Arsenic
Cadmium	Copper
Lead	Mercury
Nickel	Selenium
Zinc	pH (SU)

- (3) Soils Analysis

Each land application site will be soil tested in the Spring prior to application for the following parameters:

- Nitrate-Nitrogen
- Phosphorus
- Arsenic
- Copper
- Mercury
- Selenium
- pH
- Cation Exchange Capacity (me/100g)
- Salt Content (micro-mohs/cm)
- Potassium
- Magnesium
- Cadmium
- Lead
- Nickel
- Zinc

b. Reporting

- (1) Annual reports will be sent to the Department and to the owner of the land receiving biosolids prior to May 1, which must include the following:

The biosolids and soil analyses conducted under section a. above (including a statement that the analyses were performed in accordance with EPA Document SW-846, "Test Methods for Evaluation of Solid Waste," or other procedures approved by the Director), application dates and locations, volumes of biosolids applied (in dry tons/acre-year and gallons/acre-year of biosolids), methods of disposal, identity of hauler, and type of crop grown, amounts of nitrogen applied, total elements added that year (lbs/acre), total elements applied to date, and copies of soil analyses for each site.

- (2) The permittee will also maintain copies of the above records for Department personnel review at the biosolids generating facility.

11. WHOLE EFFLUENT TOXICITY TESTING (7-DAY CHRONIC NOEC FRESHWATER)

1. SCOPE AND METHODOLOGY

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL:

CRITICAL DILUTION (%): 100%

# DRAFT

Permit Number: AR0021903  
Page 12 of Part III

EFFLUENT DILUTION SERIES (%): 32%, 42%, 56%, 75%, & 100%

COMPOSITE SAMPLE TYPE: Defined at Part I

TEST SPECIES/METHODS: 40 CFR Part 136

Ceriodaphnia dubia chronic static renewal survival and reproduction test, Method 1002.0, EPA/600/4-91/002 or the most recent update thereof. This test should be terminated when 60% of the surviving females in the control produce three broods or at the end of eight days, whichever comes first.

Pimephales promelas (fathead minnow) chronic static renewal 7-day larval survival and growth test, Method 1000.0, EPA/600/4-91/002, or the most recent update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Effect Concentration) is defined as the greatest effluent dilution at and below which lethality that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Chronic lethal test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.
  - c. This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.
  - d. Test failure is defined as a demonstration of statistically significant sub-lethal or lethal effects to a test species at or below the effluent critical dilution.
2. PERSISTENT LETHALITY: The requirements of this subsection apply only when a toxicity test demonstrates significant lethal effects at or below the critical dilution. Significant lethal effects are herein defined as a statistically significant difference at the 95% confidence level between the survival of the appropriate test organism in a specified effluent dilution and the control (0% effluent).
- a. Part I Testing Frequency Other Than Monthly

- i. The permittee shall conduct a total of two (2) additional tests for any species that demonstrates significant lethal effects at or below the critical dilution. The two additional tests shall be conducted monthly during the next two consecutive months. The permittee shall not substitute either of the two additional tests in lieu of routine toxicity testing. The full report shall be prepared for each test required by this section in accordance with procedures outlined in Item 5 of this section and submitted with the period DMR to the permitting authority for review.
- ii. If one or both of the two additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall initiate Toxicity Reduction Evaluation (TRE) requirements as specified in Item 7 of this section. The permittee shall notify ADEQ in writing within 5 days of the failure of any retest, and the TRE initiation date will be the test completion date of the first failed retest. A TRE may be also be required due to a demonstration of persistent significant sub-lethal effects or intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests. Monthly retesting is not required if the permittee is performing a TRE.
- iii. If one or both of the two additional tests demonstrates significant lethal effects at or below the critical dilution, the permittee shall henceforth increase the frequency of testing for this species to once per quarter for the life of the permit.
- iv. The provisions of Item 2.a are suspended upon submittal of the TRE Action Plan.

b. Part I Testing Frequency of Monthly

The permittee shall initiate the Toxicity Reduction Evaluation (TRE) requirements as specified in Item 7 of this section when any two of three consecutive monthly toxicity tests exhibit significant lethal effects at or below the critical dilution. A TRE may be also be required due to a demonstration of persistent significant sub-lethal effects or intermittent lethal effects at or below the critical dilution, or for failure to perform the required retests.

3. SUB-LETHAL FAILURES: If a statistically significant sub-lethal effect is demonstrated at or below the critical dilution during any quarterly test, the permittee shall conduct two additional tests. The additional tests shall be

conducted monthly during the next two consecutive months. The permittee shall not substitute either of the two additional in lieu of routine toxicity testing.

If during the first four quarters, statistically significant sub-lethal effects are exhibited, quarterly testing will be required for that species until the effluent passes both the lethal and sub-lethal tests endpoints for the affected species, for four consecutive quarters. After passing four consecutive quarters for the affected species the permittee may request a reduction in testing frequency. Monthly retesting is not required if the permittee is performing a TRE.

#### 4. REQUIRED TOXICITY TESTING CONDITIONS

##### a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- i. The toxicity test control (0% effluent) must have survival equal to or greater than 80%.
- ii. The mean number of Ceriodaphnia dubia neonates produced per surviving female in the control (0% effluent) must be 15 or more.
- iii. 60% of the surviving control females must produce three broods.
- iv. The mean dry weight of surviving fathead minnow larvae at the end of the 7 days in the control (0% effluent) must be 0.25 mg per larva or greater.
- v. The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for: the young of surviving females in the Ceriodaphnia dubia reproduction test; the growth and survival endpoints of the fathead minnow test.
- vi. The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal or nonlethal effects are exhibited for: the young of surviving females in the Ceriodaphnia dubia reproduction test; the growth and survival endpoints of the fathead minnow test.

Test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%. A repeat test shall be

conducted within the required reporting period of any test determined to be invalid.

b. Statistical Interpretation

- i. For the Ceriodaphnia dubia survival test, the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be Fisher's Exact Test as described in EPA/600/4-91/002 or the most recent update thereof.
- ii. For the Ceriodaphnia dubia reproduction test and the fathead minnow larval survival and growth test, the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA/600/4-91/002 or the most recent update thereof.
- iii. If the conditions of Test Acceptability are met in Item 4.a above and the percent survival of the test organism is equal to or greater than 80% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report an NOEC of not less than the critical dilution for the DMR reporting requirements found in Item 5 below.

c. Dilution Water

- i. Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness, and alkalinity to the closest downstream perennial water for;
  - (A) toxicity tests conducted on effluent discharges to receiving water classified as intermittent streams; and
  - (B) toxicity tests conducted on effluent discharges where no receiving water is available due to zero flow conditions.
- ii. If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 4.a), the permittee may substitute synthetic dilution water for the receiving

water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:

- (A) a synthetic dilution water control which fulfills the test acceptance requirements of Item 3.a was run concurrently with the receiving water control;
- (B) the test indicating receiving water toxicity has been carried out to completion (i.e., 7 days);
- (C) the permittee includes all test results indicating receiving water toxicity with the full report and information required by Item 5 below; and
- (D) the synthetic dilution water shall have a pH, hardness, and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

- i. The permittee shall collect a minimum of three flow-weighted composite samples from the outfall(s) listed at Item 1.a above.
- ii. The permittee shall collect second and third composite samples for use during 24-hour renewals of each dilution concentration for each test. The permittee must collect the composite samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on an intermittent basis.
- iii. The permittee must collect the composite samples so that the maximum holding time for any effluent sample shall not exceed 72 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first composite sample. Samples shall be chilled to 4 degrees Centigrade during collection, shipping, and/or storage.
- iv. If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must collect an effluent



composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days if the discharge occurs over multiple days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 5 of this section.

- v. MULTIPLE OUTFALLS: If the provisions of this section are applicable to multiple outfalls, the permittee shall combine the composite effluent samples in proportion to the average flow from the outfalls listed in Item 1.a above for the day the sample was collected. The permittee shall perform the toxicity test on the flow-weighted composite of the outfall samples.
- vi. The permittee shall not allow the sample to be dechlorinated at the laboratory. At the time of sample collection the permittee shall measure the TRC of the effluent. The measured concentration of TRC for each sample shall be included in the lab report submitted by the permittee.

## 5. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this section in accordance with the Report Preparation Section of EPA/600/4-91/002, or the most current publication, for every valid or invalid toxicity test initiated whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of Part II.C.7 of this permit. The permittee shall submit full reports to the Department. For any test which fails, is considered invalid or which is terminated early for any reason, the full report must be submitted for review.
- b. A valid test for each species must be reported on the DMR during each reporting period specified in Part I of this permit unless the permittee is performing a TRE which may increase the frequency of testing and reporting. Only ONE set of biomonitoring data for each species is to be recorded on the DMR for each reporting period. The data submitted should reflect the LOWEST survival results for each species during the reporting period. All invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached to the DMR for ADEQ review.

- c. The permittee shall submit the results of each valid toxicity test on DMR for that reporting period in accordance with Part II.D.4 of this permit, as follows below. Submit retest information clearly marked as such with the following DMR. Only results of valid tests are to be reported on the DMR.
- i. Pimephales promelas (fathead minnow)
- (A) If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TLP6C.
  - (B) If the NOEC for growth is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TGP6C.
  - (C) Report the NOEC value for survival, Parameter No. TOP6C.
  - (D) Report the NOEC value for growth, Parameter No. TPP6C.
  - (E) Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQP6C.
- ii. Ceriodaphnia dubia
- (A) If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TLP3B.
  - (B) If the NOEC for reproduction is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TGP3B.
  - (C) Report the NOEC value for survival, Parameter No. TOP3B.
  - (D) Report the NOEC value for reproduction, Parameter No. TPP3B.
  - (E) Report the higher (critical dilution or control) Coefficient of Variation, Parameter No. TQP3B.

## 6. Monitoring Frequency Reduction

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first four consecutive quarters of testing for one or both test species, with no lethal or sub-lethal effects demonstrated at or below the critical dilution without a major modification. If granted, the monitoring frequency for that test species may be reduced to not less than once per year for the less sensitive species (usually the fathead minnow) and not less than twice per year for the more sensitive test species (usually the Ceriodaphnia dubia).
- b. CERTIFICATION - The permittee must certify in writing that no test failures have occurred and that all tests meet all test acceptability criteria in Item 4.a above. In addition the permittee must provide a list with each test performed including test initiation date, species, NOECs for lethal and sub-lethal effects and the maximum coefficient of variation for the controls. Upon review and acceptance of this information the Department will issue a letter of confirmation of the monitoring frequency reduction. A copy of the letter will be forwarded to the Permit Compliance System section to update the permit reporting requirements.
- c. This monitoring frequency reduction applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to once per quarter until the permit is re-issued.

## 7. TOXICITY REDUCTION EVALUATION (TRE)

- a. Within ninety (90) days of confirming lethality in the retests, the permittee shall submit a Toxicity Reduction Evaluation (TRE) Action Plan and Schedule for conducting a TRE. The TRE Action Plan shall specify the approach and methodology to be used in performing the TRE. A Toxicity Reduction Evaluation is an investigation intended to determine those actions necessary to achieve compliance with water quality-based effluent limits by reducing an effluent's toxicity to an acceptable level. A TRE is defined as a step-wise process which combines toxicity testing and analyses of the physical and chemical characteristics of a toxic effluent to identify the constituents causing effluent toxicity and/or treatment methods which will reduce the effluent toxicity. The TRE Action Plan shall lead to the successful elimination of effluent toxicity at the critical dilution and include the following:
  - i. Specific Activities. The plan shall detail the specific approach the permittee intends to utilize in conducting the TRE. The approach may include toxicity characterizations, identifications and

confirmation activities, source evaluation, treatability studies, or alternative approaches. When the permittee conducts Toxicity Characterization Procedures the permittee shall perform multiple characterizations and follow the procedures specified in the documents "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures" (EPA-600/6-91/003) and "Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I" (EPA-600/6-91/005F), or alternate procedures. When the permittee conducts Toxicity Identification Evaluations and Confirmations, the permittee shall perform multiple identifications and follow the methods specified in the documents "Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081), as appropriate.

The documents referenced above may be obtained through the National Technical Information Service (NTIS) by phone at (800) 553-6847, or by writing:

U.S. Department of Commerce  
National Technical Information Service  
5285 Port Royal Road  
Springfield, VA 22161

- ii. Sampling Plan (e.g., locations, methods, holding times, chain of custody, preservation, etc.). The effluent sample volume collected for all tests shall be adequate to perform the toxicity test, toxicity characterization, identification and confirmation procedures, and conduct chemical specific analyses when a probable toxicant has been identified;

Where the permittee has identified or suspects specific pollutant(s) and/or source(s) of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical specific analyses for the identified and/or suspected pollutant(s) and/or source(s) of effluent toxicity. Where lethality was demonstrated within 48 hours of test initiation, each composite sample shall be analyzed independently. Otherwise the permittee may substitute a composite sample, comprised of equal portions of the individual composite samples, for the chemical specific analysis;

- iii. Quality Assurance Plan (e.g., QA/QC implementation, corrective actions, etc.); and
  - iv. Project Organization (e.g., project staff, project manager, consulting services, etc.).
- b. The permittee shall initiate the TRE Action Plan within thirty (30) days of plan and schedule submittal. The permittee shall assume all risks for failure to achieve the required toxicity reduction.
  - c. The permittee shall submit a quarterly TRE Activities Report, with the Discharge Monitoring Report in the months of January, April, July and October, containing information on toxicity reduction evaluation activities including:
    - i. any data and/or substantiating documentation which identifies the pollutant(s) and/or source(s) of effluent toxicity;
    - ii. any studies/evaluations and results on the treatability of the facility's effluent toxicity; and
    - iii. any data which identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant lethality at the critical dilution.
  - d. The permittee shall submit a Final Report on Toxicity Reduction Evaluation Activities no later than twenty-eight (28) months from confirming lethality in the retests, which provides information pertaining to the specific control mechanism selected that will, when implemented, result in reduction of effluent toxicity to no significant lethality at the critical dilution. The report will also provide a specific corrective action schedule for implementing the selected control mechanism.

Quarterly testing during the TRE is a minimum monitoring requirement. EPA recommends that permittees required to perform a TRE not rely on quarterly testing alone to ensure success in the TRE, and that additional screening tests be performed to capture toxic samples for identification of toxicants. Failure to identify the specific chemical compound causing toxicity test failure will normally result in a permit limit for whole effluent toxicity limits per federal regulations at 40 CFR 122.44(d)(1)(v).

# DRAFT

Permit Number: AR0021903

Page 22 of Part III

12. If any individual analytical test results is less than the minimum quantification level (MQL) listed below, a value of zero (0) may be used for that individual result for the Discharge Monitoring report (DMR) calculations and reporting requirements.

Pollutant	EPA Method	MQL ( $\mu\text{g/l}$ )
Arsenic	206.2	10
Copper	220.2	10

The permittee may develop a matrix specific method detection limit (MDL) in accordance with Appendix B of 40 CFR Part 136. For any pollutant for which the permittee determines a site specific MDL, the permittee shall send to ADEQ, NPDES Permits Branch, a report containing QA/QC documentation, analytical results, and calculations necessary to demonstrate that a site specific MDL was correctly calculated. A site specific minimum quantification level (MQL) shall be determined in accordance with the following calculation:

$$\text{MQL} = 3.3 \times \text{MDL}$$

Upon written approval by the NPDES Permits Branch, the site specific MQL may be utilized by the permittee for all future Discharge Monitoring Report (DMR) calculations and reporting requirements.

13. In lieu of stormwater pollution prevention plan requirements, a No Exposure Certification (Tracking #ARR000293) was submitted. Under the no exposure certification, any discharge of stormwater not in compliance with the No Exposure Certification requirements is a violation of the permit.

## PART IV DEFINITIONS

All definitions contained in Section 502 of the Clean Water Act shall apply to this permit and are incorporated herein by reference. Additional definitions of words or phrases used in this permit are as follows:

1. **“Act”** means the Clean Water Act, Public Law 95-217 (33.U.S.C. 1251 et seq.) as amended.
2. **“Administrator”** means the Administrator of the U.S. Environmental Protection Agency.
3. **“Applicable effluent standards and limitations”** means all State and Federal effluent standards and limitations to which a discharge is subject under the Act, including, but not limited to, effluent limitations, standards of performance, toxic effluent standards and prohibitions, and pretreatment standards.
4. **“Applicable water quality standards”** means all water quality standards to which a discharge is subject under the federal Clean Water Act and which has been (a) approved or permitted to remain in effect by the Administrator following submission to the Administrator pursuant to Section 303(a) of the Act, or (b) promulgated by the Director pursuant to Section 303(b) or 303(c) of the Act, and standards promulgated under (APCEC) Regulation No. 2, as amended.
5. **“Bypass”** means the intentional diversion of waste streams from any portion of a treatment facility.
6. **“Daily Discharge”** means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling.  
*Mass Calculations:* For pollutants with limitations expressed in terms of mass, the “daily discharge” is calculated as the total mass of pollutant discharged over the sampling day.  
*Concentration Calculations:* For pollutants with limitations expressed in other units of measurement, determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the “daily discharge” determination of concentration shall be the arithmetic average (weighted by flow value) of all the samples collected during that sampling day by using the following formula: where C= daily concentration, F=daily flow and n=number of daily samples  
$$\frac{C_1F_1 + C_2F_2 + \dots + C_nF_n}{F_1 + F_2 + \dots + F_n}$$
7. **“Monthly average”** means the highest allowable average of “daily discharges” over a calendar month, calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month. For Fecal Coliform Bacteria (FCB) report the monthly average (see 30-day average below).
8. **“Daily Maximum”** discharge limitation means the highest allowable “daily discharge” during the calendar month. The 7-day average for Fecal Coliform Bacteria (FCB) is the



# DRAFT

Permit Number: AR0021903

Page 2 of Part IV

geometric mean of the values of all effluent samples collected during the calendar week in colonies per 100 ml.

9. **“Department”** means the Arkansas Department of Environmental Quality (ADEQ).
10. **“Director”** means the Administrator of the U.S. Environmental Protection Agency and/or the Director of the Arkansas Department of Environmental Quality.
11. **“Grab sample”** means an individual sample collected in less than 15 minutes in conjunction with an instantaneous flow measurement.
12. **“Industrial User”** means a nondomestic discharger, as identified in 40 CFR Part 403, introducing pollutants to a POTW.
13. **“National Pollutant Discharge Elimination System”** means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements under Sections 307, 402, 318, and 405 of the Clean Water Act.
14. **“POTW”** means a Publicly Owned Treatment Works.
15. **“Severe property damage”** means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in products.
16. **“APCEC”** means the Arkansas Pollution Control and Ecology Commission.
17. **“Sewage sludge”** means the solids, residues, and precipitate separated from or created in sewage by the unit processes at a POTW. Sewage as used in this definition means any wastes, including wastes from humans, households, commercial establishments, industries, and storm water runoff that are discharged to or otherwise enter a POTW.
18. **“7-day average”** discharge limitation, other than for Fecal Coliform Bacteria (FCB), is the highest allowable arithmetic mean of the values for all effluent samples collected during the calendar week. The 7-day average for Fecal Coliform Bacteria (FCB) is the geometric mean of the values of all effluent samples collected during the calendar week in colonies/100 ml. The Discharge Monitoring Report should report the highest 7-day average obtained during the calendar month. For reporting purposes, the 7-day average values should be reported as occurring in the month in which the Saturday of the calendar week falls in.
19. **“30-day average”**, other than for Fecal Coliform Bacteria (FCB), is the arithmetic mean of the daily values for all effluent samples collected during a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. The 30-day average for Fecal Coliform Bacteria (FCB) is the geometric mean of the values for all effluent samples collected during a calendar month. For Fecal Coliform Bacteria (FCB), report the monthly average as a 30-day geometric mean in colonies per 100 ml.
20. **“24-hour composite sample”** consists of a minimum of 12 effluent portions collected at equal time intervals over the 24-hour period and combined proportional to flow or a sample collected at frequent intervals proportional to flow over the 24-hour period.



21. **"12-hour composite sample"** consists of 12 effluent portions, collected no closer together than one hour and composited according to flow. The daily sampling intervals shall include the highest flow periods.
22. **"6-hour composite sample"** consists of six effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.
23. **"3-hour composite sample"** consists of three effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.
24. **"Treatment works"** means any devices and systems used in storage, treatment, recycling, and reclamation of municipal sewage and industrial wastes, of a liquid nature to implement section 201 of the Act, or necessary to recycle reuse water at the most economic cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and alterations thereof; elements essential to provide a reliable recycled supply such as standby treatment units and clear well facilities, and any works, including site acquisition of the land that will be an integral part of the treatment process or is used for ultimate disposal of residues resulting from such treatment.
25. **"Upset"** means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. Any upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, lack of preventive maintenance, or careless or improper operations.
26. **"For Fecal Coliform Bacteria (FCB)"**, a sample consists of one effluent grab portion collected during a 24-hour period at peak loads. For Fecal Coliform Bacteria (FCB) report the monthly average as a 30-day geometric mean in colonies per 100 ml.
27. **"Dissolved oxygen limit"**, shall be defined as follows:
  - a. When limited in the permit as a minimum monthly average, shall mean the lowest acceptable monthly average value, determined by averaging all samples taken during the calendar month;
  - b. When limited in the permit as an instantaneous minimum value, shall mean that no value measured during the reporting period may fall below the stated value.
28. **The term "MGD"** shall mean million gallons per day.
29. **The term "mg/l"** shall mean milligrams per liter or parts per million (ppm).
30. **The term "µg/l"** shall mean micrograms per liter or parts per billion (ppb).
31. **The term "cfs"** shall mean cubic feet per second.
32. **The term "ppm"** shall mean parts per million.
33. **The term "s.u."** shall mean standard units.
34. **The term "Instantaneous Maximum"** when limited in the permit as an instantaneous maximum value, shall mean that no value measured during the reporting period may fall above the stated value.
35. **Monitoring and Reporting:**

When a permit becomes effective, monitoring requirements are of the immediate period of the permit effective date. Where the monitoring requirement for an effluent

# DRAFT

Permit Number: AR0021903

Page 4 of Part IV

characteristic is monthly or more frequently, the Discharge Monitoring Report (DMR) shall be submitted by the 25<sup>th</sup> of the month following the sampling. Where the monitoring requirement for an effluent characteristic is Quarterly, Semi-Annual, Annual, or Yearly, the DMR shall be submitted by the 25<sup>th</sup> of the month following the monitoring period end date.

**MONTHLY:**

is defined as a calendar month or any portion of a calendar month for monitoring requirement frequency of once/month or more frequently.

**QUARTERLY:**

- (1) is defined as a fixed calendar quarter or any part of the fixed calendar quarter for a non-seasonal effluent characteristic with a measurement frequency of once/quarter. Fixed calendar quarters are: January through March, April through June, July through September, and October through December; or
- (2) is defined as a fixed three month period (or any part of the fixed three month period) of or dependent upon the seasons specified in the permit for a seasonal effluent characteristic with a monitoring requirement frequency of once/quarter that does not coincide with the fixed calendar quarter. Seasonal calendar quarters are: May through July, August through October, November through January, and February through April.

**SEMI-ANNUAL:**

is defined as the fixed time periods January through June, and July through December (or any portion thereof) for an effluent characteristic with a measurement frequency of once/6 months or twice/year.

**ANNUAL or YEARLY:**

is defined as a fixed calendar year or any portion of the fixed calendar year for an effluent characteristic or parameter with a measurement frequency of once/year. A calendar year is January through December, or any portion thereof.

36. **The term “Weekday”** means Monday – Friday.

ATTACHMENT 1

Priority Pollutant Scan Calculation

Permittee: City of Wynne Wastewater Treatment Plant  
 Receiving Stream: Un-named tributary, Caney Creek, L'Anguille River, St. Francis River  
 Permit number: AR0021903 Qe for:  
 Flow (Qe): 2.76 MGD Municipalities = Design Flow  
 Flow (Qe): 4.26 CFS Industrial Discharges = Highest monthly average flow of the last two years  
 7Q10 = 0.00 CFS  
 Long Term Average = 0.00 CFS  
 Using Diffusers: no  
 pH = 7.52 Yes/No  
 Total Hardness: 81.00 mg/l S.U.  
 TSS: 8 mg/l  
 (% of 7Q10 for Chronic): 0.67  
 (% of 7Q10 for Acute): 0.33

TSS for:

Gulf Coastal	5.5 mg/l	Ouach Mound	= 2 mg/l
Ark River Valley	= 3 mg/l	Ozark Highlands	= 2.5 mg/l
Boston Mound	= 1.3 mg/l	Delta	= 8 mg/l

Total Hardness for:

Arkansas River	= 125 mg/l	Red River	= 211 mg/l
Ouachita River	= 28 mg/l	St. Francis River	= 103 mg/l

For the following receiving enter 0.06 in cell "C17" White River = 116 mg/l

Mississippi, Arkansas, Red River.	Gulf Coastal = 31 mg/l	Ouachita Mound = 31 mg/l
White (Below confluence with Black River)	Ozark Highlands = 148 mg/l	Ark River Valley = 25 mg/l
Ouachita (below Confluence with Little Miss. River)	Boston Mound = 25 mg/l	Delta = 81 mg/l

Upstream Flow (Qb) = 0.00 (Chronic) 0.00 (Acute)  
 Pollutant Concentration Upstream (Cb) = 0 ug/l  
 Water Effect Ratio(WER) 1.00  
 Cancer Risk Level: 1.00E-05 (STATE); 1.00e-6 (EPA)

IWC = Instream concentration of pollutant after mixing with the receiving stream  
 $IWC = (Ce * Qe + Cb * Qb) / (Qb + Qe)$   
 Ce = Pollutant concentration in the effluent (ug/l) = Reported value as Total Recov



METALS and CYANIDE

	Reported Value (Ce) (ug/l)	Ce*2.13 (ug/l)	EPA Acute (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	EPA Chronic (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	EPA Bioacc. (ug/l)
1. Antimony Total	2.00	4.26	9000	*****	4.26	1600	*****	4.26	4300
2. Arsenic Total	2.00	4.26	662.95	*****	4.26	349.89	*****	4.26	1.40
3. Beryllium Total	0.00	0.00	130.00	*****	0.00	5.30	*****	0.00	*****
4. Cadmium Total*	0.00	0.00	*****	11.94	0.00	*****	3.58	0.00	*****
6. Chromium (Tri)*	0.00	0.00	*****	2256.37	0.00	*****	731.94	0.00	*****
7. Chromium (hex)	0.00	0.00	*****	15.71	0.00	*****	10.58	0.00	*****
8. Copper Total Recoverable*	13.00	27.69	*****	38.87	27.69	*****	26.41	27.69	*****
9. Lead Total*	0.00	0.00	*****	269.04	0.00	*****	10.48	0.00	*****
10. Mercury Total*	0.00	0.00	*****	6.46	0.00	*****	0.0120	0.00	0.15
12. Nickel Total*	1.00	2.13	*****	2603.30	2.13	*****	289.12	2.13	4600
13. Selenium Total	0.00	0.00	*****	20.00	0.00	*****	5.00	0.00	*****
14. Silver Total*	0.00	0.00	*****	7.8153	0.00	*****	*****	0.00	*****
15. Thallium Total	0.00	0.00	1400	*****	0.00	40.00	*****	0.00	6.30
16. Zinc Total*	50.00	106.50	*****	319.04	106.50	*****	291.33	106.50	*****
129. Phenols, Total	10.00	21.30	*****	*****	*****	*****	*****	*****	*****
17. Cyanide Total	0.00	0.00	*****	22.36	0.00	*****	5.20	0.00	220000

\* See linear partition coefficient (Page 6)

DIOXIN

	Reported Value (Ce) (ug/l)	Ce*2.13 (ug/l)	EPA Acute (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	EPA Chronic (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	EPA Bioacc. (ug/l)
18. 2-3-7-8-TCDD	0.00	0.00	0.01	*****	0.00	*****	*****	0.00	1.40E-07

VOLATILE COMPOUNDS



19. Acrolein	0.00	0.00	68.00	*****	0.00	21.00	*****	0.00	780.00
20. Acrylonitrile	0.00	0.00	7550	*****	0.00	2600	*****	0.00	6.60
21. Benzene	0.00	0.00	5300	*****	0.00	*****	*****	0.00	710.00
22. Bromoform	0.00	0.00	*****	*****	0.00	*****	*****	0.00	3600.00
23. Carbon T Tet	0.00	0.00	35200	*****	0.00	*****	*****	0.00	44.00
24. Chlorobenzene	0.00	0.00	250.00	*****	0.00	50.00	*****	0.00	2.10E+04
25. Chlorodibromomethane	0.00	0.00	*****	*****	0.00	*****	*****	0.00	340.00
26. Chloroethane	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
27. 2-Chloroethylvinyl ether	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
28. Chloroform	0.13	0.28	28900	*****	0.28	1240	*****	0.28	4700.00
29. Dichlorobromomethane	0.00	0.00	*****	*****	0.00	*****	*****	0.00	220.00
30. 1-1-Dichlorethane	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
31. 1-2-Dichloroethane	0.00	0.00	118000	*****	0.00	20000	*****	0.00	990.00
32. 1-1-Dichlorethylene	0.00	0.00	11600	*****	0.00	*****	*****	0.00	32.00
33. 1,2 Dichloropropane	0.00	0.00	23000	*****	0.00	5700	*****	0.00	*****
34. 1,3 Dichloropropylene	0.00	0.00	6060	*****	0.00	244.00	*****	0.00	1700.00
35. Ethylbenzene	0.00	0.00	32000	*****	0.00	*****	*****	0.00	29000.00
37. Methyl Chloride	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
36. Methyl bromide	0.00	0.00	*****	*****	0.00	*****	*****	0.00	4000.00
38. Methylene chloride	0.00	0.00	*****	*****	0.00	*****	*****	0.00	16000.00
39. 1-1-2-2-Tetrachloroethane	0.00	0.00	9320	*****	0.00	2400	*****	0.00	110.00
40. Tetrachloroethylene	0.00	0.00	5280	*****	0.00	840	*****	0.00	88.50
41. Toluene	0.00	0.00	17500	*****	0.00	*****	*****	0.00	2.0E+05
42. 1,2-trans-dichloroethylene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
44. 1-1-2-Trichloroethane	0.00	0.00	18000	*****	0.00	9400	*****	0.00	420.00
43. 1-1-1-Trichloroethane	0.00	0.00	18000	*****	0.00	*****	*****	0.00	*****
45. Trichloroethylene	0.00	0.00	45000	*****	0.00	21900	*****	0.00	810.00
46. Vinyl Chloride	0.00	0.00	*****	*****	0.00	*****	*****	0.00	5250.00





Chemical Name	Reported Value (ug/l)	Ce*2.13 (ug/l)	EPA Acute (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	EPA Chronic (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	EPA Bioacc. (ug/l)
ACID COMPOUNDS									
47. 2-Chlorophenol	0.00	0.00	4380	*****	0.00	*****	*****	0.00	*****
48. 2-4-Dichlorophenol	0.00	0.00	2020	*****	0.00	365	*****	0.00	*****
49. 2-4 Dimethylphenol	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
50. 4,6-Dinitro-o-Cresol	0.00	0.00	*****	*****	0.00	*****	*****	0.00	765.00
51. 2,4-Dinitrophenol	0.00	0.00	*****	*****	0.00	*****	*****	0.00	14000
52-53. Nitrophenols	0.00	0.00	230	*****	0.00	150	*****	0.00	*****
54. 4 Chloro-3-methylphenol	0.00	0.00	30.00	*****	0.00	*****	*****	0.00	*****
55. Pentachlorophenol	0.00	0.00	2.48	15.30	0.00	9.66	9.66	0.00	82.00
56. Phenol	0.00	0.00	10200	*****	0.00	2560	*****	0.00	4600000
57. 2-4-6-Trichlorophenol	0.00	0.00	*****	*****	0.00	*****	*****	0.00	65.00
BASE/NEUTRAL COMPOUNDS									
58. Acenaphthene	0.00	0.00	1700	*****	0.00	520	*****	0.00	*****
59. Acenaphthylene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
60. Anthracene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	110000.00
61. Benzidine	0.00	0.00	2500	*****	0.00	*****	*****	0.00	5.4E-03
62. Benzo(a) anthracene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310
63. Benzo(a) pyrene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310
64. 3,4-benzoflouranthene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310
65. Benzo(g,h,i)perylene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
66. Benzo(k) fluoranthene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310
67. Bis(2-chloroethoxy)methane	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
68. Bis(2-cloroethyl) Ether	0.00	0.00	*****	*****	0.00	*****	*****	0.00	14.00
69. Bis(2-Chloroisopropyl) eth	0.00	0.00	*****	*****	0.00	*****	*****	0.00	1.7E+05
70. Bis(2-ethylhexyl)phthalate	7.80	16.61	*****	*****	16.61	*****	*****	16.61	59.00
71. 4-Bromophenyl phenyl ether	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
72. Butylbenzy phthalate	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
73. 2-chloronaphthalene	0.00	0.00	1600	*****	0.00	*****	*****	0.00	*****
74. 4-chlorophenyl phenyl ether	0.00	0.00	*****	*****	0.00	*****	*****	0.00	*****
75. Chrysene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310
76. Dibenzo(a,h)anthracene	0.00	0.00	*****	*****	0.00	*****	*****	0.00	0.310
77-79. Dichlorobenzene(1,2-1,3-1,4)	0.00	0.00	1120	*****	0.00	763	*****	0.00	2600.0



80. 3,3'-Dichlorobenzidine	0.00	*****	*****	0.00	*****	*****	0.00	*****	0.770
81. Diethyl Phthalate	0.00	*****	*****	0.00	*****	*****	0.00	*****	1.2E+05
82. Dimethyl phthalate	0.00	*****	*****	0.00	*****	*****	0.00	*****	2.9E+06
83. Di-n-Butyl phthalate	0.00	*****	*****	0.00	*****	*****	0.00	*****	1.2E+04
84. 2-4-Dinitrotoluene	0.00	330	*****	0.00	230	*****	0.00	*****	91.00
85. 2-6-Dinitrotoluene	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****
86. Di-n-octyl phthalate	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****
87. 1,2-diphenylhydrazine	0.00	270	*****	0.00	*****	*****	0.00	*****	5.400
88. Fluoranthene	0.00	3980	*****	0.00	*****	*****	0.00	*****	370.00
89. Fluorene	0.00	*****	*****	0.00	*****	*****	0.00	*****	14000.000
90. Hexachlorobenzene	0.00	*****	*****	0.00	*****	*****	0.00	*****	0.00770
91. Hexachlorobutadiene	0.00	90.00	*****	0.00	9.30	*****	0.00	*****	500.000
92. Hexachlorocyclopentadiene	0.00	7.00	*****	0.00	5.20	*****	0.00	*****	1.70E+04
93. Hexachloroethane	0.00	980	*****	0.00	540	*****	0.00	*****	89.00
Hexachlorocyclohexane	0.00	2.00	*****	0.00	0.08	*****	0.00	*****	*****
94. Indeno(1,2,3-cd)pyrene	0.00	*****	*****	0.00	2.00	*****	0.00	*****	0.31000
95. Isophorone	0.00	117000	*****	0.00	*****	*****	0.00	*****	6000
96. Naphthalene	0.00	2300	*****	0.00	620	*****	0.00	*****	*****
97. Nitrobenzene	0.00	27000	*****	0.00	*****	*****	0.00	*****	1900.00
98. N-nitrosodimethylamine	0.00	*****	*****	0.00	*****	*****	0.00	*****	81.00
99. N-nitrosodi-n-propylamine	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****
100. N-nitrosodiphenylamine	0.00	*****	*****	0.00	*****	*****	0.00	*****	160.00
101. Phenanthrene	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****
103. 1,2,4-trichlorobenzene	0.00	*****	*****	0.00	*****	*****	0.00	*****	*****

Reported Value (ug/l)	Ce*2.13 (ug/l)	EPA Acute (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	EPA Chronic (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	EPA Bioacc. (ug/l)
0.00	0.00	3.00	3.00	0.00	*****	*****	0.00	0.00140
0.00	0.00	*****	2.00	0.00	*****	0.08	0.00	1.300E-01
0.00	0.00	*****	2.00	0.00	*****	0.08	0.00	0.4600
0.00	0.00	2.00	2.00	0.00	0.08	0.08	0.00	0.6300

PESTICIDES

104. Aldrin	0.00	0.00	3.00	0.00	*****	*****	0.00	0.00140
105. Alpha-BHC	0.00	0.00	*****	0.00	*****	0.08	0.00	1.300E-01
106. Beta-BHC	0.00	0.00	*****	0.00	*****	0.08	0.00	0.4600
107. Gamma-BHC	0.00	0.00	2.00	0.00	0.08	0.08	0.00	0.6300



108. Delta-BHC	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.08	0.00	*****
109. Chlordane	0.00	0.00	2.40	2.00	0.00	0.00	0.0043	0.0043	0.00	0.0043	0.00	5.900E-03
110. 4,4'-DDT	0.00	0.00	1.10	1.10	0.00	0.00	0.0010	0.0010	0.00	0.0010	0.00	0.0059
111. 4,4'-DDE	0.00	0.00	*****	1.10	0.00	0.00	*****	*****	0.00	0.0010	0.00	0.0059
112. 4,4'-DDD	0.00	0.00	*****	1.10	0.00	0.00	*****	*****	0.00	0.0010	0.00	0.0084
113. Dieldrin	0.00	0.00	2.50	2.50	0.00	0.00	0.0019	0.0019	0.00	0.0019	0.00	1.400E-03
114. Alpha-endosulfan	0.00	0.00	0.22	0.22	0.00	0.00	0.0560	0.0560	0.00	0.0560	0.00	2.00
115. Beta-endosulfan	0.00	0.00	0.22	0.22	0.00	0.00	0.0560	0.0560	0.00	0.0560	0.00	2.00
116. Endosulfan sulfate	0.00	0.00	*****	0.22	0.00	0.00	*****	*****	0.00	0.0560	0.00	2.00
117. Endrin	0.00	0.00	0.18	0.18	0.00	0.00	0.0023	0.0023	0.00	0.0023	0.00	8.100E-01
118. Endrin aldehyde	0.00	0.00	*****	0.18	0.00	0.00	*****	*****	0.00	0.0023	0.00	8.100E-01
119. Heptachlor	0.00	0.00	0.52	0.52	0.00	0.00	0.0038	0.0038	0.00	0.0038	0.00	0.0021
120. Heptachlor epoxide	0.00	0.00	0.52	0.52	0.00	0.00	0.0038	0.0038	0.00	0.0038	0.00	0.0011
121. PCB-1242	0.00	0.00	*****	*****	0.00	0.00	0.0140	0.0140	0.00	0.0140	0.00	4.500E-04
122. PCB-1254	0.00	0.00	*****	*****	0.00	0.00	0.0140	0.0140	0.00	0.0140	0.00	4.500E-04
123. PCB-1221	0.00	0.00	*****	*****	0.00	0.00	0.0140	0.0140	0.00	0.0140	0.00	4.500E-04
124. PCB-1232	0.00	0.00	*****	*****	0.00	0.00	0.0140	0.0140	0.00	0.0140	0.00	4.500E-04
125. PCB-1248	0.00	0.00	*****	*****	0.00	0.00	0.0140	0.0140	0.00	0.0140	0.00	4.500E-04
126. PCB-1260	0.00	0.00	*****	*****	0.00	0.00	0.0140	0.0140	0.00	0.0140	0.00	4.500E-04
127. PCB-1016	0.00	0.00	*****	*****	0.00	0.00	0.0140	0.0140	0.00	0.0140	0.00	4.500E-04
128. Toxaphene	0.00	0.00	0.73	0.73	0.00	0.00	0.00020	0.00020	0.00	0.0002	0.00	4.500E-04
130. Chlorpyrifos	0.00	0.00	0.083	0.083	0.00	0.00	0.041	0.041	0.00	0.041	0.00	*****



**Attachment 2**

Permittee	City of Wynne Wastewater Treatment Plant										
Receiving Stream	Un-named tributary, Caney Creek, L'Anguille River, St. Francis River										
Permit number	AR0021903										
Flow (Qe)	2.76	MGD									
Flow (Qe)	4.26	CFS									
7Q10 =	0.00	CFS									
Long Term Average =	0.00	CFS									
Using Diffusers	no	Yes/No									
pH =	7.52	S.U.									
Total Hardness	81.00	mg/l									
TSS	8.00	mg/l									
(% of 7Q10 for Chronic)	0.67	Qb	0.00								
(% of 7Q10 for Acute)	0.33	Qb	0.00								
Cb	0.00	ug/l									
AML factor	1.55										
DML/AML	1.64										
			WQSa	WLAa	LTAa	WQSc	WLAc	LTAc	LTAa/LTAc	AML, ug/l	DML, ug/l
Copper Total*	38.87	38.87	22.15	26.4109	26.41	19.02	19.02	19.02	29.47	59.14	

