

**NPDES DRAFT PERMITTING DECISION  
PERMIT NUMBER AR0043401**

This is to give notice that the Water Division of the Arkansas Department of Environmental Quality, Post Office Box 8913, Little Rock, Arkansas 72219-8913 proposes a draft renewal of the permit application which was received on 09/19/2005 for the following applicant under the National Pollutant Discharge Elimination System and the Arkansas Water and Air Pollution Control Act.

City Water and Light Plant of the City of Jonesboro - Eastside WWTP  
400 East Monroe  
Jonesboro, AR 72404

The applicant is requesting a renewal of their existing NPDES discharge permit.

**Facility Location:** The facility is located as follows: approximately one mile west of the intersection of Arkansas State Highway 463 and Ingels Road; Latitude: 35° 47' 27"; Longitude: 90° 37' 36" in Section 2, Township 13 North, Range 4 East in Criaghead County, Arkansas.

**Discharge Location:** The discharge from this existing facility is made into Whiteman Creek, thence into Little Bay Ditch, thence into Ditch No. 9, thence into the Ditch No. 10, thence into the Ditch No. 23, thence into St. Francis Bay Straight Slough, thence into St. Francis Bay, thence into the St. Francis River in Segment 5A of the St. Francis River Basin. The receiving stream is a Water of the State classified for secondary contact recreation; raw water source for public, industrial, and agricultural water supplies; propagation of desirable species of fish and other aquatic life; and other compatible uses.

**Outfall Location:** The outfall is located at the following coordinates: Latitude: 35° 47' 29"; Longitude: 90° 37' 51"

**303(d) List Consideration:** The receiving stream is not listed on the 303(d) list. Therefore no permit action is needed.

**Endangered Species Consideration:** No comments on the application were received from the U.S. Fish and Wildlife Service (USF&WS). The drafted permit and Fact Sheet will be sent to the USF&WS for their review.

**Type of Treatment:** screening, grit removal, extended aeration activated sludge, clarification, chlorination, dechlorination, and post aeration.

**Sludge Condition:** Sludge is thickened in a series of sludge storage tanks then land applied at the following locations:

Field Number	Quarter Section	Section	Township	Range	Total (Acres)	Acreage (Acres)	Loading Rate (tones/year)
1	E 1/2 of NE 1/4	2	13 North	4 East	132	45.36	132
2	N 1/2 of NW 1/4	2	13 North	4 East	235	51.45	235
3	SE 1/4 of SW 1/4	35	14 North	4 East	0	22.12	0
4	SW 1/4 of SE 1/4	35	14 North	4 East	77	26.24	77
5	SE 1/4 of SE 1/4	35	14 North	4 East	0	30.13	0
6	SE 1/4 of NE 1/4	2	13 North	4 East	10	8.32	10
7	SW 1/4 of NW 1/4	2	13 North	4 East	81	14.81	81

8	SE 1/4 of NW 1/4	2	13 North	4 East	126	28.26	126
9	SE 1/4 of NE 1/4	2	13 North	4 East	169	19.62	169
10	NW 1/4 of SW 1/4	2	13 North	4 East	42	11.92	42
11	NE 1/4 of SW 1/4	2	13 North	4 East	21	6.23	21
12	NE 1/4 of SE 1/4	2	13 North	4 East	227	17.68	227
13	SE 1/4 of SW 1/4	2	13 North	4 East	88	31.68	88
14	SE 1/4 of SE 1/4	2	13 North	4 East	12	30.56	12

**Activity:** Under the standard industrial classification (SIC) code 4952, the applicant's activities are the operation of a municipal treatment plant.

**Changes:** Changes from the previously issued permit are listed below. Permittee is responsible for reading this permit in detail carefully and becoming familiar with all the changes even if they are not listed below.

1. Parts II, III, and IV have been revised.
2. Condition dealing with odor in Part III has been removed.
3. pH limits have changed from 6 - 9 s.u. to 6.0 - 9.0 s.u.
4. DO limits have been changed from Instantaneous Maximum to Monthly Average Minimum.
5. Ammonia limits have been changed.
6. The facility and Outfall 001 coordinates have been corrected.
7. Monitoring and reporting requirements for Zinc have been removed.
8. A schedule of compliance for Ammonia-Nitrogen has been included.
9. Metal condition has been removed from Part III of the permit.
10. The description of the receiving waters has been expanded.
11. Reporting requirements for Whole Effluent Toxicity have changed.

**Public Notice:** In accordance with APCEC Regulation No. 8 the public notice will be published by ADEQ in a newspaper of general circulation on or before September 8, 2006 for one (1) day only. Comments must be received at ADEQ prior to the close of the public comment period October 9, 2006. The public comment period will begin on the date of publication and will end no sooner than 30 days from that date.

A draft permit and draft public notice will be sent to the District Engineer, Corps of Engineers, and to the Regional Director of the U.S. Fish and Wildlife Service on a case-by-case basis, and the EPA and Arkansas Department of Health prior to the publication of that notice.

**Issuance of the Final Permit:** The permit will become effective on or after November 1, 2006 unless: Comments are received and/or public hearing is requested prior to October 9, 2006, in which case the permit will be effective on or after December 1, 2006.

**Comments and Public Hearing:** NPDES comments and public hearing procedures may be found at 40 CFR 124.10 through 124.12 and Regulation No. 8. All persons, including the permittee, who wish to comment on ADEQ's draft decision to renew the permit must submit written comments to ADEQ, along with their name and mailing address. During the comment period, any interested person may request a public hearing by filing a written request which must state the technical issues to be raised. A public hearing will be held if ADEQ finds a significant degree of public interest. If a public hearing is held, ADEQ will issue a public notice of hearing at least 30 days prior to the scheduled hearing.

After the public comment period, and public hearing if one is held, ADEQ will issue a final permit decision. ADEQ will notify the applicant and each person who has submitted written comments or

After the public comment period, and public hearing if one is held, ADEQ will issue a final permit decision. ADEQ will notify the applicant and each person who has submitted written comments or requested notice of the final permitting decision. A final permitting decision means a final decision to issue, deny, modify, revoke and reissue, or terminate a permit. Any interested person who has submitted comments may appeal a final decision by ADEQ in accordance with the Arkansas Pollution Control and Ecology Commission Regulation No. 8 (Administrative Procedures).

Submitting written comments to ADEQ or making oral statements on the record at the public hearing on the proposed permitting decision provides individuals with legal standing to appeal a final Department permitting decision. Comments supporting or opposing the proposed decision will provide legal standing. Only parties with legal standing may appeal a permitting decision.

**Permit Application Record:** The permit application and the administrative record is available for review and copying in the Central Records Section, ADEQ, State Police Headquarters, One State Police Plaza, near Interstate 30 and Geyer Springs, Little Rock, Arkansas.

**Web Site Information:** For those with Internet access, a copy of the proposed draft permit may be found on the Arkansas Department of Environmental Quality's website at:

[http://www.adeq.state.ar.us/water/branch\\_npdes/pn\\_permits/pnpermits.asp](http://www.adeq.state.ar.us/water/branch_npdes/pn_permits/pnpermits.asp).

**Contact Person:** The ADEQ contact person for submitting written comments, requesting information, or obtaining copies of the application, permit and the Fact Sheet is:

Parviz Mokhtari  
NPDES Branch, Water Division  
Arkansas Department of Environmental Quality  
Post Office Box 8913  
Little Rock, Arkansas 72219-8913  
(501) 682-0622

# ADEQ

ARKANSAS  
Department of Environmental Quality

September 8, 2006

CERTIFIED MAIL: RETURN RECEIPT REQUESTED (7005 1820 0006 2081 6606)

Mr. Ronald L. Bowen  
City Water and Light Plant of the City of Jonesboro - Eastside WWTP  
400 East Monroe  
Jonesboro, AR 72404

RE: Application to Discharge to Waters of the State Permit Number AR0043401

Dear Mr. Bowen:

Enclosed is the public notice, Fact Sheet, and a copy of the permit which the Arkansas Department of Environmental Quality has drafted under the authority of the National Pollutant Discharge Elimination System and the Arkansas Water and Air Pollution Control Act. A copy of the final permit will be mailed to you when the Department has made a final permitting decision.

In accordance with APCEC Regulation No. 8, Part 2.1.6, the enclosed public notice will be published by ADEQ in a newspaper of general circulation on or before **September 8, 2006** for one (1) day only. An invoice for the cost of publishing the public notice and proof of publication will be sent to you by the advertising newspaper. The permittee must send proof of publication and payment to the following address as soon as possible but no later than **October 9, 2006**. Until this Department receives proof of publication of the public notice, no further action will be taken on the issuance of your NPDES discharge permit.

Arkansas Department of Environmental Quality  
NPDES-Water Division  
P.O. Box 8913  
Little Rock, AR 72219-8913  
501-682-0620 Fax: 501-682-0910

Comments must be received at ADEQ prior to the close of the public comment period as shown in the enclosed public notice. The public comment period will begin on the date of publication and will end no sooner than 30 days from that date. Once a final permit is issued by the Director and becomes effective, the permittee must comply with all terms and conditions of the permit, or be subject to enforcement actions for any instances of noncompliance during the duration of the permit, usually five (5) years. Consequently, it is imperative that you, as the applicant, thoroughly review the enclosed documentation for accuracy, applicability, and your ability to comply with all conditions therein.

Should you have any questions concerning any part of the permit, please contact the NPDES Branch at (501) 682-0622.

Sincerely,



Martin Maner, P.E.  
Chief, Water Division

MM: pm

Enclosure

# DRAFT

## Fact Sheet

for renewal of draft NPDES Permit Number AR0043401 to discharge to Waters of the State

### 1. PERMITTING AUTHORITY.

The issuing office is:

Arkansas Department of Environmental Quality  
8001 National Drive  
Post Office Box 8913  
Little Rock, Arkansas 72219-8913

### 2. APPLICANT.

The applicant is:

City Water and Light Plant of the City of Jonesboro - Eastside WWTP  
400 East Monroe  
Jonesboro, AR 72404

### 3. PREPARED BY.

The permit was prepared by:

Parviz Mokhtari  
NPDES Branch, Water Division

### 4. DATE PREPARED.

The permit was prepared on April 10, 2006.

### 5. PREVIOUS PERMIT ACTIVITY.

Effective Date: April 1, 2001  
Modification Date: N/A  
Expiration Date: March 31, 2006

The permittee submitted a permit renewal application on September 19, 2005. It is proposed that the current NPDES permit be reissued for a 5-year term in accordance with regulations promulgated at 40 CFR Part 122.46(a).

# DRAFT

## 6. RECEIVING STREAM SEGMENT AND DISCHARGE LOCATION.

The outfall is located at the following coordinates:

Latitude: 35° 47' 29"; Longitude: 90° 37' 51"

The receiving waters named:

Whiteman Creek, thence into Little Bay Ditch, thence into Ditch No. 9, thence into the Ditch No. 10, thence into the Ditch No. 23, thence into St. Francis Bay Straight Slough, thence into Straight Slough, thence into St. Francis Bay, thence into the St. Francis River in Segment 5A of the St. Francis River Basin. The receiving stream is a Water of the State classified for secondary contact recreation, raw water source for public, industrial, and agricultural water supplies, propagation of desirable species of fish and other aquatic life, and other compatible uses.

### a. 303(d) List and Endangered Species Considerations

#### i. 303(d) List

The receiving stream is not listed on the 303(d) list. Therefore no permit action is needed.

#### ii. Endangered Species:

No comments on the application were received from the U.S. Fish and Wildlife Service (USF&WS). The drafted permit and Fact Sheet will be sent to the USF&WS for their review.

## 7. OUTFALL AND TREATMENT PROCESS DESCRIPTION.

The following is a description of the facility described in the application:

- a. Design Flow: 9.0 MGD
- b. Type of treatment: screening, grit removal, extended aeration activated sludge, clarification, chlorination, dechlorination, and post aeration.
- c. Discharge Description: treated municipal wastewater.

A quantitative and qualitative description of the discharge described in the NPDES Permit Application Forms received are available for review.

# DRAFT

## 8. INDUSTRIAL WASTEWATER CONTRIBUTIONS.

### INDUSTRIAL USERS

A written certification that existing technically based local limits are adequate to prevent pass through, inhibition, or interference is required or; a written notification that a technical evaluation revising the current technically based limits will be submitted.

Pretreatment requirements have been added to modify the permittee's Program to be current with the newly revised (10/05) Pretreatment Regulations under 40 CFR 403.

## 9. SEWAGE SLUDGE PRACTICES.

Sludge is thickened in a series of sludge storage tanks then land applied at the approved locations (See Attachment 5).

## 10. PERMIT CONDITIONS.

The Arkansas Department of Environmental Quality has made a tentative determination to issue a permit for the discharge described in the application. Permit requirements are based on NPDES regulations (40 CFR Parts 122, 124, and Subchapter N), the National Pretreatment Regulation in 40 CFR 403 and regulations promulgated pursuant to the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended, Ark. Code Ann. 8-4-101 et. seq.).

# DRAFT

a. Interim Effluent Limitations

Outfall 001- treated municipal wastewater

i. Conventional and/or Toxic Pollutants

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow (MGD)	N/A	Report	Report	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)	1501	20	30	once/weekday	24-hr composite
Total Suspended Solids (TSS)	2252	30	45	once/weekday	24-hr composite
Ammonia Nitrogen (NH3-N)					
(May-Oct)	525	7	10.5	once/weekday	24-hr composite
(Nov-April)	901	12	18	once/weekday	24-hr composite
Dissolved Oxygen					
(May-Oct)	N/A	5.0 (Monthly Avg. Min.)		once/weekday	grab
(Nov-Apr)	N/A	7.0 (Monthly Av. Min.)		once/weekday	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
	N/A	1000	2000	once/weekday	grab
Total Residual Chlorine (TRC)	N/A	<0.1 mg/l (Inst. Max.)		once/weekday	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/weekday	grab
<u>Whole Effluent Lethality</u> (7-day NOEC) 22414	<u>Daily Average Minimum</u> not < 100%		<u>7-day Minimum</u> not < 100%	once/quarter	24-hr composite

- ii. **Solids, Foam, and Free Oil:** There shall be no discharge of distinctly visible solids, scum or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).



# DRAFT

a. **Final Effluent Limitations**

Outfall 001- treated municipal wastewater

ii. **Conventional and/or Toxic Pollutants**

<b><u>Effluent Characteristics</u></b>	<b><u>Discharge Limitations</u></b>			<b><u>Monitoring Requirements</u></b>	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow (MGD)	N/A	Report	Report	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)	1501	20	30	once/weekday	24-hr composite
Total Suspended Solids (TSS)	2252	30	45	once/weekday	24-hr composite
Ammonia Nitrogen (NH3-N)					
(April -Oct)	158	2.1	5.2	once/weekday	24-hr composite
(Nov-March)	443	5.9	10.5	once/weekday	24-hr composite
Dissolved Oxygen					
(May-Oct)	N/A	5.0 (Monthly Avg. Min.)		once/weekday	grab
(Nov-Apr)	N/A	7.0 (Monthly Av. Min.)		once/weekday	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
	N/A	1000	2000	once/weekday	grab
Total Residual Chlorine (TRC)	N/A	<0.1 mg/l (Inst. Max.)		once/weekday	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/weekday	grab
Whole Effluent Lethality (7-day NOEC) 22414		<u>Daily Average Minimum</u> not < 100%	<u>7-day Minimum</u> not < 100%	once/quarter	24-hr composite

- ii. **Solids, Foam, and Free Oil:** There shall be no discharge of distinctly visible solids, scum or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

# DRAFT

## 11. BASIS FOR PERMIT CONDITIONS.

The following is an explanation of the derivation of the conditions of the draft permit and the reasons for them or, in the case of notices of intent to deny or terminate, reasons suggesting the tentative decisions as required under 40 CFR 124.7 (48 FR 1413, April 1, 1983).

### Technology-Based versus Water Quality-Based Effluent Limitations and Conditions

Following regulations promulgated at 40 CFR Part 122.44 (1) (2) (ii), the draft permit limits are based on either technology-based effluent limits pursuant to 40 CFR Part 122.44 (a) or on State water quality standards and requirements pursuant to 40 CFR Part 122.44 (d), whichever are more stringent.

#### 1. Technology-Based Effluent Limitations and/or Conditions

The permit must at least comply with 40 CFR 133 (Secondary Treatment Regulation) when applicable.

#### 2. State Water Quality Numerical Standards Based Limitations

Final effluent limits basis for CBOD5, TSS, and DO is a desk top model performed by staff on March 6, 2006. These limitations are included in the updated Arkansas Water Quality Management Plan (WQMP). The calculation of the loadings (lbs per day) uses a design flow of 9.0 MGD and the following equation (See below). Fecal Coliform Bacteria and pH limitations are based on chapter 5, Sections 2.507 and 2.504 of Regulation No. 2 as amended, respectively.

$$\text{lbs/day} = \text{Concentration (mg/l)} \times \text{Flow (MGD)} \times 8.34$$

#### Ammonia-Nitrogen (NH3-N)

The water quality effluent limitations for Ammonia - Nitrogen are based either on DO-based effluent limits or on toxicity-based standards, whichever are more stringent.

The toxicity-based effluent limitations are based on Chapter 5, Section 2.512 of Regulation No. 2 and memo dated March 28, 2005. The following formula has been used to calculate toxicity based Ammonia limits:

$$C_d = (IWC(Q_d + Q_b) - C_b Q_b) / Q_d,$$

Where:

$C_d$  = effluent limit concentration (mg/l)

IWC = Ammonia toxicity standard for Delta Ecoregion.

$Q_d$  = design flow = 9.0 MGD = 13.93 cfs

The 7Q10 of 0 cfs is based on "Identification and Classification of Perennial Stream of Arkansas", Arkansas Geological Commission Map.

# DRAFT

Qb = Critical flow of the receiving stream = 0 cfs. This flow is 67 percent of the 7-day, 10-year low-flow (7Q10) for the receiving stream.

Cb = background concentration = 0 mg/l

The following pH and temperature were used for Delta Ecoregion:

Month	pH s.u.	Temperature C	IWC (30-day Average)	IWC (4-day Average)
April-October	7.1	30	2.1 mg/l	5.2 mg/l
November -March	7.1	14	5.9 mg/l	14.7 mg/l

for April – October:

IWC (Monthly Average) = 2.1 mg/l

$Cd = (2.1 \text{ mg/l} (13.93 \text{ cfs} + 0 \text{ cfs})) - (0 \text{ mg/l})(0 \text{ cfs}) / 13.93 \text{ cfs}$

Cd = 2.1 mg/l

IWC (7-day Average) = 5.2 mg/l

$Cd = (5.2 \text{ mg/l} (13.93 \text{ cfs} + 0 \text{ cfs})) - (0 \text{ mg/l})(0 \text{ cfs}) / 13.93 \text{ cfs}$

Cd = 5.2 mg/l

for the month November through March:

IWC (Monthly Average) = 5.9 mg/l

$Cd = (5.9 \text{ mg/l} (13.93 \text{ cfs} + 0 \text{ cfs})) - (0 \text{ mg/l})(0 \text{ cfs}) / 13.93 \text{ cfs}$

Cd = 5.9 mg/l

IWC (7-day Average) = 14.7 mg/l

$Cd = (14.7 \text{ mg/l} (13.93 \text{ cfs} + 0 \text{ cfs})) - (0 \text{ mg/l})(0 \text{ cfs}) / 13.93 \text{ cfs}$

Cd = 14.7 mg/l

Months	DO based limit*		Toxicity based limit		Permit limit	
	Monthly Average mg/l	7-day Average, mg/l	Monthly Average, mg/l	7-day Average, mg/l	Monthly Average, mg/l	7-day Average, mg/l
April	7	10.5	2.1	5.2	2.1	5.2
May - October	6	9	2.1	5.2	2.1	5.2
November - March	7	10.5	5.9	14.7	5.9	10.5

\* DO based water quality limit based on the desktop model performed by staff on March 6, 2006.

Notes:

- 7-day average = 4-day Average in Regulation No. 2
- Monthly Average = 30-day Average in Regulation No. 2

### 3. Toxics Pollutants-Priority Pollutant Scan (PPS)

#### i. Post Third Round Policy and Strategy

Section 101 of the Clean Water Act (CWA) states that "...it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited...". To insure that the CWA's prohibitions on toxic discharges are met, EPA has issued a "Policy for the Development of Water Quality-Based Permit Limitations by Toxic Pollutants"(49 FR 9016-9019,3/9/84). In support of the national policy, Region 6 adopted the "Policy for post Third Round NPDES Permitting" and the "Post Third Round NPDES Permit Implementation Strategy" on October 1, 1992. The Regional policy and strategy are designed to insure that no source will be allowed to discharge any wastewater which (1) results in instream aquatic toxicity; (2) causes a violation of an applicable narrative or numerical State water quality standard resulting in non-conformance with the provisions of 40 CFR Part 122.44(d); (3) results in the endangerment of a drinking water supply; or (4) results in aquatic bioaccumulation which threatens human health.

#### ii. Implementation

The State of Arkansas is currently implementing EPA's Post Third-Round Policy in conformance with the EPA Regional strategy. The 5-year NPDES permits contain technology-based effluent limitations reflecting the best controls available. Where these technology-based permit limits do not protect water quality or the designated uses, or where there are no applicable technology-based limits, additional water quality-based effluent limitations and/or conditions are included in the NPDES permits. State narrative and numerical water quality standards from the Regulation No. 2 are used in conjunction with EPA criteria and other available toxicity information to determine the adequacy of technology-based permit limits and the need for additional water quality-based controls.

#### iii. Priority Pollutant Scan

In accordance with the regional policy ADEQ has reviewed and evaluated the effluent in evaluating the potential toxicity of each analyzed pollutant:

- (a) The results were evaluated and compared to EPA's Minimum Quantification Levels (MQLs) to determine the potential presence of a respective toxic pollutant. Those pollutants which are greater than or equal to the MQLs are determined to be reasonably present in the effluent and an evaluation of their potential toxicity is necessary.
- (b) Those pollutants with one datum shown as "non-detect" (ND), providing the level of detection is equal to or lower than MQL are determined to be not potentially present in the effluent and eliminated from further evaluation.
- (c) Those pollutants with a detectable value even if below the MQL are determined to be reasonably present in the effluent and an evaluation of their potential toxicity is necessary.

# DRAFT

- (d) For those pollutants with multiple data values and all values are determined to be non-detect, therefore no further evaluation is necessary. However, where data set includes some detectable concentrations and some values as ND, one-half of the detection level is used for those values below the level of detection to calculate the geometric mean of the data set.

The concentration of each pollutant after mixing with the receiving stream was compared to the applicable water quality standards as established in the Arkansas Water Quality Standards, Reg. No. 2 and with the aquatic toxicity, human health, and drinking water criteria obtained from the "Quality Criteria for Water, 1986 (Gold Book)". The following expression was used to calculate the pollutant instream waste concentration(IWC):

$$IWC = ((C_e \times Q_e) + (C_b \times Q_b)) / (Q_e + Q_b)$$

where:

- IWC = instream concentration of pollutant after mixing with receiving stream ( $\mu\text{g/l}$ )  
 $C_e$  = pollutant concentration in effluent ( $\mu\text{g/l}$ )  
 $Q_e$  = effluent flow of facility (cfs)  
 $C_b$  = background concentration of pollutant in receiving stream ( $\mu\text{g/l}$ )  
 $Q_b$  = background flow of receiving stream (cfs)

The following values were used in the IWC calculations:

- $C_e$  = varies with pollutant. A single value from the Priority Pollutant Screen (PPS) submitted by the permittee as part of the NPDES permit application or the geometric mean of a group of data points (less than 20 data points) is multiplied by a factor of 2.13. This factor is based on EPA's Region VI procedure (See attachment IV of Continuing Planning Process (CPP)) to extrapolate limited data sets to better evaluate the potential toxicity for higher effluent concentrations to exceed water quality standards. This procedure employs a statistical approach which yields an estimate of a selected upper percentile value (the 95th percentile) of an effluent data set which would be expected to exceed 95% of effluent concentrations in a discharge. If 20 or more data points during the last two years are available, do not multiply by 2.13, but instead use the maximum reported values.

$$Q_e = 9.0 \text{ MGD} = 13.91 \text{ cfs}$$

$$C_b = 0 \mu\text{g/l}$$

$$Q_b = (\text{See below}):$$

- (e) Aquatic Toxicity

# DRAFT

**Chronic Toxicity:** Flow = 0 cfs, for comparison with chronic aquatic toxicity. This flow is 67 percent of the 7-day, 10-year low-flow (7Q10) for the receiving stream. The 7Q10 of 0 cfs is based on "Identification and Classification of Perennial Stream of Arkansas", Arkansas Geological Commission Map.

**Acute Toxicity:** Flow = 0 cfs, for comparison with acute aquatic toxicity. This flow is 33 percent of the 7Q10 for the receiving stream.

(f) Bioaccumulation

Flow = 0 cfs, for comparison with bioaccumulation criteria. This flow is the long term average (LTA) of the receiving stream which is based on "Identification and Classification of Perennial Stream of Arkansas", Arkansas Geological Commission Map.

(g) Drinking Water

Flow = 0 cfs, for comparison with drinking water criteria. This flow is the 7Q10 for the receiving stream.

The following values were used to determine limits for the pollutants:

Hardness = 81 mg/l, based on attachment VI of CPP.

pH = 7.63 s.u., based on compliance data from Water Quality Data Base System, utilizing ADEQ accumulated data for Station FRA0013.

iv. Water Quality Standards for Metals and Cyanide

Standards for Chromium (VI), Mercury, Selenium, and Cyanide are expressed as a function of the pollutant's water-effect ratio (WER), while standards for cadmium, chromium (III), copper, lead, nickel, silver, and zinc are expressed as a function of the pollutant's water-effect ratio, and as a function of hardness.

The Water-effect ratio (WER) is assigned a value of 1.0 unless scientifically defensible study clearly demonstrates that a value less than 1.0 is necessary or a value greater than 1.0 is sufficient to fully protect the designated uses of the receiving stream from the toxic effects of the pollutant.

The WER approach compares bioavailability and toxicity of a specific pollutant in receiving water and in laboratory test water. It involves running toxicity tests for at least two species, measuring LC50 for the pollutant using the local receiving water collected from the site where the criterion is being implemented, and laboratory toxicity testing water made comparable to the site water in terms of chemical hardness. The ratio between site water and lab water LC50 is used to adjust the national acute and chronic criteria to site specific values.

# DRAFT

v. Conversion of Dissolved Metals Criteria for Aquatic Life to Total Recoverable Metal

Metals criteria established in Regulation No. 2 for aquatic life protection are based on dissolved metals concentrations and hardness values (See Page 6 of **Attachment 1**). However, Federal Regulations cited at 40 CFR 122.45(c) require that effluent limitations for metals in NPDES permits be expressed as total recoverable (See Pages 1 and 6 of **Attachment 1**). Therefore a dissolved to the total recoverable metal conversion must be implemented. This involves determining a linear partition coefficient for the metal of concern and using this coefficient to determine the fraction of metal dissolved, so that the dissolved metal ambient criteria may be translated to a total effluent limit. The formula for converting dissolved metals to total recoverable metals for streams and lakes are provided in **Attachment 2** and Region 6 Implementation Guidance for Arkansas Water Quality Standards promulgated at 40 CFR 131.36.

vi. Comparison of the submitted information with the water quality standards and criteria

The following pollutants were determined to be present in the effluent for each pollutant as reported by the permittee.

Pollutant	Concentration Reported, µg/l	MQL, µg/l
Di-n-Butyl	9.73	10

However, ADEQ has determined from the information submitted by the permittee that no water quality standards or Gold Book criteria are exceeded. Therefore, no permit action is necessary to maintain these standards or criteria (See **Attachment 1**).

**Total Zinc, Recoverable:**

The previous permit included effluent monitoring and reporting limitations for Zinc since it was determined that there was a potential of violation of the Arkansas Water Quality Standards, Reg. No. 2. Based on the submitted Discharge Monitoring Reports, it does not appear that this pollutant has a potential to violate the Arkansas Water Quality Standards. Therefore, the monitoring and reporting are not continued in the proposed permit. Based on 40 CFR 122.44 (l) the elimination of monitoring and reporting do not constitute backsliding since new information is available which was not available at the time the previous permit was issued (See Attachment 1 and the following calculation).

Pollutant	Concentration Reported, µg/l	MQL, µg/l
Total Zinc, Recoverable	27.65*	20

\* The Geometric Mean of the DMRs data (54, 41, 0.072, 68, 80, 40, 52, and 52) µg/l for September 2003 through June 2005 and 110 µg/l reported in PPS renewal application is as follows:

$$GM = (54 \times 41 \times 0.072 \times 68 \times 80 \times 40 \times 52 \times 52 \times 110)^{1/9}$$
$$\approx 27.65 \text{ µg/l}$$

# DRAFT

$$IWC = ((C_e \times Q_e) + (C_b \times Q_b)) / (Q_e + Q_b)$$

where:

IWC = instream concentration of pollutant after mixing with receiving stream (µg/l)

$C_e$  = pollutant concentration in effluent (µg/l)

$Q_e$  = 9.0 MGD = 13.91 cfs (effluent flow of facility)

$C_b$  = 0 µg/l (background concentration of pollutant in receiving stream)

$7Q_{10}$  = 0 cfs

$Q_b$  (Acute or Chronic) = 0 cfs ( $7Q_{10}$ , background flow of receiving stream)

Water Quality Standard (WQS) = 319.04 µg/l (State Acute)

Water Quality Standard (WQS) = 291.33 µg/l (State Chronic)

$$IWC = ((27.65 \mu\text{g/L} \times 13.91 \text{ cfs}) + (0 \mu\text{g/l} \times 0 \text{ cfs})) / (13.91 \text{ cfs} + 0)$$

$$IWC = 58.89 \mu\text{g/l} < 319.04 \mu\text{g/l (WQS)}$$

## 12. Total Residual Chlorine (TRC) Requirements

No measurable which is defined as less than 0.1 mg/l is continued from the previous permit.

## 13. Final Limitations

The following effluent limitations requirements were placed in the permit based on the more stringent of the technology-based, water quality-based or previous NPDES permit limitations:

Parameter	Water Quality-Based		Technology-Based/BPJ		Previous NPDES Permit		Permit Limit	
	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l	Monthly Avg. mg/l	7-day Avg. mg/l
CBOD5	20	30	30	40	20	30	20	30
TSS	30	45	30	45	30	45	30	45
NH3-N								
(April-Oct)	2.1	5.2	N/A	N/A	7	11	2.1	5.2
(Nov-March)	5.9	10.5	N/A	N/A	12	18	5.9	10.5
Dissolved Oxygen								
(May-Oct)	5.0 (Monthly Avg. Min.)		N/A		5.0 (Instantaneous Max)		5.0 (Monthly Avg. Min.)	
(Nov-Apr)	7.0 (Monthly Avg. Min.)		N/A		7.0 (Instantaneous Max)		7.0 (Monthly Avg. Min.)	
FCB (col/100ml)	1000	2000	N/A	N/A	1000	2000	1000	2000
TRC (Inst. Max)	N/A		< 0.1 mg/l		< 0.1 mg/l		< 0.1 mg/l	
pH	6.0-9.0 s.u.		6.0-9.0 s.u.		6-9 s.u.		6.0-9.0 s.u.	



# DRAFT

## 14. Biomonitoring

Section 101(a)(3) of the Clean Water Act states that ".....it is the national policy that the discharge of toxic pollutants in toxic amounts be prohibited." In addition, ADEQ is required under 40 CFR Part 122.44(d)(1), adopted by reference in Regulation 6, to include conditions as necessary to achieve water quality standards as established under Section 303 of the Clean Water Act. Arkansas has established a narrative criteria which states "toxic materials shall not be present in receiving waters in such quantities as to be toxic to human, animal, plant or aquatic life or to interfere with the normal propagation, growth and survival of aquatic biota."

Whole effluent biomonitoring is the most direct measure of potential toxicity which incorporates the effects of synergism of effluent components and receiving stream water quality characteristics. It is the national policy of EPA to use bioassays as a measure of toxicity to allow evaluation of the effects of a discharge upon a receiving water (49 Federal Register 9016-9019, March 9, 1984). EPA Region 6 and the State of Arkansas are now implementing the Post Third Round Policy and Strategy established on September 9, 1992, and EPA Region 6 Post-Third Round Whole Effluent Toxicity Testing Frequencies, revised March 13, 2000. Biomonitoring of the effluent is thereby required as a condition of this permit to assess potential toxicity. The biomonitoring procedures stipulated as a condition of this permit are as follows:

### TOXICITY TESTS

Chronic Biomonitoring

### FREQUENCY

Once/quarter

Requirements for measurement frequency are based on appendix D of CPP.

Since 7Q10 is less than 100 cfs (ft<sup>3</sup>/sec) and dilution ratio is less than 100:1, chronic biomonitoring requirements will be included in the permit.

The calculations for dilution used for chronic biomonitoring are as follows:

$$\text{Critical dilution (CD)} = (Q_d / (Q_d + Q_b)) \times 100$$

$$Q_d = \text{Design flow} = 9.0 \text{ MGD} = 13.91 \text{ cfs}$$

$$7Q_{10} = 0 \text{ Cfs}$$

$$Q_b = \text{Background flow} = (0.67) \times 7Q_{10} = 0 \text{ cfs}$$

$$CD = (13.91) / (13.91 + 0) \times 100 = 100 \%$$

Toxicity tests shall be performed in accordance with protocols described in "Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms", EPA/600/4-91/002, July 1994. A minimum of five effluent dilutions in addition to an appropriate control (0%) are to be used in the toxicity tests. These additional effluent concentrations are 32%, 42%, 56%, 75%, and 100% (See Attachment I of CPP). The low-flow effluent concentration (critical dilution) is defined as 100% effluent. The requirement for chronic biomonitoring tests is based

# DRAFT

on the magnitude of the facility's discharge with respect to receiving stream flow. The stipulated test species, *Ceriodaphnia dubia* and the Fathead Minnow (*Pimephales promelas*) are indigenous to the geographic area of the facility; the use of these is consistent with the requirements of the State water quality standards. The biomonitoring frequency has been established to provide data representative of the toxic potential of the facility's discharge, in accordance with the regulations promulgated at 40 CFR Part 122.48.

Results of all dilutions as well as the associated chemical monitoring of pH, temperature, hardness, dissolved oxygen conductivity, and alkalinity shall be reported according to EPA/600/4-91/002, July 1994 and shall be submitted as an attachment to the Discharge Monitoring Report (DMR).

This permit may be reopened to require further biomonitoring studies, Toxicity Reduction Evaluation (TRE) if biomonitoring data submitted to the Department shows toxicity in the permittee's discharge. Modification or revocation of this permit is subject to the provisions of 40 CFR 122.62, as adopted by reference in ADEQ Regulation No. 6. Increased or intensified toxicity testing may also be required in accordance with Section 308 of the Clean Water Act and Section 8-4-201 of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

## Administrative Records

The following information summarized toxicity test submitted by the permittee during the term of the current permit at outfall 001 (See Attachment 4).

### 15. Sample Type and Sampling Frequency

Regulations promulgated at 40 CFR 122.44(i) require permit to establish monitoring requirements which assure compliance with permit limitations.

Requirements for sample type and sampling frequency were based on recommended frequencies for self-monitoring of discharges within the flow of 5 to 10 MGD.

### 16. Changes from the previously issued permit

Permittee is responsible for reading the permit in detail carefully and becoming familiar with all the changes even they are not listed below.

1. Parts II, III, and IV have been revised.
2. Condition dealing with odor in Part III has been removed.
3. pH limits have changed from 6 - 9 s.u. to 6.0 - 9.0 s.u.
4. DO limits have been changed from Instantaneous Maximum to Monthly Average Minimum.
5. Ammonia limits have been changed.
6. The facility and Outfall 001 coordinates have been corrected.
7. Monitoring and reporting requirements for Zinc have been removed.
8. A schedule of compliance for Ammonia-Nitrogen has been included.
9. Metal condition has been removed from Part III of the permit.
10. The description of the receiving waters has been expanded.

# DRAFT

11. Reporting requirements for Whole Effluent Toxicity have changed.

## 17. Storm water pollution prevention plan requirements

“No exposure certificate” was submitted in lieu of storm water prevention plan requirements.

## 18. SCHEDULE OF COMPLIANCE

Compliance with final effluent limitations is required by the following schedule:

### Interim Limits:

Compliance is required on the effective date of the permit.

### Final Limits:

The permittee shall submit progress reports to the NPDES Enforcement Section addressing the progress towards attaining the final effluent limits for Ammonia-Nitrogen at Outfall 001 according to the following schedule:

<u>ACTIVITY</u>	<u>DUE DATE</u>
Progress Report	one (1) year from effective date of permit
Progress Report	two (2) years from effective date of permit
Achieve Final Limits	three (3) years from effective date of permit

## 19. MONITORING AND REPORTING.

The applicant is at all times required to monitor the discharge on a regular basis; and report the results monthly. The monitoring results will be available to the public.

## 20. SOURCES.

The following sources were used to draft the permit:

- a. NPDES application No. AR0043401 received 09/19/2005.
- b. Arkansas Water Quality Management Plan (WQMP).
- c. Regulation No. 2.
- d. Regulation No. 6.
- e. 40 CFR Parts 122, 125, 133 and 403.
- f. NPDES permit file AR0043401.
- g. Discharge Monitoring Reports (DMRs).
- h. "Arkansas Water Quality Inventory Report 2000 (305B)", ADEQ.

# DRAFT

- i. Memo from Mo Shafii to NPDES Engineers dated March 28, 2005
- j. "Identification and Classification of Perennial Streams of Arkansas", Arkansas Geological Commission.
- k. Continuing Planning Process (CPP).
- l. Technical Support Document For Water Quality-based Toxic Control.

## 21. PUBLIC NOTICE.

The public notice describes the procedures for the formulation of final determinations and shall provide for a public comment period of 30 days. During this period, any interested persons may submit written comments on the permit and may request a public hearing to clarify issues involved in the permit decision. A request for a public hearing shall be in writing and shall state the nature of the issue(s) proposed to be raised in the hearing.

A copy of the permit and public notice will be sent to the District Engineer, Corps of Engineers, and to the Regional Director of the U.S. Fish and Wildlife Service on a case-by-case basis, and the EPA and Arkansas Department of Health prior to the publication of that notice.

## 22. NPDES POINT OF CONTACT.

For additional information, contact:

Parviz Mokhtari  
NPDES Branch, Water Division  
Arkansas Department of Environmental Quality  
8001 National Drive  
Post Office Box 8913  
Little Rock, Arkansas 72219-8913  
Telephone: (501) 682-0622

ATTACHMENT 1

Priority Pollutant Scan Calculation

Permittee Jonesboro City Water and Light (East)  
 Receiving Stream Whiteeman Creek  
 Permit number AR000434D1  
 Flow (Qd) 9.00 MGD  
 Flow (Qd) 13.81 CFS  
 7Q10 = 0.00 CFS  
 Long Term Average = 0.00 CFS  
 Using Diffusers No  
 pH = 7.53 S.U.  
 Total Hardness 81.00 mg/l  
 TSS 8 mg/l  
 Chronic Aquatic Toxicity 0.87  
 Acute Aquatic Toxicity 0.33

Qd for:  
 Municipalities = Design Flow  
 Industrial Discharges = Highest monthly average flow of the last two years

TSS for:  
 Gulf Coastal 5.5 mg/l Ouch Mount = 2 mg/l  
 Ark River Valley = 3 mg/l Ozark Highlands = 2.5 mg/l  
 Boston Mount = 1.3 mg/l Delta = 8 mg/l

Total Hardness for:  
 Arkansas River = 125 mg/l  
 Ouachita River = 28 mg/l  
 Red River = 211 mg/l  
 St. Francis River = 103 mg/l

For the following receiving enter 0.05 in cell "C17 White River = 116 mg/l

Mississippi, Arkansas, Red River, Gulf Coastal = 31 mg/l  
 White (Below confluence with Black River) Ozark Highlands = 148 mg/l  
 Ouachita (below Confluence with Little Miss. River Boston Mount = 25 mg/l Delta = 81 mg/l

Upstream Flow (Qb) = 0.00 (Chronic) 0.00 (Acute)  
 Pollutant Concentration Upstream (Cb) = 0 ug/l  
 Water Effect Ratio(WER) 1.00  
 Cancer Risk Level 1.00E-05 (STATE); 1.00E-6 (EPA)

IWC = Instream concentration of pollutant after mixing with the receiving stream

IWC = (Cd\*Qd + Cb\*Qb)/(Qb + Qd)

Cd = Pollutant concentration in the effluent (ug/l) ; Reported value as Total

	Reported Value (Cd) (ug/l)	Cd*2.13 (ug/l)	EPA Acute (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	EPA Chronic (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	EPA Bioacc. (ug/l)	STATE Bioacc. (ug/l)	IWC Bioacc. (ug/l)	Violation of Acute	Violation of Chronic
1. Antimony Total	0.00	0.00	9000	.....	0.00	1600	.....	0.00	4300	.....	0.00	NO	NO
2. Arsenic Total	0.00	0.00	662.95	.....	0.00	349.89	.....	0.00	1.40	.....	0.00	NO	NO
3. Beryllium Total	0.00	0.00	130.00	.....	0.00	5.30	.....	0.00	0.076	.....	0.00	NO	NO
4. Cadmium Total*	0.00	0.00	.....	11.94	0.00	.....	3.58	0.00	.....	.....	0.00	NO	NO
5. Chromium (Tr)*	0.00	0.00	2256.37	.....	0.00	.....	731.94	0.00	.....	.....	0.00	NO	NO
7. Chromium (hex)	0.00	0.00	.....	15.71	0.00	.....	10.58	0.00	.....	.....	0.00	NO	NO
9. Copper Total*	0.00	0.00	.....	38.87	0.00	.....	26.41	0.00	.....	.....	0.00	NO	NO
9. Lead Total*	0.00	0.00	.....	269.04	0.00	.....	10.48	0.00	.....	.....	0.00	NO	NO
10. Mercury Total*	0.00	0.00	.....	8.46	0.00	.....	0.0120	0.00	0.15	.....	0.00	NO	NO
12. Nickel Total*	0.00	0.00	.....	2903.30	0.00	.....	289.12	0.00	4600	.....	0.00	NO	NO
13. Selenium Total	0.00	0.00	.....	20.00	0.00	.....	5.00	0.00	.....	.....	0.00	NO	NO
14. Silver Total*	0.00	0.00	.....	7.8153	0.00	.....	.....	0.00	.....	.....	0.00	NO	NO
15. Thallium Total	0.00	0.00	.....	1400	0.00	40.00	.....	0.00	6.30	.....	0.00	NO	NO
16. Zinc Total*	27.65	58.89	.....	319.04	58.89	.....	291.33	58.89	.....	.....	58.89	NO	NO
129. Phenols, Total	0.00	0.00	.....	.....	.....	.....	.....	.....	.....	.....	0.00	NO	NO
17. Cyanide Total	0.00	0.00	.....	22.36	0.00	.....	5.20	0.00	220000	.....	0.00	NO	NO

\* See linear partition coefficient (Page 6)

Reported Cd\*2.13 EPA STATE IWC EPA STATE IWC EPA STATE IWC Violation of

Value (Cd) (ug/l)	(ug/l)	Acute (ug/l)	Acute (ug/l)	Chronic (ug/l)	Chronic (ug/l)	Chronic (ug/l)	Bioacc. (ug/l)	Bioacc. (ug/l)	Acute Chr	Bio	
0.00	0.00	0.01	0.00	0.00	0.00	1.40E-07	1.00E-09	0.00	NO	NO	
DIOXIN											
18. 2,3,7,8-TCDD											
VOLATILE COMPOUNDS											
0.00	0.00	58.00	0.00	21.00	0.00	780.00	0.00	0.00	NO	NO	
0.00	0.00	7550	0.00	2600	0.00	6.60	0.00	0.00	NO	NO	
0.00	0.00	5300	0.00	0.00	0.00	710.00	0.00	0.00	NO	NO	
0.00	0.00	0.00	0.00	0.00	0.00	3600.00	0.00	0.00	NO	NO	
0.00	0.00	35200	0.00	0.00	0.00	44.00	0.00	0.00	NO	NO	
0.00	0.00	250.00	0.00	50.00	0.00	2.10E+04	0.00	0.00	NO	NO	
0.00	0.00	0.00	0.00	0.00	0.00	340.00	0.00	0.00	NO	NO	
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	NO	NO	
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	NO	NO	
0.00	0.00	28900	0.00	1240	0.00	4700.00	0.00	0.00	NO	NO	
0.00	0.00	0.00	0.00	0.00	0.00	220.00	0.00	0.00	NO	NO	
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	NO	NO	
0.00	0.00	118000	0.00	20000	0.00	990.00	0.00	0.00	NO	NO	
0.00	0.00	11600	0.00	0.00	0.00	32.00	0.00	0.00	NO	NO	
0.00	0.00	23000	0.00	5700	0.00	1700.00	0.00	0.00	NO	NO	
0.00	0.00	6060	0.00	244.00	0.00	29000.00	0.00	0.00	NO	NO	
0.00	0.00	32000	0.00	0.00	0.00	0.00	0.00	0.00	NO	NO	
0.00	0.00	0.00	0.00	0.00	0.00	4000.00	0.00	0.00	NO	NO	
0.00	0.00	0.00	0.00	0.00	0.00	16000.00	0.00	0.00	NO	NO	
0.00	0.00	8320	0.00	2400	0.00	110.00	0.00	0.00	NO	NO	
0.00	0.00	5290	0.00	840	0.00	86.50	0.00	0.00	NO	NO	
0.00	0.00	17500	0.00	0.00	0.00	2.0E+05	0.00	0.00	NO	NO	
0.00	0.00	18000	0.00	9400	0.00	420.00	0.00	0.00	NO	NO	
0.00	0.00	18000	0.00	0.00	0.00	0.00	0.00	0.00	NO	NO	
0.00	0.00	45000	0.00	21900	0.00	810.00	0.00	0.00	NO	NO	
0.00	0.00	0.00	0.00	0.00	0.00	5250.00	0.00	0.00	NO	NO	

Reported Value (Cd) (ug/l)	Cd7.13 (ug/l)	EPA Acute (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	EPA Chronic (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	EPA Bioacc. (ug/l)	STATE Bioacc. (ug/l)	IWC Bioacc. (ug/l)	Violation of Acute Chr	Bio
<b>ACID COMPOUNDS</b>												
0.00	0.00	4360		0.00	0.00		0.00			0.00	NO	NO
0.00	0.00	2020		0.00	0.00	365	0.00			0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	765.00		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	14000		0.00	NO	NO
0.00	0.00	230		0.00	0.00	150	0.00			0.00	NO	NO
0.00	0.00	30.00		0.00	0.00		0.00			0.00	NO	NO
0.00	0.00	17.08	17.08	0.00	0.00	10.78	0.00	82.00		0.00	NO	NO
0.00	0.00	10200		0.00	0.00	2560	0.00	4600000		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	65.00		0.00	NO	NO
<b>BASE/NEUTRAL COMPOUNDS</b>												
0.00	0.00	1700		0.00	0.00	520	0.00			0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	110000.00		0.00	NO	NO
0.00	0.00	2500		0.00	0.00		0.00	5.4E-03		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	0.310		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	0.310		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	0.310		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	0.310		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	0.310		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	14.00		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	1.7E+05		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	59.00		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00	1600		0.00	0.00		0.00			0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	0.310		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	0.310		0.00	NO	NO
0.00	0.00	1120		0.00	0.00	763	0.00	2600.0		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	0.770		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	1.2E+05		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	2.8E+08		0.00	NO	NO
9.73	20.72			20.72	20.72		20.72	1.2E+04		20.72	NO	NO
0.00	0.00	330		0.00	0.00	230	0.00	91.00		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00	270		0.00	0.00		0.00	5.400		0.00	NO	NO
0.00	0.00	3980		0.00	0.00		0.00	370.00		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	140000.000		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00	90.00		0.00	0.00	9.30	0.00	0.00770		0.00	NO	NO
0.00	0.00	7.00		0.00	0.00	5.20	0.00	500.000		0.00	NO	NO
0.00	0.00	980		0.00	0.00		0.00	1.70E+04		0.00	NO	NO
0.00	0.00	2.00	2.00	0.00	0.00	0.08	0.00	89.00		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00	117000		0.00	0.00		0.00	0.31000		0.00	NO	NO
0.00	0.00	2300		0.00	0.00	620	0.00	6000		0.00	NO	NO
0.00	0.00	27000		0.00	0.00		0.00	1900.00		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	81.00		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00			0.00	0.00		0.00	160.00		0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO
0.00	0.00			0.00	0.00		0.00			0.00	NO	NO

PESTICIDES

	Reported Value (Cd) (ug/l)	Cd*2.13 (ug/l)	EPA Acute (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	EPA Chronic (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	EPA Bloacc (ug/l)	STATE Bloacc (ug/l)	IWC Bloacc (ug/l)	Violation of Acute Chr	Blo
104. Aldrin	0.00	0.00	3.00	3.00	0.00	0.00	0.00	0.00	0.00140	0.00140	0.00	NO	NO
105. Alpha-BHC	0.00	0.00	2.00	2.00	0.00	0.08	0.08	0.00	1.300E-01	0.0373	0.00	NO	NO
106. Beta-BHC	0.00	0.00	2.00	2.00	0.00	0.08	0.08	0.00	0.600	0.600	0.00	NO	NO
107. Gamma-BHC	0.00	0.00	2.00	2.00	0.00	0.08	0.08	0.00	0.6300	0.6300	0.00	NO	NO
108. Delta-BHC	0.00	0.00	2.00	2.00	0.00	0.08	0.08	0.00	0.6300	0.6300	0.00	NO	NO
109. Chlordane	0.00	0.00	2.40	2.40	0.00	0.0043	0.0043	0.00	5.900E-03	0.0050	0.00	NO	NO
110. 4,4'-DDT	0.00	0.00	1.10	1.10	0.00	0.0010	0.0010	0.00	0.0059	0.0059	0.00	NO	NO
111. 4,4'-DDE	0.00	0.00	1.10	1.10	0.00	0.0010	0.0010	0.00	0.0059	0.0059	0.00	NO	NO
112. 4,4'-DDD	0.00	0.00	1.10	1.10	0.00	0.0010	0.0010	0.00	0.0084	0.0084	0.00	NO	NO
113. Dieldrin	0.00	0.00	2.50	2.50	0.00	0.0019	0.0019	0.00	1.400E-03	0.0012	0.00	NO	NO
114. Alpha-endosulfan	0.00	0.00	0.22	0.22	0.00	0.0560	0.0560	0.00	2.00	2.00	0.00	NO	NO
115. Beta-endosulfan	0.00	0.00	0.22	0.22	0.00	0.0560	0.0560	0.00	2.00	2.00	0.00	NO	NO
116. Endosulfan sulfate	0.00	0.00	0.22	0.22	0.00	0.0560	0.0560	0.00	2.00	2.00	0.00	NO	NO
117. Endrin	0.00	0.00	0.18	0.18	0.00	0.0023	0.0023	0.00	8.100E-01	0.0000	0.00	NO	NO
118. Endrin aldehyde	0.00	0.00	0.18	0.18	0.00	0.0023	0.0023	0.00	8.1000E-01	0.0000	0.00	NO	NO
119. Heptachlor	0.00	0.00	0.52	0.52	0.00	0.0038	0.0038	0.00	0.0021	0.0021	0.00	NO	NO
120. Heptachlor epoxide	0.00	0.00	0.52	0.52	0.00	0.0038	0.0038	0.00	0.0011	0.0011	0.00	NO	NO
121. PCB-1242	0.00	0.00	0.52	0.52	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO
122. PCB-1254	0.00	0.00	0.52	0.52	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO
123. PCB-1221	0.00	0.00	0.52	0.52	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO
124. PCB-1232	0.00	0.00	0.52	0.52	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO
125. PCB-1246	0.00	0.00	0.52	0.52	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO
126. PCB-1260	0.00	0.00	0.52	0.52	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO
127. PCB-1016	0.00	0.00	0.52	0.52	0.00	0.0140	0.0140	0.00	4.500E-04	4.00E-04	0.00	NO	NO
128. Toxaphene	0.00	0.00	0.73	0.73	0.00	0.00020	0.00020	0.00	4.500E-04	0.0063	0.00	NO	NO
130. Chlortpyrifos	0.00	0.00	0.083	0.083	0.00	0.041	0.041	0.00	0.0000	0.0000	0.00	NO	NO



AWQ, Reg No. 2

	Reported Value (Cd) (ug/l)	Cd <sup>2+</sup> 13 (ug/l)	STATE Acute (ug/l)	IWC Acute (ug/l)	STATE Chronic (ug/l)	IWC Chronic (ug/l)	STATE Bioacc. (ug/l)	IWC Bioacc. (ug/l)	Violation of Acute Chr	Bio
Alpha-BHC	0.00	0.00	2.00	0.00	0.08	0.00	0.0373	0.00	NO	NO
Beta-BHC	0.00	0.00	2.00	0.00	0.08	0.00			NO	NO
Gamma-BHC	0.00	0.00	2.00	0.00	0.08	0.00			NO	NO
Delta-BHC	0.00	0.00	2.00	0.00	0.08	0.00			NO	NO
Pentachlorophenol	0.00	0.00	17.06	0.00	10.76	0.00			NO	NO
Aldrin	0.00	0.00	3.00	0.00					NO	NO
Chlordane	0.00	0.00	2.40	0.00	0.0043	0.00	0.005	0.00	NO	NO
4,4'-DDT	0.00	0.00	1.10	0.00	0.0010	0.00			NO	NO
4,4'-DDE	0.00	0.00	1.10	0.00	0.0010	0.00			NO	NO
4,4'-DDD	0.00	0.00	1.10	0.00	0.0010	0.00			NO	NO
Dieldrin	0.00	0.00	2.50	0.00	0.0019	0.00	0.0012	0.00	NO	NO
Alpha-endosulfan	0.00	0.00	0.22	0.00	0.0560	0.00			NO	NO
Beta-endosulfan	0.00	0.00	0.22	0.00	0.0560	0.00			NO	NO
Endosulfan sulfate	0.00	0.00	0.22	0.00	0.0560	0.00			NO	NO
Endrin	0.00	0.00	0.18	0.00	0.0023	0.00			NO	NO
Endrin aldehyde	0.00	0.00	0.18	0.00	0.0023	0.00			NO	NO
Heptachlor	0.00	0.00	0.52	0.00	0.0038	0.00			NO	NO
Heptachlor epoxide	0.00	0.00	0.52	0.00	0.0038	0.00			NO	NO
Toxaphene	0.00	0.00	0.73	0.00	0.0002	0.00	0.0063	0.00	NO	NO
Chlorpyrifos	0.00	0.00	0.083	0.00	0.0410	0.00			NO	NO
Cadmium Total*	0.00	0.00	11.94	0.00	3.58	0.00			NO	NO
Chromium (hex)	0.00	0.00	15.71	0.00	10.58	0.00			NO	NO
Copper Total*	0.00	0.00	38.87	0.00	26.41	0.00			NO	NO
Lead Total*	0.00	0.00	269.04	0.00	10.48	0.00			NO	NO
Mercury Total*	0.00	0.00	5.46	0.00	0.0120	0.00			NO	NO
Nickel Total*	0.00	0.00	2603.30	0.00	289.12	0.00			NO	NO
Selenium Total	0.00	0.00	20.00	0.00	5.00	0.00			NO	NO
Silver Total*	0.00	0.00	7.8153	0.00					NO	NO
Zinc Total*	27.65	58.89	319.04	58.89	291.33	58.89			NO	NO
Chromium (Trn)*	0.00	0.00	2256.37	0.00	731.94	0.00			NO	NO
Cyanide Total	0.00	0.00	22.35	0.00	5.20	0.00			NO	NO
Beryllium Total	0.00	0.00					0.076	0.00	NO	NO
PCB-1242	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1254	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1221	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1232	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1248	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1260	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
PCB-1016	0.00	0.00			0.0140	0.00	4.00E-04	0.00	NO	NO
2-3-7-8-TCDD	0.00	0.00					1E-06	0.00	NO	NO

\* See Linear Partition Coefficient (Page 6)

Linear Partition Coefficients

Metals	K <sub>po</sub>	Streams	a
Arsenic	.....		-0.73
Cadmium	.....		-1.13
Chromium(3)	.....		-0.93
Copper	.....		-0.74
Lead	.....		-0.80
Mercury	.....		-1.14
Nickel	.....		-0.57
Zinc	.....		-0.70
Silver	.....		-1.03

K<sub>p</sub> = K<sub>po</sub> X TSS<sup>a</sup>

K<sub>p</sub> = Linear Partition Coefficient  
 TSS = Total Suspended Solids (mg/l)  
 K<sub>po</sub> = found from above table  
 a = found from above table

C/Ct = 1 / (1 + K<sub>p</sub> X TSS X 10<sup>-6</sup>)

C / Ct = Fraction of Metal Dissolved

Metals	K <sub>p</sub>	Streams	C / Ct
Arsenic	105193	0.5430	
Cadmium	381565	0.2469	
Chromium (3)	485809	0.2046	
Copper	223227	0.3590	
Lead	530501	0.1907	
Mercury	270941	0.3157	
Nickel	149773	0.4549	
Zinc	291573	0.3001	
Silver	281857	0.3072	

Total Metal = Dissolved Metal / (C/Ct)

AQUATIC LIFE CRITERIA (DISSOLVED ACUTE VALUES)

Pollutant	Dissolved(ug/l)	Formula
Cadmium	2.95	WER X Conversion Factor X e <sup>[(1.128ln(hardness))-3.828]</sup>
Chromium(III)	461.76	WER X 0.316 X e <sup>[0.819ln(hardness)]+3.688</sup>
Chromium(V)	15.71	WER X 0.982 X 16
Copper	13.95	WER X 0.96 X e <sup>[0.9422ln(hardness)]-1.464</sup>
Lead	51.30	WER X Conversion Factor** X e <sup>[1.273ln(hardness)]-1.460</sup>
Mercury	2.04	WER X 0.85 X 2.4
Nickel	1184.29	WER X 0.998 X e <sup>[0.8460ln(hardness)]+3.3612</sup>
Silver	2.4011	WER X 0.66 X e <sup>[1.72ln(hardness)]-6.52</sup>
Zinc	95.73	WER X 0.978 X e <sup>[0.8473ln(hardness)]+0.8604</sup>
	*	1.136672 - [(ln hardness)/(0.041838)]
	**	1.46203 - [(ln hardness)/(0.145712)]

AQUATIC LIFE CRITERIA (DISSOLVED CHRONIC VALUES)

Pollutant	Dissolved(ug/l)	Formula
Cadmium	0.89	WER X Conversion Factor* X e <sup>[0.7852ln(hardness)]-3.490</sup>
Chromium(III)	149.79	WER X 0.86 X e <sup>[0.819ln(hardness)]+1.561</sup>
Chromium(V)	10.58	WER X 10
Copper	9.48	WER X 0.96 X e <sup>[0.9545ln(hardness)]-1.465</sup>
Lead	2.00	WER X Conversion Factor** X e <sup>[1.273ln(hardness)]-4.705</sup>
Nickel	131.66	WER X 0.997 X e <sup>[0.8460ln(hardness)]+1.1645</sup>
Zinc	87.42	WER X 0.966 X e <sup>[0.8473ln(hardness)]+0.7614</sup>
	*	1.101672 - [(ln hardness)/(0.041838)]
	**	1.46203 - [(ln hardness)/(0.145712)]

## Attachment 2

### Linear Partition Coefficients for Priority Metals in Streams and Lakes\*

METAL	STREAMS		LAKES	
	K <sub>po</sub>	a	K <sub>po</sub>	a
Arsenic	0.48 X 10 <sup>6</sup>	-0.73	0.48 X 10 <sup>6</sup>	-0.73
Cadmium	4.00 X 10 <sup>6</sup>	-1.13	3.52 X 10 <sup>6</sup>	-0.92
Chromium**	3.36 X 10 <sup>6</sup>	-0.93	2.17 X 10 <sup>6</sup>	-0.27
Copper	1.04 X 10 <sup>6</sup>	-0.74	2.85 X 10 <sup>6</sup>	-0.9
Lead***	2.80 X 10 <sup>6</sup>	-0.8	2.04 X 10 <sup>6</sup>	-0.53
Mercury	2.90 X 10 <sup>6</sup>	-1.14	1.97 X 10 <sup>6</sup>	-1.17
Nickel	0.49 X 10 <sup>6</sup>	-0.57	2.21 X 10 <sup>6</sup>	-0.76
Silver****	2.40 X 10 <sup>6</sup>	-1.03	2.40 X 10 <sup>6</sup>	-1.03
Zinc	1.25 X 10 <sup>6</sup>	-0.7	3.34 X 10 <sup>6</sup>	-0.68

$$K_p = K_{po} \times TSS^a$$

K<sub>p</sub> = Linear Partition Coefficient

TSS = Total Suspended Solids (mg/l)-(See **Attachment 3**)

K<sub>po</sub> = found from table

a = found from table

$$C/C_t = 1/(1 + (K_p \times TSS \times 10^{-6})) \quad C/C_t = \text{Fraction of Metal Dissolved}$$

\* Delos, C. G., W. L. Richardson, J. V. DePinto, R. B., Ambrose, P. W. Rogers, K. Rygwelski, J. P. St. John, W. J. Shaughnessey, T. A. Faha, W. N. Christie. Technical Guidance for Performing Waste Load Allocations, Book II: Streams and Rivers. Chapter 3: Toxic Substances, for the U. S. Environmental Protection Agency.(EPA-440/4-84-022).

\*\* Linear partition coefficient shall not apply to the Chromium VI numerical criterion. The approved analytical method for Chromium VI measures only the dissolved form. Therefore permit limits for Chromium VI shall be expressed in the dissolved form. See 40 CFR 122.45(c)(3).

\*\*\* Reference page 18 of EPA memo dated March 3, 1992, from Margaret J. Stasikowski(WH-586) to Water management Division Directors, Region I-IX.

\*\*\*\* Texas Environmental Advisory Council, 1994

**Attachment 3**

**TOTAL SUSPENDED SOLIDS(15th PERCENTILE) BY RECEIVING STREAM AND ECOREGION**

For direct discharges to the Arkansas, Red, Ouachita, White, and St. Francis Rivers use the following mean values:

Receiving Stream	TSS (mg/l)
<b>Arkansas River:</b>	
Ft. Smith to Dardanelle Dam	12.0
Dardanelle Dam to Terry L&D	10.5
Terry L&D to L&D #5	8.3
L&D #5 to Mouth	9.0
<b>Red River</b>	33
<b>Ouachita River:</b>	
above Caddo River	2.0
below Caddo River	5.5
<b>White River:</b>	
above Beaver Lake	2.5
Bull Shoals to Black River	3.3
Black River to Mouth	18.5
<b>St. Francis River</b>	18

For all other discharges use the following ecoregion TSS:

Ecoregion	TSS (mg/l)
Ouachita	2
Gulf Coastal	5.5
Delta	8
Ozark Highlands	2.5
Boston Mountains	1.3
Arkansas River Valley	3

Attachment 4

**BIOMONITORING FREQUENCY RECOMMENDATION  
AND RATIONALE FOR ADDITIONAL REQUIREMENTS**

Permit Number: AR0043401

Facility Name: Jonesboro City Water and Light – East Plant

Previous Critical Dilution: 100% Proposed Critical Dilution: 100%

Date of Review: 3-24-06 Name of Reviewer: Clem

**Outfall 001**

**Number of Test Performed during previous 5 years by Species:**

*Pimephales promelas* (Fathead minnow) : 20

*Ceriodaphnia dubia* (water flea): 20

**Failed Test Dates during previous 5 years by Species:**

*Pimephales promelas* (Fathead minnow) : None

*Ceriodaphnia dubia* (water flea): None

**Previous TRE Activities:** None

**Frequency Recommendation by Species:**

*Pimephales promelas* (Fathead minnow): 4 / year

*Ceriodaphnia dubia* (water flea): 4 / year

Additional Requirements (including WET Limits): WET Limits are appropriate.

Rationale/Comments Concerning Permitting: *Continuous Planning Process, 2000, Appendix D, E., 1.b.* "For permittees with a design flow greater than or equal to 2 MGD and no known problems, the toxicity testing frequency shall be four times a year for both species."

## Attachment 5

The following locations will be used for land application of biosolids:

Field Number	Quarter Section	Section	Township	Range	Total (Acres)	Acreage (Acres)	Loading Rate (tones/year)
1	E 1/2 of NE 1/4	2	13 North	4 East	132	45.36	132
2	N 1/2 of NW 1/4	2	13 North	4 East	235	51.45	235
3	SE 1/4 of SW 1/4	35	14 North	4 East	0	22.12	0
4	SW 1/4 of SE 1/4	35	14 North	4 East	77	26.24	77
5	SE 1/4 of SE 1/4	35	14 North	4 East	0	30.13	0
6	SE 1/4 of NE 1/4	2	13 North	4 East	10	8.32	10
7	SW 1/4 of NW 1/4	2	13 North	4 East	81	14.81	81
8	SE 1/4 of NW 1/4	2	13 North	4 East	126	28.26	126
9	SE 1/4 of NE 1/4	2	13 North	4 East	169	19.62	169
10	NW 1/4 of SW 1/4	2	13 North	4 East	42	11.92	42
11	NE 1/4 of SW 1/4	2	13 North	4 East	21	6.23	21
12	NE 1/4 of SE 1/4	2	13 North	4 East	227	17.68	227
13	SE 1/4 of SW 1/4	2	13 North	4 East	88	31.68	88
14	SE 1/4 of SE 1/4	2	13 North	4 East	12	30.56	12

# DRAFT

Permit number: AR0043401

## AUTHORIZATION TO DISCHARGE WASTEWATER UNDER THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM AND THE ARKANSAS WATER AND AIR POLLUTION CONTROL ACT

In accordance with the provisions of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended, Ark. Code Ann. 8-4-101 et seq.), and the Clean Water Act (33 U.S.C. 1251 et seq.),

City Water and Light Plant of the City of Jonesboro - Eastside WWTP  
400 East Monroe  
Jonesboro, AR 72404

is authorized to discharge from a facility located as follows: approximately one mile west of the intersection of Arkansas State Highway 463 and Ingels Road, in Section 2, Township 13 North, Range 4 East in Criaghead County, Arkansas.

Latitude: 35° 47' 29"; Longitude: 90° 37' 51"

to receiving waters named:

Whiteman Creek, thence into Little Bay Ditch, thence into Ditch No. 9, thence into the Ditch No. 10, thence into the Ditch No. 23, thence into St. Francis Bay Straight Slough, thence into Straight Slough, thence into St. Francis Bay, thence into the St. Francis River in Segment 5A of the St. Francis River Basin.

The outfall is located at the following coordinates:

Outfall 001: Latitude: 35° 47' 29"; Longitude: 90° 37' 51"

Discharge shall be in accordance with effluent limitations, monitoring requirements, and other conditions set forth in Parts I, II, III, and IV hereof.

Issue date:

Effective date:

Expiration Date:

---

Martin Maner, P.E.  
Chief, Water Division  
Arkansas Department of Environmental Quality

## PART I PERMIT REQUIREMENTS

### SECTION A. INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: OUTFALL 001-treated municipal wastewater

During the period beginning on effective date and lasting until three years from the effective date, the permittee is authorized to discharge from outfall serial number 001. Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow <sup>1</sup> (MGD)	N/A	Report	Report	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)	1501	20	30	once/weekday <sup>6</sup>	24-hr composite
Total Suspended Solids (TSS)	2252	30	45	once/weekday <sup>6</sup>	24-hr composite
Ammonia Nitrogen (NH3-N)					
(May-Oct)	525	7	10.5	once/weekday <sup>6</sup>	24-hr composite
(Nov-April)	901	12	18	once/weekday <sup>6</sup>	24-hr composite
Dissolved Oxygen <sup>2</sup>					
(May-Oct)	N/A	5.0 (Monthly Avg. Min.)		once/weekday <sup>6</sup>	grab
(Nov-Apr)	N/A	7.0 (Monthly Av. Min.)		once/weekday <sup>6</sup>	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
	N/A	1000	2000	once/weekday <sup>6</sup>	grab
Total Residual Chlorine (TRC) <sup>3</sup>	N/A	<0.1 mg/l (Inst. Max.)		once/weekday <sup>6</sup>	grab
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/weekday <sup>6</sup>	grab
Whole Effluent Lethality (7-day NOEC) <sup>4,5</sup> 22414	<u>Daily Average Minimum</u> not < 100%	<u>7-day Minimum</u> not < 100%		once/quarter <sup>4</sup>	24-hr composite
<b>Pimephales promelas (Chronic)<sup>4</sup></b> Pass/Fail Lethality (7-day NOEC) TLP6C Pass/Fail Growth (7-day NOEC)TGP6C Survival (7-day NOEC) TOP6C Coefficient of Variation TQP6C Growth (7-day NOEC) TPP6C		<u>7-Day Average</u> Report (Pass=0/Fail=1) Report (Pass=0/Fail=1) Report % Report % Report %		once/quarter once/quarter once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite 24-hr composite 24-hr composite
<b>Ceriodaphnia dubia (Chronic)<sup>4</sup></b> Pass/Fail Lethality (7-day NOEC) TLP3B Pass/Fail production (7-day NOEC)TGP3B Survival (7-day NOEC) TOP3B Coefficient of Variation TQP3B Reproduction (7-day NOEC) TPP3B		<u>7-Day Average</u> Report (Pass=0/Fail=1) Report (Pass=0/Fail=1) Report % Report % Report %		once/quarter once/quarter once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite 24-hr composite 24-hr composite



# DRAFT

- 1 Report monthly average and daily maximum as MGD.
- 2 See item #27(a) of Part IV (Dissolved Oxygen).
- 3 See Condition No. 10 of Part III. (TRC Condition)
- 4 See Condition No. 9 of Part III (Biomonitoring Condition)
- 5 The NOEC (No Observed Lethal Effect Concentration) is defined as the greatest effluent dilution at and below which lethality that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Chronic lethal test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.
6. Weekday is defined as Monday through Friday.

---

There shall be no discharge of distinctly visible solids, scum or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit except for flows are measured prior to the chlorination unit.

## PART I PERMIT REQUIREMENTS

### SECTION A. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: OUTFALL 001-treated municipal wastewater

During the period beginning three years from the effective date and lasting until date of expiration, the permittee is authorized to discharge from outfall serial number 001. Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day, unless otherwise specified)	Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
		Monthly Avg.	Monthly Avg.		
Flow <sup>1</sup> (MGD)	N/A	Report	Report	once/day	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)	1501	20	30	once/weekday <sup>6</sup>	24-hr composite
Total Suspended Solids (TSS)	2252	30	45	once/weekday <sup>6</sup>	24-hr composite
Ammonia Nitrogen (NH3-N)					
(April -Oct)	158	2.1	5.2	once/weekday <sup>6</sup>	24-hr composite
(Nov-March)	443	5.9	10.5	once/weekday <sup>6</sup>	24-hr composite
Dissolved Oxygen <sup>2</sup>					
(May-Oct)	N/A	5.0 (Monthly Avg. Min.)		once/weekday <sup>6</sup>	grab
(Nov-Apr)	N/A	7.0 (Monthly Avg. Min.)		once/weekday <sup>6</sup>	grab
Fecal Coliform Bacteria (FCB)		(colonies/100ml)			
	N/A	1000	2000	once/weekday <sup>6</sup>	grab
Total Residual Chlorine (TRC) <sup>3</sup>	N/A	<0.1 mg/l (Inst. Max.)		once/weekday <sup>6</sup>	once/weekday <sup>6</sup>
pH	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/weekday <sup>6</sup>	grab
Whole Effluent Lethality (7-day NOEC) <sup>4,5</sup> 22414	<u>Daily Average Minimum</u> not < 100%	<u>7-day Minimum</u> not < 100%		once/quarter <sup>4</sup>	24-hr composite
<b>Pimephales promelas (Chronic)<sup>4</sup></b> Pass/Fail Lethality (7-day NOEC) TLP6C Pass/Fail Growth (7-day NOEC)TGP6C Survival (7-day NOEC) TOP6C Coefficient of Variation TQP6C Growth (7-day NOEC) TPP6C		<u>7-Day Average</u> Report (Pass=0/Fail=1) Report (Pass=0/Fail=1) Report % Report % Report %		once/quarter once/quarter once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite 24-hr composite 24-hr composite
<b>Ceriodaphnia dubia (Chronic)<sup>4</sup></b> Pass/Fail Lethality (7-day NOEC) TLP3B Pass/Fail production (7-day NOEC)TGP3B Survival (7-day NOEC) TOP3B Coefficient of Variation TQP3B Reproduction (7-day NOEC) TPP3B		<u>7-Day Average</u> Report (Pass=0/Fail=1) Report (Pass=0/Fail=1) Report % Report % Report %		once/quarter once/quarter once/quarter once/quarter once/quarter	24-hr composite 24-hr composite 24-hr composite 24-hr composite 24-hr composite

# DRAFT

Permit number: AR0043401  
Page 4 of Part IA

- 1 Report monthly average and daily maximum as MGD.
- 2 See item #27(a) of Part IV (Dissolved Oxygen).
- 3 See Condition No. 10 of Part III. (TRC Condition)
- 4 See Condition No. 9 of Part III (Biomonitoring Condition)
- 5 The NOEC (No Observed Lethal Effect Concentration) is defined as the greatest effluent dilution at and below which lethality that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Chronic lethal test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.
6. Weekday is defined as Monday through Friday.

---

There shall be no discharge of distinctly visible solids, scum or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits or sludge banks. There shall be no visible sheen due to the presence of oil (Sheen means an iridescent appearance on the surface of the water).

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit except for flows are measured prior to the chlorination unit.

# DRAFT

Permit number: AR0043401  
Page 1 of Part IB

## SECTION B. SCHEDULE OF COMPLIANCE

The permittee shall achieve compliance with the effluent limitations specified for discharges in accordance with the following schedule:

### Interim Limits:

Compliance is required on the effective date of the permit.

### Final Limits:

The permittee shall submit progress reports to the NPDES Enforcement Section addressing the progress towards attaining the final effluent limits for Ammonia-Nitrogen at Outfall 001 according to the following schedule:

<u>ACTIVITY</u>	<u>DUE DATE</u>
Progress Report	one (1) year from effective date of permit
Progress Report	two (2) years from effective date of permit
Achieve Final Limits	three (3) years from effective date of permit

# DRAFT

Permit number: AR0043401  
Page 1 of Part II

## PART II STANDARD CONDITIONS

### SECTION A – GENERAL CONDITIONS

#### 1. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the federal Clean Water Act and the Arkansas Water and Air Pollution Control Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. **Any values reported in the required Discharge Monitoring Report, which are in excess of an effluent limitation specified in Part I shall constitute evidence of violation of such effluent limitation and of this permit.**

#### 2. Penalties for Violations of Permit Conditions

The Arkansas Water and Air Pollution Control Act provides that any person who violates any provisions of a permit issued under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year, or a fine of not more than ten thousand dollars (\$10,000) or by both such fine and imprisonment for each day of such violation. Any person who violates any provision of a permit issued under the Act may also be subject to civil penalty in such amount, as the court shall find appropriate, not to exceed ten thousand dollars (\$10,000) for each day of such violation. The fact that any such violation may constitute a misdemeanor shall not be a bar to the maintenance of such civil action.

#### 3. Permit Actions

This permit may be modified, revoked and reissued, or terminated for causes including, but not limited to the following:

- a. Violation of any terms or conditions of this permit; or
- b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
- c. A change in any conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- d. A determination that the permitted activity endangers human health or the environment and can only be regulated to acceptable levels by permit modification or termination.
- e. Failure of the permittee to comply with the provisions of APCEC Regulation No. 9 (Permit fees) as required by Condition II A.10 herein.

# DRAFT

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

## 4. Toxic Pollutants

Notwithstanding Part II.A.3., if any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under Regulation No. 2, as amended, (regulation establishing water quality standards for surface waters of the State of Arkansas) or Section 307(a) of the Clean Water Act for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitations on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standards or prohibition and the permittee so notified.

The permittee shall comply with effluent standards, narrative criteria, prohibitions established under Regulation No. 2 (Arkansas Water Quality Standards), as amended, or Section 307 (a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

## 5. Civil and Criminal Liability

Except as provided in permit conditions on “Bypassing” (Part II.B.4.a.), and “Upsets” (Part II.B.5.b), nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. Any false or materially misleading representation or concealment of information required to be reported by the provisions of this permit or applicable state and federal statutes or regulations which defeats the regulatory purposes of the permit may subject the permittee to criminal enforcement pursuant to the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).

## 6. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Section 311 of the Clean Water Act.

## 7. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation under authority preserved by Section 510 of the Clean Water Act.

# DRAFT

## 8. Property Rights

The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

## 9. Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provisions of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

## 10. Permit Fees

The permittee shall comply with all applicable permit fee requirements for wastewater discharge permits as described in APCEC Regulation No. 9 (Regulation for the Fee System for Environmental Permits). Failure to promptly remit all required fees shall be grounds for the Director to initiate action to terminate this permit under the provisions of 40 CFR 122.64 and 124.5 (d), as adopted in APCEC Regulation No. 6 and the provisions of APCEC Regulation No. 8.

## SECTION B – OPERATION AND MAINTENANCE OF POLLUTION CONTROLS

### 1. Proper Operation and Maintenance

- a. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems, which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
- b. The permittee shall provide an adequate operating staff, which is duly qualified to carryout operation, maintenance and testing functions required to insure compliance with the conditions of this permit.

### 2. Need to Halt or Reduce not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. Upon reduction, loss, or failure of the treatment facility, the permittee shall, to the extent necessary to maintain compliance with its permit, control production or

# DRAFT

discharges or both until the facility is restored or an alternative method of treatment is provided. This requirement applies, for example, when the primary source of power for the treatment facility is reduced, is lost, or alternate power supply fails.

### 3. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit, which has a reasonable likelihood of adversely affecting human health or the environment, or the water receiving the discharge.

### 4. Bypass of Treatment Facilities

#### a. Bypass not exceeding limitation.

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Part II.B 4.b.and 4.c.

#### b. Notice

- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
- (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Part II.D.6 (24-hour notice).

#### c. Prohibition of bypass

- (1) Bypass is prohibited and the Director may take enforcement action against a permittee for bypass, unless:
  - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
  - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if the permittee could have installed adequate backup equipment to prevent a bypass which occurred during normal or preventive maintenance; and
  - (c) The permittee submitted notices as required by Part II.B.4.b.
- (2) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in Part II.B.4.c(1).



# DRAFT

## 5. Upset Conditions

- a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Part II.B.5.b of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- b. Conditions necessary for demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (1) An upset occurred and that the permittee can identify the specific cause(s) of the upset.
  - (2) The permitted facility was at the time being properly operated.
  - (3) The permittee submitted notice of the upset as required by Part II.D.6.: and
  - (4) The permittee complied with any remedial measures required by Part II.B.3.
- c. Burden of proof. In any enforcement proceeding the permittee, seeking to establish the occurrence of an upset has the burden of proof.

## 6. Removed Substances

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering the waters of the State. Written approval must be obtained from the ADEQ for land application only.

## 7. Power Failure

The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failure either by means of alternate power sources, standby generators, or retention of inadequately treated effluent.

## SECTION C – MONITORING AND RECORDS

### 1. Representative Sampling

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points shall not be changed without notification to and the approval of the Director. Intermittent discharges shall be monitored.

# DRAFT

## 2. Flow Measurement

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to insure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure the accuracy of the measurements are consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than +/- 10% from true discharge rates throughout the range of expected discharge volumes and shall be installed at the monitoring point of the discharge.

## 3. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals frequent enough to insure accuracy of measurements and shall insure that both calibration and maintenance activities will be conducted. An adequate analytical quality control program, including the analysis of sufficient standards, spikes, and duplicate samples to insure the accuracy of all required analytical results shall be maintained by the permittee or designated commercial laboratory. At a minimum, spikes and duplicate samples are to be analyzed on 10% of the samples.

## 4. Penalties for Tampering

The Arkansas Water and Air Pollution Control Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year or a fine of not more than ten thousand dollars (\$10,000) or by both such fine and imprisonment.

## 5. Reporting of Monitoring Results

Monitoring results must be reported on a Discharge Monitoring Report (DMR) form (EPA No. 3320-1). Permittees are required to use preprinted DMR forms provided by ADEQ, unless specific written authorization to use other reporting forms is obtained from ADEQ. Monitoring results obtained during the previous calendar month shall be summarized and reported on a DMR form postmarked no later than the 25<sup>th</sup> day of the month, following the completed reporting period to begin on the effective date of the permit. Duplicate copies of DMR forms signed and certified as required by Part II.d.11 and all other reports required by Part II.D. (Reporting Requirements), shall be submitted to the Director at the following address:

# DRAFT

Permit number: AR0043401  
Page 7 of Part II

NPDES Enforcement Section  
Water Division  
Arkansas Department of Environmental Quality  
8001 National Drive  
P.O. Box 8913  
Little Rock, AR 72219-8913

If permittee uses outside laboratory facilities for sampling and/or analysis, the name and address of the contract laboratory shall be included on the DMR.

## 6. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR. Such increased frequency shall also be indicated on the DMR.

## 7. Retention of Records

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit for a period of at least 3 years from the date of the sample, measurement, report or application. This period may be extended by request of the Director at any time.

## 8. Record Contents

Records and monitoring information shall include:

- a. The date, exact place, time and methods of sampling or measurements, and preservatives used, if any;
- b. The individuals(s) who performed the sampling or measurements;
- c. The date(s) and time analyses were performed;
- d. The individual(s) who performed the analyses;
- e. The analytical techniques or methods used; and
- f. The measurements and results of such analyses.

## 9. Inspection and Entry

The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

# DRAFT

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, and
- d. Sample, inspect or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

## SECTION D – REPORTING REQUIREMENTS

### 1. Planned Changes

The permittee shall give notice and provide plans and specification to the Director for review and approval prior to any planned physical alterations or additions to the permitted facility. Notice is required only when:

#### *For Industrial Dischargers*

- a. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR Part 122.29(b).
- b. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR Part 122.42 (a)(1).

#### *For POTW Dischargers:*

Any change in the facility discharge (including the introduction of any new source or significant discharge or significant changes in the quantity or quality of existing discharges of pollutants) must be reported to the permitting authority. In no case are any new connections, increased flows, or significant changes in influent quality permitted that cause violation of the effluent limitations specified herein.

### 2. Anticipated Noncompliance

The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

# DRAFT

### 3. Transfers

The permit is nontransferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act.

### 4. Monitoring Reports

Monitoring results shall be reported at the intervals and in the form specified in Part II.C.5. (Reporting). **Discharge Monitoring Reports must be submitted even when no discharge occurs during the reporting period.**

### 5. Compliance Schedule

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date. Any reports of noncompliance shall include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirement.

### 6. Twenty-four Hour Report

- a. The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain the following information:
  - (1) a description of the noncompliance and its cause;
  - (2) the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and
  - (3) steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance.
- b. The following shall be included as information which must be reported within 24 hours:
  - (1) Any unanticipated bypass which exceeds any effluent limitation in the permit;
  - (2) Any upset which exceeds any effluent limitation in the permit and
  - (3) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in Part I of the permit to be reported within 24 hours to the ADEQ Enforcement Section of Water Division.
- c. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours to the ADEQ Enforcement Section of Water Division.

# DRAFT

Permit number: AR0043401

Page 10 of Part II

## 7. Other Noncompliance

The permittee shall report all instances of noncompliance not reported under Part II.D.4,5 and 6, at the time monitoring reports are submitted. The reports shall contain the information listed at Part II.D.6.

## 8. Changes in Discharge of Toxic Substances for Industrial Dischargers

The permittee shall notify the Director as soon as he/she knows or has reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, in a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the “notification levels” described in 40 CFR Part 122.42(a)(1).
- b. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit if that discharge will exceed the highest of the “notification levels” described in 40 CFR Part 122.42(a)(2).

## 9. Duty to Provide Information

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit. Information shall be submitted in the form, manner and time frame requested by the Director.

## 10. Duty to reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The complete application shall be submitted at least 180 days before the expiration date of this permit. The Director may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date. Continuation of expiring permits shall be governed by regulations promulgated in APCEC Regulation No. 6.

## 11. Signatory Requirements

All applications, reports or information submitted to the Director shall be signed and certified as follows:

- a. All permit applications shall be signed as follows:

# DRAFT

- (1) For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
    - (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or
    - (ii) The manager of one or more manufacturing, production, or operation facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
  - (2) For a partnership or sole proprietorship: by a general partner or proprietor, respectively; or
  - (3) For a municipality, State, Federal, or other public agency; by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes:
    - (i) The chief executive officer of the agency; or
    - (ii) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.
- b. All **reports** required by the permit and **other information** requested by the Director shall be signed by a person described above or by a duly authorized representative of that person.
- A person is a duly authorized representative only if:
- (1) The authorization is made in writing by a person described above;
  - (2) The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility. (A duly authorized representative may thus be either a named individual or any individual occupying a named position); and
  - (3) The written authorization is submitted to the Director.
- c. Certification. Any person signing a document under this section shall make the following certification:
- “I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant

# DRAFT

Permit number: AR0043401  
Page 12 of Part II

penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

## 12. Availability of Reports

Except for data determined to be confidential under 40 CFR Part 2 and Regulation 6, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department of Environmental Quality. As required by the Regulations, the name and address of any permit applicant or permittee, permit applications, permits and effluent data shall not be considered confidential.

## 13. Penalties for Falsification of Reports

The Arkansas Air and Water Pollution Control Act provides that any person who knowingly makes any false statement, representation, or certification in any application, record, report, plan or other document filed or required to be maintained under this permit shall be subject to civil penalties specified in Part II.A.2 and/or criminal penalties under the authority of the Arkansas Water and Air Pollution Control Act (Act 472 of 1949, as amended).



# DRAFT

Permit number: AR0043401  
Page 1 of Part III

## PART III OTHER CONDITIONS

1. The operator of this wastewater treatment facility shall be licensed as Class III by the State of Arkansas in accordance with Act 211 of 1971, Act 1103 of 1991, Act 556 of 1993, and Regulation No. 3, as amended.
2. For publicly owned treatment works, the 30-day average percent removal for Biochemical Oxygen Demand (BOD5) or Carbonaceous Biochemical Oxygen Demand (CBOD5) and Total Suspended Solids shall not be less than 85 percent unless otherwise authorized by the permitting authority in accordance with 40 CFR 133.102, as adopted by reference in APCEC Regulation No. 6.
2. Produced sludge shall be disposed of by land application only when meeting the following criteria:
  - a. Sewage sludge from treatment works treating domestic sewage (TWTDS) must meet the applicable provisions of 40 CFR Part 503; and
  - b. The sewage sludge has not been classified as a hazardous waste under state or federal regulations.
3. The permittee shall give at least 120 days prior notice to the Director of any change planned in the permittee's sludge disposal practice or land use applications, including types of crops grown (if applicable).
4. The permittee shall report all overflows with the Discharge Monitoring report (DMR) submittal. These reports shall be summarized and reported in tabular format. The summaries shall include: the date, time, duration, location, estimated volume, and cause of overflow; observed environmental impacts from the overflow; action taken to address the overflow; and ultimate discharge location if not contained (e.g., storm sewer system, ditch, tributary.) Overflows which endanger health or the environment shall be orally reported to this department (Enforcement Section of Water Division), within 24 hours from the time the permittee becomes aware of the circumstance. A written report of overflows which endanger health or the environment, shall be provided within 5 days of the time the permittee becomes aware of the circumstance.
5. In accordance with 40 CFR Parts 122.62 (a) (2) and 124.5, this permit may be reopened for modification or revocation and/or reissuance to require additional monitoring and/or effluent limitations when new information is received that actual or potential exceedance of State water quality criteria and/or narrative criteria are determined to be the result of the permittee's discharge(s) to a relevant water body, or a Total Maximum Daily Load (TMDL) is established or revised for the water body that was not available at the time of the permit

# DRAFT

- (2) The frequency and nature of industrial user compliance monitoring activities by the permittee shall be commensurate with the character, consistency and volume of waste. The permittee must inspect and sample the effluent from each Significant Industrial User in accordance with 40 CFR 403.8(f)(2)(v). This is in addition to any industrial self-monitoring activities;
- (3) The permittee shall enforce and obtain remedies for noncompliance by any industrial users with applicable pretreatment standards and requirements;
- (4) The permittee shall control through permit, order, or similar means, the contribution to the POTW by each Industrial User to ensure compliance with applicable Pretreatment Standards and Requirements. In the case of Industrial Users identified as significant under 40 CFR 403.3 (v), this control shall be achieved through individual or general control mechanisms, in accordance with 40 CFR 403.8(f)(1)(iii). Both individual and general control mechanisms must be enforceable and contain, at a minimum, the following conditions:
  - (i) Statement of duration (in no case more than five years);
  - (ii) Statement of non-transferability without, at a minimum, prior notification to the POTW and provision of a copy of the existing control mechanism to the new owner or operator;
  - (iii) Effluent limits, including Best Management Practices, based on applicable general Pretreatment Standards, categorical Pretreatment Standards, local limits, and State and local law;
  - (iv) Self-monitoring, sampling, reporting, notification and recordkeeping requirements, including an identification of the pollutants to be monitored (including the process for seeking a waiver for a pollutant neither present nor expected to be present in the Discharge in accordance with § 403.12(e)(2), or a specific waiver for a pollutant in the case of an individual control mechanism), sampling location, sampling frequency, and sample type, based on the applicable general Pretreatment Standards in 40 CFR 403, categorical Pretreatment Standards, local limits, and State and local law;
  - (v) Statement of applicable civil and criminal penalties for violation of Pretreatment Standards and requirements, and any applicable compliance schedule. Such schedules may not extend the compliance date beyond federal deadlines; and
  - (vi) Requirements to control slug discharges, if determined by the POTW to be necessary.

# DRAFT

issuance that would have justified the application of different permit conditions at the time of permit issuance.

## 6. Other Specified Monitoring Requirements

The permittee may use alternative appropriate monitoring methods and analytical instruments other than as specified in Part I Section A of the permit without a major permit modification under the following conditions:

- The monitoring and analytical instruments are consistent with accepted scientific practices;
- The requests shall be submitted in writing to the NPDES Section of the Water Division of the ADEQ for use of the alternate method or instrument.
- The method and/or instrument is in compliance with 40 CFR 136 or acceptable to the Director; and
- All associated devices are installed, calibrated, and maintained to insure the accuracy of the measurements and are consistent with accepted capability of that type of device. The calibration and maintenance shall be performed as part of the permittee's laboratory Quality Control/Quality Assurance program.

Upon written approval of the alternative monitoring method and/or analytical instruments, these methods or instruments must be consistently utilized throughout the monitoring period. ADEQ must be notified in writing and the permittee must receive written approval from ADEQ, if the permittee decides to return to the original permit monitoring requirements.

## 7. CONTRIBUTING INDUSTRIES AND PRETREATMENT REQUIREMENTS

- a. The permittee shall operate an industrial pretreatment program in accordance with Section 402(b)(8) of the Clean Water Act, the General Pretreatment Regulations (40 CFR Part 403) and the approved POTW pretreatment program submitted by the permittee. The pretreatment program was approved on November 1, 1983 and modified on May 15, 1990. The Sewer Use Ordinance and the Pretreatment Program have not been modified to come into compliance with the current 40 CFR 403 regulations. The permittee shall submit all necessary proposed modifications to ADEQ within six (6) months of the effective date of this permit. The POTW pretreatment program is hereby incorporated by reference and shall be implemented in a manner consistent with the following requirements:

- (1) Industrial user information shall be updated at a frequency adequate to ensure that all IUs are properly characterized at all times;

# DRAFT

Permit number: AR0043401

Page 4 of Part III

- (5) The permittee shall evaluate, whether each Significant Industrial User needs a plan or other action to control slug discharges, in accordance with 40 CFR 403.8(f)(2)(vi);
  - (6) The permittee shall provide adequate staff, equipment, and support capabilities to carry out all elements of the pretreatment program; and
  - (7) The approved program shall not be modified by the permittee without the prior approval of ADEQ.
- b. The permittee shall establish and enforce specific limits to implement the provisions of 40 CFR Parts 403.5(a) and (b), as required by 40 CFR Part 403.5(c). POTWs may develop Best Management Practices (BMPs) to implement paragraphs 40 CFR 403.5 (c)(1) and (c)(2). Such BMPs shall be considered local limits and Pretreatment Standards. Each POTW with an approved pretreatment program shall continue to develop these limits as necessary and effectively enforce such limits.

The permittee shall, within sixty (60) days of the effective date of this permit, (1) submit a **WRITTEN CERTIFICATION** that a technical evaluation has been demonstrated that the existing technically based local limits (TBLL) are based on current state water quality standards and are adequate to prevent pass through of pollutants, inhibition of or interference with the treatment facility, worker health and safety problems, and sludge contamination, **OR** (2) submit a **WRITTEN NOTIFICATION** that a technical evaluation revising the current TBLL and a draft sewer use ordinance which incorporates such revisions will be submitted within 12 months of the effective date of this permit.

All specific prohibitions or limits developed under this requirement are deemed to be conditions of this permit. The specific prohibitions set out in 40 CFR Part 403.5(b) shall be enforced by the permittee unless modified under this provision.

- c. The permittee shall analyze the treatment facility influent and effluent for the presence of the toxic pollutants listed in 40 CFR 122 Appendix D (NPDES Application Testing Requirements) Table II at least once/year and the toxic pollutants in Table III at least 4 times/year (quarterly). If, based upon information available to the permittee, there is reason to suspect the presence of any toxic or hazardous pollutant listed in Table V, or any other pollutant, known or suspected to adversely affect treatment plant operation, receiving water quality, or solids disposal procedures, analysis for those pollutants shall be performed at least 4 times/year (quarterly) on both the influent and the effluent.

The influent and effluent samples collected shall be composite samples consisting of at least 12 aliquots collected at approximately equal intervals over a

# DRAFT

representative 24 hour period and composited according to flow. Sampling and analytical procedures shall be in accordance with guidelines established in 40 CFR 136. Where composite samples are inappropriate, due to sampling, holding time, or analytical constraints, at least 4 grab samples, taken at equal intervals over a representative 24 hour period, shall be taken.

- d. The permittee shall prepare annually a list of Industrial Users which during the preceding twelve months were in significant noncompliance with applicable pretreatment requirements. For the purposes of this Part, significant noncompliance shall be determined based upon the more stringent of either criteria established at 40 CFR Part 403.8(f)(2)(viii) [rev. 10/14/05] or criteria established in the approved POTW pretreatment program. This list is to be published annually in the newspaper of general circulation that provides meaningful public notice within the jurisdiction(s) served by the POTW during the month of **December**.

In addition, during the month of **December** the permittee shall submit an updated pretreatment program status report to EPA and the State containing the following information:

- (1) An updated list of all significant industrial users. The list must also identify Industrial Users subject to categorical Pretreatment Standards that are subject to reduced reporting requirements under 40 CFR 403.12(e)(3), and identify which Industrial Users are Non-Significant Categorical Industrial Users. For each industrial user listed the following information shall be included:
  - (i) Standard Industrial Classification (SIC) or NAISC code and categorical determination;
  - (ii) Control document status. Whether the user has an effective control document, and the date such document was last issued, reissued, or modified, (indicate which industrial users were added to the system (or newly identified) within the previous 12 months);
  - (iii) A summary of all monitoring activities performed within the previous 12 months. The following information shall be reported:
    - \* total number of inspections performed;
    - \* total number of sampling visits made;
  - (iv) Status of compliance with both effluent limitations and reporting requirements. Compliance status shall be defined as follows:

# DRAFT

- \* Compliant (C) - no violations during the previous 12 month period;
- \* Non-compliant (NC) - one or more violations during the previous 12 months but does not meet the criteria for significantly noncompliant industrial users;
- \* Significant Noncompliance (SNC) - in accordance with requirements described in d. above; and

(v) For significantly noncompliant industrial users, indicate the nature of the violations, the type and number of actions taken (notice of violation, administrative order, criminal or civil suit, fines or penalties collected, etc.) and current compliance status. If ANY industrial user was on a schedule to attain compliance with effluent limits, indicate the date the schedule was issued and the date compliance is to be attained;

(2) A list of all significant industrial users whose authorization to discharge was terminated or revoked during the preceding 12 month period and the reason for termination;

(3) A report on any interference, pass through, upset or POTW permit violations known or suspected to be caused by industrial contributors and actions taken by the permittee in response;

*Part III (7)(c) X* (4) The results of all influent and effluent analyses performed pursuant to ~~Part III(A)(1)(e)~~ *paragraph (c) X* above;

(5) A copy of the newspaper publication of the significantly noncompliant industrial users giving the name of the newspaper and the date published;

(6) The information requested may be submitted in tabular form as per the example tables provided for your convenience (See Attachment A, B and C); and

(7) The monthly average water quality based effluent concentration necessary to meet the state water quality standards as developed in the approved technically based local limits.

e. The permittee shall provide adequate notice of the following:

# DRAFT

Permit number: AR0043401  
Page 7 of Part III

- (1) Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 and 306 of the Act if it were directly discharging those pollutants; and
- (2) Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.

Adequate notice shall include information on (i) the quality and quantity of effluent to be introduced into the treatment works, and (ii) any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.

## 8. ADDITIONAL CONDITIONS FOR LAND APPLICATION OF BIOSOLIDS

Sludge is thickened in a series of sludge storage tanks then land applied at the approved locations (See Attachment 5).

### A. GENERAL REQUIREMENTS:

1. Only biosolids which are not classified as a hazardous waste under state or federal regulations may be land applied.
2. Plant Available Nitrogen (PAN) will not be applied at a rate exceeding the annual nitrogen uptake of the crop. At no time will the nitrogen application rate (PAN/acre-year) be allowed to exceed the site specific rate approved by the Department.
3. Biosolids with Polychlorinated Biphenyls (PCB's) concentrations equal or greater than 50 mg/kg (dry basis) will not be land applied at any time.
4. **CEILING CONCENTRATIONS** (milligrams per kilogram, dry weight basis): If the biosolids to be land applied exceed any of the pollutant concentrations listed in **Table 1** below, the biosolids shall not be land applied.

<b>TABLE 1</b>	
<b>Element</b>	<b>Concentration (mg/kg)</b>
Arsenic	75
Cadmium	85
Chromium	*
Copper	4,300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
Selenium	100
Zinc	7,500

\* This value is being reevaluated by US EPA.

5. **POLLUTANTS LIMITS:** When bulk biosolids are applied to agricultural land, forest, a public contact site, or reclamation site, the permittee shall not exceed the Cumulative Pollutant Loading Rate values listed in **Table 2**, or the Pollutant Concentration values listed in **Table 3**.

<b>TABLE 2</b>		
<b>Element</b>	<b>Cumulative Pollutant Loading Rate</b>	
	<b>kg/ha</b>	<b>lbs/ac</b>
Arsenic	41	37
Cadmium	39	35
Chromium	*	*
Copper	1,500	1,350
Lead	300	270
Mercury	17	15
Molybdenum	*	*
Nickel	420	378
Selenium	100	90
Zinc	2,800	2,520

\* These values are being reevaluated by US EPA.



<u>Element</u>	<u>Monthly Average Concentration (mg/kg)</u>
Arsenic	41
Cadmium	39
Chromium	*
Copper	1,500
Lead	300
Mercury	17
Molybdenum	*
Nickel	420
Selenium	36
Zinc	2,800

\* These values are being reevaluated by US EPA.

6. The biosolids generator must issue a signed certification stating that the Pathogen Reduction, Vector Attraction Reduction, and Pollutant Concentration Limits have been met. The State requirements on Pathogen Reduction, Vector Attraction Reduction, and Pollutant Concentration Limits are the same as those listed in 40 CFR Part 503. All the above information must be made available to the land-applicator before the biosolids materials are delivered. Concurrently, a signed copy of each certification must be also submitted to the ADEQ Water Division.
7. Biosolids can only be stored in accordance with the permit and the approved waste management plan, if provisions are made in the plan for that purpose. The utilization of improvised field storage sites or any other site not approved by the Department is strictly prohibited.
8. Transportation of the biosolids must be such that will prevent the attraction, harborage or breeding of insects or rodents. It must not produce conditions harmful to public health, the environment, odors, unsightliness, nuisances, or safety hazards.
9. The containers used for the transportation of the biosolids must be of the closed type. Transportation equipment must be leak-proof and kept in a top sanitary condition at all times. Biosolids must be enclosed or covered as to prevent littering, vector attraction, or any other nuisances.
10. The permittee will be responsible for assuring that the land owner, of any land application site not owned by the permittee, and the waste applicator, if different from the permittee, abide by the conditions of this permit.

# DRAFT

11. Biosolids will be spread evenly over the application area and in no way biosolids will be allowed to enter the waters of the State.
12. Biosolids will not be applied to slopes with a gradient greater than 15%; or to soils that are saturated, frozen or covered with snow, during rain, or when precipitation is imminent.
13. The permittee will not cause any underground drinking water source to exceed the limitations in 40 CFR Part 257, Appendix I.
14. The permittee will not cause or contribute to the taking of life or the destruction or adverse modification of the critical habitat of any known endangered or threatened species of plant, fish or wildlife.
15. The permittee will take all necessary measures to reduce obnoxious and offensive odors. Equipment will be maintained and operated to prevent spillage and leakage.
16. Disposal of wastewater biosolids in a flood plain will not restrict the flow of the base flood, reduce the temporary storage capacity of the flood plain, or result in a washout of solid waste, so as to pose a hazard to human life, wildlife or land and water uses.
17. Biosolids will not be spread within 50 feet of rock outcrops and property lines; 100 feet of lakes, ponds, springs, streams, wetlands and sinkholes; 200 feet of drinking water wells; 300 feet of occupied buildings and streams classified as an "extraordinary resource water body."
18. All new land application sites must have a waste management plan approved by the Department prior to land application of wastewater biosolids. This change normally requires a permit modification.

## **B. MONITORING AND REPORTING REQUIREMENTS:**

1. The permittee will be responsible for the biosolids analyses, soil analyses, and a reporting schedule that must include the following:
  - a. Biosolids Analysis
    - (1) Biosolids samples collected must be representative of the treated biosolids to be land applied. The samples are to be stored in appropriate containers and kept refrigerated or frozen to prevent any change in composition.

# DRAFT

- (2) Quarterly representative samples of the land-applied biosolids will be analyzed and results expressed in dry basis in mg/kg, except as otherwise indicated:

Volatile Solids(%)	Total Kjeldahl Nitrogen
Total Solids(%)	Total Phosphorus
Nitrate +Nitrate Nitrogen	Total Potassium
Ammonia Nitrogen	Arsenic
Cadmium	Copper
Lead	Mercury
Nickel	Selenium
Zinc	pH (SU)

b. Soils Analysis

- (1) Each land application site will be soil tested *Starting gas test* ~~in the Spring~~ prior to application for the following parameters:

Nitrate-Nitrogen	Potassium
Phosphorus	Magnesium
Arsenic	Cadmium
Copper	Lead
Mercury	Nickel
Selenium	Zinc
pH	
Cation Exchange Capacity (me/100g)	
Salt Content (micro-mohs/cm)	

c. Reporting

- (1) Annual reports will be sent to the Department and to the owner of the land receiving biosolids prior to May 1, which must include the following:

The biosolids and soil analyses conducted under section a. above (including a statement that the analyses were performed in accordance with EPA Document SW-846, "Test Methods for Evaluation of Solid Waste," or other procedures approved by the Director), application dates and locations, volumes of biosolids applied (in dry tons/acre-year and gallons/acre-year of biosolids), methods of disposal, identity of hauler, and type of crop grown, amounts of nitrogen applied, total elements added that year (lbs/acre), total elements applied to date, and copies of soil analyses for each site.

# DRAFT

- (2) The permittee will also maintain copies of the above records for Department personnel review at the biosolids generating facility.

## 9. WHOLE EFFLUENT TOXICITY TESTING (WET LIMITS, 7-DAY CHRONIC NOEC FRESHWATER)

### 1. SCOPE AND METHODOLOGY

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL:	001
CRITICAL DILUTION (%):	100
EFFLUENT DILUTION SERIES (%):	32, 42, 56, 75, 100
COMPOSITE SAMPLE TYPE:	Defined at PART I
TEST SPECIES/METHODS:	40 CFR Part 136

Ceriodaphnia dubia chronic static renewal survival and reproduction test, Method 1002.0, EPA/600/4-91/002 or the most recent update thereof. This test should be terminated when 60% of the surviving adults in the control produce three broods.

Pimephales promelas (Fathead minnow) chronic static renewal 7-day larval survival and growth test, Method 1000.0, EPA/600/4-91/002, or the most recent update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Effect Concentration) is defined as the greatest effluent dilution at and below which lethality that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Chronic lethal test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.
- c. When the testing frequency stated above is less than monthly and the effluent fails the survival endpoint at the critical dilution, the permittee shall be considered in violation of this permit limit and the frequency for the affected species will increase to monthly until such time compliance with the Lethal No Observed Effluent Concentration (NOEC) effluent limitation is demonstrated for a period of three consecutive months, at which time the permittee may return to the testing

frequency stated in Part I of this permit. During the period the permittee is out of compliance, test results shall be reported on the DMR for that reporting period.

- d. This permit may be reopened to require chemical specific effluent limits, additional testing, toxicity reduction evaluation, and/or other appropriate actions to address toxicity.
- e. Test failure is defined as a demonstration of statistically significant sub-lethal or lethal effects to a test species at or below the effluent critical dilution.

## 2. REQUIRED TOXICITY TESTING CONDITIONS

### a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- i. The toxicity test control (0% effluent) must have survival equal to or greater than 80%.
- ii. The mean number of Ceriodaphnia dubia neonates produced per surviving female in the control (0% effluent) must be 15 or more.
- iii. The mean dry weight of surviving Fathead minnow larvae at the end of the 7 days in the control (0% effluent) must be 0.25 mg per larva or greater.
- iv. The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for: the young of surviving females in the Ceriodaphnia dubia reproduction test, the growth and survival of the Fathead minnow test.
- v. The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal or nonlethal effects are exhibited for: the young of surviving females in the Ceriodaphnia dubia reproduction test; the growth and survival endpoints in the Fathead minnow test.

Test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.

b. Statistical Interpretation

- i. For the Ceriodaphnia dubia survival test, the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be Fisher's Exact Test as described in EPA/600/4-91/002, or the most recent update thereof.

If the conditions of Test Acceptability are met in Item 2.a above and the percent survival of the test organism is equal to or greater than 80% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report an NOEC of not less than the critical dilution for the DMR reporting requirements found in Item 3 below.

- ii. For the Ceriodaphnia dubia reproduction test and the Fathead minnow larval survival and growth test, the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA/600/4-91/002, or the most recent update thereof.

c. Dilution Water

- i. Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness and alkalinity to the closest downstream perennial water where the receiving stream is classified as intermittent or where the receiving stream has no flow due to zero flow conditions.
- ii. If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 2.a.), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
- A. a synthetic dilution water control which fulfills the test acceptance requirements of Item 2.a. was run concurrently with the receiving water control;
- B. the test indicating receiving water toxicity has been carried out to completion (i.e., 7 days);

# DRAFT

- C. the permittee includes all test results indicating receiving water toxicity with the full report and information required by Item 3.a. below; and
  - D. the synthetic dilution water shall have a pH, hardness and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.
- d. Samples and Composites
- i. The permittee shall collect a minimum of three flow-weighted 24-hour composite samples from the outfall(s) listed at item 1.a. above. A 24-hour composite sample consists of a minimum of 4 effluent portions collected at equal time intervals representative of a 24-hour operating day and combined proportional to flow or a sample continuously collected proportional to flow over a 24-hour operating day.
  - ii. The permittee shall collect second and third 24-hour composite samples for use during 24-hour renewals of each dilution concentration for each test. The permittee must collect the 24-hour composite samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on an intermittent basis.
  - iii. The permittee must collect the 24-hour composite samples so that the maximum holding time for any effluent sample shall not exceed 72 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first 24-hour composite sample. Samples shall be chilled to 4 degrees Centigrade during collection, shipping and/or storage.
  - iv. If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must collect an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days if the discharge occurs over multiple days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 3. of this section.

# DRAFT

Permit number: AR0043401

Page 16 of Part III

- v. MULTIPLE OUTFALLS: If the provisions of this section are applicable to multiple outfalls, the permittee shall combine the 24-hour composite effluent samples in proportion to the average flow from the outfalls listed in item 1.a. above for the day the sample was collected. The permittee shall perform the toxicity test on the flow-weighted composite of the outfall samples.
  
- vi. At the time of sample collection the permittee shall measure the TRC of the effluent. The measured concentration of TRC for each sample shall be included in the lab report submitted by the permittee. The permittee shall not allow the sample to be dechlorinated prior to delivery to the laboratory nor at the laboratory.

### 3. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this section in accordance with the Report Preparation Section of EPA/600/4-91/002, or the most current publication, for every valid or invalid toxicity test initiated whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of Part III.C. of this permit. The permittee shall submit full reports only upon the specific request of the Department.
  
- b. The permittee shall report the Whole Effluent Lethality values for the 30-Day Average Minimum and the 7-Day Minimum under Parameter No. 22414 on the DMR for that reporting period.

If more than one valid test for a species was performed during the reporting period, the test NOECs will be averaged arithmetically and reported as the DAILY AVERAGE MINIMUM NOEC for that reporting period.

If more than one species is tested during the reporting period, the permittee shall report the lowest 30-Day Average Minimum NOEC and the lowest 7-Day Minimum NOEC for Whole Effluent Lethality.

A valid test for each species must be reported on the DMR during each reporting period specified in PART I of this permit. Only ONE set of biomonitoring data for each species is to be recorded on the DMR for each reporting period. The data submitted should reflect the LOWEST Survival results for each species during the reporting period. All invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached to the DMR for review.



- c. The permittee shall submit the results of the valid toxicity test on the DMR for that reporting period. Submit retest information clearly marked as such with the following month's DMR. Only results of valid tests are to be reported on the DMR.
    - i. **Pimephales promelas** (Fathead Minnow)
      - A. If the No Observed Effect Concentration (NOEC) for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TLP6C.
      - B. Report the NOEC value for survival, Parameter No. TOP6C.
      - C. Report the NOEC value for growth, Parameter No. TPP6C.
      - D. If the No Observed Effect Concentration (NOEC) for growth is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TGP6C.
      - E. Report the highest (Critical dilution or control) Coefficient of Variation, Parameter No. TQP6C.
    - ii. **Ceriodaphnia dubia**
      - A. If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TLP3B.
      - B. Report the NOEC value for survival, Parameter No. TOP3B.
      - C. Report the NOEC value for reproduction, Parameter No. TPP3B.
      - D. If the No Observed Effect Concentration (NOEC) for reproduction is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TGP3B.
      - E. Report the highest (Critical dilution or control) Coefficient of Variation, Parameter No. TQP3B.
10. If TRC test results are less than Detection Level Achieved (DL), a value of zero (0) may be used for the Discharge Monitoring Report (DMR) calculations and reporting requirements.

## PART IV DEFINITIONS

All definitions contained in Section 502 of the Clean Water Act shall apply to this permit and are incorporated herein by reference. Additional definitions of words or phrases used in this permit are as follows:

1. “**Act**” means the Clean Water Act, Public Law 95-217 (33.U.S.C. 1251 et seq.) as amended.
2. “**Administrator**” means the Administrator of the U.S. Environmental Protection Agency.
3. “**Applicable effluent standards and limitations**” means all State and Federal effluent standards and limitations to which a discharge is subject under the Act, including, but not limited to, effluent limitations, standards of performance, toxic effluent standards and prohibitions, and pretreatment standards.
4. “**Applicable water quality standards**” means all water quality standards to which a discharge is subject under the federal Clean Water Act and which has been (a) approved or permitted to remain in effect by the Administrator following submission to the Administrator pursuant to Section 303(a) of the Act, or (b) promulgated by the Director pursuant to Section 303(b) or 303(c) of the Act, and standards promulgated under regulation No. 2, as amended, (regulation establishing water quality standards for surface waters of the State of Arkansas.)
5. “**Bypass**” means the intentional diversion of waste streams from any portion of a treatment facility.

6. “**Daily Discharge**” means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling.

*Mass Calculations:* For pollutants with limitations expressed in terms of mass, the “daily discharge” is calculated as the total mass of pollutant discharged over the sampling day.

*Concentration Calculations:* For pollutants with limitations expressed in other units of measurement, determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the “daily discharge” determination of concentration shall be the arithmetic average (weighted by flow value) of all the samples collected during that sampling day by using the following formula: where C= daily concentration, F=daily flow and n=number of daily samples; daily average discharge

$$\frac{C_1F_1 + C_2F_2 + \dots + C_nF_n}{F_1 + F_2 + \dots + F_n}$$

7. “**Monthly average**” means the highest allowable average of “daily discharges” over a calendar month, calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month. For Fecal Coliform Bacteria (FCB) report the monthly average see 30-day average below.

8. “**Daily Maximum**” discharge limitation means the highest allowable “daily discharge” during the calendar month. The 7-day average for fecal coliform bacteria is the geometric mean of the values of all effluent samples collected during the calendar week in colonies/100 ml.

# DRAFT

Permit number: AR0043401  
Page 2 of Part IV

9. **“Department”** means the Arkansas Department of Environmental Quality (ADEQ).
10. **“Director”** means the Administrator of the U.S. Environmental Protection Agency and/or the Director of the Arkansas Department of Environmental Quality.
11. **“Grab sample”** means an individual sample collected in less than 15 minutes in conjunction with an instantaneous flow measurement.
12. **“Industrial User”** means a nondomestic discharger, as identified in 40 CFR 403, introducing pollutants to a publicly-owned treatment works.
13. **“National Pollutant Discharge Elimination System”** means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under sections 307, 402, 318 and 405 of the Clean Water Act.
14. **“POTW”** means a Publicly Owned Treatment Works.
15. **“Severe property damage”** means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in products.
16. **“APCEC”** means the Arkansas Pollution Control and Ecology Commission.
17. **“Sewage sludge”** means the solids, residues, and precipitate separated from or created in sewage by the unit processes a publicly-owned treatment works. Sewage as used in this definition means any wastes, including wastes from humans, households, commercial establishments, industries, and storm water runoff that are discharged to or otherwise enter a publicly-owned treatment works.
18. **“7-day average”** discharge limitation, other than for fecal coliform bacteria, is the highest allowable arithmetic means of the values for all effluent samples collected during the calendar week. The 7-day average for fecal coliform bacteria is the geometric mean of the values of all effluent samples collected during the calendar week in colonies/100 ml. The DMR should report the highest 7-day average obtained during the calendar month. For reporting purposes, the 7-day average values should be reported as occurring in the month in which the Saturday of the calendar week falls in.
19. **“30-day average”**, other than for fecal coliform bacteria, is the arithmetic mean of the daily values for all effluent samples collected during a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. The 30-day average for fecal coliform bacteria is the geometric mean of the values for all effluent samples collected during a calendar month.  
For Fecal Coliform Bacteria (FCB) report the monthly average as a 30-day geometric mean in colonies per 100 ml.
20. **“24-hour composite sample”** consists of a minimum of 12 effluent portions collected at equal time intervals over the 24-hour period and combined proportional to flow or a sample collected at frequent intervals proportional to flow over the 24-hour period.
21. **“12-hour composite sample”** consists of 12 effluent portions, collected no closer together than one hour and composited according to flow. The daily sampling intervals shall include the highest flow periods.

# DRAFT

22. **“6-hour composite sample”** consists of six effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.

23. **“3-hour composite sample”** consists of three effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.

24. **“Treatment works”** means any devices and systems used in storage, treatment, recycling, and reclamation of municipal sewage and industrial wastes, of a liquid nature to implement section 201 of the Act, or necessary to recycle reuse water at the most economic cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and alterations thereof; elements essential to provide a reliable recycled supply such as standby treatment units and clear well facilities, and any works, including site acquisition of the land that will be an integral part of the treatment process or is used for ultimate disposal of residues resulting from such treatment.

25. **“Upset”** means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. Any upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, lack or preventive maintenance, or careless or improper operations.

26. **“For Fecal Coliform Bacteria”**, a sample consists of one effluent grab portion collected during a 24-hour period at peak loads. For Fecal Coliform Bacteria (FCB) report the monthly average as a 30-day geometric mean in colonies per 100 ml.

27. **“Dissolved oxygen limit”** shall be defined as follows:

- a. When limited in the permit as a monthly average minimum, shall mean the lowest acceptable monthly average value, determined by averaging all samples taken during the calendar month;
- b. When limited in the permit as an instantaneous minimum value, shall mean that no value measured during the reporting period may fall below the stated value.

28. **The term “MGD”** shall mean million gallons per day.

29. **The term “mg/l”** shall mean milligrams per liter or parts per million (ppm).

30. **The term “µg/l”** shall mean micrograms per liter or parts per billion (ppb).

31. **The term “cfs”** shall mean cubic feet per second.

32. **The term “ppm”** shall mean parts per million.

33. **The term “s.u.”** shall mean standard units.

34. **The term “Instantaneous Maximum”** When limited in the permit as an instantaneous maximum value, shall mean that no value measured during the reporting period may fall above the stated value.

## 35. **Monitoring and Reporting:**

When a permit becomes effective, monitoring requirements are of the immediate period of the permit effective date. Where the monitoring requirement for an effluent characteristic is Monthly or more frequently, the Discharge Monitoring Report shall be submitted by the 25<sup>th</sup> of the month following the sampling. Where the monitoring requirement for an effluent

# DRAFT

Permit number: AR0043401  
Page 4 of Part IV

characteristic is Quarterly, Semi-Annual, Annual, or Yearly, the Discharge Monitoring report shall be submitted by the 25<sup>th</sup> of the month following the monitoring period end date.

## **MONTHLY:**

is defined as a calendar month or any portion of a calendar month for monitoring requirement frequency of once/month or more frequently.

## **QUARTERLY:**

(1) is defined as a fixed calendar quarter or any part of the fixed calendar quarter for a non-seasonal effluent characteristic with a measurement frequency of once/quarter. Fixed calendar quarters are: January through March, April through June, July through September, and October through December; or

(2) is defined as a fixed three month period (or any part of the fixed three month period) of or dependent upon the seasons specified in the permit for a seasonal effluent characteristic with a monitoring requirement frequency of once/quarter that does not coincide with the fixed calendar quarter. Seasonal calendar quarters are: May through July, August through October, November through January, and February through April.

## **SEMI-ANNUAL:**

is defined as the fixed time periods January through June, and July through December (or any portion thereof) for an effluent characteristic with a measurement frequency of once/6 months or twice/year.

## **ANNUAL or YEARLY:**

is defined as a fixed calendar year or any portion of the fixed calendar year for an effluent characteristic or parameter with a measurement frequency of once/year. A calendar year is January through December, or any portion thereof.