

# ADEQ

ARKANSAS  
Department of Environmental Quality

DEC 10 2015

CERTIFIED MAIL: RETURN RECEIPT REQUESTED ( 91 7199 9991 7035 3536 1393 )

Gail Mainard, Assistant Director  
Arkansas Department of Correction - North Central Unit, IZARD County Facility  
P.O. Box 8707  
Pine Bluff, AR 71611

RE: Discharge Permit Number AR0044016 – AFIN 33-00036

Dear Mr. Mainard:


Enclosed are the public notice, a copy of the draft permit, and Statement of Basis which the Arkansas Department of Environmental Quality (ADEQ) has prepared and mailed to you on the above date under the authority of the National Pollutant Discharge Elimination System (NPDES) and the Arkansas Water and Air Pollution Control Act. A copy of the final permit will be mailed to you when the Department has made a final permitting decision.

In accordance with Reg. 8.207, the enclosed public notice will be or has been published by ADEQ in a newspaper of general circulation of your facility for one (1) day only. An invoice for the cost of publishing the public notice and proof of publication will be sent to you by the advertising newspaper. The permittee must send proof of publication and proof of payment to the address at the bottom of this letter as soon as possible but no later than 30 days from the above date. Until this Department receives proof of publication of the public notice and payment of all permit fees, no further action will be taken on the issuance of your discharge permit.

For a list of changes, please see Section 5 of the enclosed Statement of Basis. Comments must be received at ADEQ prior to the close of the public comment period as described in the enclosed public notice. Once a final permit is issued by the Director and becomes effective, the permittee must comply with all terms and conditions of the permit, or be subject to enforcement actions for any instances of noncompliance during the duration of the permit, usually five (5) years. Consequently, it is imperative that you, as the applicant, thoroughly review the enclosed documentation for accuracy, applicability, and your ability to comply with all conditions therein.

Should you have any questions concerning any part of the draft permit, please contact Guy Lester at (501) 682-0023.

Sincerely,

  
Ellen Carpenter  
Chief, Water Division

EC:gl

Enclosure

PUBLIC NOTICE OF DRAFT DISCHARGE PERMIT  
PERMIT NUMBER AR0044016, AFIN 33-00036

This is to give notice that the Arkansas Department of Environmental Quality (ADEQ), Water Division, 5301 Northshore Drive, North Little Rock, Arkansas 72118-5317 at telephone number (501) 682-0623, proposes a draft renewal of the permit number AR0044016 for which an application was received on August 13, 2015, and additional information was received on August 17, 2015, August 19, 2015, and September 30, 2015, for the following applicant under the National Pollutant Discharge Elimination System (NPDES) and the Arkansas Water and Air Pollution Control Act.

Applicant: Arkansas Department of Correction - North Central Unit, IZARD COUNTY FACILITY, Route 5 Hwy 5 North, Calico Rock, AR 72519. Location: from Calico Rock, go approximately 3 miles north on Arkansas State Highway 5, then northeast on County Road 46 for 1¼ miles to the entrance of the prison; Latitude: 36° 9' 58.72" N; Longitude: 92° 9' 6.35" W in IZARD COUNTY, ARKANSAS. The discharge of treated sanitary and cafeteria wastewater is into Moccasin Creek, thence to the White River in Segment 4F of the White River Basin.

ADEQ's contact person for submitting written comments on the draft permit, requesting information regarding the draft permit, or obtaining a copy of the permit and the Statement of Basis is Guy Lester, at the above address and telephone number or by email at [Water-Draft-Permit-Comment@adeq.state.ar.us](mailto:Water-Draft-Permit-Comment@adeq.state.ar.us). For those with Internet access, a copy of the proposed draft permit as well as the publication date may be found on the ADEQ's website at: [http://www.adeq.state.ar.us/water/branch\\_permits/individual\\_permits/pn\\_permits/pnpermits.asp](http://www.adeq.state.ar.us/water/branch_permits/individual_permits/pn_permits/pnpermits.asp).

The comment period for the draft permit shall end at 4:30 P.M. (Central Time) on the 30<sup>th</sup> day after the publication date. If the last day of the comment period is a Saturday, Sunday, or legal holiday, the public comment period shall expire on the next day that is not a Saturday, Sunday, or legal holiday. For information regarding the actual publication date along with the actual date and time the comment period will end, please contact Guy Lester at the above address and telephone number or by email at [Water-Draft-Permit-Comment@adeq.state.ar.us](mailto:Water-Draft-Permit-Comment@adeq.state.ar.us). Public notice, comments, and hearings will be conducted in accordance with Regulation 6.104(A)(5) [40 CFR Parts 124.10 through 124.12 by reference] and Regulation 8.207 through 8.210 (Administrative Procedures). All persons, including the permittee, who wish to comment on ADEQ's draft permitting decision must submit written comments to ADEQ, along with their name and mailing address. A Public Hearing will be held when ADEQ finds a significant degree of public interest. After the public comment period, ADEQ will issue a final permitting decision. ADEQ will notify the applicant and each person who has submitted written comments or request notice of the final permitting decision. Any interested person who has submitted comments may appeal a final decision by ADEQ in accordance with the APCEC Regulation No. 8.603.

# DRAFT

## Statement of Basis

This Statement of Basis is for information and justification of the permit limits only. Please note that it is not enforceable. This draft permitting decision is for renewal of the discharge Permit Number AR0044016 with Arkansas Department of Environmental Quality (ADEQ) Facility Identification Number (AFIN) 33-00036 to discharge to Waters of the State.

### 1. PERMITTING AUTHORITY.

The issuing office is:

Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, Arkansas 72118-5317

### 2. APPLICANT.

The applicant's mailing address is:

Arkansas Department of Correction  
North Central Unit, Izard County Facility  
P.O. Box 8707  
Pine Bluff, AR 71611

The facility address is:

Arkansas Department of Correction  
North Central Unit, Izard County Facility  
Route 5 Hwy 5 North  
Calico Rock, AR 72519

### 3. PREPARED BY.

The permit was prepared by:

Guy Lester  
Staff Engineer  
Permits Branch  
Water Division  
(501) 682-0023  
E-mail: [lester@adeq.state.ar.us](mailto:lester@adeq.state.ar.us)

John Bailey P.E.  
Manager  
Permits Branch  
Water Division  
(501) 682-0629  
E-mail: [bailey@adeq.state.ar.us](mailto:bailey@adeq.state.ar.us)

### 4. PERMIT ACTIVITY.

Previous Permit Effective Date: February 1, 2011  
Previous Permit Expiration Date: January 31, 2016

The permittee submitted a permit renewal application on August 13, 2015, and additional information was received on August 17, 2015, August 19, 2015, and September 30, 2015. It is proposed that the current discharge permit be reissued for a 5-year term in accordance with regulations promulgated at 40 CFR Part 122.46(a).

# DRAFT

Page 2 of Statement of Basis  
Permit Number: AR0044016  
AFIN: 33-00036

## DOCUMENT ABBREVIATIONS

In the document that follows, various abbreviations are used. They are as follows:

BAT - best available technology economically achievable  
BCT - best conventional pollutant control technology  
BMP - best management practice  
BOD<sub>5</sub> - five-day biochemical oxygen demand  
BPJ - best professional judgment  
BPT - best practicable control technology currently available  
CBOD<sub>5</sub> - carbonaceous biochemical oxygen demand  
CD - critical dilution  
CFR - Code of Federal Regulations  
cfs - cubic feet per second  
COD - chemical oxygen demand  
COE - United States Corp of Engineers  
CPP - continuing planning process  
CWA - Clean Water Act  
DMR - discharge monitoring report  
DO - dissolved oxygen  
ELG - effluent limitation guidelines  
EPA - United States Environmental Protection Agency  
ESA - Endangered Species Act  
FCB - fecal coliform bacteria  
gpm - gallons per minute  
MGD - million gallons per day  
MQL - minimum quantification level  
NAICS - North American Industry Classification System  
NH<sub>3</sub>-N - ammonia nitrogen  
NO<sub>3</sub> + NO<sub>2</sub>-N - nitrate + nitrite nitrogen  
NPDES - National Pollutant Discharge Elimination System  
O&G - oil and grease  
Reg. 2 - APCEC Regulation No. 2  
Reg. 6 - APCEC Regulation No. 6  
Reg. 8 - APCEC Regulation No. 8  
Reg. 9 - APCEC Regulation No. 9  
RP - reasonable potential  
SIC - standard industrial classification  
TDS - total dissolved solids  
TMDL - total maximum daily load  
TP - total phosphorus  
TRC - total residual chlorine  
TSS - total suspended solids  
UAA - use attainability analysis

# DRAFT

Page 3 of Statement of Basis  
Permit Number: AR0044016  
AFIN: 33-00036

USF&WS - United States Fish and Wildlife Service  
USGS – United States Geological Survey  
WET - Whole effluent toxicity  
WQMP - water quality management plan  
WQS - Water Quality standards  
WWTP - wastewater treatment plant

## Compliance and Enforcement History:

Compliance and Enforcement History for this facility can be reviewed by using the following web link:

[https://www.adeg.state.ar.us/downloads/WebDatabases/PermitsOnline/NPDES/PermitInformation/AR0044016\\_Compliance%20Review\\_20150924.pdf](https://www.adeg.state.ar.us/downloads/WebDatabases/PermitsOnline/NPDES/PermitInformation/AR0044016_Compliance%20Review_20150924.pdf)

## **5. SIGNIFICANT CHANGES FROM THE PREVIOUSLY ISSUED PERMIT.**

The permittee is responsible for carefully reading the permit in detail and becoming familiar with all of the changes therein:

1. The outfall coordinates have been corrected based on GPS measurements.
2. The receiving stream description has been corrected to remove the reference to the unnamed tributary based on the corrected location of the outfall. The reach number of the receiving stream has also been corrected in Section 6 of the Statement of Basis.
3. All of the effluent limits have been corrected to reference the nearest tenth to ensure the required accuracy in reporting.
4. The NH<sub>3</sub>-N Daily Max. mass limit for the months of May-October has been corrected from 3.8 lbs/day to 2.9 lbs/day. See Section 11.C.1 below for details.
5. Part II.1 has been added to the permit to clarify that any discharge from the facility other than through the permitted outfall is not authorized by the permit and must be reported within 24 hours.
6. The land application requirements in Parts II.5, II.6, and II.7 have been deleted from the permit and replaced with Part II.6 because the facility land applies sludge under No Discharge Permit No. 5124-WR-1.
7. The treatment system description has been revised to include an existing grease trap.

## **6. RECEIVING STREAM SEGMENT AND DISCHARGE LOCATION.**

The outfall is located at the following coordinates based on Google Earth using WGS84:

Latitude: 36° 10' 10.65" N; Longitude: 92° 9' 29.15" W

# DRAFT

Page 4 of Statement of Basis  
Permit Number: AR0044016  
AFIN: 33-00036

The receiving waters named:

Moccasin Creek, thence to the White River in Segment 4F of the White River Basin. The receiving stream with USGS Hydrologic Unit Code (H.U.C) of 11010004 and Reach #908 is a Water of the State classified for secondary contact recreation, raw water source for domestic (public and private), industrial, and agricultural water supplies, propagation of desirable species of fish and other aquatic life, and other compatible uses.

## 7. **303(d) LIST, TOTAL MAXIMUM DAILY LOADS, ENDANGERED SPECIES, AND ANTI-DEGRADATION CONSIDERATIONS.**

### A. **303(d) List:**

This facility discharges to a water body that is not on the State's currently approved 303(d) list of impaired waterbodies (2008). Therefore, the effluent limitations and monitoring requirements in the proposed permit are based on current technology and water quality standards requirements and are protective of the stream designated uses.

### B. **Applicable Total Maximum Daily Load (TMDL) Reports**

There are no TMDLs issued for the receiving stream.

### B. **Endangered Species:**

No comments on the application were received from the USF&WS. The draft permit and Statement of Basis will be sent to the USF&WS for their review.

### C. **Anti-Degradation:**

The limitations and requirements set forth in this permit for discharge into waters of the State are consistent with the Antidegradation Policy and all other applicable water quality standards found in APC&EC Regulation No. 2.

## 8. **OUTFALL, TREATMENT PROCESS DESCRIPTION, AND FACILITY CONSTRUCTION.**

The following is a description of the facility described in the application:

A. Design Flow: 0.09 MGD

B. Type of Treatment: grease trap, bar screen, oxidation ditch, 2 clarifiers, tertiary filter, UV disinfection, and sludge drying beds

# DRAFT

Page 5 of Statement of Basis  
Permit Number: AR0044016  
AFIN: 33-00036

- C. Discharge Description: treated sanitary and cafeteria wastewater
- D. Facility Status: This facility was evaluated using the NPDES Permit Rating Worksheet (MRAT) to determine the correct permitting status. Since the facility's MRAT score of 10 less than 80, this facility is classified as a Minor industrial.
- E. Facility Construction: This permit does not authorize or approve the construction or modification of any part of the treatment system or facilities. Approval for such construction must be by permit issued under Reg. 6.202.

## 9. ACTIVITY.

Under the Standard Industrial Classification (SIC) code of 9223 or North American Industry Classification System (NAICS) code of 922140, the applicant's activities are the operation of correctional institution.

## 10. SEWAGE SLUDGE PRACTICES.

Sludge is dried in drying beds and land applied under Arkansas State No Discharge Permit No. 5124-WR-1.

## 11. DEVELOPMENT AND BASIS FOR PERMIT CONDITIONS.

The Arkansas Department of Environmental Quality has determined to issue a draft permit for the discharge described in the application. Permit requirements are based on federal regulations (40 CFR Parts 122, 124, and Subchapter N), the National Pretreatment Regulation in 40 CFR Part 403 and regulations promulgated pursuant to the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. 8-4-101 et. seq.). All of the information contained in the application, including all of the submitted effluent testing data, was reviewed to determine the need for effluent limits and other permit requirements.

The following is an explanation of the derivation of the conditions of the draft permit and the reasons for them or, in the case of notices of intent to deny or terminate, reasons suggesting the decisions as required under 40 CFR Part 124.7.

### **Technology-Based Versus Water Quality-Based Effluent Limitations and Conditions**

Following regulations promulgated at 40 CFR Part 122.44, the draft permit limits are based on either technology-based effluent limits pursuant to 40 CFR Part 122.44 (a) or on State water quality standards and requirements pursuant to 40 CFR Part 122.44 (d), whichever are more stringent as follows:

# DRAFT

Parameter	Water Quality-Based		Technology-Based		Previous Permit		Draft Permit	
	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l	Monthly Avg. mg/l	Daily Max. mg/l
CBOD5	10.0	15.0	N/A	N/A	10	15	10.0	15.0
TSS	N/A	N/A	15.0	22.5	15	23	15.0	22.5
NH3-N								
(April)	3.9	3.9	N/A	N/A	3.9	3.9	3.9	3.9
(May-Oct)	3.0	3.9	N/A	N/A	3.0	3.9	3.0	3.9
(Nov-March)	5.0	7.5	N/A	N/A	5.0	7.5	5.0	7.5
DO	5.0 (Inst. Min.)		N/A		5.0 (Inst. Min.)		5.0 (Inst. Min.)	
FCB (col/100ml)	1000	2000	200	400	200	200	200	200
NO <sub>3</sub> +NO <sub>2</sub> -N	10.0 (Max.)		N/A		10 (Max.)		10.0 (Max.)	
O&G	10.0	15.0	N/A	N/A	N/A	N/A	10.0	15.0
pH	6.0-9.0 s.u.		N/A		6.0-9.0 s.u.		6.0-9.0 s.u.	

## A. Justification for Limitations and Conditions of the Draft Permit

Parameter	Water Quality or Technology	Justification
CBOD5	Water Quality	MultiSMP Model dated October 9, 2015, CWA § 402(o), and previous permit
TSS	Technology	40 CFR 122.44(l), and previous permit
NH3-N	Water Quality	Reg. 2.512, Reg. 2 - Appendix A - page A-4 (Use Variation Supported by UAA), MultiSMP Model dated October 9, 2015, CWA § 402(o), and previous permit
DO	Water Quality	Reg. 2.505, Reg. 2 - Appendix A - page A-4 (Use Variation Supported by UAA), MultiSMP Model dated October 9, 2015, CWA § 402(o), and previous permit
FCB	Water Quality	CWA § 402(o) and previous permit
NO <sub>3</sub> +NO <sub>2</sub> -N	Technology	40 CFR 122.44(l), and previous permit
O&G <sup>1</sup>	Water Quality	Reg. 2.510
pH	Water Quality	Reg. 2.504, CWA § 402(o), and previous permit

<sup>1</sup> O&G limits have been added to the permit because the facility treats cafeteria wastewater. A schedule of compliance is not necessary because data from the renewal application shows that the facility is already in compliance with the new limits.



# DRAFT

Page 7 of Statement of Basis  
Permit Number: AR0044016  
AFIN: 33-00036

No new information was received to warrant adding, removing, or revising any limitations in the permit except for O&G (as noted above). Therefore, except for O&G limits, the limitations in the permit are consistent with the limitations in the previous permit.

## B. Anti-backsliding

The draft permit is consistent with the requirements to meet Anti-backsliding provisions of the Clean Water Act (CWA), Section 402(o) [40 CFR 122.44(l)]. The final effluent limitations for reissuance permits must be as stringent as those in the previous permit, unless the less stringent limitations can be justified using exceptions listed in CWA 402(o)(2), CWA 303(d)(4), or 40 CFR 122.44 (l)(2)(i).

The draft permit meets or exceeds the requirements of the previous permit.

## C. Limits Calculations

### 1. Mass limits:

In accordance with 40 CFR 122.45(f)(1), all pollutants limited in permits shall have limitations expressed in terms of mass if feasible. 40 CFR 122.45(f)(2) allows for pollutants which are limited in terms of mass to also be limited in terms of other units of measurement.

The calculation of the loadings (lbs per day) uses a design flow of 0.09 MGD and the following equation:

$$\text{lbs/day} = \text{Concentration (mg/l)} \times \text{Flow (MGD)} \times 8.34$$

Note: In the previous permit, the Daily Max. mass limit of 3.8 lbs/day for NH<sub>3</sub>-N for the months of May-October was incorrect. The limit has been corrected to 2.9 lbs/day based on the above calculation method.

### 2. Daily Maximum Limits:

The daily maximum limits for CBOD<sub>5</sub>, TSS, and NH<sub>3</sub>-N (November through March) are based on Section 5.4.2 of the Technical Support Document for Water Quality-Based Toxics Control.

$$\text{Daily Maximum limits} = \text{Monthly average limits} \times 1.5$$

The daily maximum NH<sub>3</sub>-N limits for the months of April through October are based on the requirements of Reg. 2.512.

The daily maximum limit for FCB is based on CWA § 402(o) and the previous permit.

The daily maximum limit for O&G is based on Reg. 2.510.

# DRAFT

## D. Ammonia-Nitrogen (NH3-N)

The water quality effluent limitations for Ammonia are based either on DO-based effluent limits or on toxicity-based standards, whichever are more stringent. The toxicity-based effluent limitations are based on Reg. 2.512 and the CPP.

The Ammonia toxicity calculations for this facility may be reviewed by using the following web link:

[https://www.adeg.state.ar.us/downloads/WebDatabases/PermitsOnline/NPDES/PermitInformation/AR0044016\\_Ammonia%20Toxicity%20Calculations\\_20150930.pdf](https://www.adeg.state.ar.us/downloads/WebDatabases/PermitsOnline/NPDES/PermitInformation/AR0044016_Ammonia%20Toxicity%20Calculations_20150930.pdf)

## E. 208 Plan (Water Quality Management Plan)

There are no changes to the 208 Plan.

## 12. SAMPLE TYPE AND FREQUENCY.

Regulations require permits to establish monitoring requirements to yield data representative of the monitored activity [40 CFR Part 122.48(b)] and to ensure compliance with permit limitations [40 CFR Part 122.44(i)(1)].

Requirements for sample type and sampling frequency have been based on the current discharge permit, except for O&G, which was based on recommended frequencies for self-monitoring of discharges within the flow of 0.05 to 0.1 MGD.

Parameter	Previous Permit		Draft Permit	
	Frequency of Sample	Sample Type	Frequency of Sample	Sample Type
Flow	daily	totalizing meter	daily	totalizing meter
CBOD5	once/month	grab	once/month	grab
TSS	once/month	grab	once/month	grab
NH3-N				
(April)	once/month	grab	once/month	grab
(May-Oct)	once/month	grab	once/month	grab
(Nov-Apr)	once/month	grab	once/month	grab
DO	once/month	grab	once/month	grab
FCB	once/month	grab	once/month	grab

# DRAFT

Parameter	Previous Permit		Draft Permit	
	Frequency of Sample	Sample Type	Frequency of Sample	Sample Type
NO <sub>3</sub> + NO <sub>2</sub> - N	once/month	grab	once/month	grab
O&G	N/A	N/A	once/month	grab
pH	once/month	grab	once/month	grab

### 13. PERMIT COMPLIANCE.

A Schedule of Compliance has not been included in this permit.

### 14. MONITORING AND REPORTING.

The applicant is at all times required to monitor the discharge on a regular basis and report the results monthly. The monitoring results will be available to the public.

### 15. SOURCES.

The following sources were used to draft the permit:

- A. Application No. AR0044016 received August 13, 2015, and additional information received on August 17, 2015, August 19, 2015, and September 30, 2015.
- B. Arkansas Water Quality Management Plan (WQMP).
- C. APCEC Regulation No. 2.
- D. APCEC Regulation No. 3.
- E. APCEC Regulation No. 6, which incorporates by reference certain federal regulations included in Title 40 of the Code of Federal Regulations at Reg. 6.104.
- F. 40 CFR Parts 122 and 125.
- G. Discharge permit file AR0044016.
- H. Discharge Monitoring Reports (DMRs).
- I. "2008 Integrated Water Quality Monitoring and Assessment Report", ADEQ.
- J. "2008 List of Impaired Waterbodies (303(d) List)", ADEQ, February 2008.
- K. "Identification and Classification of Perennial Streams of Arkansas", Arkansas Geological Commission.
- L. Continuing Planning Process (CPP).
- M. Technical Support Document For Water Quality-based Toxic Control.
- N. [Inspection Report #077257, dated April 14, 2014.](#)
- O. [Compliance Review Memo dated September 24, 2015, from Jacqueline Trotta to Guy Lester.](#)
- P. MultiSMP Model dated October 9, 2015.
- Q. Telephone conversation on September 25, 2015 to discuss changes to the permit.

# DRAFT

Page 10 of Statement of Basis  
Permit Number: AR0044016  
AFIN: 33-00036

## 16. PUBLIC NOTICE.

The public notice describes the procedures for the formulation of final determinations and shall provide for a public comment period of 30 days. During this period, any interested persons may submit written comments on the permit and may request a public hearing to clarify issues involved in the permitting decision. A request for a public hearing shall be in writing and shall state the nature of the issue(s) proposed to be raised in the hearing.

A copy of the permit and public notice will be sent via email to the Corps of Engineers, the Regional Director of the U.S. Fish and Wildlife Service, the Department of Arkansas Heritage, the EPA, and the Arkansas Department of Health.

## 17. POINT OF CONTACT.

For additional information, contact:

Guy Lester  
Permits Branch, Water Division  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, Arkansas 72118-5317  
Telephone: (501) 682-0023

# DRAFT

Permit Number: AR0044016  
AFIN: 33-00036

**AUTHORIZATION TO DISCHARGE WASTEWATER UNDER  
THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM AND  
THE ARKANSAS WATER AND AIR POLLUTION CONTROL ACT**

In accordance with the provisions of the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. 8-4-101 et seq.), and the Clean Water Act (33 U.S.C. § 1251 et seq.),

Arkansas Department of Correction  
North Central Unit, IZARD County Facility

is authorized to discharge treated sanitary and cafeteria wastewater from a facility located as follows: from Calico Rock, go approximately 3 miles north on Arkansas State Highway 5, then northeast on County Road 46 for 1¼ miles to the entrance of the prison in IZARD County, Arkansas. The applicant's mailing address is: 7800 Correction Circle, Pine Bluff, AR 71603.

Latitude: 36° 9' 58.72" N; Longitude: 92° 9' 6.35" W

to receiving waters named:

Moccasin Creek, thence to the White River in Segment 4F of the White River Basin.

The outfall is located at the following coordinates:

Outfall 001: Latitude: 36° 10' 10.65" N; Longitude: 92° 9' 29.15" W

Discharge shall be in accordance with effluent limitations, monitoring requirements, and other conditions set forth in this permit. Per Part III.D.10, the permittee must re-apply 180 days prior to the expiration date below for permit coverage to continue beyond the expiration date.

Effective Date:

Expiration Date:

---

Ellen Carpenter  
Chief, Water Division  
Arkansas Department of Environmental Quality

---

Issue Date

## PART I PERMIT REQUIREMENTS

### SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS: OUTFALL 001 - treated sanitary and cafeteria wastewater.

During the period beginning on the effective date and lasting until the date of expiration, the permittee is authorized to discharge from Outfall 001. Such discharges shall be limited and monitored by the permittee as specified below as well as Parts II and III. See Part IV for all definitions and calculations.

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>				<u>Monitoring Requirements</u>	
	Mass (lbs/day, unless otherwise specified)		Concentration (mg/l, unless otherwise specified)		Frequency	Sample Type
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max		
Flow	N/A	N/A	Report, MGD	Report, MGD	daily	totalizing meter
Carbonaceous Biochemical Oxygen Demand (CBOD5)	7.5	11.3	10.0	15.0	once/month	grab
Total Suspended Solids (TSS)	11.3	17.3	15.0	22.5	once/month	grab
Ammonia Nitrogen (NH3-N)						
(April)	2.9	2.9	3.9	3.9	once/month	grab
(May-Oct)	2.3	2.9	3.0	3.9	once/month	grab
(Nov-March)	3.8	5.6	5.0	7.5	once/month	grab
Dissolved Oxygen (DO)	N/A	N/A	5.0 (Inst. Min.)		once/month	grab
Fecal Coliform Bacteria (FCB)			(colonies/100ml)			
	N/A	N/A	200	200	once/month	grab
Nitrate+Nitrite-Nitrogen (NO <sub>3</sub> +NO <sub>2</sub> -N)	7.5 (Max.)		10.0 (Max.)		once/month	grab
Oil and Grease (O&G)	7.5	11.3	10.0	15.0	once/month	grab
pH	N/A	N/A	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/month	grab

There shall be no discharge of distinctly visible solids, scum, or foam of a persistent nature, nor shall there be any formation of slime, bottom deposits, or sludge banks. There shall be no visible sheen as defined in Part IV of this permit.

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. Flow samples shall be taken at the flow monitoring station prior to the UV disinfection unit. All other samples shall be taken just after final treatment at the monitoring station after the UV disinfection unit.

# DRAFT

Permit Number: AR0044016  
AFIN: 33-00036  
Page 1 of Part IB

## **SECTION B. PERMIT COMPLIANCE SCHEDULE**

None.

## **PART II OTHER CONDITIONS**

1. Any discharge other than from the permitted Outfall is not authorized under this permit and shall be reported to ADEQ as a noncompliance event within 24 hours of occurrence.
2. The operator of this wastewater treatment facility shall be a Class III licensed by the State of Arkansas in accordance with APCEC Regulation No. 3.
3. In accordance with 40 CFR Parts 122.62 (a)(2) and 124.5, this permit may be reopened for modification or revocation and/or reissuance to require additional monitoring and/or effluent limitations when new information is received that actual or potential exceedance of State water quality criteria and/or narrative criteria are determined to be the result of the permittee's discharge(s) to a relevant water body or a Total Maximum Daily Load (TMDL) is established or revised for the water body that was not available at the time of the permit issuance that would have justified the application of different permit conditions at the time of permit issuance.

#### 4. Other Specified Monitoring Requirements

The permittee may use alternative appropriate monitoring methods and analytical instruments other than as specified in Part I Section A of the permit without a major permit modification under the following conditions:

- The monitoring and analytical instruments are consistent with accepted scientific practices.
- The requests shall be submitted in writing to the Permits Section of the Water Division of the ADEQ for use of the alternate method or instrument.
- The method and/or instrument is in compliance with 40 CFR Part 136 or approved in accordance with 40 CFR Part 136.5.
- All associated devices are installed, calibrated, and maintained to insure the accuracy of the measurements and are consistent with the accepted capability of that type of device. The calibration and maintenance shall be performed as part of the permittee's laboratory Quality Control/Quality Assurance program.

Upon written approval of the alternative monitoring method and/or analytical instruments, these methods or instruments must be consistently utilized throughout the monitoring period. ADEQ must be notified in writing and the permittee must receive written approval from ADEQ if the permittee decides to return to the original permit monitoring requirements.

5. Best Management Practices (BMPs), as defined in Part IV.6, must be implemented for the facility to prevent or reduce the pollution of waters of the State from stormwater runoff, spills or leaks, and/or waste disposal. The permittee must amend the BMPs whenever there is a change in the facility or a change in the operation of the facility.
6. Sludge is dried in drying beds and land applied under Arkansas State No Discharge Permit No. 5124-WR1.



## **PART III STANDARD CONDITIONS**

### **SECTION A – GENERAL CONDITIONS**

#### **1. Duty to Comply**

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the federal Clean Water Act and the Arkansas Water and Air Pollution Control Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; and/or for denial of a permit renewal application. **Any values reported in the required Discharge Monitoring Report (DMR) which are in excess of an effluent limitation specified in Part I shall constitute evidence of violation of such effluent limitation and of this permit.**

#### **2. Penalties for Violations of Permit Conditions**

The Arkansas Water and Air Pollution Control Act provides that any person who violates any provisions of a permit issued under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year, or a fine of not more than twenty-five thousand dollars (\$25,000) or by both such fine and imprisonment for each day of such violation. Any person who violates any provision of a permit issued under the Act may also be subject to civil penalty in such amount as the court shall find appropriate, not to exceed ten thousand dollars (\$10,000) for each day of such violation. The fact that any such violation may constitute a misdemeanor shall not be a bar to the maintenance of such civil action.

#### **3. Permit Actions**

This permit may be modified, revoked and reissued, or terminated for cause including, but not limited to the following:

- A. Violation of any terms or conditions of this permit.
- B. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts.
- C. A change in any conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- D. A determination that the permitted activity endangers human health or the environment and can only be regulated to acceptable levels by permit modification or termination.
- E. Failure of the permittee to comply with the provisions of APCEC Regulation No. 9 (Permit fees) as required by Part III.A.11 herein.

# DRAFT

Permit Number: AR0044016  
AFIN: 33-00036  
Page 2 of Part III

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

## **4. Toxic Pollutants**

Notwithstanding Part III.A.3, if any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under APCEC Regulation No. 2, as amended, or Section 307(a) of the Clean Water Act for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitations on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standards or prohibition and the permittee so notified.

The permittee shall comply with effluent standards, narrative criteria, or prohibitions established under APCEC Regulation No. 2, as amended, or Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

## **5. Civil and Criminal Liability**

Except as provided in permit conditions for “Bypass of Treatment Facilities” (Part III.B.4), and “Upset” (Part III.B.5), nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. Any false or materially misleading representation or concealment of information required to be reported by the provisions of this permit or applicable state and federal statutes or regulations which defeats the regulatory purposes of the permit may subject the permittee to criminal enforcement pursuant to the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. § 8-4-101 et seq.).

## **6. Oil and Hazardous Substance Liability**

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject to under Section 311 of the Clean Water Act.

## **7. State Laws**

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law or regulation under authority preserved by Section 510 of the Clean Water Act.

## **8. Property Rights**

The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State, or local laws or regulations.

## **9. Severability**

The provisions of this permit are severable, and if any provision of this permit, or the application of any provisions of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

## **10. Applicable Federal, State or Local Requirements**

Permittees are responsible for compliance with all applicable terms and conditions of this permit. Receipt of this permit does not relieve any operator of the responsibility to comply with any other applicable federal such as endangered species, state or local statute, ordinance or regulation.

## **11. Permit Fees**

The permittee shall comply with all applicable permit fee requirements (i.e., including annual permit fees following the initial permit fee that will be invoiced every year the permit is active) for wastewater discharge permits as described in APCEC Regulation No. 9 (Regulation for the Fee System for Environmental Permits). Failure to promptly remit all required fees shall be grounds for the Director to initiate action to terminate this permit under the provisions of 40 CFR Parts 122.64 and 124.5(d), as adopted in APCEC Regulation No. 6 and the provisions of APCEC Regulation No. 8.

## **SECTION B – OPERATION AND MAINTENANCE OF POLLUTION CONTROLS**

### **1. Proper Operation and Maintenance**

A. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

# DRAFT

Permit Number: AR0044016  
AFIN: 33-00036  
Page 4 of Part III

- B. The permittee shall provide an adequate operating staff which is duly qualified to carryout operation, maintenance, and testing functions required to insure compliance with the conditions of this permit.

## 2. **Need to Halt or Reduce not a Defense**

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. Upon reduction, loss, or failure of the treatment facility, the permittee shall, to the extent necessary to maintain compliance with its permit, control production or discharges or both until the facility is restored or an alternative method of treatment is provided. This requirement applies, for example, when the primary source of power for the treatment facility is reduced, is lost, or alternate power supply fails.

## 3. **Duty to Mitigate**

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment or the water receiving the discharge.

## 4. **Bypass of Treatment Facilities**

“Bypass” means the intentional diversion of waste streams from any portion of a treatment facility, as defined at 40 CFR 122.41(m)(1)(i).

### A. Bypass not exceeding limitation

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts III.B.4.B and 4.C.

### B. Notice

1. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
2. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Part III.D.6 (24-hour notice).

### C. Prohibition of bypass

1. Bypass is prohibited and the Director may take enforcement action against a permittee for bypass, unless:
  - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage.

# DRAFT

Permit Number: AR0044016  
AFIN: 33-00036  
Page 5 of Part III

- (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if the permittee could have installed adequate backup equipment to prevent a bypass which occurred during normal or preventive maintenance.
  - (c) The permittee submitted notices as required by Part III.B.4.B.
2. The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in Part III.B.4.C(1).

## 5. Upset Conditions

- A. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Part III.B.5.B of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- B. Conditions necessary for demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - 1. An upset occurred and that the permittee can identify the specific cause(s) of the upset.
  - 2. The permitted facility was at the time being properly operated.
  - 3. The permittee submitted notice of the upset as required by Part III.D.6.
  - 4. The permittee complied with any remedial measures required by Part III.B.3.
- C. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

## 6. Removed Substances

- A. Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering waters of the State. The Permittee must comply with all applicable state and Federal regulations governing the disposal of sludge, including but not limited to 40 CFR Part 503, 40 CFR Part 257, and 40 CFR Part 258.

# DRAFT

Permit Number: AR0044016  
AFIN: 33-00036  
Page 6 of Part III

- B. Any changes to the permittee's disposal practices described in Part II of the permit will require at least 180 days prior notice to the Director to allow time for additional permitting. Please note that the 180 day notification requirement may be waived if additional permitting is not required for the change.

## **7. Power Failure**

The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failure either by means of alternate power sources, standby generators, or retention of inadequately treated effluent.

## **SECTION C – MONITORING AND RECORDS**

### **1. Representative Sampling**

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge during the entire monitoring period. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points shall not be changed without notification to and the approval of the Director. Intermittent discharge shall be monitored.

### **2. Flow Measurement**

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to insure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure the accuracy of the measurements are consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than +/- 10% from true discharge rates throughout the range of expected discharge volumes and shall be installed at the monitoring point of the discharge.

#### Calculated Flow Measurement

For calculated flow measurements that are performed in accordance with either the permit requirements or a Department approved method (i.e., as allowed under Part II.3), the +/- 10% accuracy requirement described above is waived. This waiver is only applicable when the method used for calculation of the flow has been reviewed and approved by the Department.

### **3. Monitoring Procedures**

Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals frequent enough to insure accuracy of measurements and shall insure that both calibration and maintenance activities will be conducted. An adequate analytical quality control program, including the analysis of sufficient standards, spikes, and duplicate samples to insure the accuracy of all required analytical results shall be maintained by the permittee or designated commercial laboratory. At a minimum, spikes and duplicate samples are to be analyzed on 10% of the samples.

### **4. Penalties for Tampering**

The Arkansas Water and Air Pollution Control Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under the Act shall be guilty of a misdemeanor and upon conviction thereof shall be subject to imprisonment for not more than one (1) year or a fine of not more than ten thousand dollars (\$10,000) or by both such fine and imprisonment.

### **5. Reporting of Monitoring Results**

Monitoring results must be reported on a Discharge Monitoring Report (DMR) form provided by the Department or other form/method approved in writing by the Department (e.g., electronic submittal of DMR once approved). Monitoring results obtained during the previous monitoring period shall be summarized and reported on a DMR form postmarked no later than the 25<sup>th</sup> day of the month or submitted electronically by 6:00 p.m. of the 25<sup>th</sup>, following the completed reporting period beginning on the effective date of the permit. When mailing the DMRs, duplicate copies of the forms signed and certified as required by Part III.D.11 and all other reports required by Part III.D, shall be submitted to the Director at the following address:

Enforcement Branch  
Water Division  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

If permittee uses outside laboratory facilities for sampling and/or analysis, the name and address of the contract laboratory shall be included on the DMR.

## **6. Additional Monitoring by the Permittee**

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR. Such increased frequency shall also be indicated on the DMR.

## **7. Retention of Records**

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of the Director at any time.

## **8. Record Contents**

Records and monitoring information shall include:

- A. The date, exact place, time and methods of sampling or measurements, and preservatives used, if any.
- B. The individual(s) who performed the sampling or measurements.
- C. The date(s) and time analyses were performed.
- D. The individual(s) who performed the analyses.
- E. The analytical techniques or methods used.
- F. The measurements and results of such analyses.

## **9. Inspection and Entry**

The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

- A. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit.
- B. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit.
- C. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit.
- D. Sample, inspect, or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.



## SECTION D – REPORTING REQUIREMENTS

### 1. Planned Changes

The Permittee shall give notice to the Director as soon as possible but no later than 180 days prior to any planned physical alterations or additions to the permitted facility [40 CFR 122.41(I)]. Notice is required only when:

- A. The alteration or addition to a permitted facility may meet one of the criteria for new sources at 40 CFR 122.29(b).
- B. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants subject to effluent limitations in the permit, or to the notification requirements under 40 CFR 122.42(b).

### 2. Anticipated Noncompliance

The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

### 3. Transfers

The permit is nontransferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act.

### 4. Monitoring Reports

Monitoring results shall be reported at the intervals and in the form specified in Part III.C.5. **Discharge Monitoring Reports must be submitted even when no discharge occurs during the reporting period.**

### 5. Compliance Schedule

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date. Any reports of noncompliance shall include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirement.

## **6. Twenty-four Hour Report**

- A. The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain the following information:
1. A description of the noncompliance and its cause.
  2. The period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue.
  3. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
- B. The following shall be included as information which must be reported within 24 hours:
1. Any unanticipated bypass which exceeds any effluent limitation in the permit.
  2. Any upset which exceeds any effluent limitation in the permit.
  3. Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in Part I of the permit to be reported within 24 hours to the Enforcement Section of the Water Division of the ADEQ.
- C. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours to the Enforcement Section of the Water Division of the ADEQ.

## **7. Other Noncompliance**

The permittee shall report all instances of noncompliance not reported under Parts III.D.4, 5, and 6, at the time monitoring reports are submitted. The reports shall contain the information listed at Part III.D.6.

## **8. Changes in Discharge of Toxic Substances for Industrial Dischargers**

The Director shall be notified as soon as the permittee knows or has reason to believe:

- A. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the “notification levels” described in 40 CFR Part 122.42(a)(1).

- B. That any activity has occurred or will occur which would result in any discharge on a non-routine or infrequent basis of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the “notification levels” described in 40 CFR Part 122.42(a)(2).

## **9. Duty to Provide Information**

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit. Information shall be submitted in the form, manner and time frame requested by the Director.

## **10. Duty to Reapply**

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The complete application shall be submitted at least 180 days before the expiration date of this permit. The Director may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date. Continuation of expiring permits shall be governed by regulations promulgated in APCEC Regulation No. 6.

## **11. Signatory Requirements**

All applications, reports, or information submitted to the Director shall be signed and certified as follows:

A. All **permit applications** shall be signed as follows:

1. For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
  - (a) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation.
  - (b) The manager of one or more manufacturing, production, or operation facilities, provided: the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and

# DRAFT

Permit Number: AR0044016  
AFIN: 33-00036  
Page 12 of Part III

accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

2. For a partnership or sole proprietorship: by a general partner or proprietor, respectively.
  3. For a municipality, State, Federal, or other public agency, by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes:
    - (a) The chief executive officer of the agency.
    - (b) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.
- B. All **reports** required by the permit and **other information** requested by the Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
1. The authorization is made in writing by a person described above.
  2. The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility. (A duly authorized representative may thus be either a named individual or any individual occupying a named position).
  3. The written authorization is submitted to the Director.
- C. Certification. Any person signing a document under this section shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

# DRAFT

Permit Number: AR0044016  
AFIN: 33-00036  
Page 13 of Part III

## **12. Availability of Reports**

Except for data determined to be confidential under 40 CFR Part 2 and APCEC Regulation No. 6, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department of Environmental Quality. As required by the Regulations, the name and address of any permit applicant or permittee, permit applications, permits, and effluent data shall not be considered confidential.

## **13. Penalties for Falsification of Reports**

The Arkansas Air and Water Pollution Control Act provides that any person who knowingly makes any false statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under this permit shall be subject to civil penalties specified in Part III.A.2 and/or criminal penalties under the authority of the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. § 8-4-101 et seq.).

## **14. Other Information**

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

## PART IV DEFINITIONS

All definitions contained in Section 502 of the Clean Water Act and 40 CFR 122.2 shall apply to this permit and are incorporated herein by reference. Additional definitions of words or phrases used in this permit are as follows:

1. **“Act”** means the Clean Water Act, Public Law 95-217 (33.U.S.C. 1251 et seq.) as amended.
2. **“Administrator”** means the Administrator of the U.S. Environmental Protection Agency.
3. **“APCEC”** means the Arkansas Pollution Control and Ecology Commission.
4. **“Applicable effluent standards and limitations”** means all State and Federal effluent standards and limitations to which a discharge is subject under the Act, including, but not limited to, effluent limitations, standards of performance, toxic effluent standards and prohibitions, and pretreatment standards.
5. **“Applicable water quality standards”** means all water quality standards to which a discharge is subject under the federal Clean Water Act and which has been (a) approved or permitted to remain in effect by the Administrator following submission to the Administrator pursuant to Section 303(a) of the Act, or (b) promulgated by the Director pursuant to Section 303(b) or 303(c) of the Act, and standards promulgated under (APCEC) Regulation No. 2, as amended.
6. **“Best Management Practices (BMPs)”** are activities, practices, maintenance procedures, and other management practices designed to prevent or reduce the pollution of waters of the State. BMPs also include treatment technologies, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw sewage. BMPs may include structural devices or nonstructural practices.
7. **“Bypass”** means the intentional diversion of waste streams from any portion of a treatment facility, as defined at 40 CFR 122.41(m)(1)(i).
8. **“Composite sample”** is a mixture of grab samples collected at the same sampling point at different times, formed either by continuous sampling or by mixing a minimum of 4 effluent portions collected at equal time intervals (but not closer than one hour apart) during operational hours, within the 24-hour period, and combined proportional to flow or a sample collected at more frequent intervals proportional to flow over the 24-hour period.
9. **“Daily Discharge”** means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling.
  - A. **Mass Calculations:** For pollutants with limitations expressed in terms of mass, the “daily discharge” is calculated as the total mass of pollutant discharged over the sampling day.
  - B. **Concentration Calculations:** For pollutants with limitations expressed in other units of measurement, the “daily discharge” is calculated as the average measurement of the pollutant over the day.
10. **“Daily Maximum”** discharge limitation means the highest allowable “daily discharge” during the calendar month.
11. **“Department”** means the Arkansas Department of Environmental Quality (ADEQ).
12. **“Director”** means the Director of the Arkansas Department of Environmental Quality.

13. **“Dissolved oxygen limit”** shall be defined as follows:
  - A. When limited in the permit as a minimum monthly average, shall mean the lowest acceptable monthly average value, determined by averaging all samples taken during the calendar month.
  - B. When limited in the permit as an instantaneous minimum value, shall mean that no value measured during the reporting period may fall below the stated value.
14. **“E-Coli”** a sample consists of one effluent grab portion collected during a 24-hour period at peak loads. For E-Coli, report the Daily Maximum as the highest “daily discharge” during the calendar month, and the Monthly Average as the geometric mean of all “daily discharges” within a calendar month, in colonies per 100 ml.
15. **“Fecal Coliform Bacteria (FCB)”** a sample consists of one effluent grab portion collected during a 24-hour period at peak loads. For FCB, report the Daily Maximum as the highest “daily discharge” during the calendar month, and the Monthly Average as the geometric mean of all “daily discharges” within a calendar month, in colonies per 100 ml.
16. **“Grab sample”** means an individual sample collected in less than 15 minutes in conjunction with an instantaneous flow measurement.
17. **“Industrial User”** means a nondomestic discharger, as identified in 40 CFR Part 403, introducing pollutants to a POTW.
18. **“Instantaneous flow measurement”** means the flow measured during the minimum time required for the flow-measuring device or method to produce a result in that instance. To the extent practical, instantaneous flow measurements coincide with the collection of any grab samples required for the same sampling period so that together the samples and flow are representative of the discharge during that sampling period.
19. **“Instantaneous Maximum”** when limited in the permit as an instantaneous maximum value, shall mean that no value measured during the reporting period may fall above the stated value.
20. **“Instantaneous Minimum”** an instantaneous minimum value, shall mean that no value measured during the reporting period may fall below the stated value.
21. **“Monthly Average”** means the highest allowable average of “daily discharges” over a calendar month, calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month. For Fecal Coliform Bacteria (FCB) or E-Coli, report the Monthly Average as the geometric mean of all “daily discharges” within a calendar month.
22. **“Monitoring and Reporting”**

When a permit becomes effective, monitoring requirements are of the immediate period of the permit effective date. Where the monitoring requirement for an effluent characteristic is monthly or more frequently, the Discharge Monitoring Report (DMR) shall be submitted by the 25<sup>th</sup> of the month following the sampling. Where the monitoring requirement for an effluent characteristic is Quarterly, Semi-Annual, Annual, or Yearly, the DMR shall be submitted by the 25<sup>th</sup> of the month following the monitoring period end date.

  - A. **MONTHLY:**

is defined as a calendar month or any portion of a calendar month for monitoring requirement frequency of once/month or more frequently.

**B. BI-MONTHLY:**

is defined as two (2) calendar months or any portion of 2 calendar months for monitoring requirement frequency of once/2 months or more frequently.

**C. QUARTERLY:**

1. is defined as a **fixed calendar quarter** or any part of the fixed calendar quarter for a non-seasonal effluent characteristic with a measurement frequency of once/quarter. Fixed calendar quarters are: January through March, April through June, July through September, and October through December.

2. is defined as a **fixed three month period** (or any part of the fixed three month period) of or dependent upon the seasons specified in the permit for a seasonal effluent characteristic with a monitoring requirement frequency of once/quarter that does not coincide with the fixed calendar quarter. Seasonal calendar quarters are: May through July, August through October, November through January, and February through April.

**D. SEMI-ANNUAL:**

is defined as the fixed time periods January through June, and July through December (or any portion thereof) for an effluent characteristic with a measurement frequency of once/6 months or twice/year.

**E. ANNUAL or YEARLY:**

is defined as a fixed calendar year or any portion of the fixed calendar year for an effluent characteristic or parameter with a measurement frequency of once/year. A calendar year is January through December, or any portion thereof.

23. **“National Pollutant Discharge Elimination System”** means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements under Sections 307, 402, 318, and 405 of the Clean Water Act.
24. **“POTW”** means Publicly Owned Treatment Works; a treatment works (see Part IV.29 below) which is owned by a state or municipality.
25. **“Reduction of CBOD5/BOD5 and TSS in mg/l Formula”**  
[(Influent – Effluent) / Influent] x 100
26. **“Severe property damage”** means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in products.
27. **“Sewage sludge”** means the solids, residues, and precipitate separated from or created in sewage by the unit processes at a POTW. Sewage as used in this definition means any wastes, including wastes from humans, households, commercial establishments, industries, and stormwater runoff that are discharged to or otherwise enter a POTW.
28. **“7-Day Average”** Also known as “average weekly” means the highest allowable average of “daily discharges” over a calendar week, calculated as the sum of all “daily discharges” measured during a calendar week divided by the number of “daily discharges” measured during that week. The 7-Day Average for Fecal Coliform Bacteria (FCB) or E-Coli is the



# DRAFT

Permit Number: AR0044016  
AFIN: 33-00036  
Page 4 of Part IV

geometric mean of the “daily discharges” of all effluent samples collected during a calendar week in colonies per 100 ml.

29. **“Treatment works”** means any devices and systems used in storage, treatment, recycling, and reclamation of municipal sewage and industrial wastes, of a liquid nature to implement section 201 of the Act, or necessary to recycle reuse water at the most economic cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and alterations thereof; elements essential to provide a reliable recycled supply such as standby treatment units and clear well facilities, and any works, including site acquisition of the land that will be an integral part of the treatment process or is used for ultimate disposal of residues resulting from such treatment.
30. **Units of Measure:**
  - “MGD” shall mean million gallons per day.
  - “mg/l” shall mean milligrams per liter or parts per million (ppm).
  - “µg/l” shall mean micrograms per liter or parts per billion (ppb).
  - “cfs” shall mean cubic feet per second.
  - “ppm” shall mean parts per million.
  - “s.u.” shall mean standard units.
31. **“Upset”** means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. Any upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, lack of preventive maintenance, or careless of improper operations.
32. **“Visible sheen”** means the presence of a film or sheen upon or a discoloration of the surface of the discharge. A sheen can also be from a thin glistening layer of oil on the surface of the discharge.
33. **“Weekday”** means Monday – Friday.