



# Arkansas Department of Health

4815 West Markham Street • Little Rock, Arkansas 72205-3867 • Telephone (501) 661-2000

Governor Asa Hutchinson

Nathaniel Smith, MD, MPH, Director and State Health Officer

Engineering Section, Slot 37

[www.Healthy.Arkansas.gov/eng/](http://www.Healthy.Arkansas.gov/eng/)

Ph 501-661-2623

After Hours Emergency 501-661-2136

Fax 501-661-2032

September 29, 2015

Mo Shafii  
Permits Branch, ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

RE: ADH No. 32-6859, ADEQ Permit No. 4811-WR-4, AFIN 04-00899  
VILLAGES OF CROSS CREEK, Benton County, Arkansas

Dear Mr. Shafii,

A staff review has been made of the information received on the referenced project. ADH site inspection on 9/17/2015 revealed both drip fields have effluent surfacing and both need mowing. In areas, the ground is very soft and effluent may be close to surfacing in these areas. Permittee should provide ADH with documentation of corrective action by 10/30/2105.

If you have any questions or comments, please coordinate them through Stephanie Burchfield at 501-280-4428.

Sincerely,

Lyle Godfrey, P.E.  
Chief, Technical Support  
Engineering Section

CH:CC:LJ:LG:DR:sb

cc: Kathryn Bartlett, Villages of Cross Creek, PO Box 9299, Fayetteville, AR 72703



**Arkansas Department of Health**

4815 West Markham Street  
Little Rock, Arkansas 72205-3867

SLOT #37

Hasler

FIRST-CLASS MAIL  
PRSRT

10/01/2015

US POSTAGE

\$000.47-1



ZIP 72201  
011D12604017

Mo Shafii  
Permits Branch ADEQ  
5301 Northshore Drive  
North Little Rock, Arkansas 72118-5317

Keeping Your Hometown Healthy

