

**ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
MONITORING REPORT FOR DECENTRALIZED WASTEWATER TREATMENT FACILITIES VIA DRIP IRRIGATION
MONTHLY MONITORING REPORT**

PERMITTEE NAME
Benton County, Arkansas Suburban Sewer District No 1 Villages of Cross Creek
PERMITTEE ADDRESS
PO Box 9299 Fayetteville AR 72703


FACILITY NAME (IF DIFFERENT)
Villages of Cross Creek
FACILITY ADDRESS
3302 N Dixieland Rd Little Flock AR

PERMIT NO.
4811-WR-4
AFIN NO.
04-00899

WASTEWATER EFFLUENT MONITORING PERIOD		
MM/DD/YYYY		MM/DD/YYYY
8/1/2017		8/31/2017

TREATED WASTEWATER EFFLUENT SAMPLING

PARAMETER	Limit	Sample Measurement	UNITS	Monitoring	Reporting
Flow, Monthly total	REPORT	0.630653	MG	Total Flow per calendar month	Prior to the 15th of the following Month
Flow, daily maximum	REPORT	0.024338	MGD	Daily	
Carbonaceous Biochemical Oxygen Demand (CBOD5)	30	10	mg/l	Grab Sample once per month	
Total Suspended Solids (TSS)	30	26	mg/l		
Fecal Coliform Bacteria (FCB)	10,000	6,500	colonies/100ml		
pH	6.0 - 9.0	6.9	s.u.		
Total Phosphorus (TP)	REPORT	6.4	mg/l		
Total Kjeldahl Nitrogen (TKN)	REPORT	No Report	mg/l	Grab sample once per quarter	
Ammonia Nitrogen	REPORT	No Report	mg/l		
Nitrate Nitrogen (NO3-N) + Nitrite Nitrogen (NO2-N)	REPORT	No Report	mg/l		
Plant Available Nitrogen (PAN)	REPORT	No Report	mg/l		
Loading Rate	REPORT	See Attached	gpd/ft 2	Daily	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
Kathy Bartlett			(479) 530-5926	9/5/2017
TYPED OR PRINTED				MM/DD/YYYY

COMMENTS AND EXPLANATION OF VIOLATIONS (Reference all attachments here)

VILLAGES OF CROSS CREEK LOADING RATES

Zone Identification	GPD/sq 2
1	2,750
2	2,750
3	2,750
4	2,750
5	2,750
6	2,750
7	3,261
8	3,797
9	Not used
10	Combined with 8
11	3,213
12	Not used
13	Not used
14	Not used
15	Not used
16	Not used
17	Not used

Environmental Services Company, Inc.

Corporate Office
 13715 West Markham
 Little Rock, AR 72211
 Tel. (501)221-2565 Fax (501)221-1341

Northwest Arkansas Branch
 1107 Century Avenue
 Springdale, AR 72762
 Tel. (479)750-1170 Fax (479)750-1172

Control Number: 1708020136
 Customer Name : DIXIELAND UTILITY LLC
 Customer/Permit No. : 1698 / 4811-WR-4 001
 Report Date : 08/18/17

Sample Date : 08/11/17
 Sample Time : 1250
 Sample Type : GRAB DIXIELAND
 Sample From : DOSE TANK EFFLUENT

Collected By: JCB
 Delivery By : JCB
 Work Order :
 Purchase Order :

Laboratory Analysis


Analysis						Quality Assurance			
Date	Time	By	Parameter	Result	Notes	Quantity	Method	Precision % RPD	Accuracy % Recovery
08/11	1250	JCB	pH	6.9 S.U.			SM 2000 4500-H+ B	0.00	N/A *
08/14	1300	TSB	Phosphorous, Total (as P)	6.4 mg/L			EPA 365.3	1.44	100.6 *
08/16	0900	JCB	Solids, Total Suspended	26.0 mg/L			SM 1997 2540 D	9.97	N/A *
08/11	1500	JCB	Coliform, Fecal	6500 /100ml			SM 9222 D 1997	26.67	N/A
08/11	1400	TSB	BOD, Carbonaceous	10.0 mg/L			SM 2001 5210 B	24.55	105.2 *

* QA data shown is from a different sample or standard on the same date.

All equipment used is checked and/or calibrated daily. All NPDES testing is conducted in accordance with 40 CFR Part 136. A minimum of 10% spiked and duplicate samples is run on each parameter where applicable for Quality Assurance purposes. Quality Assurance Plan on file with Arkansas Department of Environmental Quality. Analysis time indicates the time of the start of the analytical batch in which the specific sample was included.

Signature Richard Brown
 Environmental Services Co., Inc.

Environmental Services Company, Inc.
 Northwest Arkansas
 1107 Century Street
 Springdale, Arkansas 72762
 website: www.esclabs.com



Corporate Office, Little Rock, Arkansas
 501-221-2565

Carlsbad, New Mexico
 575-887-1ESC

Phone: 479-750-1170 Fax: 479-750-1172

CHAIN OF CUSTODY

Client Information						Project Information					Requested Parameters								
Company Name: Dixieland Utility LLC.			Permit/Project #:			Purchaser Name(s): <i>John Beard</i> and Signature(s): <i>John Beard</i>					pH(23)	Phos(25), NH ₃ -N(15.A)	TKN(16.A)N+N(91)	CBOD(70), TSS(28), PAN(99.99)	Fecal Coliform(43)				
Address: 3302 N. Dixieland			Purchase Order #:																
Rogers AR																			
Telephone: (479)936-0333 (Cell)																			
Telephone:						ESC Client Number: 1698													
Sample Identification		Sample Collection				Sample Containers				pH(23)	Phos(25), NH ₃ -N(15.A)	TKN(16.A)N+N(91)	CBOD(70), TSS(28), PAN(99.99)	Fecal Coliform(43)					
Identification	ESC Control #	Date	Time	Type	Matrix	Type	Volume	Preservative	#										
Dose Tank/Effluent	17080201350	8/11/17	1250	GRAB	Water	teflon	150 ml	none	1	X									
				GRAB	Water	Plastic	8 oz	H ₂ SO ₄ , pH<2	1		X	X							
				GRAB	Water	Plastic	1 qt	none/ice	1				X						
				GRAB	Water	Whirlpak	300ml	NaS ₂ O ₄	1					X					
Relinquished By: (Signature and Printed Name)		Date	Time	Received By: (Signature and Printed Name)		Date	Time	Custody Seals:		Used?	Intact?								
<i>John Beard</i> John Beard		8/11/17	1340	<i>Richard Brown</i> RICHARD BROWN		8-11-17	1340	Were samples properly preserved:		Regular	Special								
Relinquished By: (Signature and Printed Name)		Date	Time	Received for Lab By: (Signature and Printed Name)		Date	Time	Yes		No									
				<i>Richard Brown</i> RICHARD BROWN		8-11-17	1340	X											
Comments:					FLOW DATA	Field Test	Time	Analyst	Result	Result	Units								
					Analyst:	pH:	1250	JCB	6.9	6.9									
					Time:	Temp.:			29.8	29.8	°F								
					Reading:	DO:													
					Units:	Debris:													
Cool all samples to 6 degrees C.							Chlorinated? Yes No			This Document is Page 1 of 1									