

**ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
MONITORING REPORT FOR DECENTRALIZED WASTEWATER TREATMENT FACILITIES VIA DRIP IRRIGATION
MONTHLY MONITORING REPORT**

PERMITTEE NAME
Benton County, Arkansas Suburban Sewer District No 1 Villages of Cross Creek
PERMITTEE ADDRESS
PO Box 9299 Fayetteville AR 72703


FACILITY NAME (IF DIFFERENT)
Villages of Cross Creek
FACILITY ADDRESS
3302 N Dixieland Rd Little Flock AR

PERMIT NO.
4811-WR-4
AFIN NO.
04-00899

WASTEWATER EFFLUENT MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
6/1/2019	6/30/2019

TREATED WASTEWATER EFFLUENT SAMPLING

PARAMETER	Limit	Sample Measurement	UNITS	Monitoring	Reporting
Flow, Monthly total	REPORT	0.485429	MG	Total Flow per calendar month	Prior to the 15th of the following Month
Flow, daily maximum	REPORT	0.019281	MGD	Daily	
Carbonaceous Biochemical Oxygen Demand (CBOD5)	30	13.2	mg/l	Grab Sample once per month	
Total Suspended Solids (TSS)	30	24.5	mg/l		
Fecal Coliform Bacteria (FCB)	10,000	4,884	colonies/100ml		
pH	6.0 - 9.0	7.2	s.u.		
Total Phosphorus (TP)	REPORT	7.16	mg/l		
Total Kjeldahl Nitrogen (TKN)	REPORT	No Report	mg/l	Grab sample once per quarter	
Ammonia Nitrogen	REPORT	No Report	mg/l		
Nitrate Nitrogen (NO ₃ -N) + Nitrite Nitrogen (NO ₂ -N)	REPORT	No Report	mg/l		
Plant Available Nitrogen (PAN)	REPORT	No Report	mg/l		
Loading Rate	REPORT	See Attached	gpd/ft 2	Daily	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
			(479) 530-5926	7/1/2019
TYPED OR PRINTED				MM/DD/YYYY

COMMENTS AND EXPLANATION OF VIOLATIONS (Reference all attachments here)

June 2019 VILLAGES OF CROSS CREEK LOADING RATES 19,281 Max Day

Zone Identification	GPD/sq 2
1	2,179
2	2,179
3	2,179
4	2,179
5	2,179
6	2,179
7	2,584
8	3,008
9	Not used
10	Combined with 8
11	2,545
12	Not used
13	Not used
14	Not used
15	Not used
16	Not used
17	Not used

Environmental Services Company, Inc.

Corporate Office
 13715 West Markham
 Little Rock, AR 72211
 Tel. (501)221-2565 Fax (501)221-1341

Northwest Arkansas Branch
 1107 Century Avenue
 Springdale, AR 72762
 Tel. (479)750-1170 Fax (479)750-1172

Control Number: 1906020078
 Customer Name : DIXIELAND UTILITY LLC
 Customer/Permit No. : 1698 / 4811-WR-4 001
 Report Date : 06/29/19

Sample Date : 06/21/19
 Sample Time : 1050
 Sample Type : GRAB
 Sample From : DOSE TANK EFFLUENT

Collected By: JEW
 Delivery By : JEW
 Work Order :
 Purchase Order :

Laboratory Analysis

Analysis							Quality Assurance		
Date	Time	By	Parameter	Result	Notes	Quantity	Method	Precision % RPD	Accuracy % Recovery
06/21	1055	JEW	pH	7.2	S.U.		SM 2011 4500-H+ B	0.00	N/A
06/27	1015	TSB	Phosphorous, Total (as P)	7.160	mg/L		EPA 365.3	1.71	116.0 *
06/28	1427	TSB	Solids, Total Suspended	24.5	mg/L		SM 2011 2540 D	20.69	N/A *
06/21	1604	TSB	Fecal Coliform (MPN/100mL)	4884.0	/100ml		06/2012 Colilert18	11.41	0.0
06/21	1300	TSB	BOD, Carbonaceous	13.2	mg/L		SM 2001 5210 B	8.13	94.0 *

* QA data shown is from a different sample or standard on the same date.


All equipment used is checked and/or calibrated daily. All NPDES testing is conducted in accordance with 40 CFR Part 136. A minimum of 10% spiked and duplicate samples is run on each parameter where applicable for Quality Assurance purposes. Quality Assurance Plan on file with Arkansas Department of Environmental Quality. Analysis time indicates the time of the start of the analytical batch in which the specific sample was included.

Signature



Environmental Services Co., Inc.

Environmental Services Company, Inc.
 Northwest Arkansas
 1107 Century Street
 Springdale, Arkansas 72762
 website: www.esclabs.com



Corporate Office, Little Rock, Arkansas
 501-221-2565


Carlsbad, New Mexico
 575-887-1ESC

Phone: 479-750-1170 Fax: 479-750-1172


CHAIN OF CUSTODY

Client Information						Project Information					Requested Parameters																	
Company Name: Dixieland Utility LLC.						Permit/Project #:					pH(23)	Phos(25)	CBOD(70), TSS(28)	Fecal Coliform(43.IF)														
Address: 3302 N. Dixieland						Purchase Order #:																						
Rogers AR						Sampler Name(s): <i>James With James W. Hse</i>																						
Telephone: (479)936-0333 (Cell)						and Signature(s):																						
Telephone:																												
ESC Client Number: 1698																												
Sample Identification		Sample Collection				Sample Containers																						
Identification	ESC Control #	Date	Time	Type	Matrix	Type	Volume	Preservative	#																			
Dose Tank/Effluent	1906020078	6-21-19	1050	GRAB	Water	teflon	150 mL	None	1	X																		
				GRAB	Water	Plastic	8 oz	H ₂ SO ₄ , pH<2	1		X																	
				GRAB	Water	Plastic	1 qt	None, Cool†	1			X																
				GRAB	Water	Whirlpak	125 mL	NaS ₂ O ₄ Cool†	1				X															
Relinquished By: (Signature and Printed Name)		Date	Time	Received By: (Signature and Printed Name)				Date	Time	Custody Seals:																		
<i>James With James W. Hse</i>		6-21-19	1140							Used? <input type="checkbox"/> Intact? <input type="checkbox"/>																		
Relinquished By: (Signature and Printed Name)		Date	Time	Received By: (Signature and Printed Name)				Date	Time	Turnaround:																		
										Regular <input type="checkbox"/> Special <input type="checkbox"/>																		
Relinquished By: (Signature and Printed Name)		Date	Time	Received for Lab By: (Signature and Printed Name)				Date	Time	Were samples properly preserved:																		
				<i>Alex Anderson</i>				6-21-19	1140	Yes <input type="checkbox"/> No <input type="checkbox"/>																		
Comments:						FLOW DATA	Field Test	Time	Analyst	Result	Result	Units																
						Analyst:	pH:	1055	JEW	7.2	7.2																	
						Time:	Temp.:	1053	JEW	27.9	28.0	°C																
						Reading:	DO:																					
						Units:	Debris:																					
Cool all samples to 6 degrees C.						Chlorinated? Yes No				This Document is Page 1 of 1																		

GCD
P.O. Box 9299
Fayetteville, AR 72703



NWA P&DF 72701
TUE 02 JUL 2019 PM



ADEQ Water Division
Permits Branch
5301 Northshore Dr
N Little Rock, AR 72118-5317

