

**ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
MONITORING REPORT FOR DECENTRALIZED WASTEWATER TREATMENT FACILITIES VIA DRIP IRRIGATION
MONTHLY MONITORING REPORT**

PERMITTEE NAME Benton County, Arkansas Suburban Sewer District No 1 Villages of Cross Creek
PERMITTEE ADDRESS PO Box 9299 Fayetteville AR 72703


FACILITY NAME (IF DIFFERENT) Villages of Cross Creek
FACILITY ADDRESS 3302 N Dixieland Rd Little Flock AR

PERMIT NO. 4811-WR-4
AFIN NO. 04-00899

WASTEWATER EFFLUENT MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
6/1/2016	6/30/2016

TREATED WASTEWATER EFFLUENT SAMPLING

PARAMETER	Limit	Sample Measurement	UNITS	Monitoring	Reporting
Flow, Monthly total	REPORT	597,572	MG	Total Flow per calendar month	Prior to the 15th of the following Month
Flow, daily maximun	REPORT	25,027	MGD	Daily	
Carbonaceous Blochemical Oxygen Demand (CBOD5)	30	5.5	mg/l	Grab Sample once per month	
Total Suspended Solids (TSS)	30	18	mg/l		
Fecal Coliform Bacteria (FCB)	10,000	4	colonies/100ml		
pH	6.0 - 9.0	6.8	s.u.		
Total Phosphorus (TP)	REPORT	6.1	mg/l		
Total Kjeldahl Nitrogen (TKN)	REPORT	no report	mg/l	Grab sample once per quarter	
Ammonia Nitrogen	REPORT	no report	mg/l		
Nitrate Nitrogen (NO3-N) + Nitrite Nitrogen (NO2-N)	REPORT	no report	mg/l		
Plant Available Nitrogen (PAN)	REPORT	no report	mg/l		
Loading Rate	REPORT	see attached	gpd/ft 2	Daily	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Kathy Bartlett	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
			(479) 530-5926	7/14/2016 MM/DD/YYYY

COMMENTS AND EXPLANATION OF VIOLATIONS (*Reference all attachments here*)

VILLAGES OF CROSS CREEK LOADING RATES

Zone Identification	GPD/sq 2
1	2,828
2	2,828
3	2,828
4	2,828
5	2,828
6	2,828
7	3,354
8	3,904
9	Not used
10	Combined with 8
11	3,304
12	Not used
13	Not used
14	Not used
15	Not used
16	Not used
17	Not used

Environmental Services Company, Inc.

Corporate Office
 13715 West Markham
 Little Rock, AR 72211
 Tel. (501)221-2565 Fax (501)221-1341

Northwest Arkansas Branch
 1107 Century Avenue
 Springdale, AR 72762
 Tel. (479)750-1170 Fax (479)750-1172

Control Number: 1606020453	Sample Date : 06/30/16	Collected By: JB
Customer Name : DIXIELAND UTILITY LLC	Sample Time : 1415	Delivery By : JB
Customer/Permit No. : 1698 / 4811-WR-4 001	Sample Type : GRAB	Work Order :
Report Date : 07/11/16	Sample From : DOSE TANK EFFLUENT	Purchase Order :


<u>Laboratory Analysis</u>							<u>Quality Assurance</u>	
<u>Analysis</u>			<u>Result</u>	<u>Notes</u>	<u>Quantity</u>	<u>Method</u>	<u>Precision</u>	<u>Accuracy</u>
<u>Date</u>	<u>Time</u>	<u>By</u>					<u>Parameter</u>	<u>% RPD</u>
06/30	1415	JCB	pH	6.8 S.U.		SM 2000 4500-H+ B	1.48	N/A
07/05	1045	TSB	Phosphorous, Total (as P)	6.1 mg/L		EPA 365.3	0.00	101.5 *
07/05	1430	TSB	Solids, Total Suspended	18.0 mg/L		SM 1997 2540 D	3.28	N/A *
06/30	1700	AEU	Coliform, Fecal	4 /100ml		SM 9222 D 1997	0.00	N/A *
07/01	1400	TSB	BOD, Carbonaceous	5.5 mg/L		SM 2001 5210 B	4.04	91.1 *

* QA data shown is from a different sample or standard on the same date.

All equipment used is checked and/or calibrated daily. All NPDES testing is conducted in accordance with 40 CFR Part 136. A minimum of 10% spiked and duplicate samples is run on each parameter where applicable for Quality Assurance purposes. Quality Assurance Plan on file with Arkansas Department of Environmental Quality. Analysis time indicates the time of the start of the analytical batch in which the specific sample was included.

Signature Richard Brown
 Environmental Services Co., Inc.

Environmental Services Company, Inc.
 Northwest Arkansas
 1107 Century Street
 Springdale, Arkansas 72762
 website: www.esclabs.com



Corporate Office, Little Rock, Arkansas
 501-221-2565
 Carlsbad, New Mexico
 575-887-1ESC

Phone: 479-750-1170 Fax: 479-750-1172

CHAIN OF CUSTODY

Client Information						Project Information				Requested Parameters																				
Company Name: Dixieland Utility LLC.						Permit/Project #:				pH(23)	Phos(25)	CBOD(70), TSS(28)	Fecal Coliform(43)																	
Address: 3302 N. Dixieland Rogers AR						Purchase Order #:																								
Telephone: (479)936-0333 (Cell)						Sampler Name(s): John Byrd																								
Telephone:						and Signature(s): <i>[Signature]</i>																								
ESC Client Number: 1698																														
Sample Identification		Sample Collection				Sample Containers				pH(23)	Phos(25)	CBOD(70), TSS(28)	Fecal Coliform(43)																	
Identification	ESC Control #	Date	Time	Type	Matrix	Type	Volume	Preservative	#																					
Dose Tank/Effluent	1606020453	6-30-16	1415	GRAB	Water	teflon	150 ml	none	1											x										
				GRAB	Water	Plastic	8 oz	H ₂ SO ₄ , pH<2	1												x									
				GRAB	Water	Plastic	1 qt	none/ice	1													x								
				GRAB	Water	Whirlpak	300ml	NaS ₂ O ₄	1				x																	
Relinquished By: (Signature and Printed Name)		Date	Time	Received By: (Signature and Printed Name)		Date	Time	Custody Seals:																						
<i>[Signature]</i> John Byrd		6-30-16	1505	<i>[Signature]</i>				Used? <input checked="" type="checkbox"/> Intact? <input type="checkbox"/>																						
Relinquished By: (Signature and Printed Name)		Date	Time	Received By: (Signature and Printed Name)		Date	Time	Turnaround:																						
				<i>[Signature]</i>				Regular <input checked="" type="checkbox"/> Special <input type="checkbox"/>																						
Relinquished By: (Signature and Printed Name)		Date	Time	Received for Lab By: (Signature and Printed Name)		Date	Time	Were samples properly preserved:																						
				<i>[Signature]</i> V.L. PAE		6/30/16	1505	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>																						
Comments:						FLOW DATA	Field Test	Time	Analyst	Result	Result	Units																		
						Analyst:	pH:	1415	JCB	6.76	6.74																			
						Time:	Temp.:	1415	JCB	27.8	27.8	°F																		
						Reading:	DO:																							
						Units:	Debris:																							
Cool all samples to 6 degrees C.						Chlorinated? Yes No				This Document is Page 1 of 1																				