

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
MONTHLY MONITORING REPORT FOR DECENTRALIZED WASTEWATER TREATMENT FACILITIES VIA DRIP IRRIGATION

PERMITTEE NAME
Sloan Estates POA, Inc.
PERMITTEE ADDRESS
PO Box 7797 Springdale, Ar 72766

FACILITY NAME (IF DIFFERENT)
Sloan Estates
FACILITY ADDRESS
5088 E Sagely Fayetteville, Ar 72703


PERMIT NO.
4837-W
AFIN NO.
72-01074

MAKE ADDITIONAL COPIES OF THIS FORM FOR FUTURE USE. SUBMIT LAB ANALYSES WITH THIS FORM.

WASTEWATER EFFLUENT MONITORING PERIOD		
MM/DD/YYYY		MM/DD/YYYY
FROM 3/1/2019	TO	3/31/2019

TREATED WASTEWATER EFFLUENT SAMPLING

PARAMETER	PERMIT REQUIREMENT	SAMPLE MEASUREMENT	UNITS	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
PHOSPHOROUS, TOTAL (AS P) GROSS VALUE	*****	7.7	MG/L	ONCE/MONTH	GRAB	
CBOD, 5-DAY (20 DEG. C) EFFLUENT GROSS VALUE	15	24	MG/L	ONCE/MONTH	GRAB	
PH EFFLUENT GROSS VALUE	6 to 9	7.4	S.U.	ONCE/MONTH	GRAB	
SOLIDS, TOTAL SUSPENDED EFFLUENT GROSS VALUE	15	16.85	MG/L	ONCE/MONTH	GRAB	
COLIFORM, FECAL GENERAL EFFLUENT GROSS VALUE	10,000	9,678	N/100 ML	ONCE/MONTH	GRAB	
NITROGEN, TOTAL KJELDAHL (AS TKN) EFFLUENT GROSS VALUE	*****	58	MG/L	ONCE/MONTH	GRAB	
NITROGEN, AMMONIA TOTAL (AS NH ₃ N) EFFLUENT GROSS VALUE	*****	56	MG/L	ONCE/MONTH	GRAB	
NITROGEN, NITRATE + NITRITE (AS NO ₃ N + NO ₂ -N) EFFLUENT GROSS VALUE	*****	1	MG/L	ONCE/MONTH	GRAB	
PLANT AVAILABLE NITROGEN (AS PAN) CALCULATED VALUE	*****	58	MG/L	ONCE/MONTH	GRAB	
FLOW, THRU CONDUIT OR TREATMENT UNIT EFFLUENT GROSS VALUE	*****	MONTHLY TOTAL	DAILY MAX	MGD	ONCE/MONTH	TOTAL FLOW
		0.006	0.006			

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
			501	888-0500	4/16/2019
TYPED OR PRINTED			AREA CODE	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF VIOLATIONS (Reference all attachments here)

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: Sloan Estates

PERMIT: 4837-W

REPORTING PERIOD: 3/1/2019-3/31/2019

REPORT DATE: 3/27/19

<u>PARAMETER (S)</u>	<u>NPDES</u> <u>MIN</u>	<u>NPDES</u> <u>AVG</u>	<u>NPDES</u> <u>MAX</u>	<u>RESULT</u> <u>REPORTED</u>	<u>DATE OF</u> <u>EXCURSION</u>
CBOD			15	24	3/20/2019
TSS			15	16.85	3/20/2019


COMMENTS:

Our re sample on CBOD was much lower than the labs. I have spoken with the director of this lab and he is going to meet with their technician, and our operator to make sure that the sample is being collected in the right place and collected properly. As for the TSS we will clean this tank in effort to lower the TSS to within permit limits.

SIGNATURE

TITLE

DATE




cognizant official


4/16/2019



New Water Systems
P.O. Box 193805
Little Rock, AR 72219
501.888.0500



Little Rock P&DC 722
WED 17 APR 2019 PM



Arkansas Department of Environmental Quality
Enforcement Section/Water Division
5301 Northshore Drive
North Little Rock, Arkansas 72118