

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
MONTHLY MONITORING REPORT FOR DECENTRALIZED WASTEWATER TREATMENT FACILITIES VIA DRIP IRRIGATION


PERMITTEE NAME
Sloan Estates POA, Inc.
PERMITTEE ADDRESS
PO Box 7797 Springdale, Ar 72766

FACILITY NAME (IF DIFFERENT)
Sloan Estates
FACILITY ADDRESS
5088 E Sagely Fayetteville, Ar 72703

PERMIT NO.
4837-W
AFIN NO.
72-01074

MAKE ADDITIONAL COPIES OF THIS FORM FOR FUTURE USE. SUBMIT LAB ANALYSES WITH THIS FORM.

WASTEWATER EFFLUENT MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
FROM 3/1/2018	TO 3/31/2018

TREATED WASTEWATER EFFLUENT SAMPLING						
PARAMETER	PERMIT REQUIREMENT	SAMPLE MEASUREMENT	UNITS	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
PHOSPHOROUS, TOTAL (AS P) EFFLUENT GROSS VALUE	*****	7.2	MG/L	ONCE/MONTH	GRAB	
CBOD, 5-DAY (20 DEG. C) EFFLUENT GROSS VALUE	15	8.7	MG/L	ONCE/MONTH	GRAB	
PH EFFLUENT GROSS VALUE	6 to 9	7	S.U.	ONCE/MONTH	GRAB	
SOLIDS, TOTAL SUSPENDED EFFLUENT GROSS VALUE	15	7.2	MG/L	ONCE/MONTH	GRAB	
COLIFORM, FECAL GENERAL EFFLUENT GROSS VALUE	10,000	6,000	N/100 ML	ONCE/MONTH	GRAB	
NITROGEN, TOTAL KJELDAHL (AS TKN) EFFLUENT GROSS VALUE	*****	33	MG/L	ONCE/MONTH	GRAB	
NITROGEN, AMMONIA TOTAL (AS NH ₃ N) EFFLUENT GROSS VALUE	*****	26	MG/L	ONCE/MONTH	GRAB	
NITROGEN, NITRATE + NITRITE (AS NO ₃ N + NO ₂ -N) EFFLUENT GROSS VALUE	*****	2	MG/L	ONCE/MONTH	GRAB	
PLANT AVAILABLE NITROGEN (AS PAN) CALCULATED VALUE	*****	30	MG/L	ONCE/MONTH	GRAB	
FLOW, THRU CONDUIT OR TREATMENT UNIT EFFLUENT GROSS VALUE	*****	MONTHLY TOTAL	DAILY MAX	MGD	ONCE/MONTH	TOTAL FLOW
		0.005	0.005			
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE
MARK A DAVIS				501	888-0500	4/23/2018
				TYPED OR PRINTED	AREA CODE	NUMBER
COMMENTS AND EXPLANATION OF VIOLATIONS (Reference all attachments here)						