

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
MONTHLY MONITORING REPORT FOR DECENTRALIZED WASTEWATER TREATMENT FACILITIES VIA DRIP IRRIGATION

PERMITTEE NAME City of Cave Springs
PERMITTEE ADDRESS P.O. Box 36 Cave Springs AR 72718

FACILITY NAME (IF DIFFERENT) Plant #2
FACILITY ADDRESS 498 Pebble Beach


PERMIT NO. 4893-WR-2
AFIN NO. 04-0642

MAKE ADDITIONAL COPIES OF THIS FORM FOR FUTURE USE. SUBMIT LAB ANALYSES WITH THIS FORM.

WASTEWATER EFFLUENT MONITORING PERIOD	
FROM MM/DD/YYYY 06/01/2016	TO MM/DD/YYYY 06/30/2016

TREATED WASTEWATER EFFLUENT SAMPLING

PARAMETER	PERMIT REQUIREMENT	SAMPLE MEASUREMENT	UNITS	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
PHOSPHOROUS, TOTAL (AS P) EFFLUENT GROSS VALUE	*****	7.5	MG/L	ONCE/MONTH	GRAB	
CBOD, 5-DAY (20 DEG. C) EFFLUENT GROSS VALUE	—	7.5	MG/L	ONCE/MONTH	GRAB	
PH EFFLUENT GROSS VALUE	6 to 9	6.7	S.U.	ONCE/MONTH	GRAB	
SOLIDS, TOTAL SUSPENDED EFFLUENT GROSS VALUE	—	11.0	MG/L	ONCE/MONTH	GRAB	
COLIFORM, FECAL GENERAL EFFLUENT GROSS VALUE	—	560	N/100 ML	ONCE/MONTH	GRAB	
NITROGEN, TOTAL KJELDAHL (AS TKN) EFFLUENT GROSS VALUE	*****	22.40	MG/L	ONCE/MONTH	GRAB	
NITROGEN, AMMONIA TOTAL (AS NH ₃ -N) EFFLUENT GROSS VALUE	*****	15.7	MG/L	ONCE/MONTH	GRAB	
NITROGEN, NITRATE + NITRITE (AS NO ₃ -N + NO ₂ -N) EFFLUENT GROSS VALUE	*****	37.644	MG/L	ONCE/MONTH	GRAB	
PLANT AVAILABLE NITROGEN (AS PAN) CALCULATED VALUE		37.6	MG/L	ONCE/MONTH	GRAB	
FLOW, THRU CONDUIT OR TREATMENT UNIT EFFLUENT GROSS VALUE	*****	MONTHLY TOTAL	DAILY MAX	MGD	ONCE/MONTH	TOTAL FLOW
		1.41	.06			

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Tony Merwath TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE		DATE
			479	295-3013	07/01/2016
			AREA CODE	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF VIOLATIONS (Reference all attachments here)

Environmental Services Company, Inc.

Corporate Office
 13715 West Markham
 Little Rock, AR 72211
 Tel. (501)221-2565 Fax (501)221-1341

Northwest Arkansas Branch
 1107 Century Avenue
 Springdale, AR 72762
 Tel. (479)750-1170 Fax (479)750-1172

Control Number: 1606020017	Sample Date : 06/01/16	Collected By: RHB
Customer Name : CAVE SPRINGS, CITY OF OUTFALL 2	Sample Time : 1208	Delivery By : RHB
Customer/Permit No. : 2379 / 4893-WR-2 002	Sample Type : GRAB EFFLUENT	Work Order :
Report Date : 06/08/16	Sample From : DIVERTER BOX	Purchase Order :


<u>Laboratory Analysis</u>							<u>Quality Assurance</u>		
<u>Analysis</u>							<u>Precision</u>	<u>Accuracy</u>	
<u>Date</u>	<u>Time</u>	<u>By</u>	<u>Parameter</u>	<u>Result</u>	<u>Notes</u>	<u>Quantity</u>	<u>Method</u>	<u>% RPD</u>	<u>% Recovery</u>
06/02	0900	TSB	Ammonia Nitrogen	15.7 mg/L			SM 1997 4500-NH3 F	1.65	102.5 *
06/07	0800	TSB	Kjeldahl Nitrogen Total	22.40 mg/L			SM 1997 4500-NorgB	1.10	100.7 *
06/02	1410	TSB	Nitrate Nitrogen	37.30 mg/L			SM 2000 4500-NO3 E	1.23	98.2 *
06/02	1330	TSB	Nitrite Nitrogen	0.344 mg/L			SM 2000 4500 NO2 B	0.21	100.0 *
06/01	1208	RHB	pH	6.7 S.U.			SM 2000 4500-H+ B	1.44	N/A *
06/02	1015	TSB	Phosphorous, Total (as P)	7.5 mg/L			EPA 365.3	1.80	102.4 *
06/06	1600	CLS	Solids, Total Suspended	11.0 mg/L			SM 1997 2540 D	6.45	N/A *
06/01	1615	CLS	Coliform, Fecal	560 /100ml			SM 9222 D 1997	0.00	N/A *
06/01	1430	TSB	BOD, Carbonaceous	7.5 mg/L			SM 2001 5210 B	7.78	96.6 *
06/03	0930	CLS	Solids, % Total by mass	0.042 %			SM 1997 2540 G	2.94	N/A *
06/07	1600	TSB	Nitrogen, Plant Available	37.6 mg/L			SM 1997 4500-N		

* QA data shown is from a different sample or standard on the same date.

All equipment used is checked and/or calibrated daily. All NPDES testing is conducted in accordance with 40 CFR Part 136. A minimum of 10% spiked and duplicate samples is run on each parameter where applicable for Quality Assurance purposes. Quality Assurance Plan on file with Arkansas Department of Environmental Quality. Analysis time indicates the time of the start of the analytical batch in which the specific sample was included.

Signature Richard Brown
 Environmental Services Co., Inc.

Environmental Services Company, Inc.
 Northwest Arkansas
 1107 Century Street
 Springdale, Arkansas 72762
 website: www.esclabs.com



Corporate Office, Little Rock, Arkansas
 501-221-2565

Carlsbad, New Mexico
 575-887-1ESC

Phone: 479-750-1170 Fax: 479-750-1172

CHAIN OF CUSTODY

Client Information					Project Information					Requested Parameters					
Company Name: Cave Springs Plant 2					Permit/Project #:					pH(23) Fecal Coliform(43) CBOD(70), TSS(28), NO2(19) NH3(15.A), P(25), TKN(16.A), NO3(18) PAN(99.99), %Solids(82)					
Address: PO BOX 5					Purchase Order #:										
Cave Springs 72718					Sampler Name(s): <i>RICHARD BROWN</i>										
Telephone: 479 248-1040					and Signature(s): <i>Richard Brown</i>										
FAX:															
ESC Client Number: 2379															
Sample Identification		Sample Collection				Sample Containers									
Identification	ESC Control #	Date	Time	Type	Matrix	Type	Volume	Preservative	#						
Effluent Diverter Box	1606020017	6-1-16	12:08	Grab	Water	Teflon	150 ml	none	1	x					
				Grab	Water	whirlpak	300 ml	none/ice	1		x				
				Grab	Water	Plastic	1 qt	none/ice	1			x		x	
				Grab	Water	Plastic	8 oz	H ₂ SO ₄ , pH <2	1				x		
Relinquished By: (Signature and Printed Name) <i>Richard Brown</i>		Date	Time	Received By: (Signature and Printed Name) <i>Tamara Brooks Tamara Brooks</i>		Date	Time	Custody Seals:							
Relinquished By: (Signature and Printed Name)		Date	Time	Received By: (Signature and Printed Name)		Date	Time	Used?	<input checked="" type="checkbox"/>	Intact?	<input type="checkbox"/>				
Relinquished By: (Signature and Printed Name)		Date	Time	Received for Lab By: (Signature and Printed Name)		Date	Time	Regular	<input checked="" type="checkbox"/>	Special	<input type="checkbox"/>				
								Were samples properly preserved:							
								Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>				
Comments:					FLOW DATA	Field Test	Time	Analyst	Result	Result	Units				
					Analyst:	pH:	12:08	RAB	6.7						
					Time:	Temp.:	1	1	24.0			°C	°F		
					Reading:	DO:									
					Units:	Debris:									
Cool all samples to 6 degrees C.										Chlorinated? Yes No			This Document is Page 1 of 1		


CAVE SPRINGS WATER DEPARTMENT

P.O. Box 5

CAVE SPRINGS, ARKANSAS 72718

RETURN SERVICE REQUESTED

AR 727 1 T
02 JUL 2016 PM



ADEQ

Enforcement Section/Water Div.

5301 Northshore Drive

North Little Rock, AR 72118

7211895317

