

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
MONITORING REPORT FOR DECENTRALIZED WASTEWATER TREATMENT FACILITIES VIA DRIP IRRIGATION
MONTHLY MONITORING REPORT

PERMITTEE NAME
Joyce Street Cottages Propert Owners Assoc

FACILITY NAME (IF DIFFERENT)
Joyce Street Cottages Property Owners Association


PERMIT NO.
4957-WR-2

PERMITTEE ADDRESS
4181 Rolling Meadows Fayetteville, AR

FACILITY ADDRESS
3578 E Joyce Blvd Fayetteville AR 72703

AFIN NO.
72-01805

WASTEWATER EFFLUENT MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
FROM 10/1/2017	10/31/2017

TREATED WASTEWATER EFFLUENT SAMPLING						
PARAMETER	PERMIT REQUIREMENT	SAMPLE MEASUREMENT		UNITS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
PHOSPHOROUS, TOTAL (AS P) EFFLUENT GROSS VALUE	*****	3.9		MG/L	ONCE/ MONTH	GRAB
CBOD, 5-DAY (20 DEG. C) EFFLUENT GROSS VALUE	15	< 2		MG/L	ONCE/ MONTH	GRAB
PH EFFLUENT GROSS VALUE	6 to 9	7.2		S.U.	ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED EFFLUENT GROSS VALUE	15	4.2		MG/L	ONCE/ MONTH	GRAB
SOLIDS, % TOTAL	*****	0.037		MG/L	ONCE/ MONTH	GRAB
COLIFORM, FECAL GENERAL EFFLUENT GROSS VALUE	3,000	< 4		N/100 ML	ONCE/ MONTH	GRAB
FLOW, THRU CONDUIT OR TREATMENT UNIT EFFLUENT GROSS VALUE	*****	MONTHLY TOTAL	DAILY MAX	GPD	ONCE/ MONTH	TOTAL FLOW
		116,196	5,613			
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM AWARE OF THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.			TELEPHONE		DATE
Kathryn Bartlett				479	5305926	11/14/2017
TYPED OR PRINTED				AREA CODE	NUMBER	MM/DD/YYYY
COMMENTS AND EXPLANATION OF VIOLATIONS (Reference all attachments here)						

Oct 2017 JOYCE STREET COTTAGES LOADING RATES 5,613 Max Day

Zone Identification	GPD/sq 2
Zone 1	803
Zone 2	999
Zone 3	1,057
Zone 4	1,072
Zone 5	1,224
Zone 6	433

Environmental Services Company, Inc.

Corporate Office
 13715 West Markham
 Little Rock, AR 72211
 Tel. (501)221-2565 Fax (501)221-1341

Northwest Arkansas Branch
 1107 Century Avenue
 Springdale, AR 72762
 Tel. (479)750-1170 Fax (479)750-1172

Control Number: 1710020184
 Customer Name : JOYCE STREET UTILITY LLC
 Customer/Permit No. : 1827 / 4957-WR-2 001
 Report Date : 10/24/17

Sample Date : 10/18/17
 Sample Time : 0953
 Sample Type : GRAB
 Sample From : EFFLUENT

Collected By: AEU
 Delivery By : AEU
 Work Order :
 Purchase Order :


<u>Laboratory Analysis</u>						<u>Quality Assurance</u>		
<u>Analysis</u>			<u>Result</u>	<u>Notes</u>	<u>Quantity</u>	<u>Method</u>	<u>Precision</u>	<u>Accuracy</u>
<u>Date</u>	<u>Time</u>	<u>By</u>					<u>Parameter</u>	<u>% RPD</u>
10/18	1002	AEU	pH	7.2 S.U.		SM 2000 4500-H+ B	0.00	N/A *
10/23	1500	TSB	Phosphorous, Total (as P)	3.9 mg/L		EPA 365.3	1.55	99.7 *
10/23	0945	AEU	Solids, Total Suspended	4.2 mg/L		SM 1997 2540 D	13.33	N/A *
10/18	1615	RHB	Coliform, Fecal	< 4 /100ml		SM 9222 D 1997	0.00	N/A *
10/18	1400	TSB	BOD, Carbonaceous	< 2.0 mg/L		SM 2001 5210 B	7.49	99.0 *
10/19	1615	JCB	Solids, % Total by mass	0.037 %		SM 1997 2540 G	0.00	N/A
10/18	1002	AEU	Sample Collection/Travel	1 each				

* QA data shown is from a different sample or standard on the same date.

All equipment used is checked and/or calibrated daily. All NPDES testing is conducted in accordance with 40 CFR Part 136. A minimum of 10% spiked and duplicate samples is run on each parameter where applicable for Quality Assurance purposes. Quality Assurance Plan on file with Arkansas Department of Environmental Quality. Analysis time indicates the time of the start of the analytical batch in which the specific sample was included.

Signature Richard Brown
 Environmental Services Co., Inc.

Environmental Services Company, Inc.
 Northwest Arkansas
 1107 Century Street
 Springdale, Arkansas 72762
 website: www.esclabs.com



Corporate Office, Little Rock, Arkansas
 501-221-2565

Carlsbad, New Mexico
 575-887-1ESC

Phone: 479-750-1170 Fax: 479-750-1172

CHAIN OF CUSTODY

Client Information				Project Information							Requested Parameters										
Company Name: Joyce St. Utility LLC				Permit/Project #:							pH(23)	Phos(25)	CBOD(70), TSS(28) % Solids(82)	F. Coliform (43)							
Address: 1849 Trillium Lane				Purchase Order #:																	
Fayetteville Ar 72704				Sampler Name(s): Amber Anderson																	
Telephone: (479)936-0333 (Cell)				and Signature(s): <i>[Signature]</i>																	
Telephone:																					
ESC Client Number: 1827																					
Sample Identification			Sample Collection			Sample Containers															
Identification	ESC Control #	Date	Time	Type	Matrix	Type	Volume	Preservative	#												
EFFLUENT	F10030184	10/18/17	09:53	GRAB	Water	teflon	150 ml	none	1	x											
EFFLUENT	I	I	I	GRAB	Water	Plastic	8 oz	H ₂ SO ₄ , pH<2	1		x										
EFFLUENT	I	I	I	GRAB	Water	Plastic	1 qt	none/ice	1			x									
EFFLUENT	I	I	I	GRAB	Water	Whirlpak	125 ml	Na ₂ S ₂ O ₃	1				x								
Relinquished By: (Signature and Printed Name)		Date	Time	Received By: (Signature and Printed Name)		Date	Time	Custody Seals:		Used?	Intact?										
<i>[Signature]</i>		10/18/17	13:25	<i>[Signature]</i>				Regular <input checked="" type="checkbox"/>		Special <input type="checkbox"/>											
Relinquished By: (Signature and Printed Name)		Date	Time	Received By: (Signature and Printed Name)		Date	Time	Were samples properly preserved:		Yes	No										
<i>[Signature]</i>				<i>[Signature]</i>		10/18/17	13:25	Yes <input checked="" type="checkbox"/>		No <input type="checkbox"/>											
Comments:				FLOW DATA	Field Test	Time	Analyst	Result	Result	Units											
				Analyst:	pH:	10002	AEU	7.2	7.2												
				Time:	Temp.:	L	L	21.3	21.4	°C											
				Reading:	DO:																
				Units:	Debris:																
Cool all samples to 6 degrees C.							Chlorinated? Yes No			This Document is Page 1 of 1											