

**ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
DECENTRALIZED WASTEWATER TREATMENT FACILITIES VIA DRIP IRRIGATION
MONTHLY MONITORING REPORT**

PERMITTEE NAME
Joyce Street Cottages Property Owners Association Inc
PERMITTEE ADDRESS
4200 Gabel Dr Fayetteville AR 72703

FACILITY NAME
Joyce Street Cottages

PERMIT NO.
4957-WR-3


FACILITY ADDRESS
3578 E Joyce Blvd Fayetteville AR 72703

AFIN NO.
72-01805

WASTEWATER EFFLUENT MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
7/1/2020	7/31/2020

TREATED WASTEWATER EFFLUENT SAMPLING

Parameter	Limit	Sample Measurement	Units	Monitoring	Reporting
Flow, Monthly total	REPORT	183,712	MG	Total Flow per calendar month	Prior to the 15th of the following Month
Flow, daily maximum *	REPORT	0.007199	GPD	Daily	
Carbonaceous Biochemical Oxygen Demand (CBOD5)	30	< 2.0	mg/l	Grab Sample once per month	
Total Suspended Solids (TSS)	45	8.3	mg/l		
Fecal Coliform Bacteria (FCB)	3,000	< 5.0	colonies/100ml		
pH	6.0 - 9.0	7.3	s.u.		
Total Phosphorus (TP)	REPORT	5.55	mg/l		
Total Kjeldahl Nitrogen (TKN)	REPORT		mg/l	Grab sample once per quarter	
Ammonia Nitrogen	REPORT		mg/l		
Nitrate Nitrogen (NO3-N) + Nitrite Nitrogen (NO2-N)	REPORT		mg/l		
Plant Available Nitrogen (PAN)	REPORT		mg/l		

NAME OF PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.		TELEPHONE
			(479) 530-5926
TYPED OR PRINTED		SIGNATURE OF COGNIZANT OFFICIAL	DATE
Kathy Bartlett			8/15/2020

COMMENTS AND EXPLANATION OF VIOLATIONS (Reference all attachments here)

* LOADING RATE BY ZONE			
Zone 1	1029	Zone 5	1569
Zone 2	1281	Zone 6	592
Zone 3	1353		
Zone 4	1375		

Environmental Services Company, Inc.

Corporate Office
 13715 West Markham
 Little Rock, AR 72211
 Tel. (501)221-2565 Fax (501)221-1341

Northwest Arkansas Branch
 1107 Century Avenue
 Springdale, AR 72762
 Tel. (479)750-1170 Fax (479)750-1172

Control Number: 2007020081
 Customer Name : JOYCE STREET UTILITY LLC
 Customer/Permit No. : 1827 / 4957-WR-2 001
 Report Date : 07/22/20

Sample Date : 07/15/20
 Sample Time : 0826
 Sample Type : GRAB
 Sample From : EFFLUENT

Collected By: HNS
 Delivery By : HNS
 Work Order :
 Purchase Order :

Laboratory Analysis

Analysis							Quality Assurance		
Date	Time	By	Parameter	Result	Notes	Quantity	Method	Precision	Accuracy
								% RPD	% Recovery
07/15	0830	HNS	pH	7.3	S.U.		SM 2011 4500-H+ B	1.42	N/A *
07/20	1410	NTR	Phosphorous, Total (as P)	5.55	mg/L		EPA 365.3	0.00	91.0 *
07/20	1630	NTR	Solids, Total Suspended	8.3	mg/L		SM 2011 2540 D	5.85	N/A
07/15	1620	JWS	Fecal Coliform (MPN/100mL)	< 5.0	/100ml		06/2012 Colilert18	0.00	N/A *
07/16	1340	NTR	BOD, Carbonaceous	< 2.0	mg/L		SM 2001 5210 B	0.00	91.9

* QA data shown is from a different sample or standard on the same date.

All equipment used is checked and/or calibrated daily. All NPDES testing is conducted in accordance with 40 CFR Part 136. A minimum of 10% spiked and duplicate samples is run on each parameter where applicable for Quality Assurance purposes. Quality Assurance Plan on file with Arkansas Department of Environmental Quality. Analysis time indicates the time of the start of the analytical batch in which the specific sample was included.

Signature _____

Environmental Services Co., Inc.

183712
 7199

Environmental Services Company, Inc.
 Northwest Arkansas
 1107 Century Street
 Springdale, Arkansas 72762
 website: www.esclabs.com



Corporate Office, Little Rock, Arkansas
 501-221-2565


Carlsbad, New Mexico
 575-887-1ESC

Phone: 479-750-1170 Fax: 479-750-1172

CHAIN OF CUSTODY

Client Information				Project Information						Requested Parameters									
Company Name:		Joyce St. Utility LLC		Permit/Project #:		Monthly				CBOD (70), TSS (28)	T-Phos (25)	F. Coliform (43.IF)	pH (23)						
Address:		1849 Trillium Lane Fayetteville Ar 72704		Purchase Order #:															
Telephone:		(479)936-0333 (Cell)		Sampler Name(s):		Hayden Smith													
Telephone:				and Signature(s):		<i>Hayden Smith</i>													
ESC Client Number:		1827																	
Sample Identification		Sample Collection				Sample Containers													
Identification	ESC Control #	Date	Time	Type	Matrix	Type	Volume	Preservative	#										
EFFLUENT	2007020081	7-15	8:26	GRAB	Water	Plastic	1/2 gal	None, Cool	1	X									
EFFLUENT	7-81	7-15	8:27	GRAB	Water	Plastic	8 oz	H ₂ SO ₄ , pH<2	1		X								
EFFLUENT	7-81	7-15	8:28	GRAB	Water	Sterile	125 mL	Na ₂ S ₂ O ₃	1			X							
EFFLUENT	7-81	7-15	8:30	GRAB	Water	Glass	250 mL	None	0				X						
Relinquished By: (Signature and Printed Name)		Date	Time	Received By: (Signature and Printed Name)		Date	Time	Custody Seals:		Used? <input checked="" type="checkbox"/> N Intact? <input type="checkbox"/>		Turnaround:		Regular <input checked="" type="checkbox"/> Special <input type="checkbox"/>		Were samples properly preserved:		Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
<i>Hayden Smith</i>		7-15	16:20	<i>Hayden Smith</i>															
Relinquished By: (Signature and Printed Name)		Date	Time	Received By: (Signature and Printed Name)		Date	Time	Were samples properly preserved:		Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>									
<i>Hayden Smith</i>				<i>Hayden Smith</i>															
Relinquished By: (Signature and Printed Name)		Date	Time	Received By: (Signature and Printed Name)		Date	Time	Were samples properly preserved:		Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>									
<i>Hayden Smith</i>				<i>Hayden Smith</i>															
Comments:				FLOW DATA		Field Test	Time	Analyst	Result	Result	Units								
				Analyst:		pH: 7.3	8:30	LNS	7.3	7.3									
				Time:		Temp.:													
				Reading:		DO:													
				Units:		Debris:													
Cool all samples to 6 degrees C.						Chlorinated? Yes No		This Document is Page ___ of ___											

Vertical barcode lines at the top left of the page.



NWA P&D 72701
WED 19 AUG 2020

 **NWA UTILITY SERVICES, INC**
PO Box 9299
Fayetteville, AR 72703

Arkansas Dept. of Energy and Environment
Water Division Permits Branch
5301 Northshore Drive
North Little Rock, AR
72118-5317