

Gage, Hannah

From: legals <legals@eldoradonews.com>
Sent: Tuesday, February 07, 2017 10:02 AM
To: Gage, Hannah
Subject: [BULK] Re: Draft PN for NPDES Permit AR0000752

Follow Up Flag: Follow up
Flag Status: Flagged

Hannah,

This Notice will publish tomorrow, February 8.

Thank you,

Adrienne

Courtney Christie
Legals and Classifieds Specialist

El Dorado News-Times
111 N. Madison
El Dorado, AR 71730
Phone: 870-862-6611 Ext. 118
Fax: 870-862-9482
legals@eldoradonews.com

On Feb 7, 2017, at 8:42 AM, Gage, Hannah wrote:

> Can someone please let me know a publication date for this notice?
> Thank you!
>
> From: Gage, Hannah
> Sent: Monday, February 06, 2017 8:01 AM
> To: legals@eldoradonews.com
> Cc: Reiber, Loretta; Deardoff, Amy
> Subject: Draft PN for NPDES Permit AR0000752
>
> Please see the notice below. Please send a confirmation email
> regarding the date of publication as well as a proof of publication
> the day after the notice has been published. If you have any
> questions, please do not hesitate to call. Thank you!
>
> Hannah Gage
> ADEQ
> 870-935-7221x16
> Arkansas Department of Environmental Quality
> NPDES- Office of Water Quality
> 5301 Northshore Drive

> North Little Rock, AR 72118
>
>
> To: Legal Ad Editor
> El Dorado News-Times
> El Dorado, AR 71731
> 870-862-6611
> legals@eldoradonews.com
>
> RE: Public Notice of NPDES Permit Number AR0000752
>
> Dear Legal Ad Editor:
>
> Please publish the following Public Notice in your newspaper on the
> next available publication date for one day only. Please DO NOT
> INVOICE THIS AGENCY. Send your invoice for the cost of publication
> and proof of publication to:
>
> Greg Withrow, General Manager
> El Dorado Chemical Company
> P.O. Box 231
> El Dorado, AR 71731-0231
> 870-863-1400
>
>
> Additionally, when you receive payment for the publication, please
> send a copy of proof of payment and publication to:
>
> Arkansas Department of Environmental Quality NPDES-Office of Water
> Quality
> 5301 Northshore Drive
> North Little Rock, AR 72118
>
> Thank you for your attention to this request. Please return a
> confirmation email upon receipt and notify me if there is a change in
> the publication date at 870-935-7221x16.
>
>
> Sincerely,
>
>
> Hannah Gage
> Administrative Specialist III, Office of Water Quality
>
>
>
> PUBLIC NOTICE OF DRAFT DISCHARGE PERMIT AND 208 Plan
> PERMIT NUMBER AR0000752, AFIN 70-00040
>
> In accordance with Ark. Code Ann. § 8-4-203(e), the Arkansas
> Department of Environmental Quality (ADEQ), Office of Water Quality,

> gives the following notice:

>

> El Dorado Chemical Company operates a facility located as follows:
> 4500 North West Avenue, El Dorado, AR 71730 in Union County. The
> facility is currently permitted to discharge treated process
> wastewater, treated groundwater, contaminated stormwater, and
> treated sanitary wastewater into an unnamed tributary of Flat Creek
> (a/k/a ELCC Tributary), thence to Flat Creek, thence to Haynes
> Creek, thence to Smackover Creek, thence to the Ouachita River in
> Segment 2D of the Ouachita River Basin and Outfall 010: via the
> joint pipeline to the Ouachita River approximately 1.5 miles
> downstream of the H.K. Thatcher Lock and Dam in Segment 2D of the
> Ouachita River Basin. El Dorado Chemical Company submitted an
> application on December 21, 2006 for renewal of NPDES Permit No.
> AR0000752. The application has been reviewed by the ADEQ's Office
> of Water Quality and has received tentative approval subject to the
> terms of this notice.

>

> The 208 Plan, developed by the ADEQ under provisions of Section 208
> of the federal Clean Water Act, is a comprehensive program to work
> toward achieving federal water goals in Arkansas. The initial 208
> Plan, adopted in 1979, provides for annual updates, but can be
> revised more often if necessary. The following updates to the 208
> Plan are proposed. These changes are also proposed to be
> incorporated into the permit.

>

> 1. DO instantaneous minimum limits of 5.0 mg/L during November
> – April and 4.0 mg/L during May – October were added at Outfall 001
> based on the 12/9/2015 modeling analysis.

>

> 2. DO instantaneous minimum limits of 2.0 mg/L during November
> – April and 4.0 mg/L during May – October were added at Outfall 003
> based on the 12/9/2015 modeling analysis.

>

> 3. NH₃-N monthly average concentration limits of 2.43 mg/L
> during April-October and 5.5 mg/L during November-March were added
> at Outfalls 001 and 003, based on TMDL dated October 3, 2002.

>

> 4. NH₃-N monthly average mass limits of 37.9 lb/day during
> April-October and 85.78 lb/day during November-March for the sum of
> Outfalls 001 and 003 were added based on TMDL dated October 3, 2002.

>

> 5. NH₃-N monthly average concentration limits of 0.0 mg/L
> during April-October and 0.32 mg/L during November-March were added
> at Outfalls 002, 006, 007, based on TMDL dated October 3, 2002.

>

> 6. NH₃-N monthly average mass limits of 0.0 lb/day during
> April-October and 5.16 lb/day during November-March for the sum of
> Outfalls 002, 006, 007 were added based on TMDL dated October 3, 2002.

>

> 7. Chlorides monthly average concentration limit of 19 mg/L,
> Sulfates monthly average concentration limit of 41 mg/L, and TDS

> monthly average concentration limit of 138 mg/L at Outfalls 001,
> 003, 002, 006, and 007 were added based on TMDL dated October 3, 2002.
>
> 8. Chlorides monthly average mass limit of 265 lb/day,
> Sulfates monthly average mass limit of 503 lb/day, and TDS monthly
> average mass limit of 1338 lb/day, for the sum of Outfalls 001 and
> 003, were added based on TMDL dated October 3, 2002.
>
> 9. Chlorides monthly average mass limit of 73 lb/day, Sulfates
> monthly average mass limit of 33 lb/day, and TDS monthly average
> mass limit of 635 lb/day, for the sum of Outfalls 002, 006, 007,
> were added based on TMDL dated October 3, 2002.
>
> Citizens wishing to examine or obtain copies of the permit
> application, the draft permitting decision, the Fact Sheet or the
> 208 Plan may do so at the ADEQ headquarters located at 5301
> Northshore Drive, North Little Rock, AR 72118-5317. To request a
> hard copy of one or more of the documents to be mailed, please call
> (501) 682-0623. For those with Internet access, a copy of the
> proposed draft permit as well as the publication date may be found
> on the ADEQ's website at:
> https://www.adeq.state.ar.us/water/permits/drafts_pn.aspx
>
> Comments on the draft renewal will be accepted in accordance with
> Arkansas Pollution Control and Ecology Commission Reg. 8.208.
> ADEQ's contact person for submitting written comments on the draft
> permit or 208 Plan, or requesting a public hearing on the draft
> permit or the proposed changes to the 208 Plan, is Loretta Reiber,
> P.E., at the above address and telephone number or by email at Water-Draft-Permit-Comment@adeq.state.ar.us
> .
>
> The comment period for the draft permit, the 208 Plan, and
> requesting a public hearing shall begin on the date of publication
> of the public notice and end at 4:30 P.M. (Central Time) on the 30th
> day after the publication date. If the last day of the comment
> period is a Saturday, Sunday, or legal holiday, the public comment
> period shall expire on the next day that is not a Saturday, Sunday,
> or legal holiday. For information regarding the actual publication
> date along with the actual date and time the comment period will
> end, please contact Loretta Reiber, P.E. at the above address and
> telephone number or by email at Water-Draft-Permit-Comment@adeq.state.ar.us
> . Public notice, comments, and hearings will be conducted in
> accordance with Regulation 6.104(A)(5) [40 CFR Parts 124.10 through
> 124.12 by reference] and Regulation 8.207 through 8.210
> (Administrative Procedures). All persons, including the permittee,
> who wish to comment on ADEQ's draft permitting decision must submit
> written comments to ADEQ, along with their name and mailing
> address. A Public Hearing will be held when ADEQ finds a
> significant degree of public interest. After the public comment
> period, ADEQ will issue a final permitting decision. ADEQ will
> notify the applicant and each person who has submitted written
> comments or request notice of the final permitting decision. Any

- > interested person who has submitted comments may appeal a final
- > decision by ADEQ in accordance with the APC&EC Regulation No. 8.603.
- >