



Certified Mail -Return receipt Requested

May 28, 2013

Ms. Kimberly Fuller  
Engineering Supervisor, Water Division  
NPDES Enforcement Section  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

Georgia-Pacific Corporation  
Consumer Products

100 Mill Supply Road  
P.O. Box 3333  
Crossett, AR 71635  
(870) 567-8000  
www.gp.com

Reference: Georgia-Pacific Crossett Paper Operations  
NPDES Permit # **AR0001210**

Dear Ms. Fuller:

This is sent in follow-up to our telephone conversation of May 1, 2013, when I called regarding concerns about sewage lift stations owned and operated by the City of Crossett and West Crossett.

On April 25, Georgia-Pacific was notified by the Mayor of Crossett that three of the five sewage lift stations that ultimately convey municipal waste from West Crossett were not operating and sewage was flowing on to the ground and into surrounding ditches and creeks.

I visited the two lift stations located on South Penn Road (owned by West Crossett Sewer Improvement District) and South Wall Road (owned by City of Crossett) and saw that they both were designed to overflow at ground level during upset conditions and then into creeks in the immediate area. I did see evidence of the overflow condition the Mayor had mentioned at the South Penn Road location along with an accompanying waste odor. During this time, I also met representatives from the West Crossett Sewer Improvement District and F&J Plumbing, who confirmed that the system does overflow periodically.

This letter is only to express our concern about the design and function of this sewage system when it overflows and the impact that it has on the local community and on our property. I also would like to bring to your attention that each time a regulatory inspection of these units is conducted or a complaint is lodged regarding these units, Georgia-Pacific's NPDES number is referenced on the inspection report. While Georgia-Pacific ultimately manages final wastewater treatment for the city, Georgia-Pacific believes that such inspections of the West Crossett Sewer Improvement District or the City of Crossett system should reference the City of Crossett's City Use Ordinance instead of our NPDES permit number.

Thank you for your attention to this matter and please contact me if you have any questions.

Sincerely,

James W. Cutbirth  
Environmental Manager  
Crossett Paper Operations  
Georgia Pacific LLC

cc: John Lamb - District ADEQ

**CERTIFIED MAIL™**



**Georgia-Pacific**

Consumer Products  
100 Mill Supply Road  
P.O. Box 3333  
Crossett, AR 71635



7011 1150 0000 8947 7058



02 1P  
0003195127  
MAILED FROM ZIP CODE 71635  
**\$ 006.11<sup>0</sup>**  
MAY 30 2013

Ms. Kimberly Fuller  
Engineering Supervisor, Water Division  
NPDES Enforcement Section  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

72118531799

