

# ADEQ

ARKANSAS  
Department of Environmental Quality

MAR 06 2020

D. Anthony Robinson  
Environmental Manager  
Georgia-Pacific Crossett LLC  
Crossett Paper Operations  
P.O. Box 3333  
Crossett, AR 71635

RE: NPDES Permit No. AR0001210, AFIN 02-00013  
Decommissioning Process

Dear Mr. Robinson:

The Office of Water Quality (OWQ) has reviewed your correspondence dated January 23, 2020, stating that some aerators in the aerated stabilization basin will be taken out of service. Based on your correspondence, it is the OWQ's understanding that fewer aerators are needed to meet permit limits due to the shut down of several processes and the ongoing decommissioning process.

In order for the OWQ to fully review your request, the following information will need to be submitted:

- The number of aerators currently in the ASB and the number of aerators to be taken out of service;
- Current BOD<sub>5</sub> loadings into the ASB; and
- Calculations regarding the amount of oxygen needed to treat the influent to the Aerated Stabilization Basin (ASB). The calculations must be signed and stamped by a Professional Engineer licensed in the State of Arkansas.

If you have any questions, please contact Loretta Carstens, P.E. of the NPDES Permit Section at [loretta.carstens@adeq.state.ar.us](mailto:loretta.carstens@adeq.state.ar.us) or at (501) 682-0612.

Sincerely,



Bryan Leamons, P.E.  
Senior Operations Manager  
Office of Water Quality

cc: Richard Healey, Enforcement Branch Manager  
Jason Bolenbaugh, Compliance Branch Manager