




ARKANSAS
Department of Environmental Quality

INTEROFFICE MEMORANDUM

TO: Kim Fuller, P.E., Engineer Supervisor
FROM:  Mark Fredricks P.E., Engineer – NPDES Permits
DATE: April 22, 2010
RE: Site Visit to Melbourne WWTP
NPDES Permit No. AR0020036

On April 21, 2010, I conducted a site visit to the above referenced facility. I met with Coy Dale, the facility operator.

The following items were noted:

1. The flow measurement is located at a different location than the sampling point/outfall (still after final treatment).
2. The city is using a polymer for drying sludge. Per the operator, this dries the sludge five times as fast.
3. I informed the operator that land application for sludge will not be covered under the NPDES permit and the facility must apply for coverage under a State Permit. The operator asked that I call his engineer about it (?).