

Enforcement Review for City of Mountain View WWTP (Renewal)

by Kristen Graham

Is there an active enforcement action for this facility?

Yes - 18-041 ponds/drying beds need maintenance, improperly operated/maintained. Unpermitted discharge not reported, failure to notify DEQ. || 18-091-011 effluent violations, sludge overflow, no emergency contact info posted, no alarms on lift station, no hook-up for generators, SSO reported late

Is there a proposed enforcement action for this facility?

Yes - possible enforcement action to come due to NODI C submissions (23 consecutive months no discharge) & the missing progress reports -- meeting with facility planned

Has a CAP or other compliance obligation been requested, submitted, and/or approved?

Yes - CAP was never completed, reports stop 2019, no indication they came into compliance.

Are there any comments/concerns that need to be taken into account when drafting the permit?

Yes - A lot of NODI C (most recently, 23 consecutive months) - I gave Richard 10yrs worth of DMR data to review, no SSOs reported since 2019