

MOUNTAIN VIEW WASTEWATER PLANT
LR05-5857

INDEX

Tab A	Narrative
Tab B	Design Basis
Tab C	Flow Data
Tab D	Influent Characteristics
Tab E	Line Size Calculations
Tab F	Influent Pump Station
Tab G	RAS Pump Station
Tab H	Extended Aeration Oxidation Ditch
Tab I	Final Clarifier

Narrative

Narrative

The current Mountain View WWTP is permitted to discharge treated wastewater to Hugh's Creek through NPDES permit #AR0020117. The permitted flow is approximately 0.73 MGD

A new parameter was added to the permit in approximately the year 2000. The newly added parameter was nitrate and nitrite nitrogen (10 mg/d, 7-day average). The current trickling filter plant has been unable to consistently meet this limit.

The proposed project has been designed to consistently comply with the NPDES permit. The project will basically construct a new plant and abandon all existing treatment phases except the headworks & final clarifier. The final clarifier will receive new equipment.

The existing treatment scheme is as follows: headworks → primary clarifier → trickling filter → secondary clarifier → bio-tower → final clarifier → chlorine disinfection. } existing

The proposed treatment scheme is as follows: headworks → extended aeration oxidation ditch → final clarifier → ultra violet disinfection. }

A change in flow capacity is ~~not~~ being requested at this time, though the oxidation ditch is sized for an average flow up to ~~0.85~~ ^{0.73} MGD. *

- The calculated maximum possible flow through plant is \pm 4MGD.
- Hydraulically, the piping systems, pumping systems, oxidation ditch and ultraviolet disinfection basin have been designed for a hydraulic capacity of at least 4MGD.

* See letter dated - July 27/2006 from Bryan Hicks


Design Basis

Design Basis

1. Design new excavation ditch to be capable of treating at least the average annual flows.
 - Between 2002 and June 2005, highest annual average flow = 0.64 MGD (2003)
 - Add New Flatwoods flow of 0.0399 mgd = 0.68 MGD
 - The Existing plant is permitted for 0.73 MGD.
Use the permitted flow of 0.73 mgd as the design flow, this will allow some future growth.

JUL 19 2005




U.S. Census Bureau
 American FactFinder

FACT SHEET

Mountain View city, Arkansas

Census 2000 Demographic Profile Highlights:

General Characteristics - show more >>

	Number	Percent	U.S.		
Total population	2,876	100.0	100%	map	brief
Male	1,288	44.8	49.1%	map	brief
Female	1,588	55.2	50.9%	map	brief
Median age (years)	46.8	(X)	35.3	map	brief
Under 5 years	157	5.5	6.8%	map	
18 years and over	2,295	79.8	74.3%		
65 years and over	738	25.7	12.4%	map	brief
One race	2,826	98.3	97.6%		
White	2,789	97.0	75.1%	map	brief
Black or African American	0	0.0	12.3%	map	brief
American Indian and Alaska Native	27	0.9	0.9%	map	brief
Asian	0	0.0	3.6%	map	brief
Native Hawaiian and Other Pacific Islander	1	0.0	0.1%	map	brief
Some other race	9	0.3	5.5%	map	
Two or more races	50	1.7	2.4%	map	brief
Hispanic or Latino (of any race)	49	1.7	12.5%	map	brief
Household population	2,735	95.1	97.2%	map	brief
Group quarters population	141	4.9	2.8%	map	
Average household size	2.13	(X)	2.59	map	brief
Average family size	2.72	(X)	3.14	map	
Total housing units	1,460	100.0	100.0%	map	
Occupied housing units	1,287	88.6	91.0%		brief
Owner-occupied housing units	771	59.9	66.2%	map	
Renter-occupied housing units	516	40.1	33.8%	map	brief
Vacant housing units	163	11.2	9.0%	map	

Social Characteristics - show more >>

	Number	Percent	U.S.		
Population 25 years and over	2,051	100.0			
High school graduate or higher	1,382	67.4	80.4%	map	brief
Bachelor's degree or higher	217	10.6	24.4%	map	
Civilian veterans (civilian population 18 years and over)	390	16.5	12.7%	map	brief
Disability status (population 21 to 64 years)	413	28.6	19.2%	map	brief
Foreign born	47	1.6	11.1%	map	brief
Male, Now married (population 15 years and over)	736	64.4	56.7%		brief
Female, Now married (population 15 years and over)	736	56.8	52.1%		brief
Speak a language other than English at home (population 5 years and over)	107	3.8	17.9%	map	brief

Economic Characteristics - show more >>

	Number	Percent	U.S.		
In labor force (population 16 years and over)	1,160	48.0	63.9%		brief
Mean travel time to work in minutes (population 16 years and over)	18.4	(X)	25.5	map	brief
Median household income (dollars)	19,302	(X)	41,994	map	
Median family income (dollars)	27,589	(X)	50,046	map	
Per capita income (dollars)	17,375	(X)	21,587	map	
Families below poverty level	85	10.2	9.2%	map	brief
Individuals below poverty level	482	17.0	12.4%	map	

Housing Characteristics - show more >>

	Number	Percent	U.S.		
Single-family owner-occupied homes	516	100.0			brief
Median value (dollars)	70,500	(X)	119,600	map	brief
Median of selected monthly owner costs	(X)	(X)			brief

Determine approx Volume of water that can come to plant through combination of 8" & 10" siphon & Dearien P.S.

10" siphon



10" > $14.5 = \frac{10.44 (1668) (Q)^{1.85}}{140^{1.85} 10.58^{4.75}}$
 $Q^{1.85} = 750,660.1$
 $\therefore Q = \underline{1500 \text{ gpm}}$

8" > $14.5 = \frac{10.44 (1668) (Q)^{1.85}}{140^{1.85} 8.55^{4.75}}$
 $Q^{1.85} = 266,250$
 $\therefore Q = \underline{857 \text{ gpm}}$

Dearien P.S. capacity design = 381 gpm
w/ both pipes running

Approx total flow to plant = 2738 gpm
= 3.943 MGD

Flow Data

	2002	2003	2004	2005	AVG
Jan.	0.68	0.70 ✓	0.80	0.94	0.78
Feb.	0.97	0.88 ✓	0.79	0.61	0.81
Mar.	1.27	0.75 ✓	0.58	0.71	0.83
Apr.	0.89	0.44 ✓	0.66	0.67	0.66
May	0.69	0.81 ✓	0.68	0.29	0.62
June	0.76	0.67 ✓	0.32	0.25	0.50
July	0.41	0.44 ✓	0.26	0.26	0.34
Aug.	0.43	0.42 ✓	0.27	0.23	0.34
Sept.	0.33	0.58 ✓	0.24		0.38
Oct.	0.32	0.38 ✓	0.55		0.42
Nov.	0.29	0.71 ✓	1.07		0.69
Dec.	0.51	0.88 ✓	0.86		0.75
AVG	0.63	0.64	0.59	0.49	0.59

$$\frac{7.64}{12} = 0.636$$

Average = 0.59 mg-D

Min flow: 0
 Max flow: 0

Min flow: 0
 Max flow: 0

January

February

March

Date Flow

Date Flow

Date Flow

1 0.71
 2 0.87
 3 0.75
 4 2.10
 5 2.60
 6 1.90
 7 1.80
 8 1.80
 9 1.20
 10 0.81
 11 0.89
 12 0.79
 13 1.20
 14 1.30
 15 1.00
 16 0.85
 17 0.76
 18 0.73
 19 0.70
 20 0.61
 21 0.66
 22 0.69
 23 0.48
 24 0.46
 25 0.46
 26 0.60
 27 0.44
 28 0.41
 29 0.53
 30 0.56
 31 0.50

1 0.48
 2 0.49
 3 0.66
 4 0.59
 5 0.67
 6 0.51
 7 0.56
 8 0.78
 9 0.69
 10 0.63
 11 0.60
 12 0.57
 13 0.75
 14 0.92
 15 0.77
 16 0.68
 17 0.60
 18 0.55
 19 0.60
 20 0.42
 21 0.56
 22 0.59
 23 0.57
 24 0.68
 25 0.62
 26 0.59
 27 0.47
 28 0.54

0.59
 0.47
 0.46
 0.44
 0.46
 0.41
 0.31
 0.45
 0.37
 0.66
 0.53
 0.47
 0.47
 0.38
 0.35
 0.38
 0.38
 0.39
 0.38
 0.34
 0.29
 0.76
 1.80
 1.00
 0.94
 1.00
 1.80
 2.00
 1.70
 1.30
 1.00

3.71" 0.94

2.10" 0.61

7.8" 0.71

Min flow: 0.41
 Max flow: 2.60

Min flow: 0.42
 Max flow: 0.92

Min flow: 0.29
 Max flow: 2.00

Annual Average = 0.49

Number flows over 2 MGD = 4
 Number flows over 1 MGD = 33

Number flows under .25 MGD = 55

April

May

June

Date	Flow	Date	Flow	Date	Flow
1	0.86	1	0.55	1	0.22
2	0.86	2	0.36	2	0.27
3	0.67	3	0.38	3	0.27
4	0.51	4	0.35	4	0.26
5	0.55	5	0.31	5	0.31
6	0.65	6	0.30	6	0.22
7	1.00	7	0.31	7	0.26
8	1.00	8	0.31	8	0.26
9	0.84	9	0.30	9	0.26
10	0.69	10	0.27	10	0.28
11	0.60	11	0.27	11	0.30
12	1.80	12	0.28	12	0.30
13	1.10	13	0.28	13	0.18
14	0.83	14	0.31	14	0.26
15	0.89	15	0.27	15	0.22
16	0.73	16	0.24	16	0.24
17	0.72	17	0.25	17	0.26
18	0.81	18	0.23	18	0.28
19	0.50	19	0.24	19	0.25
20	0.47	20	0.28	20	0.20
21	0.46	21	0.24	21	0.33
22	0.45	22	0.25	22	0.25
23	0.50	23	0.24	23	0.22
24	0.34	24	0.30	24	0.21
25	0.31	25	0.26	25	0.26
26	0.35	26	0.23	26	0.29
27	0.33	27	0.26	27	0.17
28	0.33	28	0.28	28	0.23
29	0.61	29	0.27	29	0.21
30	0.43	30	0.26	30	0.21
		31	0.23		
3.33"	0.67	0.55"	0.29	1.55"	0.25

Min flow: 0.31
Max flow: 1.80

Min flow: 0.23
Max flow: 0.55

Min flow: 0.17
Max flow: 0.33

05

mat

min

mat

min

July

August

Date Flow Date Flow

1	0.27	1	0.22
2	0.29	2	0.23
3	<u>0.30</u>	3	0.21
4	0.28	4	0.21
5	0.25	5	0.24
6	0.27	6	0.23
7	0.24	7	<u>0.29</u>
8	0.25	8	0.21
9	0.26	9	0.23
10	0.28	10	0.22
11	0.22	11	0.23
12	0.24	12	0.23
13	0.25	13	0.24
14	0.26	14	<u>0.27</u>
15	0.24	15	0.24
16	<u>0.31</u>	16	0.24
17	0.27	17	0.26
18	0.22	18	0.25
19	0.26	19	0.22
20	0.24	20	<u>0.27</u>
21	0.24	21	0.25
22	0.27	22	<u>0.18</u>
23	0.27	23	0.24
24	0.28	24	0.24
25	<u>0.19</u>	25	0.21
26	0.23	26	0.23
27	0.23	27	0.24
28	0.27	28	0.25
29	0.24	29	0.21
30	0.28	30	0.23
31	0.24	31	0.22

1.28" 0.26

1.20" 0.23

Min flow: 0.19
Max flow: 0.31

Min flow: 0.18
Max flow: 0.29

0.29


X

X

max

min

2005 Flow Data



January		February		March		April		Peak
Date	Flow	Date	Flow	Date	Flow	Date	Flow	
1	1.20	1	0.56		0.43	1	0.50	1.20
2	0.84	2	0.46		0.51	2	0.38	1.20
3	0.91	3	0.72		0.48	3	0.35	
4	0.82	4	0.60		0.80	4	0.42	
5	0.92	5	0.67		1.30	5	0.25	
6	1.00	6	1.90		1.40	6	0.32	
7	0.79	7	1.80		0.98	7	0.43	
8	0.72	8	1.30		0.80	8	0.32	
9	0.71	9	0.99		0.76	9	0.35	
10	0.71	10	1.40		0.67	10	0.36	
11	0.60	11	0.81		0.59	11	0.41	
12	0.50	12	0.90		0.58	12	0.37	
13	0.56	13	1.10		0.60	13	0.38	
14	0.54	14	0.86		0.71	14	0.31	
15	0.55	15	0.84		0.38	15	0.31	
16	0.49	16	0.76		0.60	16	0.34	
17	0.94	17	0.74		0.58	17	0.39	
18	1.20	18	0.74		0.51	18	0.49	
19	1.50	19	0.69		0.45	19	0.23	
20	0.87	20	0.71		0.47	20	0.35	
21	0.82	21	0.75		0.54	21	0.34	
22	0.80	22	0.58		0.27	22	0.62	
23	0.75	23	0.39		0.35	23	1.80	
24	0.71	24	0.51		0.38	24	2.10	
25	0.81	25	0.49		0.38	25	2.20	
26	0.79	26	0.48		0.41	26	1.70	
27	0.77	27	0.43		0.41	27	1.30	
28	0.77	28	0.42		0.39	28	1.00	
29	0.68	29	0.48	1	0.46	29	0.85	
30	0.68			2	0.47	30	0.76	
31	0.71			3	0.43			
2.3"	0.80	2.3"	0.79	2.6"	0.58	7.7"	0.66	

Min flow: 0.49 Min flow: 0.39 Min flow: 0.27 Min flow: 0.23
 Max flow: 1.50 Max flow: 1.90 Max flow: 1.40 Max flow: 2.20

Annual Average = 0.59

Number flows over 2 MGD = 12
 Number flows over 1 MGD = 92

Number flows under .25 MGD = 54

May		<i>Peak</i>	June		July		August	
Date	Flow		Date	Flow	Date	Flow	Date	Flow
1	0.81		1	0.39	1	0.25	1	0.22
2	0.94		2	0.33	2	0.29	2	0.19
3	0.79		3	0.36	3	0.34	3	0.21
4	0.74		4	0.31	4	0.32	4	0.22
5	0.65		5	0.32	5	0.34	5	0.23
6	0.55		6	0.34	6	0.23	6	0.25
7	0.49		7	0.31	7	0.26	7	0.30
8	0.48		8	0.32	8	0.34	8	0.29
9	0.41		9	0.40	9	0.29	9	0.19
10	0.31		10	0.40	10	0.38	10	0.34
11	0.34		11	0.37	11	0.26	11	0.28
12	0.34		12	0.42	12	0.29	12	0.55
13	0.54		13	0.39	13	0.29	13	0.31
14	1.80		14	0.24	14	0.26	14	0.27
15	2.10		15	0.28	15	0.25	15	0.36
16	1.50		16	0.33	16	0.26	16	0.22
17	0.84		17	0.30	17	0.33	17	0.23
18	0.98		18	0.30	18	0.33	18	0.24
19	0.63		19	0.28	19	0.21	19	0.25
20	0.74		20	0.31	20	0.22	20	0.29
21	0.65		21	0.21	21	0.21	21	0.29
22	0.56		22	0.32	22	0.21	22	0.29
23	0.65		23	0.36	23	0.20	23	0.25
24	0.34 0.36	<i>.49</i>	24	0.28	24	0.21	24	0.26
25	0.45		25	0.30	25	0.27	25	0.23
26	0.41		26	0.29	26	0.24	26	0.24
27	0.42		27	0.29	27	0.22	27	0.20
28	0.43		28	0.29	28	0.19	28	0.27
29	0.41		29	0.25	29	0.21	29	0.35
30	0.41		30	0.27	30	0.23	30	0.21
31	0.44				31	0.24	31	0.24
4.3"	0.68		1.9"	0.32	2.4"	0.28	3.5"	0.27
Min flow:	0.31		Min flow:	0.21	Min flow:	0.19	Min flow:	0.19
Max flow:	2.10		Max flow:	0.42	Max flow:	0.38	Max flow:	0.55

September		October		November		December	
Date	Flow	Date	Flow	Date	Flow	Date	Flow
1	0.22	1	0.25	1	1.50	1	2.00
2	0.22	2	0.28	2	2.10	2	1.40
3	0.24	3	0.23	3	1.70	3	1.30
4	0.32	4	0.20	4	1.20	4	1.10
5	0.26	5	0.22	5	1.20	5	0.89
6	0.28	6	0.24	6	1.10	6	1.40
7	0.18	7	0.19	7	0.87	7	1.00
8	0.22	8	0.23	8	0.61	8	1.30
9	0.22	9	0.78	9	0.66	9	1.20
10	0.23	10	0.42	10	0.57	10	1.10
11	0.26	11	0.78	11	0.84	11	0.97
12	0.30	12	1.30	12	1.60	12	0.75
13	0.18	13	0.72	13	1.20	13	0.70
14	0.25	14	0.45	14	0.82	14	0.84
15	0.25	15	1.10	15	0.69	15	0.50
16	0.24	16	0.72	16	0.69	16	0.58
17	0.25	17	0.51	17	0.61	17	0.51
18	0.25	18	0.30	18	0.57	18	0.60
19	0.26	19	0.49	19	0.76	19	0.49
20	0.20	20	0.39	20	0.78	20	0.34
21	0.22	21	0.39	21	0.66	21	0.43
22	0.22	22	0.36	22	0.53	22	0.47
23	0.22	23	0.42	23	1.00	23	0.88
24	0.22	24	0.38	24	1.50	24	0.77
25	0.29	25	0.29	25	2.00	25	0.67
26	0.25	26	0.33	26	1.40	26	0.66
27	0.20	27	0.33	27	1.40	27	0.66
28	0.21	28	0.35	28	1.70	28	0.77
29	0.20	29	1.10	29	0.92	29	0.78
30	0.21	30	1.30	30	0.97	30	0.80
		31	1.60			31	0.92
0"	0.24	9.4"	0.55	6.5"	1.07	2.3"	0.86
Min flow:	0.18	Min flow:	0.19	Min flow:	0.53	Min flow:	0.34
Max flow:	0.32	Max flow:	1.60	Max flow:	2.10	Max flow:	2.00

Mountain View Wastewater Treatment Plant

2003 Flow Data
 +/- 15% of monthly avg.

January		February		March		April	
Date	Flow	Date	Flow	Date	Flow	Date	Flow
1	2.20	1	0.41	1	1.10	1	0.54
2	1.70	2	0.40	2	0.82	2	0.51
3	1.80	3	0.34	3	0.84	3	0.44
4	1.40	4	0.39	4	0.85	4	0.44
5	1.20	5	0.33	5	0.77	5	0.34
6	0.80	6	0.33	6	0.67	6	0.44
7	0.94	7	0.41	7	0.78	7	0.58
8	0.84	8	0.47	8	0.65	8	0.63
9	0.78	9	0.46	9	0.64	9	0.55
10	0.63	10	0.39	10	0.47	10	0.47
11	0.61	11	0.53	11	0.54	11	0.42
12	0.42	12	0.54	12	0.52	12	0.42
13	0.33	13	0.54	13	0.50	13	0.38
14	0.50	14	0.84	14	0.59	14	0.30
15	0.48	15	1.26	15	0.52	15	0.41
16	0.49	16	1.91	16	0.52	16	0.41
17	0.48	17	1.71	17	0.43	17	0.40
18	0.47	18	1.10	18	0.46	18	0.40
19	0.44	19	0.92	19	0.80	19	0.42
20	0.44	20	1.10	20	1.10	20	0.47
21	0.46	21	1.00	21	1.50	21	0.33
22	0.44	22	1.50	22	1.20	22	0.36
23	0.40	23	1.90	23	0.85	23	0.31
24	0.41	24	1.50	24	0.63	24	0.51
25	0.40	25	1.20	25	0.73	25	0.59
26	0.42	26	1.10	26	1.00	26	0.50
27	0.31	27	1.00	27	0.92	27	0.41
28	0.39	28	1.10	28	0.82	28	0.36
29	0.41			29	0.79	29	0.37
30	0.45			30	0.83	30	0.35
31	0.44			31	0.45		
1.6"	0.70	4.3"	0.88	2.7"	0.75	2.0"	0.44
Min flow:	0.31	Min flow:	0.33	Min flow:	0.43	Min flow:	0.30
Max flow:	2.20	Max flow:	1.91	Max flow:	1.50	Max flow:	0.63

Annual Average = 0.64

Number flows over 2 MGD = 5
 Number flows over 1 MGD = 94

Number flows under .25 MGD = 0

Mountain View Wastewater Treatment Plant

2003 Flow Data
 +/- 15% of monthly avg.

May		June		July		August	
Date	Flow	Date	Flow	Date	Flow	Date	Flow
1	0.35	1	0.55	1	0.44	1	0.40
2	0.43	2	0.55	2	0.36	2	0.37
3	0.39	3	1.80	3	0.49	3	0.48
4	0.41	4	1.10	4	0.46	4	0.77
5	0.33	5	0.91	5	0.36	5	0.67
6	0.42	6	0.81	6	0.39	6	0.66
7	0.39	7	0.75	7	0.35	7	0.50
8	0.39	8	0.73	8	0.34	8	0.45
9	0.85	9	0.57	9	0.33	9	0.38
10	0.63	10	0.55	10	0.33	10	0.42
11	0.95	11	0.55	11	0.32	11	0.35
12	0.87	12	0.70	12	0.45	12	0.37
13	0.64	13	1.10	13	0.34	13	0.33
14	0.74	14	0.77	14	0.38	14	0.38
15	1.10	15	0.84	15	0.30	15	0.36
16	0.82	16	0.65	16	0.31	16	0.38
17	1.80	17	0.64	17	0.29	17	0.28
18	2.10	18	0.58	18	0.31	18	0.24
19	1.70	19	0.58	19	0.61	19	0.33
20	1.30	20	0.58	20	0.60	20	0.33
21	1.00	21	0.61	21	0.34	21	0.31
22	0.97	22	0.48	22	0.49	22	0.34
23	0.83	23	0.46	23	0.92	23	0.30
24	0.75	24	0.42	24	0.42	24	0.35
25	0.97	25	0.38	25	0.42	25	0.27
26	0.88	26	0.55	26	0.40	26	0.29
27	0.70	27	0.64	27	0.42	27	0.24
28	0.79	28	0.46	28	0.29	28	0.32
29	0.59	29	0.48	29	0.94	29	0.29
30	0.58	30	0.37	30	0.81	30	0.43
31	0.52			31	0.48	31	1.07
8.4"	0.81	5.0"	0.67	6.8"	0.44	5.1"	0.42
Min flow:	0.33	Min flow:	0.37	Min flow:	0.29	Min flow:	0.24
Max flow:	2.10	Max flow:	1.80	Max flow:	0.94	Max flow:	1.37

Mountain View Wastewater Treatment Plant

2003 Flow Data
 +/- 15% of monthly avg.

September		October		November		December	
Date	Flow	Date	Flow	Date	Flow	Date	Flow
1	0.83	1	0.30	1	0.26	1	0.77
2	1.00	2	0.29	2	0.32	2	0.71
3	1.80	3	0.30	3	0.27	3	0.73
4	1.20	4	0.39	4	0.33	4	1.10
5	0.92	5	0.28	5	0.33	5	0.91
6	0.72	6	0.31	6	0.43	6	0.85
7	0.68	7	0.34	7	0.45	7	0.79
8	0.42	8	0.32	8	0.45	8	0.56
9	0.48	9	0.31	9	0.36	9	0.69
10	0.42	10	0.51	10	0.22	10	1.90
11	0.44	11	0.51	11	0.33	11	1.10
12	0.49	12	0.49	12	0.35	12	0.89
13	0.60	13	0.37	13	0.32	13	0.86
14	0.76	14	0.47	14	0.30	14	0.85
15	0.50	15	0.49	15	0.38	15	0.81
16	0.47	16	0.40	16	0.38	16	0.84
17	0.40	17	0.44	17	0.30	17	0.81
18	0.40	18	0.48	18	1.20	18	0.75
19	0.39	19	0.37	19	2.00	19	0.71
20	0.34	20	0.31	20	1.20	20	0.82
21	0.39	21	0.36	21	1.10	21	0.59
22	0.38	22	0.35	22	1.00	22	0.42
23	0.38	23	0.39	23	0.85	23	1.00
24	0.33	24	0.41	24	1.30	24	0.87
25	0.33	25	0.41	25	1.10	25	0.88
26	0.34	26	0.43	26	0.93	26	0.74
27	0.39	27	0.34	27	0.97	27	0.79
28	0.34	28	0.39	28	1.90	28	0.66
29	0.27	29	0.35	29	1.10	29	0.82
30	0.28	30	0.31	30	0.90	30	1.80
		31	0.34			31	1.30
1.4"	0.56	2.8"	0.38	10.4"	0.71	5.4"	0.88
Min flow:	0.27	Min flow:	0.28	Min flow:	0.22	Min flow:	0.42
Max flow:	1.80	Max flow:	0.51	Max flow:	2.00	Max flow:	1.90

January			February			March		April	
Date	Time	Flow	Date	Time	Flow	Date	Flow	Date	Flow
1	noon	0.61	1	AM	2.60	1	0.55	1	1.50
2	AM	0.33	2	noon	1.70	2	0.67	2	1.20
3	AM	0.50	3	AM	1.80	3	1.22	3	0.80
4	AM	0.44	4	AM	0.84	4	0.81	4	0.81
5	noon	0.49	5	AM	0.75	5	0.79	5	0.79
6	noon	0.59	6	AM	0.71	6	0.72	6	0.84
7	AM	0.63	7	AM	0.97	7	0.64	7	0.69
8	AM	0.62	8	AM	1.30	8	0.71	8	1.20
9	AM	0.56	9	noon	1.40	9	1.20	9	1.80
10	AM	0.58	10	noon	1.00	10	1.80	10	1.30
11	AM	0.50	11	AM	0.82	11	0.96	11	1.20
12	AM	0.48	12	AM	0.81	12	2.10	12	0.97
13	noon	0.57	13	AM	0.75	13	1.80	13	0.97
14	AM	0.35	14	AM	0.76	14	1.40	14	1.40
15	AM	0.43	15	AM	0.71	15	1.20	15	1.10
16	AM	0.45	16	AM	0.67	16	0.89	16	0.94
17	AM	0.40	17	AM	0.77	17	0.94	17	0.84
18	AM	0.41	18	AM	0.63	18	0.86	18	0.80
19	AM	0.56	19	AM	0.62	19	1.10	19	0.76
20	AM	0.65	20	AM	1.30	20	2.90	20	0.74
21	AM	0.56	21	AM	1.30	21	2.40	21	0.71
22	AM	0.56	22	AM	0.98	22	1.60	22	0.59
23	AM	0.84	23	AM	0.86	23	1.20	23	0.56
24	AM	1.50	24	AM	0.84	24	1.10	24	0.82
25	AM	1.80	25	AM	0.75	25	1.00	25	0.65
26	noon	1.40	26	AM	0.85	26	1.90	26	0.55
27	AM	0.83	27	AM	0.62	27	1.80	27	0.56
28	AM	0.95	28	AM	0.61	28	1.40	28	0.63
29	AM	0.86				29	1.20	29	0.42
30	AM	0.77				30	1.10	30	0.46
31	AM	0.99				31	1.40		

4.55" RAIN	0.88	3.1" RAIN	0.97	9.4"	1.27	3.45"	0.89
Min flow:	0.33	Min flow:	0.61	Min flow:	0.55	Min flow:	0.42
Max flow:	1.80	Max flow:	2.60	Max flow:	2.90	Max flow:	1.80

Annual Average 0.63

17 periods of low flow for 4+ consecutive days
6 periods of high flow for 4+ consecutive days

Number flows over 2 MGD = 9
Number flows over 1 MGD = 94

Number flows under .25 MGD = 7

May		June		July		August	
Date	Flow	Date	Flow	Date	Flow	Date	Flow
1	0.90	1	0.74	1	0.34	1	0.74
2	0.77	2	0.64	2	0.38	2	0.50
3	0.65	3	0.51	3	0.35	3	0.51
4	0.62	4	0.50	4	0.51	4	0.37
5	0.52	5	0.48	5	0.50	5	0.39
6	0.43	6	2.00	6	0.47	6	0.41
7	0.61	7	1.30	7	0.48	7	0.48
8	0.45	8	0.95	8	0.39	8	0.42
9	0.53	9	0.86	9	0.36	9	0.35
10	0.64	10	0.85	10	0.34	10	0.47
11	0.72	11	1.80	11	0.33	11	0.33
12	0.66	12	1.40	12	0.36	12	0.33
13	0.94	13	1.30	13	0.46	13	0.34
14	1.00	14	1.20	14	0.47	14	0.80
15	0.80	15	0.83	15	0.31	15	0.88
16	0.70	16	0.56	16	0.33	16	0.51
17	0.74	17	0.59	17	0.38	17	0.53
18	1.20	18	0.53	18	0.38	18	0.39
19	0.94	19	0.39	19	0.74	19	0.34
20	0.80	20	0.60	20	0.59	20	0.37
21	0.68	21	0.54	21	0.45	21	0.35
22	0.64	22	0.55	22	0.39	22	0.36
23	0.57	23	0.53	23	0.37	23	0.34
24	0.56	24	0.46	24	0.36	24	0.35
25	0.50	25	0.47	25	0.33	25	0.38
26	0.53	26	0.45	26	0.34	26	0.32
27	0.58	27	0.45	27	0.35	27	0.35
28	0.50	28	0.42	28	0.41	28	0.34
29	0.62	29	0.49	29	0.30	29	0.32
30	0.89	30	0.47	30	0.37	30	0.34
31	0.77			31	0.44	31.00	0.34
5.15"	0.69	6.1"	0.76	4.35"	0.41	5.9"	0.43
Min flow	0.43	Min flow:	0.39	Min flow:	0.30	Min flow:	0.32
Max flow	1.20	Max flow:	2.00	Max flow:	0.74	Max flow:	0.88

Annual Average 0.63

September		October		November		December	
Date	Flow	Date	Flow	Date	Flow	Date	Flow
1	0.37	1	0.22	1	0.28	1	0.27
2	0.34	2	0.18	2	0.27	2	0.25
3	0.36	3	0.32	3	0.35	3	0.27
4	0.34	4	0.32	4	0.33	4	0.49
5	0.36	5	0.32	5	0.42	5	0.62
6	0.35	6	0.23	6	0.47	6	0.38
7	0.44	7	0.28	7	0.33	7	0.40
8	0.28	8	0.30	8	0.31	8	0.38
9	0.33	9	0.28	9	0.32	9	0.32
10	0.28	10	0.33	10	0.32	10	0.31
11	0.30	11	0.34	11	0.26	11	0.31
12	0.44	12	0.29	12	0.29	12	0.30
13	0.29	13	0.33	13	0.27	13	0.32
14	0.34	14	0.28	14	0.30	14	0.39
15	0.37	15	0.28	15	0.28	15	0.41
16	0.34	16	0.27	16	0.29	16	0.37
17	0.33	17	0.27	17	0.26	17	0.40
18	0.32	18	0.28	18	0.25	18	0.42
19	0.29	19	0.31	19	0.29	19	0.49
20	0.40	20	0.32	20	0.26	20	0.33
21	0.52	21	0.24	21	0.27	21	0.52
22	0.36	22	0.28	22	0.25	22	0.48
23	0.28	23	0.29	23	0.24	23	0.41
24	0.40	24	0.25	24	0.24	24	0.23
25	0.26	25	0.29	25	0.24	25	0.90
26	0.27	26	0.32	26	0.24	26	0.91
27	0.29	27	1.30	27	0.28	27	0.74
28	0.27	28	0.29	28	0.30	28	0.72
29	0.25	29	0.33	29	0.25	29	0.54
30	0.23	30	0.31	30	0.27	30	0.54
		31	0.28			31	1.70
1.8*	0.33	1.9*	0.32	1.53**	0.29	7.4*	0.51
Min flow:	0.23	Min flow:	0.18	Min flow:	0.24	Min flow:	0.23
Max flow:	0.52	Max flow:	1.30	Max flow:	0.47	Max flow:	1.70


Annual Average 0.63

	2002	2003	2004	AVG
Jan.	0.68	0.70	0.80	0.73
Feb.	0.97	0.88	0.79	0.88
Mar.	1.27	0.75	0.58	0.87
Apr.	0.89	0.44	0.66	0.66
May	0.69	0.81	0.68	0.73
June	0.76	0.67	0.32	0.58
July	0.41	0.44	0.26	0.37
Aug.	0.43	0.42	0.27	0.37
Sept.	0.33	0.56	0.24	0.38
Oct.	0.32	0.38	0.55	0.42
Nov.	0.29	0.71	1.07	0.69
Dec.	0.51	0.88	0.86	0.75
AVG	0.63	0.64	0.59	0.62


Min flow: 0
 Max flow: 0

Min flow: 0
 Max flow: 0


2002 Flow Data



2003 Flow Data



2004 Flow Data



Influent Characteristics

MCE McCLELLAND CONSULTING ENGINEERS, INC.

DEDICATED TO SERVING YOU

P.O. Box 34087 • Little Rock, Arkansas 72203-4087
 501-371-0272 • FAX 501-371-9932

Job No. _____ Sheet _____

Project Influent - Mtn View

Prepared By 8/28/05 - 9/4/05 Date: _____

Checked By _____ Date: _____

Date	BOD	TSS	NH3	No3
Sun, 8/28	246.6	64	8	.1
Mon 8/29	201	132	18.15	.1
Tues 8/30	180.3	108	22.4	.1
Wed 8/31	450	520	22.9	.1
Thurs 9/1	151.2	112	21.1	.01
Fri 9/2	114.6	212	30.9	.01
Sat 9/3	205.8	256	32	.01
Sun 9/4	214.8	176	29.9	.01

Joe Thakker
 says to discount this

Avg (Less Wed)

187.8

200

BOD History

32-7910

Oct 03

	Results after primary clarifier	estimated influent	Q
10/19-20 →	$156 \times 1.3 =$	203	.37
10/21-22 →	$123 \times 1.3 =$	160	.36
10/23-24 →	$93.6 \times 1.3 =$	122	.39
10/26-27 →	$120 \times 1.3 =$	156	.43
10/28-29 →	$54 \times 1.3 =$	70.2	.39
10/30 → 31 →	$63.6 \times 1.3 =$	83	.31

Nov 03

11/2-3 →	$76.5 \times 1.3 =$	99.5	.32
11/4-5 →	$70.5 \times 1.3 =$	91.65	.33
11/6-7 →	$56.1 \times 1.3 =$	73	.43
11/9-10 →	$67.5 \times 1.3 =$	87.8	.36
11/11-12 →	$70.5 \times 1.3 =$	91.7	.33
11/13-14 →	$132.8 \times 1.3 =$	173	.32
11/16-17 →	$45 \times 1.3 =$	58.5	.38
11/18-19 →	$33 \times 1.3 =$	42.9	1.2

Ammonia Range 2 - 25 Avg 9-15
 Nitrate Range .01 to 4 Avg < 1

Sup - Mow

Client: City of Mt View
Sample: Self Monitoring
Sample Location: WWTP Influent
Permit Number: AR0020117

Sample Number: 25126-01
Date Reported: 9/16/2005

References: 40 CFR Part 136 Approved Methods, Containers, Preservation, Holding Times
Standard Methods for the Examination of Water and Wastewater: EPA-600/4-79-020

Quality Control: Blank, duplication, known addition, quarterly analysis of external references samples
QA Frequency: Minimum of 10% Spikes and Duplicates

Parameter	Reference	Test Date/Time	Initials	Result	QAQC	
					RPD	Spike Rec.
Basic WW cBOD	5210 B	8/29/2005 2:00:00 PM	AP	246.6 mg/l		
TSS	2540 D	9/2/2005 12:00:00 PM	DC	64 mg/l		
Ammonia, NH3-N	4500-NH3 B,C	8/31/2005 8:00:00 AM	RJH	8.0 mg/l		
Nitrate Nitrogen	4500 NO3 E	9/8/2005 10:00:00 AM	DC	0.1 mg/l		
Total Phosphorus Phosphorus	EPA 365.2	9/6/2005 8:30:00 AM	RJH	5.9 mg/l		

* Quality assurance performed on other samples.

Chain of custody, equipment calibration and maintenance records, and QA/QC information are on file at the laboratory.

Kim Carman, Laboratory Manager

J. McClelland, P.E., President

Mon to Tues

Client: City of Mt View
Sample: Self Monitoring
Sample Location: WWTP Influent
Permit Number: AR0020117
References: 40 CFR Part 136 Approved Methods, Containers, Preservation, Holding Times
Standard Methods for the Examination of Water and Wastewater; EPA-600/4-79-020
Quality Control: Blank, duplication, known addition, quarterly analysis of external references samples
QA Frequency: Minimum of 10% Spikes and Duplicates

Sample Number: 25130-01
Date Reported: 9/16/2005

Parameter	Reference	Grab		Composite		Date/Time Received:	
		Date/Time	Sampler	Date/Time	Sampler	RPD	Spike Rec.
		08/30/05 0:00	J Thatcher	08/29/05 0:00		08/31/05 13:30	
Basic WW cBOD	5210 B			9/2/2005 8:00:00 AM	DC	201 mg/l	
TSS	2540 D			9/2/2005 12:00:00 PM	DC	132 mg/l	
Ammonia, NH3-N	4500-NH3 B,C			9/9/2005 8:00:00 AM	RJH	18.15 mg/l	
Nitrate Nitrogen	4500 NO3 E			9/8/2005 10:00:00 AM	DC	0.1 mg/l	
Total Phosphorus	EPA 365.2			9/6/2005 8:30:00 AM	RJH	4.1 mg/l	

* Quality assurance performed on other samples.

Kim Carman, Laboratory Manager

Chain of custody, equipment calibration and maintenance records, and QA/QC information are on file at the laboratory.

J. McClelland, P.E., President

Tues - Wed

Client: City of Mt View
Sample: Self Monitoring
Sample Location: WWTP Influent
Permit Number: AR0020117

Sample Number: 25130-002
Date Reported: 9/16/2005

References: 40 CFR Part 136 Approved Methods, Containers, Preservation, Holding Times
Standard Methods for the Examination of Water and Wastewater: EPA-600/4-79-020

Quality Control: Blank, duplication, known addition, quarterly analysis of external references samples
QA Frequency: Minimum of 10% Spikes and Duplicates

Parameter	Reference	Grab		Composite		Date/Time Received:	
		Date/Time	Sampler	Date/Time	Sampler	08/31/05 13:30	QAQC
		08/31/05 0:00	J Thatcher	08/30/05 0:00		RPD	Spike Rec.
Basic WW cBOD	5210 B			9/2/2005 8:00:00 AM	DC	180.3 mg/l	
TSS	2540 D			9/2/2005 12:00:00 PM	DC	108 mg/l	
Ammonia, NH3-N	4500-NH3 B,C			9/9/2005 8:00:00 AM	RJH	22.4 mg/l	
Ammonia Nitrogen Nitrate	4500-NH3 B			9/8/2005 10:00:00 AM	DC	0.1 mg/l	
Total Phosphorus Phosphorus	EPA 365.2			9/6/2005 8:30:00 AM	RJH	6.5 mg/l	

* Quality assurance performed on other samples.

Kim Carman, Laboratory Manager

Chain of custody, equipment calibration and maintenance records, and QA/QC information are on file at the laboratory.

J. McClelland, P.F., President

Wed - Thurs

Client: City of Mt View
Sample: Self Monitoring
Sample Location: WWTP Influent
Permit Number: AR0020117

Sample Number: 25130-003
Date Reported: 9/16/2005

References: 40 CFR Part 136 Approved Methods, Containers, Preservation, Holding Times
Standard Methods for the Examination of Water and Wastewater: EPA-600/4-79-020

Quality Control: Blank, duplication, known addition, quarterly analysis of external references samples
QA Frequency: Minimum of 10% Spikes and Duplicates

Parameter	Reference	Grab		Composite		Date/Time Received:	
		Date/Time	Sampler	Date/Time	Sampler	08/31/05 13:30	QAQC
						RPD	Spike Rec.
Basic WW cBOD	5210 B	09/01/05 0:00	J Thatcher	08/31/05 0:00			
TSS	2540 D						
Ammonia, NH3-N	4500-NH3 B,C						
rate Nitrogen Nitrate	4500 NO3 E						
Total Phosphorus Phosphorus	EPA 365.2						

* Quality assurance performed on other samples.

Chain of custody, equipment calibration and maintenance records, and QA/QC information are on file at the laboratory.

Kim Carman, Laboratory Manager

J. McClelland, P.E., President

Thurs

Client: City of Mt View
Sample: Self Monitoring
Sample Location: WWTP Influent
Permit Number: AR0020117
References: 40 CFR Part 136 Approved Methods, Containers, Preservation, Holding Times
Standard Methods for the Examination of Water and Wastewater: EPA-600/4-79-020
Quality Control: Blank, duplication, known addition, quarterly analysis of external references samples
QA Frequency: Minimum of 10% Spikes and Duplicates

Sample Number: 25156-002
Date Reported: 9/16/2005

Parameter	Reference	Composite		Result	QAQC	
		Date/Time	Sampler		RPD	Spike Rec.
Basic WW cBOD	5210 B	09/01/05 0:00	AP	151.2 mg/l		
TSS	2540 D	9/9/2005 12:45:00 PM	DC	112 mg/l		
Ammonia, NH3-N	4500 NH3 B,C	9/9/2005 8:00:00 AM	RJH	21.1 mg/l		
Nitrate Nitrogen	4500 NO3 E	9/15/2005 1:00:00 PM	DC	0.01 mg/l		
Total Phosphorus Phosphorus	EPA 365.2	9/6/2005 8:30:00 AM	RJH	5.9 mg/l		

* Quality assurance performed on other samples.

Kim Carman, Laboratory Manager

Chain of custody, equipment calibration and maintenance records, and QA/QC information are on file at the laboratory.

J. McClelland, P.E., President

Fri

Client: City of Mt View
Sample: Self Monitoring
Sample Location: WWTP Influent
Permit Number: AR0020117

Sample Number: 25156-003
Date Reported: 9/16/2005

References: 40 CFR Part 136 Approved Methods, Containers, Preservation, Holding Times
Standard Methods for the Examination of Water and Wastewater: EPA-600/4-79-020

Quality Control: Blank, duplication, known addition, quarterly analysis of external references samples
QA Frequency: Minimum of 10% Spikes and Duplicates

Parameter	Reference	Composite		Result	QA/QC	
		Date/Time	Sampler		RPD	Spike Rec.
Basic WW cBOD	5210 B	09/02/05 0:00		114.6 mg/l		
TSS	2540 D	9/9/2005 12:45:00 PM	DC	212 mg/l		
Ammonia, NH3-N	4500-NH3 B,C	9/9/2005 8:00:00 AM	RJH	50.9 mg/l		
rate Nitrogen Nitrate	4500 NO3 E	9/15/2005 1:00:00 PM	DC	0.01 mg/l		
Total Phosphorus Phosphorus	EPA 365.2	9/14/2005 8:00:00 AM	RJH	10.3 mg/l		

* Quality assurance performed on other samples.

Kim Carman, Laboratory Manager

Chain of custody, equipment calibration and maintenance records, and QA/QC information are on file at the laboratory.

J McClelland, P.E., President

SAT

Client: City of Mt View
 Sample: Self Monitoring
 Sample Location: WWTP Influent
 Permit Number: AR0020117

Sample Number: 25156-004
 Date Reported: 9/16/2005

References: 40 CFR Part 136 Approved Methods, Containers, Preservation, Holding Times
 Standard Methods for the Examination of Water and Wastewater: EPA-600/4-79-020

Quality Control: Blank, duplication, known addition, quarterly analysis of external references samples
 QA Frequency: Minimum of 10% Spikes and Duplicates

Parameter	Reference	Composite		Result	QAQC	
		Date/Time	Sampler		RPD	Spike Rec.
Basic WW						
 cBOD	5210 B	09/03/05 0:00	AP	205.8 mg/l		
TSS	2540 D	9/9/2005 12:45:00 PM	DC	256 mg/l		
Ammonia, NH3-N	4500-NH3 B.C	9/9/2005 8:00:00 AM	RJH	32.0 mg/l		
Nitrate Nitrogen	4500 NO3 E	9/15/2005 1:00:00 PM	DC	0.01 mg/l		
Total Phosphorus						
Phosphorus	EPA 365.2	9/14/2005 8:00:00 AM	RJH	10 mg/l		

* Quality assurance performed on other samples.

Kim Carman, Laboratory Manager

Chain of custody, equipment calibration and maintenance records, and QA/QC information are on file at the laboratory.

J. McClelland, P.E., President

SUN.

Client: City of Mt View
Sample: Self Monitoring
Sample Location: WWTP Influent
Permit Number: AR0020117

Sample Number: 25156-005
Date Reported: 9/16/2005

References: 40 CFR Part 136 Approved Methods, Containers, Preservation, Holding Times
Standard Methods for the Examination of Water and Wastewater: EPA-600/4-79-020

Quality Control: Blank, duplication, known addition, quarterly analysis of external references samples
QA Frequency: Minimum of 10% Spikes and Duplicates

Date/Time	Grab Sampler	Composite		Date/Time Received:	QAQC	
		Date/Time	Sampler		RPD	Spike Rec.
		09/04/05 0:00		09/07/05 14:40		
Parameter	Reference	Test Date/Time	Initials	Result	RPD	Spike Rec.
Basic WW cBOD	5210 B	9/7/2005 4:30:00 PM	AP	214.8 mg/l		
TSS	2540 D	9/9/2005 12:45:00 PM	DC	176 mg/l		
Ammonia, NH3-N	4500-NH3 B,C	9/9/2005 8:00:00 AM	RJH	29.9 mg/l		
Nitrate Nitrogen	4500 NO3 E	9/15/2005 1:50:00 PM	DC	0.01 mg/l		
Total Phosphorus	EPA 365.2	9/14/2005 8:00:00 AM	RJH	7.35 mg/l		

* Quality assurance performed on other samples.


Kim Carman, Laboratory Manager

Chain of custody, equipment calibration and maintenance records, and QA/QC information are on file at the laboratory.

J. McClelland, P.E., President

Line Size Calculations

Size Line from Oxidation Ditch to final clarifier



$L_{90} = 168'$
 $90^\circ \text{ Bends} = 2 \times 17' = 34'$

Eq length = 202'

exit loss $\cdot \frac{KL^2}{2g} = \frac{1(5.86)^2}{2(32.2)} \cdot .44 \cdot 3 = 1.82'$ (use 4 MSD)

Entrance loss = $.78 \frac{(5.86)^2}{2(32.2)} = .34 \times 2 = .68'$

$14'' \text{ pipe} \Rightarrow \frac{h_L f = 10.44(202)(2778)^{1.85}}{110^{1.85} \cdot 14.35^{4.8655}} = 1.82'$

Total $h_L = 1.82 + .68 + 1.82 = 3.82'$

Available head = 4.03'

use 16" to be conservative

Box 34087 • Little Rock, Arkansas 72203-4087
 501-371-0272 • FAX 501-371-9932

Check Flow From Oxidation Ditch to Final Clarifier

16" Line

- $L = 98 + 30 + \dots = 128'$
- 2 - 90° BND = $19 \times 2 = 38$
 - 1 - Valve = 3
 - 1 - Exit Loss $KV^2/2g = 1(1.108)^2/2g = .02'$
 - 1 - Entrance Loss $.78(.02) = .016$
- | | | |
|--|------|--------|
| | 1MGD | 4MGD |
| | | .3047' |
| | | .24 |

$$h_{L@1MGD} = \frac{10.44 (169) (6.95)^{1.85}}{110^{1.85} (14.675)^{4.75}} = .0605 + .02 + .016 + .097 = .1945'$$

$$h_{L@4MGD} = \frac{10.44 (169) (27.8)^{1.85}}{110^{1.85} (14.675)^{4.75}} = .785 + .31 + .24 = 1.34'$$

14" Line

- $L = 40'$
- 1 - 90° BND = 17
 - 1 - exit loss $.78(.0325) = .0254$
 - 1 - exit loss = .0325
- | | | |
|--|------|------|
| | 1MGD | 4MGD |
| | | .426 |
| | | .521 |

$$h_{L@1MGD} = \frac{10.44 (57) (6.95)^{1.85}}{110^{1.85} (14.55)^{4.75}} = .04 + .0254 + .0325 = .0979'$$

$$h_{L@4MGD} = \frac{10.44 (57) (27.8)^{1.85}}{110^{1.85} (14.55)^{4.75}} = .51 + .406 + .521 = 1.44'$$

Total $h_L @ 1MGD = 1.02'$ ok 3' available
 $V_{14} = 1.447$

Total $h_L @ 4MGD = 2.78'$ ok 4' available
 $V_{14} = 5.79$

1MGD	$V_{16} = 1.108$
4MGD	$V_{16} = 4.43$

$A_{14} = 1.069 \text{ ft}^2$
 $A_{16} = 1.137 \text{ ft}^2$

$Q = VA$

1MGD = 1.547 cfs
 4MGD = 6.189 cfs

Determine size of Ductile Iron Pipe from Headworks to relift pump sta.

- Design Flow max = 4 MGD - See calcs

For max flow through siphon: (3.943)

(Keep in mind that Avg Daily Flow = ± .3 MGD)
↑ dry weather

- Design as a pressure line

will 14" line be suitable?

$$HL = \frac{10.44 (\pm 145) (2778)^{1.85}}{110^{1.85} (14)^{4.8255}} = 1.58' \quad \text{LS 9' IS Avail, OK}$$

check velocity:

$$Q = VA \quad (14.6 \text{ } ^2)$$

$$6.19 = V (1.102)$$

$$V = 5.32 \text{ ft/sec OK}$$

Note: This will actually be a gravity line at 4MGD

Size RAS Line

$$\begin{aligned} \text{Max Flow} &= \pm 1.3 Q = 1.3 \times .85 = 1.11 \text{ MGD} = 1.72 \text{ cfs} \\ \text{Min Flow} &= \pm 1 \times .3 = .3 \text{ MGD} = .464 \text{ cfs} \\ \text{Ann. avg} &= \pm .68 \times 1.0 = .68 \text{ MGD} = 1.05 \text{ cfs} \end{aligned}$$

$$6'' \text{ area} = \pm \frac{5.97^2 \pi}{4} = 144 = .1944 \text{ ft}^2$$

$$8'' \text{ area} = \pm \frac{8.12^2 \pi}{4} = 144 = .365 \text{ ft}^2$$

$$Q = VA$$

$$V_{6 \text{ max}} = 3.85$$

$$V_{8 \text{ max}} = 4.71$$

$$V_{6 \text{ min}} = 2.38$$

$$V_{8 \text{ min}} = 1.27$$

$$V_{6 \text{ avg}} = 5.4$$

$$V_{8 \text{ avg}} = 2.27$$

Use 6" - it covers a larger flow area w/ higher velocity. Velocities do not appear too high, especially since it is an "open system"

check elevation of water in pipe bet. splitter box
& down section

14" pipe : L = 100'
1 - 45° = 12'
1 - 90° = 3'

eq. length = 115'

entrance loss
Exit loss

1MGD
0.0254
0.0325

4MGD
0.406
0.521

$$1MGD) \frac{10.44(115)(695)}{110^{1.85} \cdot 14.55 \cdot 4.8265} = 0.08$$

$$4MGD) \frac{10.44(115)(2778)}{110^{1.85} \cdot 14.55 \cdot 4.8265} = 1.04$$

Elev of water @ 1MGD = 603.73 + 0.08 + 0.0254 + 0.0325 = 603.9

@ 4MGD = 603.73 + 1.04 + 0.406 + 0.521 = 605.7

TAB H

Extended Aeration Oxidation Ditch

Dosing flow = 0.73 m³/D



Box 34087 • Little Rock, Arkansas 72203-4087
501-371-0272 • FAX 501-371-9932

Size line (Force main) from influent p.s. to oxidation ditch

Pump Sta. may be set up one of two ways!

- 1) pump when well is full, shut off when empty
- 2) maintain continuous level in well

Let's look at option 2:

Flow range 118 gpm, 263 cfs to 2712 gpm, 619 cfs
17 MGD / day to 4 MGD

Look at velocities!


$\frac{263}{.3672}$	$8^{(17)}$	$= .716 \text{ ft/sec}$
$\frac{619}{.3672}$	$8^{(4)}$	$= 16.86 \text{ ft/sec}$
$\frac{1311}{.3672}$	$8^{(35)}$	$= 3.58 \text{ ft/sec}$
$\frac{2321}{.3672}$	$8^{(15)}$	$= 6.32 \text{ ft/sec}$
$\frac{263}{.5691}$	$10^{(17)}$	$= .462$
$\frac{619}{.5691}$	$10^{(4)}$	$= 10.87$
$\frac{1311}{.5691}$	$10^{(35)}$	$= 2.3$
$\frac{2321}{.5691}$	$10^{(15)}$	$= 4.07$
$\frac{.464}{.3672}$	$8^{(3)}$	$= 1.26$
$\frac{.464}{.3672}$	$10^{(3)}$	$= .8153$
$\frac{.928}{.3672}$	$8^{(16)}$	$= 2.52$
$\frac{.928}{.3672}$	$10^{(6)}$	$= 1.63$

This line used for normal
Flow
combination of 2 pumps
should be able to achieve
this

$$\begin{aligned} \text{Average Annual Daily } Q &= .68 \text{ MGD} \\ &\times 3.44 \text{ peak} \\ &= 2.33 \text{ MGD} \end{aligned}$$

$$\begin{aligned} \pm \text{ Avg. dry weather} &= \\ &= .35 \\ &\times 3.44 \\ &= 1.2 \text{ MGD} \end{aligned}$$

$$Q = .1 - 2 \text{ MGD}$$



$$Q = 2 \text{ MGD}$$

Variable Speed

(one pump should
be able to accomplish
this)

$$\begin{aligned} \text{Design } Q &= .35 \text{ MGD} \\ &\times 3.44 \text{ peak} \\ &= 2.924 \text{ MGD} \end{aligned}$$

This line will be used for I/I flow -
This flow will normally be directed to
the outer channel but be capable of all
channels.

Box 34087 • Little Rock, Arkansas 72203-4087
501-371-0272 • FAX 501-371-9932

Design Pumps for Influent Pump Station

Design Q = .85 MGD

Max Flow to plant = 4 MGD

Firm capacity should exceed 4 MGD


ONE pump should be able to pump design Q
* two pumps = 2 MGD

pumps will be designed to maintain a certain level in the wetwell.

minimum recorded flowrate / day = 170,000 gal/day
= 118 gpm

Try this Scenario -

- pump 1 • Max = .85 MGD
- pump 2 • Max = .85 MGD
- pump 3 • Max = 3 MGD
- pump 4 • Max = 3 MGD (redundant)



Length = 260 + 20 = 280, add 300

8" CV (1)	=	1 x 74 =	74
8" 6V (2)	=	2 x 3 =	6
8" Tee (run) (2)	=	2 x 4 =	8
8" Tee branch (1)	=	1 x 20 =	20
90° (7)	=	7 x 10 =	70
60° (1)	=	1 x 6.5 =	6.5
45° (1)	=	1 x 6.5 =	6.5
			<u>191</u>

$V_{.85} = \frac{.81}{.3077} = 2.638$
 $V_4 = \frac{6.189}{.3491} = 17.72$

Exit loss = $\frac{KV^2}{2g} = 1 \frac{(3.58)^2}{20} = .2'$

MOUNTAIN VIEW INFLUENT PUMP STATION

SYSTEM CURVE FOR 2MGD PUMPS

Pipe size = 8"

FLOW	HL(f)	STATIC	EXIT LOSS	TDH	VELOCITY
500000	1.391458	19.1	0.08912	20.56058	2.109812
750000	2.946039	19.1	0.155519	22.20156	3.164718
1000000	5.016203	19.1	0.278479	24.39268	4.219624
1250000	7.579815	19.1	0.431998	27.11181	5.27453
1500000	10.62047	19.1	0.622077	30.34255	6.329436
1750000	14.12523	19.1	0.846716	34.07194	7.384342
2000000	18.08342	19.1	1.105915	38.28934	8.439248
2250000	22.48603	19.1	1.399673	42.9857	9.494154
2500000	27.32525	19.1	1.727992	48.15324	10.54906
2750000	32.59422	19.1	2.09087	53.78509	11.60397
3000000	38.28683	19.1	2.488308	59.87514	12.65887

use 43' TDH surge

Pump specified can pump 2MGD @ 43' TDH

SYSTEM CURVE FOR NORMAL FLOW PUMPS (.15 TO 2MGD-FOR BOTH PUMPS)

Pipe size = 8"

FLOW	HL(f)	STATIC	EXIT LOSS	TDH	VELOCITY
150000	0.165898	19.1	0.006221	19.27212	0.832944
200000	0.282474	19.1	0.011059	19.39353	0.843925
300000	0.598064	19.1	0.024883	19.72295	1.265887
400000	1.018321	19.1	0.044237	20.16256	1.68786
500000	1.53875	19.1	0.06912	20.70787	2.109812
600000	2.156023	19.1	0.099532	21.35556	2.531774
700000	2.86751	19.1	0.135475	22.10298	2.953737
850000	4.106753	19.1	0.199756	23.40651	3.58668
1000000	5.547197	19.1	0.276479	24.92368	4.219624
1250000	8.382183	19.1	0.431998	27.91418	5.27453
1500000	11.74471	19.1	0.622077	31.46879	6.329436
1750000	15.62047	19.1	0.846716	35.56718	7.384342
2000000	19.99766	19.1	1.105915	40.20357	8.439248
2250000	24.86631	19.1	1.399673	45.36598	9.494154

4-4-06

note: Pumps specified can pump

325,000 gpd w/ both pumps on @ 45.3' TDH

Total Dynamic head ✓ ^{85 MGD}


$$h_{df} = \frac{10.44 (491) 591^{1.85}}{110^{1.85} (8.2)^{4.75}} = 4.12'$$

$$TDH = \underset{h_{df}}{4.12} + \underset{Exit}{.2} + \underset{Static}{19.1} = 23.42'$$

Create system curve:

Q	Static	H _{df}	Exit Loss	TDH
.2 (139)	19.1	.28	.02	19.4
.5 (347)	19.1	1.54	.07	20.7
.85	19.1	4.12	.2	23.4
1.0 (695)	19.1	5.50	.28	24.9
1.25 (872)	19.1	8.38	.43	27.9
1.5 (1002)	19.1	11.75	.62	31.5
1.75 (1245)	19.1	15.6	.84	35.5

Box 34087 • Little Rock, Arkansas 72203-4087
501-371-0272 • FAX 501-371-9932




This is the curve for the smaller pumps (2 pumps @ 2 MGD)

RAS Pump Station

Box 34087 • Little Rock, Arkansas 72203-4087
501-371-0272 • FAX 501-371-9932 **RAS Design**

Find level of water in Wetwell @ 834 gpm



Find Equivalent length

Pipe length AB 45'
Valve = 2.6
Tee = 15'
63'

$$h_L = 12.4 + (63) \left(\frac{834}{140} \right)^{1.85} \left(\frac{1}{5.37} \right)^{4.75} = 5.58'$$

Entrance loss = $0.5 \frac{V^2}{2g} = 0.71'$

Exit loss = $(1) \frac{V^2}{2g} = 1.42'$

Total Losses to "B" = 7.71' < NO GOOD >

G Pipe cannot be used w/ telescoping valve
if G is used - it must come in through lower pipe.

If G USED -

WL in p.s. @ Flow = 1.42 (834 gpm)
= 611.18 - 7.71 = 603.5


Box 34087 • Little Rock, Arkansas 72203-4087
501-371-0272 • FAX 501-371-9932

Design BAS Pump Station Renovations

- Design Pumps to be variable speed

Range • 2MGD to 1.2 MGD ← 1.4 x Q Des
1.5 x if range is acceptable

- Find Total Dynamic head



$Q = 1.2 \text{ MGD} = 334 \text{ gpm}$ (6" PIPING) $ID = 5.97"$

Eq length BAS = 15 + 25 + 85 + 15 = 140'

90' bend = 5 x 7.2 = 36
Tee = 4 x 15 = 60
G.V. = 3 x 2.6 = 8
G.V. = 1 x 52 = 52
156'

$h_f = \frac{10.44 (300) 334^{1.85}}{140^{4.85} (5.97)^{4.85}} = 22.3'$; 156 + 140 = 296
Say 300'

Losses ; Exit loss = $\frac{KV^2}{200} = \frac{9.55^2}{2(32.2)} = 1.42'$

Total Losses = 22.3 + 1.42 = 23.71 Say 24'

Oxidation Ditch a.F. = 615.43

E Water level in AS = 603.5 → Say 603

Box 34087 • Little Rock, Arkansas 72203-4087
501-371-0272 • FAX 501-371-9932

∴ Static head = $616.43 - 603 = 13.43$ say $13.5'$

$TDH = 13.5 + 24 = 37.5'$
 $Q = 334 \text{ gpm}$

* Now - Find head conditions at normal flow:

$Q = 1.68 \times 1.4 = .95 \text{ MGD} = \text{say } 1 \text{ MGD} = 694 \text{ gpm}$

$h_{L_f} = \frac{10.44 (300) (694)^{1.85}}{110^{1.85} (5.97)^{4.8655}} = 15.85$ say $16'$

Exit Loss = $\frac{KV^2}{2g} = (1) \frac{(7.96)^2}{2(32.2)} = .98$ say $1'$

Level in wetwell =

$h_{L_f} = \frac{10.44 (65) (694)^{1.85}}{110^{1.85} (5.97)^{4.8655}} = 4.1$

Exit loss = $\frac{1}{.5}$
 Entrance loss = $\frac{1}{.5}$
 ∴ $611.18 - 5.6 = 605.6$

level = 605.6

∴ static Head = $616.43 - 605.6 = 10.83$ say $11'$

∴ $TDH_{\text{Normal}} = 11 + 17 =$ say $28'$

$Q = 694$
 $TDH = 28$

* Now find head conditions @ low flow:

$$Q = 200,000 \text{ gpd} = 139 \text{ gpm}$$

$$h_{L_f} = \frac{10.44 (300) (139)^{1.85}}{110^{1.85} (5.97) 4.8655} = .81'$$

$$\text{Exit loss} = \frac{V^2}{2g} = \frac{1.59^2}{2 \times 32.2} = .04'$$

- level in wetwell:

$$h_{L_f} = \frac{10.44 (65) (139)^{1.85}}{100^{1.85} (5.97) 4.8655} = .21'$$

$$\text{Exit loss} = .04$$

$$\text{Entrance loss} = .02$$

$$\text{level} = 61.18 - .21 - .04 - .02 = 610.9$$

$$\therefore \text{Static Head} = 616.43 - 610.9 = 5.52$$

$$\therefore \text{TDH} = 5.52 + .81 + .04 = 6.37', \text{ say } 6.5'$$

$$\text{TDH} = 6.5'$$

Q = 139 gpm

**Extended Aeration
Oxidation Ditch**

ORBAL DESIGN OUTLINE

Project: Mt View - AR Orbal Prepared: 07/18/2006
Engineer: McClelland consulting engineer Designer: Dennis Barnes

Influent Characteristics

Flow, MGD	0.73
BOD5, mg/L	200
TSS, mg/L	200
TP, mg/L	6
NH3-N, mg/L	40
TKN, mg/L	50

Effluent Requirements

BOD5, mg/L	10
TSS mg/L	15
TP, mg/L	1.5
NH3-N, mg/L	1.0
TN, mg/L	10.0

Orbal Design Parameters

Total Load, lb BOD5/day	1,218	MLSS, mg/L	3,470
Primary Clarifiers	NO	No. of Trains in Parallel	1
Organic Loading, lb/1000 cft/day	21.15	Solids under Aeration, Lbs.	12,466
Total Hydraulic Detention Time, Hr	14.2	Sludge Yield	0.85
		WAS per train, lb/day	1,039
		Sludge Age, days	12

Basin Dimensions

No. of Channels per Train	3	Wall Thickness, ft	1.00
Channel Depth, ft	12.00	Radius of Center Island, ft.	5.0
Channel Width, ft		Length of Short Axis Straight Section, ft.	0.0
Inner	10.00	Length of Long Axis Straight Section, ft.	14.0
Middle	10.00	Overall Width, ft.	76.0
Outer	10.00	Overall Length, ft.	90.0
		Volume per Train, cubic feet	57,581
		Volume per Train, gal	430,705

Pumping Requirements

RAS pumping rate at 150% of Q, (where Q is the average design flow rate)
Pump MLSS containing Nitrates from Aerobic Inner channel to Anoxic Outer channel at 400% of Q

Drives Recommendation

Location	Channels spanned	Discs per aerator	Design rpm	Max. rpm	Quantity per train	HP
Outer	1	18	29	45	(2)	10.0
Center Island	2	36	43	55	(2)	30.0
Wall Pumps for Nitrate Recycle to Anoxic Outer Channel					1	5.6
Based on max. disc immersion of		21 inches		Installed HP per Train		86 HP
Based on motor efficiency of		90%		Operating electrical Hp per Train		38 HP
and design disc immersion of		14 inches				

Additional Costs	Concrete	Unit Price		Orbal Basin	
		Walls	\$550	Cubic Yards	\$176,000
		Floors	\$500	158	\$78,000
	Installation	Hourly Rate	Orbal	SmartBNR	
		\$55	130 man-hrs	100 man-hrs	\$13,000
Total Additional Costs					\$267,000

Influent Characteristics		Ave. design flow, MGD	0.73		
BOD5, mg/L	200	NH3-N, mg/L	40		
TSS, mg/L	200	TKN, mg/L	50	TP, mg/L	6

A) Determine Basin Volume

Basin volume is determined by minimum sludge age required to maintain a healthy population of nitrifying organisms at the minimum wastewater temperature. $\theta_{min} = 1 / (\mu_{max} * EXP(0.098 * (T_{min} - 15))) * TPF * SF$, where:

Minimum wastewater temperature, T_{min} =	53.6 degrees F
θ_{max} =	0.47 days ⁻¹
Diurnal Peak Factor, DPF =	1.2
Monthly Peak Factor, MPF =	1.3
DPF x MPF = Total Process Peak Factor, TPF =	1.56
Safety Factor, SF =	2.5
Minimum Solids Residence Time, θ_{min} =	11.1 days
Selected Solids Residence Time, θ_x =	12.0 days

Use McCarty kinetic equations to calculate basin volume required:

- 1) **Inert solids:**

$M_{i,IS} = (M_{o,TSS})(1 - f_{VSSo}) =$	
(1218 lb/day influent TSS)(100 - 80% VSS) / (100%) =	244 lb/day

- 2) **Nonbiodegradable VSS:**

$M_{i,NS} = (M_{o,TSS})(f_{VSSo})(f_{NS}) =$	
(1218 lb/day influent TSS)(80% VSS)(40% NBVSS) / (100%) =	390 lb/day

- 3) **Heterotrophic Kinetic Parameters**

Growth Rate, $Y_{true, 15} =$	0.6 lb VSS/lb BOD5
Decay rate, $b_{15} =$	0.06 days ⁻¹
BOD Half-saturation coefficient, $K_{BOD} =$	20 mg/l BOD
Adjusting for temperature, $b_T = b_{15}(1.04)^{(T-15)} =$	0.073 days ⁻¹
Maximum Growth Rate, $\mu_{MAX,H} =$	6

Estimate Effluent BOD₅:

Soluble BOD, $S_e = [K_{BOD}(1+b_T \theta_x)] / [K_{MAX,H} - b_T] - 1 =$	0.54 mg/l
Effluent VSS concentration, $f =$	40%
$BOD_{5, total} = S_e + (TSS \times f) =$	
0.54 + (10mg/l effluent TSS)(40% VSS) / (100%) =	4.54 mg/l

Observed yield of heterotrophs:

$Y_{OBS,H} = Y_{true} / (1 + b_T \theta_x) =$	0.32
---	------

Heterotrophic Biomass Produced:

$M_H = (M_{o,BOD} - M_{o,BOD})(Y_{OBS,H}) =$	381 lb/day
--	------------

- 4) **Autotrophic Kinetic Parameters**

Growth Rate, $Y_{true, 15} =$	0.15 lb VSS/lb NH3-N
Decay Rate, $b =$	0.05 days ⁻¹
Ammonia half-saturation coefficient, $K_{am} =$	0.5 mg NH ₃ -N/L
Oxygen half-saturation coefficient, $K_o =$	1 mg DO/L
θ_{max} =	0.47 days ⁻¹
Adjusting for temperature: $\theta_{max T} = \theta_{max 15} e^{0.098(T-15)} =$	0.350 days ⁻¹
$b_T = b_{15}(1.04)^{(T-15)} =$	0.044 days ⁻¹

Calculate observed yield of autotrophs:

$Y_{OBS,A} = Y_{true} / (1 + b_T \theta_x) =$	0.098
---	-------

Nitrogen assimilated by heterotrophic biomass:

$$\begin{aligned} \text{Nitrogen content of biomass: } N_{cm} &= 12\% \\ \text{Nitrogen assimilated: } M_{NA-H} &= (M_H)(N_{cm}) = 46 \text{ lb/day} \end{aligned}$$

Nitrogen assimilated by autotrophic biomass (1st iteration):

$$\begin{aligned} \text{TKN oxidized: } M_{TKN-o} &= M_{o-TKN} - M_{NA-H} = 259 \text{ lb/day} \\ \text{Autotrophic Biomass Produced: } M_A &= (M_{TKN-o})(Y_{OBS A}) = 25 \text{ lb/day} \\ \text{Nitrogen assimilated by autotrophic biomass: } M_{NA-A} &= (M_A)(N_{cm}) = 3 \text{ lb/day} \end{aligned}$$

Nitrogen assimilated by autotrophic biomass (2nd iteration):

$$\begin{aligned} \text{TKN oxidized: } M_{TKN-o} &= M_{o-TKN} - M_{NA-H} - M_{NA-A} = 256 \text{ lb/day} \\ \text{Autotrophic Biomass Produced: } M_A &= (M_{TKN-o})(Y_{OBS A}) = 25 \text{ lb/day} \\ \text{Nitrogen assimilated by autotrophic biomass: } M_{NA-A} &= (M_A)(N_{cm}) = 3 \text{ lb/day} \\ \text{TKN oxidized: } M_{TKN-o} &= M_{o-TKN} - M_{NA-H} - M_{NA-A} = 256 \text{ lb/day} \\ \text{Oxidized TKN Concentration} &= (M_{TKN-o})(1000)/Q = 42 \text{ mg/l} \end{aligned}$$

5) **Total Solids Production Rate:**

$$\begin{aligned} P_x &= M_{o-BS} + M_{o-NS} + M_H + M_A = 1039 \text{ lb/day} \\ \text{Overall Yield: } Y_H &= P_x/M_{o-BOD} = 0.85 \\ \text{MLVSS: } (M_{o-NS} + M_H + M_A) / P_x &= 76.56\% \end{aligned}$$

6) **Orbal Basin Volume Calculations:**

Calculate required volume, based on MLSS concentration of 3500 mg/l

$$\begin{aligned} \text{Required Volume, } V &= (\theta_x)(P_x)(1,000,000)/8.34/\text{MLSS} = 427048 \text{ gallons} \\ \text{Selected Orbal basin volume} &= 430705 \text{ gallons} \\ \text{Actual MLSS: } X &= (\theta_x)(P_x)(1,000,000)/V/8.34 = 3470 \text{ mg/l} \end{aligned}$$

7) **Waste Activated Sludge:**

$$\begin{aligned} \text{WAS TSS: } X_{WV} &= (1 + F_R)(X)/(F_R) = 5784 \text{ mg/l} \\ \text{WAS Flow: } Q_W &= (P_x)(1000000)/(X_W)/8.34 = 21535 \text{ gal/day} \end{aligned}$$

B. Determine Actual Oxygen Transfer Rate (AOTR) to be satisfied in Orbal

1) **Carbonaceous O₂ demand**

$$\begin{aligned} \text{oxygen equivalent of cell mass, } B &= 1.42 \text{ lb O}_2/\text{lb VSS} \\ \text{Influent BOD}_{ULT}:\text{BOD}_5 \text{ RATIO:} &= 1.46 \\ \text{Effluent BOD}_{ULT}:\text{BOD}_5 \text{ RATIO:} &= 1.2 \\ \text{Carbonaceous oxygen demand design factor, } f_{c-o_2} &= 1.16 \end{aligned}$$

a) **Mass of BOD₅ O₂ demand equivalents entering the system:**

$$\begin{aligned} \text{lb BOD}_5/\text{d} \times \text{Influent BOD}_{ULT}:\text{BOD}_5 \text{ RATIO} &= \\ (1218 \text{ lb/day Influent BOD})(1.46) &= 1778 \text{ lb/day} \end{aligned}$$

b) **Mass of BOD₅ O₂ demand equivalents leaving the system:**

$$\begin{aligned} \text{lb BOD}_5/\text{day} \times \text{Effluent BOD}_{ULT}:\text{BOD}_5 \text{ RATIO} &= \\ (28 \text{ lb/day effluent BOD})(1.46) &= 33 \text{ lb/day} \end{aligned}$$

c) **Mass of O₂ equivalents leaving the system as biomass:**

$$\begin{aligned} \text{heterotrophic VSS/d} + \text{autotrophic VSS/d} \times \text{lb O}_2/\text{lb VSS} &= \\ (381 + 25.01)(1.42) &= 578 \text{ lb/day} \end{aligned}$$

d) **Carbonaceous O₂ demand (calc.):** $f_{c-o_2}(a - b - c) = 1356 \text{ lb/day}$

e) **Carbonaceous O₂ demand (selected):** 1356 lb/day

2) **Nitrification oxygen demand:**

Nitrification oxygen equivalent: 4.6
Denitrification oxygen credit: 2.9

Nitrification oxygen demand: $\text{lb O}_2/\text{kg NH}_3\text{-N} \times \text{lb TKN oxidized}/\text{day} =$
 $(256 \text{ lb}/\text{day TKN oxidized})(4.6) = 1176 \text{ lb}/\text{day}$

3) **Denitrification oxygen credit:**

As long as that the organic loading is high enough and the O₂ supply is distributed to multiple locations, the outer channel(s) of Orbal systems can be maintained in an anoxic state by limiting the percentage of the overall system AOR satisfied in each anoxic channel to a value close to the percentage of the overall system volume in that channel, resulting in simultaneous nitrification and denitrification. Ammonia oxidation will occur at a rate proportional to the percentage of AOR satisfied in each Orbal channel. With a strong oxygen deficit (DO = near zero mg/l), 100% of the ammonia oxidized will be denitrified. With a mild oxygen deficit condition (DO = near 0.5 mg/l), 65% of ammonia oxidized will be denitrified. Based on the process split listed in the table below, we can calculate the rate of denitrification for the Orbal system:

	Channel			Total
	1	2	3	
Volume Split	47.7%	33.3%	18.9%	100.0%
AOR Split	19.4%	44.2%	36.4%	100.0%
DO, mg/l	0.0	0.5	2.0	
Denite Rate	100%	65%	0%	

Nitrogen Mass Balance

Nitrogen components in clarifier return activated sludge, with RAS flow at 150% of design flow

Ammonia-N: $M_{R-NH_3} = (C_e-NH_3)(Q)(RAS\%)(8.34) = 3 \text{ lb}/\text{day}$
Nitrate-N: $M_{R-NO_x} = (C_e-NO_x)(Q)(RAS\%)(8.34) = 32 \text{ lb}/\text{day}$
Total-N: $M_{R-TN} = (C_e-TN)(Q)(RAS\%)(8.34) = 52 \text{ lb}/\text{day}$

Nitrogen components in MLSS recycle stream, with internal recycle (IR) at 400% of design flow

Ammonia-N: $M_{IR-NH_3} = (C_e-NH_3)(Q)(Recycle\%)(8.34) = 7 \text{ lb}/\text{day}$
Nitrate-N: $M_{IR-NO_x} = (C_e-NO_x)(Q)(Recycle\%)(8.34) = 86 \text{ lb}/\text{day}$
Total-N: $M_{IR-TN} = (C_e-TN)(Q)(Recycle\%)(8.34) = 140 \text{ lb}/\text{day}$

Nitrogen components in channel 1 influent:

Ammonia-N: $M_{i-NH_3} = M_{e-NH_3} + M_{R-NH_3} + M_{IR-NH_3} = 266 \text{ lb}/\text{day}$
Nitrate-N: $M_{i-NO_x} = M_{e-NO_x} + M_{R-NO_x} + M_{IR-NO_x} = 118 \text{ lb}/\text{day}$

Nitrogen Components in Reactor 1 Effluent:

Ammonia-N: $M_{1-NH_3} = M_{i-NH_3} - (M_{e-NH_3} - M_{e-NH_3})(f_{NH_3}) = 217 \text{ lb}/\text{day}$
Nitrate-N: $M_{1-NO_x} = (M_{i-NH_3} - M_{1-NH_3} + M_{i-NO_x})(1-f_{DN}) = 0 \text{ lb}/\text{day}$

Nitrogen Components in Reactor 2 Effluent:

$$\begin{aligned} \text{Ammonia-N: } M2\text{-NH3} &= M1\text{-NH3} - (M0\text{-NH3} - M0\text{-NH3})(fN2) = & 104 \text{ lb/day} \\ \text{Nitrate-N: } M2\text{-Nox} &= (M1\text{-NH3} - M2\text{-NH3} + N1\text{-NOx})(1-fD2) = & 39 \text{ lb/day} \end{aligned}$$

Nitrogen Components in Reactor 3 Effluent:

$$\begin{aligned} \text{Ammonia-N: } M3\text{-NH3} &= M2\text{-NH3} - (M0\text{-NH3} - M0\text{-NH3})(fN3) = & 5 \text{ lb/day} \\ \text{Nitrate-N: } M3\text{-NOx} &= (M2\text{-NH3} - M3\text{-NH3} + N2\text{-NOx})(1-fD3) = & 53 \text{ lb/day} \end{aligned}$$

Nitrogen Components in Clarifier Effluent:

$$\begin{aligned} \text{Ammonia-N: } M_{w\text{-NH3}} &= M_{w\text{-NH3}} - M_{R\text{-NH3}} = & 2 \text{ lb/day} \\ \text{Nitrate-N: } M_{e\text{-NOx}} &= M_{e\text{-NOx}} - M_{R\text{-NOx}} = & 21 \text{ lb/day} \\ \text{Effluent NH}_3\text{-N Concentration} &= (M_{w\text{-NH3}})(1000)/Q = & 0.3 \text{ mg/l} \\ \text{Effluent NO}_3\text{-N Concentration} &= (M_{e\text{-NOx}})(1000)/Q = & 3.5 \text{ mg/l} \end{aligned}$$

Denitrification oxygen credit:

$$\begin{aligned} &(\text{lb O}_2/\text{lb NO}_3\text{-N})(\text{lb TKN oxidized/d} - \text{lb effluent NO}_3\text{-N/day}) = \\ &(2.9)(258 - 21) = & 680 \text{ lb/day} \end{aligned}$$

4) Net oxygen demand, AOR:

$$\text{lb Carbonaceous O}_2/\text{d} + \text{lb Nitrogenous O}_2/\text{d} - \text{lb Denitrification Credit/day} = 1852 \text{ lb/day}$$

C) Determine Standard Oxygen Transfer Rate (SOTR) to be satisfied in Orbal

$$\text{SOTR} = \text{AOTR} / \text{FCF} \qquad \text{FCF} = A \times (B \times \text{ACF} \times C_s - \text{DO}) \times \text{TCF} / 9.092$$

$$\begin{aligned} \text{Alpha, } A &= 0.95 & \text{Beta, } B &= 0.98 \\ \text{Elevation} &= 770 \text{ feet} & \text{Altitude Correction Factor (ACF)} &= 0.972 \\ \text{Design water temperature} &= 68\text{F} & \text{Temperature Correction Factor (TCF)} &= 1.000 \\ \text{Saturation Concentration of Oxygen at Design Water Temperature, } C_s &= & &= 9.09 \text{ mg/l} \end{aligned}$$

DO = Dissolved oxygen concentration in each reactor, mg/l

	Channel			
	1	2	3	Total
AOR, lb/hr	15	34	28	77
DO, mg/l	0.0	0.5	2.0	
FCF	0.905	0.853	0.696	
SOR, lb/hr	17	40	40	97

1) Calculate disc quantity required per channel # of discs required = SOTR / SOTR/disc

	Channel			
	1	2	3	
Design disc immersion (in.)	14.0	14.0	14.0	
Design disc speed (rpm)	29	43	43	
Design SOTR/disc lb/hr/disc	0.48	1.18	1.18	Total
Disc Quantity	36	36	36	108

2) Disc aerator drive selection

- (2) 10.0 Hp aerator(s) on periphery of basin, each turning 18 discs
- (2) 30.0 Hp aerator(s) on periphery of basin, each turning 36 discs

3) Check for adequate oxygen reserve capacity

	Channel		
	1	2	3
Max. disc immersion (in.)	21.0	21.0	21.0
Max. disc speed (rpm)	45	55	55
Max. SOTR/disc lb/hr/disc	1.80	2.50	2.50

RESERVE SOTR CAPACITY

	All aerators in service	Largest aerator out
Maximum SOTR =	245 lb/hr	155 lb/hr
Reserve Over Design Load =	152%	80%

1) Calculate disc quantity required per channel # of discs required = SOTR / SOTR/disc

	Channel			
	1	2	3	
Design disc immersion (in.)	15.0	16.0	16.0	
Design disc speed (rpm)	29	43	43	
Design SOTR/disc lb/hr/disc	0.54	1.32	1.32	Total
Disc Quantity	36	36	36	108

2) Disc aerator drive selection

- (2) 10.0 Hp aerator(s) on periphery of basin, each turning 18 discs
- (2) 30.0 Hp aerator(s) on periphery of basin, each turning 36 discs

80 Hp

3) Check for adequate oxygen reserve capacity

	Channel		
	1	2	3
Max. disc immersion (in.)	21.0	21.0	21.0
Max. disc speed (rpm)	45	55	55
Max. SOTR/disc lb/hr/disc	1.80	2.50	2.50

Handwritten calculations:
 $1.8 \times 24 = 43.2 \frac{\text{lb O}_2}{\text{hr}}$
 $2.5 \times 24 = 60 \frac{\text{lb O}_2}{\text{hr}}$
 $2.5 \times 24 = 60 \frac{\text{lb O}_2}{\text{hr}}$

RESERVE SOTR CAPACITY

All aerators in service
 Maximum SOTR = 245 lb/hr
 Reserve Over Design Load = 115%

Largest aerator out
 155 lb/hr
 36%

Page 446 chapter 45


transfer rate = $\frac{2 \text{ lbs O}_2}{1 \text{ hp} \cdot \text{hr}}$

$$\frac{1 \text{ hp}}{2 \text{ lbs O}_2} = \frac{x \text{ hp}}{114 \text{ lb O}_2}$$

$$x = \frac{114 \text{ lb O}_2 \times 1 \text{ hp}}{2 \text{ lbs O}_2} = 57 \text{ hp}$$

Number of Channels in Orbal 3

APPROXIMATE MAXIMUM FUTURE FLOWS



SUGGESTED SIZING FOR INTERCHANNEL TRANSFER PORTS
(ports between outer, middle, and inner channels)

Maximum flow = 9.89 MGD = 5.02 MGD peak + 1.28 MGD RAS + 3.40 MGD SIM-PRE
Limit headloss to 0.50 inches at peak flow

Headloss Calculations: $h = 1.21 (Q/A)^2$

where:
h = headloss in inches
Q = flow in MGD
A = area in sq. ft.


Solving for A, we have:

$A = (1.21 Q^2 / h)^{1/2} = 15.07 \text{ sq. ft.}$

Recommended port opening size =

Actual hl at peak, inches = 0.444
Actual hl at peak, ft = 0.037

15.00 sq. ft. = 48 inch x 48 inch
Actual hl at average, inches = 0.144
Actual hl at average, ft = 0.012



SUGGESTED SIZING FOR EFFLUENT CONTROL STRUCTURE GATE

(gate between inner channel and effluent weirs)

Maximum flow = 6 290 MGD = 5.015 MGD peak + 1.275 MGD RAS
 Limit headloss to 1 inches at peak flow


Headloss Calculations: $h = 1.21 (Q/A)^2$

Where: h = headloss in inches
 Q = flow in MGD
 A = area in sq. ft.

Solving for A, we have:

$A = (1.21Q^2/h)^{1/2} = 6.919 \text{ sq. ft.}$

Recommended port opening size = 7.111 sq. ft. = 32 inch x 32 inch
 Actual hl at peak, inches = 0.947
 Actual hl at ave., ft = 0.079
 Actual hl at average, inches = 0.1081
 Actual hl at average, ft = 0.009



HYDRAULIC CALCULATIONS FOR ORBAL SYSTEM

SUGGESTED SIZING FOR EFFLUENT WEIRS

Maximum flow = 6 290 MGD = 5.015 MGD peak + 1.275 MGD RAS
 Limit headloss to 3 inches at peak flow with adjustable gate at 100% closed

Headloss Calculations: $h = (18.96Q/L)^{2/3}$

Where: h = headloss in inches
 Q = flow in MGD
 L = length of weir in feet

Solving for L, we have:

$(18.96Q/h^{3/2}) = 23.0 \text{ feet}$


Recommended high weir length = 23 feet
 Actual hl at peak, inches = 2.986
 Actual hl at peak, ft = 0.250

Minimum recommended low weir length = 5.157 feet

Actual low weir length, feet = 6 feet
 Actual hl at peak, inches = 7.338 inches
 Actual hl at peak, ft = 0.611 feet

Maximum disc immersion = 21"
 Minimum disc immersion = 9"
 disc radius = 27"

Section view of Center Island Weirs



- Top of high level weir plate should

be placed: $6" + \frac{(18.96Q/h^{3/2})}{12} = 6" + \frac{23.0}{12} = 9.58"$
 below the centerline
 of the shaft. Top of concrete weir support should be placed 3" below the high weir plate.

- Top of low level weir plate

should be placed 18" below the center line of the shaft. Top of concrete weir support to be 21" below the centerline of the shaft.

With high level weir at 0.8236 feet below shaft centerline, max. disc immersion at average flow = 18.68 inches

If chamber between low weir and gate has a cross-sectional area = 2 sq. ft. average velocity = 0.658 fps
 peak velocity = 3.88 fps

Doc J

Final Clarifier

Check Clarifier Capacity

Avg Annual Flow (2003 was max) = .64 mgd

Acc. for additions

133 homes (3 people) (100) = .039,900 mgd

Total Peak hourly : (.64 + .039900) (3,44) = 2.34 MGD

10 state stas :

A • Surface overflow rate : 1000 gpd/ft²

B • Peak solids loading : 35 lb/day/ft²

A. Surface overflow : $\frac{\pi d^2}{4} = \frac{\pi (55)^2}{4} = 2376 \text{ ft}^2$

$2376 \times 1000 = 2,375,829 \text{ gpd} = 2.375 \text{ MGD}$

2.375 > 2.34 ok

B. Solids Loading :

MLSS = 4041 per calcs, ∴ use 4500 mg/L

$4500 \times 0.73 \times 25 \text{ mgd} \times 8.34 = 31,900 \text{ lb/day} = 27396.9$

$\frac{27396.9}{2376} = 11.53$
 $\frac{31900}{2376} = 13.4 \text{ lb/day/ft}^2 < 35 \text{ ok}$