

EPA Identification Number	NPDES Permit Number AR0021717	Facility Name Flippin WWTF	Outfall Number
---------------------------	----------------------------------	-------------------------------	----------------

Form Approved 03/05/19  
OMB No. 2040-0004

**TABLE B. EFFLUENT PARAMETERS FOR ALL POTWS WITH A FLOW EQUAL TO OR GREATER THAN 0.1 MGD**

Pollutant	Maximum Daily Discharge		Average Daily Discharge			Analytical Method <sup>1</sup>	ML or MDL (include units)
	Value	Units	Value	Units	Number of Samples		
Ammonia (as N)	39.72	mg/L	15.14	mg/L	18		<input type="checkbox"/> ML <input type="checkbox"/> MDL
Chlorine (total residual, TRC) <sup>2</sup>	N/A	N/A	N/A	N/A			<input type="checkbox"/> ML <input type="checkbox"/> MDL
Dissolved oxygen	8.62	mg/L	7.14	mg/L	9		<input type="checkbox"/> ML <input type="checkbox"/> MDL
Nitrate/nitrite	7.42	mg/L	3.4	mg/L	3		<input type="checkbox"/> ML <input type="checkbox"/> MDL
Kjeldahl nitrogen	22	mg/L	15.03	mg/L	3		<input type="checkbox"/> ML <input type="checkbox"/> MDL
Oil and grease	<5	mg/L	<5	mg/L	3		<input type="checkbox"/> ML <input type="checkbox"/> MDL
Phosphorus	2.71	mg/L	2.13	mg/L	3		<input type="checkbox"/> ML <input type="checkbox"/> MDL
Total dissolved solids	369	mg/L	295.33	mg/L	3		<input type="checkbox"/> ML <input type="checkbox"/> MDL

<sup>1</sup> Sampling shall be conducted according to sufficiently sensitive test procedures (i.e., methods) approved under 40 CFR 136 for the analysis of pollutants or pollutant parameters or required under 40 CFR chapter I, subchapter N or O. See instructions and 40 CFR 122.21(e)(3).

<sup>2</sup> Facilities that do not use chlorine for disinfection, do not use chlorine elsewhere in the treatment process, and have no reasonable potential to discharge chlorine in their effluent are not required to report data for chlorine.