

Permit No. AR0021717
Facility Name: FLIPPIN
Date: 06/21/07
Engineer: Marysia Jastrzebski

Previous permit: effective date: 09/01/02
modification date:
expiration date: 08/31/07

Address: Mayor Mary Jane Eakin
222 East Ind. Drive
Flippin, AR 72634
PO Box 40
AR 72634

Changed Yes No
870-453-8300

Narrative Description:
similar

Changed Yes No

Coordinates: confirmed 07/22/07
Facility: PDS: 36°16'56" Outfall: 36°17'00"
appl. 36°18'00" 92°35'10" Appl: 36°17'00" 92°35'10"
WRONG OW

Changed Yes No
facility coordinates

Receiving Stream:
Fallen Ash Creek → White Creek

Changed Yes No

Segment: 41

Changed Yes No

AWQMP: 305(b): Permit:

Uses: primary & secondary more than 10 sq. miles

Changed Yes No

AWQMP summary:
10115/217.6
10115/9/9.2

Changed Yes No

Design flow: 0.175
See e-mail from HDT dated 03/29/07

Limits: same + FCB (primary & secondary)

Changed Yes No

Treatment system:
screen, grit removal, oxidation ditch, clarifier, ISF,
UV DISINF, POST-AERATION

Changed Yes No

Codes:

Biomonitoring:

Changed ___ Yes ___ No

N/A

See e-mail dated _____ from _____

Toxics:

Changed ___ Yes ___ No

N/A

Minerals:

Changed ___ Yes ___ No

N/A

Frequency of sampling, type:

Changed ___ Yes ___ No

flow - 5/week
all - 2/month

Technology limits?:

Changed ___ Yes No

DMR data summary/violations:

FCB - 1 - 146 col/100 ml
CBOD5 - 0.7 - 2.56 mg/L
NH3-N - 0.1 - 1.37 mg/L
DO - OK
pH - OK
TSS - max MA 3.98 mg/L

Enforcement actions?:

NONE

Sludge:

Changed ___ Yes ___ No

→ landfill Norbars Sanitation

See e-mail from _____ dated _____

Changes to the permit:

Changed Yes

No

- 1) Tracking address added
- 2) Facility coordinates changed
- 3) Sampling locations added
- 4) DO
- 5) PH
- 6) Feb for primary contact notes
- 7) 7-day avg ~~Aug~~ ^{is} 7-day avg May Oct
- 8) NH 3-N ~~Apr~~ ^{is} 7-day avg
- 9) TSS 7-day Avg

Phone calls, letters, e-mails, corrections, contacts, etc:

001 :
 36° 17' 00"
 92° 35' 09"
 Source
 flow
 36° 16' 59"
 92° 35' 06"

Facility
 36° 16' 56"
 92° 35' 03"

Summa

Aske

(O

altav : 36° 17' 00"
 92° 35' 07"

001 = 36° 17' 00" , 92° 35' 10" = ~~PERMIT~~ / MPZ.
 sampling (flow) 36° 16' 59" , 92° 35' 06"
 " (all other parameters) 36° 17' 00" 92° 35' 07"