

**Jastrzebski, Marysia**

---

**From:** Cotter, Amy  
**Sent:** Thursday, March 29, 2007 10:23 AM  
**To:** Jastrzebski, Marysia  
**Subject:** RE: City of Flippin

M,  
 The modeled limits seem to be overly conservative. If the facility is having trouble, let me know and we can work something out. Thanks.

-AB

-----Original Message-----  
**From:** Jastrzebski, Marysia  
**Sent:** Wednesday, March 28, 2007 12:26 PM  
**To:** Cotter, Amy  
**Subject:** City of Flippin

Hello Amy,

Below is a request for the effluent limits for the City of Flippin. **Please note that AWQMP shows design flow of 0.4 mgd, while all previous permits and the recent application show design flow of 0.175 mgd. Could you please revise the plan?)**

thanks,

m

**ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY**

**MEMORANDUM**

**TO:** Amy Cotter, Engineer  
**FROM:** Marysia Jastrzebski, P.E. , Engineer  
**DATE:** March 28, 2007  
**SUBJECT:** Update Effluent Limits

-----  
 Name of facility: City of Flippin

NPDES Permit No. AR0021717

NPDES Permit Expiration Date: 08/31/07

Are there any changes from previously permit? Yes \_\_\_\_\_ NO  
 \_\_\_\_\_X\_\_\_\_\_

The following **Effluent Limits** and the **receiving stream** exist in WQMP, please confirm the

accuracy:

**Effluent Limits:** (CBOD5/TSS/NH3-N/DO) (May-Oct.)10/15/2/7.6

(CBOD5/TSS/NH3-N/DO) (Nov.-Apr.) 10/15/9/9.2

**Q = 0.175 MGD ( please note that AWQMP shows design flow of 0.4 mgd, all previous permits and application show design flow of 0.175 mgd. Could you please revise the plan?)**

**The receiving stream is:** Fallen Ash Creek, thence into the White River

**Outfall Coordinates:** Latitude: 36 deg 17' 00" Longitude: 92 deg 35' 10"

**County:** Marion

**Planning Segment:** 4I

**Previous permit 7Q10:** \_\_\_\_\_ 0 \_\_\_\_\_

---

**From:** Amy Cotter  
**TO:** Marysia Jastrzebski, P.E.

7Q10 = \_\_\_\_\_ 0 \_\_\_\_\_ cfs  
less than 10 square miles \_\_\_\_\_  
more than 10 square miles \_\_\_\_\_ x \_\_\_\_\_  
May affect water of another State \_\_\_\_\_ Yes \_\_\_x\_\_\_ No

Justification Renew as is. AB 3/29/07