Date of review: 7/2/2020 Reviewer: DEH

Comment: Under a CAP for SSOs. Has had 84 SSOs in the last three years.

ENFORCEMENT COMPLIANCE REVIEW

NPDES Permit No. AR0034037

City of Yellville

1. Effluent Violations:

DMR End Date	Disch- Desig	Parameter Desc	Reported DMR Value	Limit Value	Vio %
03/31/2018	001-A	BOD, carbonaceous [5 day, 20 C] (7 DA AVG, mg/L)	23	15	53%
02/28/2019	001-A	Nitrite + Nitrate total [as N] (MO AVG, lb/d)	1100.76	62.6	1,658%
02/28/2019	001-A	Nitrite + Nitrate total [as N] (MO AVG, mg/L)	184.23	10	1,742%
02/28/2019	001-A	Nitrite + Nitrate total [as N] (7 DA AVG, mg/L)	438	15	2,820%
01/31/2020	001-A	BOD, carbonaceous [5 day, 20 C] (7 DA AVG, mg/L)	24.3	15	62%

- 2. How many times in the past 3 years has the Permittee reported No-Discharge? 0
- 3. How many times in the past 3 years has the Facility reported flow greater than their Design Flow? 19
- 4. How many times in the past 3 years has the Facility reported No Data Indicator (NODI) codes (other than "C") on their DMRs? 0
- 5. Has the Facility submitted adequate Non-Compliance Reports for all effluent violations? Yes
 - Did the Facility correct the problem? Yes
- 6. Is the Facility on the Significant Non Compliance Reduction List? No
- 7. Did we take any action to resolve the above violations? No
- 8. A CAP was requested on <u>January 22, 2018</u> for the following reasons: Sanitary Sewer Overflows

- 9. Number of reported Bypasses/Unpermitted Discharges/SSOs (if applicable) over the past three years: 84
 - a. Of those Unpermitted Discharges, how many greater than 1,000 gallons?
- 10. The Facility has not had a CAO/NOV/DAO issued.
- 11. A non-compliance letter(s) was sent to the Facility regarding effluent violations/DMR non-receipts/Deficient DMR/Fees/Deficient non-compliance reports. No
- 12. How many violations for late DMRs or DMR non-receipts are there? **0**
- 13. What corrective actions were taken for item above and are they in compliance now? N/A
- 14. The facility **has** met the compliance schedule with the permit for the following reports: compliance with effluent limitations in the permit
- 15. Was the permit renewal application timely submitted? Yes
- 16. Does the Facility currently employ an appropriately licensed Operator? Yes
- 17. The date of the last inspection for this facility was: March 27, 2019 Are there any inspection violations Permits needs to be aware of? PetAg was dumping goat milk down the manholes.
- 18. Permit fees **are** current.
- 19. Has a NetDMR account been set up for the Facility's DMR data submittals? Yes
- 20. Based on information above are you able to solve compliance issue prior to issuance of the permit? Yes
- 21. Other helpful information