

**Jastrzebski, Marysia**

---

**To:** Clem, Sarah

**Subject:** City of Yellville - discharge to 303d stream - FYI

Sarah,

This is language I proposed in SoB:

**"303(d) LIST AND ENDANGERED SPECIES CONSIDERATIONS.****a. 303(d) List:**

The receiving stream is listed on the 2008 303(d) list in Category 5a as impaired for Total Dissolved Solids (TDS) and Temperature. No TMDL is available at this time and low priority has been assigned to this corrective action. Since the source for Temperature impairment is listed as a resource extraction (mining) no permit action is required. The source for TDS impairment is shown to be unknown. It is the best engineering judgment of the permit writer that the discharge from the City of Yellville does not cause or contribute to this impairment. Therefore, no permitting action is required.

A reopener clause is established in Part II of the permit, which allows the permit to be modified, if necessary, to include more stringent limits, if necessary, based on final loading allocations in the completed and approved TMDL."

Thanks,

m

*Marysia Jastrzebski, P. E.*

NPDES Permit Engineer, Water Division

Arkansas Department of Environmental Quality

Voice: 870-446-5939

Fax: 870-446-2181

E-mail: [marysia@adeq.state.ar.us](mailto:marysia@adeq.state.ar.us)