

Archived: Tuesday, November 7, 2023 11:16:03 AM

From: Guy Lester (adpce.ad)

Sent: Friday, November 3, 2023 3:20:00 PM

To: cwalden@greatriv.com

Cc: rgraham53@cox.net; Jessica Sears (adpce.ad)

Subject: RE: AR0034088 - Generator

Importance: Normal

It should be noted that it will be sufficient to certify that you have access to another generator to operate the facility. If you have access to a second generator, it will not be necessary to purchase another one.

Guy Lester, P.E. | Permit Engineer

Division of Environmental Quality | Office of Water Quality

NPDES Permits Section

5301 Northshore Drive | North Little Rock, AR 72118

t: 501.519.0304 | e: Guy.Lester@adeq.state.ar.us



ARKANSAS
ENERGY & ENVIRONMENT

From: Guy Lester (adpce.ad)

Sent: Friday, November 3, 2023 3:00 PM

To: cwalden@greatriv.com <cwalden@greatriv.com>

Cc: rgraham53@cox.net <rgraham53@cox.net>; Jessica Sears (adpce.ad) <Jessica.Sears@adeq.state.ar.us>

Subject: AR0034088 - Generator

The renewal application notes that there is a backup generator at the pump station, but not at the facility itself.

Part II.B.7 of the permit states: "The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failure either by means of alternate power sources, standby generators, or retention of inadequately treated effluent."

A backup generator for the facility is required. Please obtain one as soon as possible. Please notify me with a letter certifying that you have obtained a generator when you have it. The letter should include the size of the generator, a statement that it is adequate to operate the facility, be signed by the Responsible Official, Ronald Graham, and include the following certification statement:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Please call me if you have any questions.

Guy Lester, P.E. | Permit Engineer

Division of Environmental Quality | Office of Water Quality

NPDES Permits Section

5301 Northshore Drive | North Little Rock, AR 72118

t: 501.519.0304 | e: Guy.Lester@adeq.state.ar.us



ARKANSAS
ENERGY & ENVIRONMENT