



**DIVISION OF
ENVIRONMENTAL QUALITY**

Sarah Huckabee Sanders
GOVERNOR

Shane E. Khoury
SECRETARY

June 27, 2023

Taylor White, Project Manager
McClelland Consulting Engineers, Inc.
7302 Kanis Rd.
Little Rock, AR 72204

RE: New Bar Screen at Arkansas Department of Corrections - North Central Unit
NPDES Permit No. AR0044016; AFIN: 33-00036

Dear Mr. White:

The Division of Environmental Quality (DEQ) has reviewed your email dated June 16, 2023 regarding the proposed new bar screen project at the subject facility. DEQ has determined that a modification of the NPDES permit is not required. However, DEQ has determined that a state construction permit from DEQ is required to be issued prior to construction/installation of the bar screen. An approval letter from Arkansas Department of Health is required in accordance with Rule 6.202(D) prior to DEQ issuing the construction permit.

When submitting a state construction permit application, please ensure that the application includes a complete set of engineering plans stamped by a professional engineer registered in Arkansas that indicates compliance with section 61 of the 2014 edition of *Recommended Standards for Wastewater Facilities* (10 State Standards).

If you have any questions, you can reach us at the contact information listed below.

Sincerely,

Handwritten signature of Shane Byrum in black ink.

Shane Byrum
Staff Engineer
Division of Environmental Quality
Office of Water Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317
(501) 682-0618
E-mail: shane.byrum@adeq.state.ar.us

Handwritten signature of Zachary Carroll in black ink.

Zachary Carroll, P.E.
Engineer Supervisor
Division of Environmental Quality
Office of Water Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317
(501) 682-0625
Email: zachary.carroll@adeq.state.ar.us

CC: Bryan Leamons, P.E., Senior Operations Manager, Office of Water Quality
Taylor White (twhite@mce.us.com)
Adam Triche, P.E. (atriche@mce.us.com)