

ADEQ

ARKANSAS
Department of Environmental Quality

February 10, 2012

Jon R. Harrison, General Manager
9201 Faulkner Lake Road
North Little Rock, AR 72117

Re: 2011 Annual Report & DMR Submittal – Benchmark Exceedances
Permit No. **AR0051454**, AFIN **60-01529**

Dear Mr. Harrison,

The 2011 Discharge Monitoring Reports (DMRs) for the above-referenced facility were received 1/31/12. The following is a list of pollutants in which the facility has exceeded the benchmark values set for the stormwater runoff:


<u>Pollutant</u>	<u>Reported Value(mg/l)</u>	<u>Benchmark Value (mg/l)</u>	<u>Outfall</u>
pH	9.3	6.0-9.0 S.U.	002
pH	9.6	6.0-9.0 S.U.	006
TSS	1092	100	007

There are no effluent limitations in this permit. The purpose of the permit is to encourage the permittee to find Best Management Practices (BMP's) that can be implemented without being mandated. By relaying this information, the Department hopes to significantly reduce the overall pollutant concentrations. Please follow the response to monitoring results above parameter benchmark values outlined in Part 2.2 of AR0051454.

The 2011 Annual Report required by Part 2.3 of the permit was received on 1/31/12. The annual report has been reviewed and determined to be in compliance with the applicable permit requirements.

If you have any questions concerning this matter or need additional information, please feel free to contact the General Permits Section at (501) 682-0623.

Sincerely,



Katherine A. Yarberry, EI
Engineer, General Permits Section
Water Division

cc: Electronic Files (Permit No. **AR0051454**, AFIN **60-01529**)
David Ramsey, ICIS Program Coordinator, Enforcement Branch
Craig Uyeda, Branch Manager, Enforcement Branch