

Department of Environmental Quality

April 8, 2014

Jon R. Harrison, General Manager North American Motor Grader Facility 9201 Faulkner Lake Road North Little Rock, AR 72117

Re: 2013 Annual Report & DMR Submittal

North American Motor Grader Facility, North Little Rock, AR

Permit No. AR0051454, AFIN 60-01529

Dear Mr. Harrison,

The 2013 Annual Report and Discharge Monitoring Reports (DMRs) for the above-referenced facility were received 1/17/2014. The Annual Report has been determined to be in compliance with the applicable permit requirements. The following is a list of pollutants for which the facility has exceeded the benchmark values set for the stormwater runoff:

Pollutant	Reported Value(mg/l)	Benchmark Value (mg/l)	<u>Outfall</u>	<u>Period</u>
Oil & Grease	80	15	001	Jan- June
Oil & Grease	1618.9	15	004	Jan- June

This permit was terminated on 1/27/2014.

If you have any questions concerning this matter or need additional information, please feel free to contact the General Permits Section at (501) 682-0623.

Sincerely,

Jessica Temple, EI

Engineer, General Permits Section

micelenge

Water Division

cc: Electronic Files (AR0051454, AFIN 60-01529)

David Ramsey, ICIS Program Coordinator, Enforcement Branch