

ck: 22322507

BAFETA

**ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
NOTICE OF INTENT
NON-CONTACT COOLING WATER, COOLING TOWER AND BOILER BLOW DOWN
NPDES GENERAL PERMIT ARG250000**

25124

Application Type: New ☐ Renewal ☒ Permit # ARG250010
AFIN# 23-00093

I. PERMITTEE/OPERATOR INFORMATION

Permittee (Legal Name): Kimberly-Clark Corporation Operator Type:
Permittee Mailing Address: 351 Phelps Dr. ☐ State ☐ Partnership
Permittee City: Irving ☐ Federal ☒ Corporation*
Permittee State: TX Zip: 75038 ☐ Sole Proprietorship/Private
Permittee Telephone Number: 972-281-1200 *State of Incorporation: DE
Permittee Fax Number: N/A The legal name of the Permittee must be
Permittee E-mail Address: N/A identical to the name listed with the
Arkansas Secretary of State.

II. INVOICE MAILING INFORMATION

Invoice Contact Person: Patrick Brodsky City: Conway
Invoice Mailing Company: Kimberly-Clark Corporation State: AR Zip: 72032
Invoice Mailing Address: 480 Exchange Ave Telephone: 501-336-6298

III. FACILITY INFORMATION

Facility Name: Kimberly-Clark Conway Facility Facility Contact Person: Patrick Brodsky
Facility Address: 480 Exchange Ave Contact Title: Env. Coordinator
Facility County: Faulkner Contact Telephone Number: 501-336-6298
Facility City, State & Zip: Conway, AR 72032 Contact E-mail: pbrodsky@kcc.com
Facility SIC Code: 2676 Facility NAICS Code: 322291 Type of Business: Sanitary Paper Manufacturing
Facility Latitude: 35 Deg 4 Min 19.89 Sec Facility Longitude: -92 Deg 25 Min 12.16 Sec
NAD
Accuracy: 1 Method: 6 Datum: 83 Scale: N/A Description: 01099
Section: 17 Township: 5 Range: 13

IV. DISCHARGE INFORMATION

Outfall Number: 002a Flow: 400 gpd (Gallons per Day)
Stream Segment: 3D Hydrologic Basin Code: 1110206
Outfall Latitude: 35Deg 4 Min 24.45 Sec Outfall Longitude: -92 Deg 25 Min 11.95 Sec
NAD
Accuracy: 5 Method: GPS Datum: 83 Scale: N/A Description: Mon. Pt.
Type of Treatment: Mechanical - No Additives
Receiving Stream: Arkansas River

WATER DIVISION
5301 NORTHSORE DRIVE / NORTH LITTLE ROCK, ARKANSAS 72118
PHONE 501-682-0623 / FAX 501-682-0880

www.adeq.state.ar.us

V. FACILITY PERMIT INFORMATION

NPDES Individual Permit Number (If Applicable): AR00 N/A
NPDES General Permit Number (If Applicable): ARR00A291
State Construction Permit Number(If Applicable): N/A
NPDES General Construction Stormwater Permit Number (If Applicable): ARR15 N/A

VI. OTHER INFORMATION:

Additional Location Description None

Additional Comments: Discharge points 002b, 002c, and 002d identified in the previous permit currently do not use additives for treatment and discharge to the sanitary sewer. Therefore, they are not included in this permit renewal.

Consultant Contact Name: N/A

Consultant Email Address: _____

Consultant Address: _____ City: _____ State: _____ Zip: _____

Consultant Phone Number: _____ Consultant Fax Number: _____

Disclosure Statements:

Arkansas Code Annotated Section 8-1-106 requires that all applicants for the issuance or transfer of any permit, license, certification or operational authority issued by the Arkansas Department of Environmental Quality (ADEQ) file a disclosure statement with their applications. The filing of a disclosure statement is mandatory. No application can be considered complete without one. You must submit a new disclosure statement even if you have one on file with the Department. The form may be obtained from ADEQ web site at: http://www.adeq.state.ar.us/disclosure_stmt.pdf.

VII. EFFLUENT CHARACTERISTICS:

A. **Existing Source-** Provide measurements for the parameters listed in the table below.

B. **New Discharges-** Provide estimates for the parameters listed in the table below.

Type	Analyses						Additives * Yes/No
	Flow, MGD	COD, mg/l	TSS, mg/l	Temperature, ° F	O & G, mg/l	pH, s.u.	
Non-Contact Cooling Water	0	0	0	N/A	0	N/A	N/A
Cooling Tower Blowdown	0.004	26	3	77	3	8.5	No
Boiler Blowdown	0	0	0	N/A	0	N/A	N/A

* Enclose MSDS Sheets for Additives *

November 7, 2012

Arkansas Department of Environmental Quality
Permits Branch, Water Division
5301 Northshore Drive
North Little Rock, AR 72118

Subject: (AFIN: 23-00093) Renewal NOI for Cooling Tower Discharge to Stormwater


To Whom It May Concern:

Enclosed is a Renewal Notice of Intent (NOI) for coverage of cooling tower blowdown and non-contact cooling water discharge under General Permit Number ARG250010 for Kimberly-Clark's Conway Facility located in Conway, Arkansas. The Conway Facility is currently covered under general industrial stormwater permit number ARR00A291. Per the NOI instructions a permit fee of \$200 accompanies this NOI.

A diagram of the facility is included showing the flow of all stormwater and the covered cooling tower blowdown. The cooling tower is located to the east of the manufacturing building. Blowdown and non-contact cooling water is discharged to the stormwater drainage system at storm sewer #5. This combines with other stormwater flow and exits the site at outfall #2 located at the southeast edge of the site. No additives are currently used for treatment of the cooling tower water and non-contact cooling water.

Please process these documents at your earliest convenience. If you have any questions regarding this matter please contact Patrick Brodsky the facility environmental coordinator at the numbers shown below. Thank you for your assistance.

Sincerely,



Kevin R. Ward
Facility Manager

Contact Person:

Patrick Brodsky – Environmental Coordinator
Ph: (501) 336-6298
Cell: (501) 269-8278
Fax: (920) 225-4039
Email: pbrodsky@kcc.com

c: Roswell E&E



ARKANSAS SECRETARY OF STATE

Mark Martin

Search Incorporations, Cooperatives, Banks and Insurance Companies

[Printer Friendly Version](#)

LLC Member information is now confidential per Act 865 of 2007

Use your browser's back button to return to the Search Results

[Begin New Search](#)

For service of process contact the [Secretary of State's office](#).

Corporation Name	KIMBERLY-CLARK CORPORATION
Fictitious Names	
Filing #	100062330
Filing Type	Foreign For Profit Corporation
Filed under Act	For Bus Corp; 958 of 1987
Status	Good Standing
Principal Address	LITTLE ROCK, AR (20,000,000 PREF NPV X, AR
Reg. Agent	THE CORPORATION COMPANY
Agent Address	124 WEST CAPITOL AVENUE SUITE 1900 LITTLE ROCK, AR 72201
Date Filed	11/15/1968
Officers	SEE FILE, Incorporator/Organizer SEE FILE, President RICHARD A BEAUVAIS , Controller
Foreign Name	N/A
Foreign Address	NORTH LAKE STREET NEENAH,
State of Origin	DE
<u>Purchase a Certificate of Good Standing for this Entity</u>	<u>Pay Franchise Tax for this corporation</u>

FACILITY ENTRANCE
COORDINATES
35°-04'-21.3" NORTH LATITUDE
-92°-25'-15.7" WEST LONGITUDE

KIMBERLY-CLARK CORP. CONWAY FACILITY

STORMWATER & WASTEWATER
DRAINAGE & OUTDOOR STORAGE
C222-L-80

ITEM	SAMPLING LOCATIONS	ITEM	AREA IDENTIFICATION
A	OUTFALL #1 - CULVERT AT COMPACTOR BOX STAGING	1	PROJECT EQUIPMENT & MATERIALS
B	OUTFALL #2 - FACILITY MAIN STORMWATER DISCHARGE	2	CLOSED TOP WASTE COMPACTOR & TRUCK RECEIVING DOCK
C	TWR WATER SAMPLE POINT	3	OPEN TOP TRASH DUMPSTERS
		4	CLOSED TOP WASTE COMPACTOR & TRUCK RECEIVING DOCK
-	-	5	PAVED TRAILER STAGING AREA
-	-	6	OUTDOOR COMPACTOR & OPEN TOP TRASH DUMPSTER
		7	POLYETHYLENE PELLET STORAGE SILO
		8	TRUCK RECEIVING AREA
		9	RAIL SPUR LOAD/UNLOAD AREA - COVERED
		10	COMPACTOR BOX STAGING ON GRAVEL
		11	COVERED COMPACTOR & TRUCK RECEIVING AREA & WASTE OIL PUMPOUT STATION
		12	CHEMICAL UNLOADING
		13	COVERED TRUCK RECEIVING
		14	EMISSIONS
		15	CHEMICAL LOADING/UNLOADING
		16	WASTE COLLECTION - OPEN TOP DUMPSTER
		17	COOLING TOWERS
		18	PUMP OUT STATION FROM TRACTOR SHOP
		19	TRANSFORMER CONTAINMENT PUMP OUT
		20	FIRE LOOP WATER TANK & DIESEL PUMP HOUSE

