

ARG250000 Recertification Notice of Intent for Non-contact Cooling Water, Cooling Tower Blowdown, and Boiler Blowdown

version 2.14

(Submission #: HPP-1SE7-4WJBJ, version 2)

Digitally signed by:
nform
DPEPORTALIIS.ADPCEDMZ.state.ar.us
Date: 2022.12.08 10:21:15 -06:00
Reason: Copy Of Record
Location: North Little Rock, Arkansas



Details

AFIN 23-00117
Reference # ARG250018
Submission ID HPP-1SE7-4WJBJ
Submission Reason Renewal

Form Input

Section 1: Review Existing Facility/Contact Information

Facility/Contact Information

For the purpose of this permit, ♦Permittee♦ means any person (any state agency, municipality, governmental subdivision of the state or the United States, public or private corporation, individual, partnership, association, or other entity) who has the primary management and decision-making responsibility over a permitted operation, facility, or activity. The permittee is responsible for ensuring compliance with all applicable environmental regulations and conditions. The permittee is the entity named as such on an individual permit or the entity covered by a general permit.

If the permittee is a corporation, the permittee legal name has to be an identical match with the Arkansas Secretary of State. Below is a link to verify the legal name:

[Arkansas Secretary of State Business Entity Search Website](#)

Permit Number

ARG250018

AFIN

23-00117

Permittee Legal Name

University of Central Arkansas

Facility Name

University of Central Arkansas

Facility Address

201 Donaghey Ave, Conway, AR 72035

Contact Person

Michelle Ellington, Director of Sustainability

Contact email

mellington@uca.edu

Contact Phone Number

501-450-3610

Invoice Address

MICHELLE ELLINGTON, UNIVERSITY OF CENTRAL ARKANSAS, 201 DONAGHEY AVE, CONWAY AR 72035

Is the above facility/contact information correct?

No

What information needs to be corrected?

Contact information/mailling address

Contact information/mailling address corrections**Prefix**

NONE PROVIDED

First Name Last Name

Nelson Landers

Title

Assistant Director of Facilities

Phone Type Number Extension

Business 5018522323

Email

nlanders@uca.edu

Address

201 Donaghey Ave

Conway, AR 72035

Section 2: Review Outfall Information**First Outfall**

Outfall 001: 35.083625, -92.461813 (35 05' 1.049"N, 92 27' 42.52"W)

Second Outfall (if applicable)

Outfall 002: 35.083625, -92.461813 (35 05' 1.049"N, 92 27' 42.52"W)

Third Outfall (if applicable)

Outfall 003: 35.082316, -92.459352 (35 04' 56.33"N, 92 27' 33.66"W)

Additional Outfalls

Outfall 004: 35.080339, -92.458394 (Latitude 35 04' 49.22"N Longitude 92 27' 30.22"W)

Outfall 005: 35.080347, -92.458297 (Latitude 35 04' 49.25"N Longitude 92 27' 29.87"W)

Outfall 006: 35.080189, -92.457333 (Latitude 35 04' 48.68"N Longitude 92 27' 26.40"W)

Outfall 008: 35.080564, -92.457147 (Latitude 35 04' 50.03"N Longitude 92 27' 25.73"W)

Outfall 009: 35.079381, -92.461472 (Latitude 35 04' 45.77"N Longitude 92 27' 41.30"W)

Outfall 010: 35.079367, -92.461197 (Latitude 35 04' 45.72"N Longitude 92 27' 40.31"W)

Outfall 011: 35.078861, -92.458914 (Latitude 35 04' 43.90"N Longitude 92 27' 32.09"W)

Outfall 012: 35.079478, -92.457403 (Latitude 35 04' 46.12"N Longitude 92 27' 26.65"W)

Outfall 013: 35.078928, -92.455786 (Latitude 35 04' 44.41"N Longitude 92 27' 20.83"W)

Outfall 014: 35.078094, -92.461842 (Latitude 35 04' 41.14"N Longitude 92 27' 42.63"W)

Outfall 015: 35.077625, -92.457806 (Latitude 35 04' 39.45"N Longitude 92 27' 28.10"W)

Outfall 016: 35.077642, -92.455944 (Latitude 35 04' 39.51"N Longitude 92 27' 21.40"W)

Outfall 017: 35.076789, -92.458361 (Latitude 35 04' 36.44"N Longitude 92 27' 30.10"W)

Outfall 018: 35.074617, -92.455667 (Latitude 35 04' 28.62"N Longitude 92 27' 20.40"W)

Is the above outfall information correct?

Yes

Section 3: Review Approved Additives

As part of this recertification, OWQ is establishing a list of approved cooling water and boiling water additives for each facility. OWQ staff have reviewed archived documents for your facility and determined that, AT MINIMUM, the below listed additives

Current Additives in DEQ Database

3DT230, 100-120 ppm
ST-70, 0.2-0.5 ppm
H-550, 150 ppm

Is the Above List of Additives Correct?

Yes

Section 4: Permittee Information & Disclosure Statement

Permittee Type

State or County

Section 5: Signatory Requirements

Cognizant Official (Duly Authorized Representative)

40 CFR 122.22(b) states that all reports required by the permit, or other information requested by the Director, shall be signed by the applicant (or person authorized by the applicant) or by a duly authorized representative of that person. A person is a duly authorized representative only if:

- (1) the authorization is made in writing by the applicant (or person authorized by the applicant);
- (2) the authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity responsibility, or an individual or position having overall responsibility for environmental matters for the company.

Cognizant Official

Larry Lawrence, Physical Plant Director

Cognizant Official Email

larryl@uca.edu

Responsible Official

The information contained in this form must be certified by a responsible official as defined in the ♦ signatory requirements for permit applications♦ (40 CFR 122.22).

Responsible official is defined as follows:

For a corporation: By a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:

- (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or
- (ii) the manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

For a partnership or sole proprietorship: By a general partner or the proprietor, respectively.

For a municipality, State, Federal, or other public agency: By either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes:

- (i) The chief executive officer of the agency, or
- (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of EPA).

Responsible Official

Michelle Ellington, Director of Energy and Sustainability

Responsible Official Email

mellington@uca.edu

Responsible Official Phone Number

(501) 450-3610

Is the above Responsible and Cognizant Official information correct?

Which Signatories Need to be Updated?

Cognizant Official (duly authorized representative)

Responsible Official

Updated Cognizant Official information

Prefix

NONE PROVIDED

First Name Last Name

Nelson Landers

Title

Assistant Director of Facilities

Phone Type Number Extension

Mobile 5016584854

Email

nlanders@uca.edu

Updated Responsible Official Information

Prefix

NONE PROVIDED

First Name Last Name

Kevin Carter

Title

Associate Vice President for Facilities

Phone Type Number Extension

Business 5014280505

Email

nlanders@uca.edu

CORRECTION REQUEST (CORRECTED)

Responsible official needs to be a Principal Executive Officer of the University

Looking at the organizational structure, this would probably need to be a President, Vice-President, or Chancellor level position. If it would be inconvenient for them to electronically sign the form, you can choose the "Hardcopy Signature" option when submitting the correction and the system will send you a link to a pdf you can print off and have them sign.

Created on 12/8/2022 9:57 AM by **Zachary Carroll**

1 COMMENT

Adam Hensley (ahensley@uca.edu) (12/8/2022 10:20 AM)

I swapped the CO and the RO. Kevin Carter is an Associate VP. Please let me know if this will not work.

Revisions

Revision	Revision Date	Revision By
Revision 1	11/8/2022 2:55 PM	Adam Hensley
Revision 2	12/8/2022 10:16 AM	Adam Hensley