



**DIVISION OF
ENVIRONMENTAL QUALITY**

Sarah Huckabee Sanders
GOVERNOR

Shane E. Khoury
SECRETARY

**NOTICE OF COVERAGE (NOC)
INDIVIDUAL TREATMENT FACILITIES GENERAL PERMIT, ARG550000**

Anthony Forest Products Company, LLC
Attn: Wade Summerville, Plant Manager
101 Dauphin Street STE 600
Mobile, AL 36602

The Recertification Notice of Intent (NOI) for coverage under the above General Permit was received on May 30, 2024 and has been reviewed. The facility has been assigned Permit Tracking Number **ARG550398** and AFIN **70-00473**. Any permit-related correspondence must include these numbers. This NOC is issued to Anthony Forest Products Company, LLC in reliance upon the statements and representations made in the submittal for the following facility located in Union County:

Permittee (Legal Name): Anthony Forest Products Company, LLC
Facility Name: Anthony Forest Products Company, LLC - Urbana Sawmill
Permit Tracking No.: ARG550398
AFIN: 70-00473
Facility Address: 4337 Lawson Road, El Dorado, AR 71730 in Union County
Facility Coordinates: Latitude: 33.159677°; Longitude: -92.443483°

The facility's treatment system consists of a Orenco AdvanTex AX25RT. Under the terms of this coverage the system must discharge at or below 1,500 gallons per day or seek coverage under an individual permit.

Compliance with all conditions and limitations of the general permit is required.

<https://www.adeq.state.ar.us/downloads/WebDatabases/PermitsOnline/NPDES/Permits/ARG550000.pdf>

Discharges allowed by the permit shall only occur at the following outfall location(s):

Outfall 001: 33.159119°, -92.44353°

to receiving waters named:

unnamed ditch, thence to Woodard Creek, thence to North Lapile Creek, thence to Lapile Creek, thence to Fishtrap Lake, thence to Lapile Creek, thence to the Ouachita River.

Expiration Date: June 30, 2029

Zachary Carroll, PhD, P.E.
Engineer Supervisor, Office of Water Quality

August 16, 2024
Issue Date

Effluent Limitations and Monitoring Requirements

See the following for effluent limitations and monitoring frequencies applicable to the referenced facility:

THE TABLE BELOW IS APPLICABLE TO ALL OUTFALLS LISTED ON THE NOC

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u> (mg/l, unless otherwise specified)		<u>Monitoring Requirements</u>	
	Monthly Avg.	Daily Max.	Frequency	Sample Type
Flow (GPD)	Report	Report	once/year	estimate
Biochemical Oxygen Demand (BOD ₅)	10	15	once/year	grab
Total Suspended Solids (TSS)	15.0	22.5	once/year	grab
Dissolved Oxygen (DO)	6.0 (Inst. Min.)		once/year	grab
Fecal Coliform Bacteria (FCB)	(colonies/100 ml)		once/year	grab
	200	400		
pH	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once/year	grab

See Part 2 of the permit for more information on effluent limitations and monitoring requirements.