



**DIVISION OF
ENVIRONMENTAL QUALITY**

Sarah Huckabee Sanders
GOVERNOR

Shane E. Khoury
SECRETARY

**NOTICE OF COVERAGE (NOC)
HYDROSTATIC TESTING DISCHARGES
NPDES GENERAL PERMIT, ARG670000**

Lion Oil Company, LLC
Attn: Michael Reed, Vice President and General Manager
1005 Robert E. Lee St.
El Dorado, AR 71730

The Notice of Intent (NOI) for coverage under the above General Permit was received on October 31, 2023 and has been reviewed. The facility has been assigned Permit Tracking Number **ARG670935** and AFIN **70-00016**. Any permit-related correspondence must include these numbers. This NOC is issued to Lion Oil Company, LLC in reliance upon the statements and representations made in the submittal for the following facility located in Union County:

Permittee (Legal Name): Lion Oil Company, LLC
Facility Name: Lion Oil Company
Permit Tracking No.: ARG670935
AFIN: 70-00016
Facility Address: 1005 Robert E. Lee St., El Dorado, AR 71730 in Union County
Facility Coordinates: Latitude: 33.2012823; Longitude: -92.6734274°

Compliance with all conditions and limitations of the general permit is required.

<https://www.adeq.state.ar.us/downloads/WebDatabases/PermitsOnline/NPDES/Permits/ARG670000.pdf>

Discharges allowed by the permit shall only occur at the following outfall location(s):

Outfall 001: Latitude 33.199722°; Longitude -92.670278°

to receiving waters named:

Unnamed tributary to Loutre Creek, thence to Loutre Creek, thence to Bayou de Loutre, thence to the Ouachita River.

Expiration Date: June 30, 2028

Bryan Leamons, P.E.
Senior Operations Manager
Office of Water Quality, Division of Environmental Quality

November 8, 2023

Issue Date

Effluent Limitations and Monitoring Requirements

See the following for effluent limitations and monitoring frequencies applicable to the referenced facility:

THE TABLE BELOW IS APPLICABLE TO ALL OUTFALLS LISTED ON THE NOC

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u> (mg/l, unless otherwise specified)		<u>Monitoring Requirements</u>	
	Daily Maximum		Frequency	Sample Type
Volume (gallons)	Report (gallons)		once per batch discharge	estimate
Duration (hours)	Report (hours)		once per batch discharge	record
Total Suspended Solids (TSS)	45		once per batch discharge	grab
Oil and Grease (O&G)	15		once per batch discharge	grab
Total Residual Chlorine (TRC)	0.011 (Inst. Max.)		once per batch discharge	grab
pH	<u>Minimum</u> 6.0 s.u.	<u>Maximum</u> 9.0 s.u.	once per batch discharge	grab
Total Organic Carbon	50		once per batch discharge	grab
Total BTEX	100 (µg/l)		once per batch discharge	grab
Benzene	50 (µg/l)		once per batch discharge	grab
Ammonia Nitrogen (NH ₃ -N)	N/A		N/A	N/A

See Part 2 of the permit for more information on effluent limitations and monitoring requirements.