Peltier, Hannah

From: Gilliam, Allen

Sent: Friday, April 10, 2015 9:40 AM

To: Randy Coats

Cc: Fuller, Kim; Donald A. Thompson; Jerry Upchurch; Kristopher Sherman; Beth Young;

Tasha Williams; Peltier, Hannah; jwadeharrison@yahoo.com

Subject: RE: AR0001210_PJs Tank Wash ARP001053 April 2015 semi annual Pretreatment

report_20150410

Corrected copy...

Allen Gilliam

From: Gilliam, Allen

Sent: Friday, April 10, 2015 9:25 AM

To: 'Randy Coats'

Cc: Fuller, Kim; Donald A. Thompson; Jerry Upchurch; Kristopher Sherman; Beth Young; Tasha Williams; Peltier, Hannah;

jwadeharrison@yahoo.com

Subject: AR0001210_PJs Tank Wash ARP001053 April 2015 semi annual Pretreatment report_20150410

Randy,

PJ's April 2015 semi-annual report was electronically received. In it, you've certified no regulated wastewater from PJ's Transportation Equipment Cleaning (40 CFR 442, Subpart A) operations have been discharged to the City of Crossett's sewage collection system.

Thank you for the timely report. Please advise this office and appropriate City officials 24 hours prior to any regulated wastewater discharges to the City's collection system.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

ec: Jeff Harrison, City of Crossett Building Official

E/NPDES/NPDES/Pretreatment/Reports

From: Randy Coats [mailto:randyc@sbht.com]
Sent: Thursday, April 09, 2015 12:01 PM

To: Gilliam, Allen

Cc: Fuller, Kim; Donald A. Thompson; Jerry Upchurch; Kristopher Sherman; Beth Young; Tasha Williams

Subject: PJs Tank Wash semi-annual Pretreatment report

Allen,

Attached is the currently due report for PJ's Tank Wash.

Thank you for the help.

Randy Coats

1

Director of Operations Liquid Bulk Division Sherman Bros/Team Transport 870 862 5477 Direct 541 285 1028 Cell



"We will not let each other fail"

SEMI-ANNUAL REPORT FOR INDUSTRIAL Jse of this form is <u>not</u> an EPA/ADEQ requirement. Attn: Water Div/NPDES Pretrea	
(1) IDENTIFYING INFORMATION	
A LEGAL NAME & MAILING ADDRESS PJ'S TANK WASH DBA SHERMAN BROS TRUCKING PO BOX 706 HARRISBURG, OR 97446	B. FACILITY & LOCATION ADDRESS PJ'S TANK WASH ZZOI HWY 82 WEST CROSSETT, AR 71635
	EPHONE NUMBER:
(2) REPORTING PERIODFISCAL YEAR From April 1st to Ma	arch 31 st (Both Semi-Annual Reports must cover Fiscal Year)
A. MONTHS WHICH REPORTS ARE DUE APRIL & OCTOBER	B. PERIOD COVERED BY THIS REPORT FROM: 10/1/2014 TO: 3/31/2015
(3) DESCRIPTION OF OPERATION	
A. REGULATED PROCESSES Subparts CHECK EACH APPLICABLE BLOCK Tank Trucks/Chemical & Petroleum Cargo Rail Tank Cars/Chemical & Petroleum Cargo Barges & Ocean/Sea Tankers/Chem & Petro Cargo Tanks/Food Grade Cargos	B. CHANGES: SUMMARIZE ANY CHANGES IN THE REGULATED PROCESSES SINCE THE LAST REPORT. ATTACH AN ADDITIONAL SHEET IF THE SPACE BELOW IS INADEQUATE. PROVIDE A NEW SCHEMATIC IF APPROPRIATE.
C. Number of Regular Employees at this Facility	D. [Reserved]

TYPE OF TREATMENT SYSTEM B. COMMENTS ON TREATMENT SYSTEM HECK EACH APPLICABLE BLOCK Neutralization Chemical Precipitation and Sedimentation DAF Filtration Other None THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSESCORNCILLARY(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE NALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT	INDIV	/IDUAL & TOTA	AL PROCESS	FLOWS DISCHARGED	TO POTW IN GALLO	ONS PER DAY	
\$403.6(e) Unregulated \$403.6(e) Dilute Cooling Water Sanitary Total Flow to POTW ************************************		Process		Average	Maximum	Type of Discharge	
\$403.6(e) Dilute Cooling Water Sanitary Total Flow to POTW **Unregulated* has a precise legal meaning; see 40CFR403.6(e). **OMEASUREMENT OF POLLUTANTS TYPE OF TREATMENT SYSTEM BECK EACH APPLICABLE BLOCK Neutralization Chemical Precipitation and Sedimentation DAF Filtration Other None THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSES—COR CILLARY—(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM, TABULATE ALL THE ALLYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NO CEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for I day 0.84 0.0031 26	Regu	lated					
Cooling Water Sanitary Total Flow to POTW ***********************************	§403	.6(e) Unregula	ated*				
Sanitary Total Flow to POTW ***Unregulated" has a precise legal meaning; see 40CFR403.6(e). 5) MEASUREMENT OF POLLUTANTS TYPE OF TREATMENT SYSTEM HECK EACH APPLICABLE BLOCK Neutralization Chemical Precipitation and Sedimentation DAF Filtration Other None THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSES—CORNCILLARY—CAFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE NALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NO CCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for I day 0.84 0.0031 26	§403	.6(e) Dilute					
Total Flow to POTW **Unregulated** has a precise legal meaning; see 40CFR403.6(e). 5) MEASUREMENT OF POLLUTANTS .TYPE OF TREATMENT SYSTEM HECK EACH APPLICABLE BLOCK Neutralization Chemical Precipitation and Sedimentation DAF Filtration Other None .THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSES—COR NCILLARY—(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE NALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NO CCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for 1 day 0.84 0.0031 26	Cooli	ing Water					
**Unregulated* has a precise legal meaning; see 40CFR403.6(e). 5) MEASUREMENT OF POLLUTANTS . TYPE OF TREATMENT SYSTEM HECK EACH APPLICABLE BLOCK Neutralization Chemical Precipitation and Sedimentation DAF Filtration Other None . THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSES—COR NCILLARY—(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM, TABULATE ALL THE NALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT CEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT. Pollutant(mg/l)	Sanit	ary					
"Unregulated" has a precise legal meaning; see 40CFR403.6(e). 5) MEASUREMENT OF POLLUTANTS TYPE OF TREATMENT SYSTEM HECK EACH APPLICABLE BLOCK Neutralization Chemical Precipitation and Sedimentation DAF Filtration Other None THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSES—COR NCILLARY—(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE NALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NO CCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for 1 day 0.84 0.0031 26	Total	Flow to POT	W				
TYPE OF TREATMENT SYSTEM B. COMMENTS ON TREATMENT SYSTEM HECK EACH APPLICABLE BLOCK Neutralization Chemical Precipitation and Sedimentation DAF Filtration Other None THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSES—COR NCILLARY—(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE NALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT COMPARISED TO COMPANY AND ANALYSIS OF THE ORDER	*"Unre	egulated" has a pr	ecise legal mea	ning; see 40CFR403.6(e).	^	
HECK EACH APPLICABLE BLOCK Neutralization Chemical Precipitation and Sedimentation DAF Filtration Other None None The industrial user must perform sampling and analysis of the effluent from all regulated processes—cornectlary—(after treatment, if applicable). Attach the lab analysis which shows a maximum, tabulate all the nalytical data collected during the report period in the space provided below. Zero concentrations are not coeptable; list the detection limit if concentration was below detection limit. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for I day 0.84 0.0031 26	(5) MEASUREMENT OF I	POLLUTANT	S				
Neutralization Chemical Precipitation and Sedimentation DAF Filtration Other None None The industrial user must perform sampling and analysis of the effluent from all regulated processes—cor northern treatment, if applicable). Attach the lab analysis which shows a maximum; tabulate all the nalytical data collected during the report period in the space provided below. Zero concentrations are not compared by the detection limit. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for 1 day 0.84 0.0031 26	TYPE OF TREATMENT SYST	ΈM			B. COMMENTS C	N TREATMENT SYSTEM	
Neutralization Chemical Precipitation and Sedimentation DAF Filtration Other None None The industrial user must perform sampling and analysis of the effluent from all regulated processes—cor northern treatment, if applicable). Attach the lab analysis which shows a maximum; tabulate all the nalytical data collected during the report period in the space provided below. Zero concentrations are not compared by the detection limit. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for 1 day 0.84 0.0031 26	HECK FACH APPLICABLE BL	OCK					
Chemical Precipitation and Sedimentation DAF	HECK EMENTAL FEICHBEE BE	JOCK					
DAF Filtration Other None None The industrial user must perform sampling and analysis of the effluent from all regulated processes—corncillary—(after treatment, if applicable). Attach the lab analysis which shows a maximum; tabulate all the nalytical data collected during the report period in the space provided below. Zero concentrations are not coeptable; list the detection limit if concentration was below detection limit. Pollutant(mg/l)	Neutralization						
Filtration Other None THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSESCOR NCILLARY(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE NALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT EXCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for 1 day 0.84 0.0031 26		10-11	on				
OtherNone THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSESCOR ICILLARY(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE HALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT CEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT. Pollutant(mg/l)		a Seaimentati	.011				
THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSESCOR NCILLARY(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE NALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT CEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for 1 day 0.84 0.0031 26		d Sedimentati	.011				
THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSESCORNCILLARY(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE NALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT CCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for 1 day 0.84 0.0031 26	DAF	a Seaimentati	Oli				
NCILLARY(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE NALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT ECCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for 1 day 0.84 0.0031 26	DAF Filtration	a Sedimentati	OII				
NCILLARY(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE NALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT ECCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT. Pollutant(mg/l) Cu Hg O&G (SGT-HEM Method) Max for 1 day 0.84 0.0031 26	DAF Filtration Other	a Sedimentati					
(SGT-HEM Method) Max for 1 day 0.84 0.0031 26	DAF Filtration Other	a Sedimentati	OII				
Max for 1 day 0.84 0.0031 26	DAF DAF Filtration Other	JST PERFORM S IENT, IF APPLIC ED DURING TH	SAMPLING A CABLE). ATT HE REPORT PI	ACH THE LAB ANAL' ERIOD IN THE SPACE	YSIS WHICH SHOWS PROVIDED BELOW.	A MAXIMUM; TABULATE AI	LL THE
	DAF Filtration Other None THE INDUSTRIAL USER MUNCILLARY(AFTER TREATM NALYTICAL DATA COLLECT CCEPTABLE; LIST THE DETER	JST PERFORM S IENT, IF APPLIC TED DURING TH CTION LIMIT IF	SAMPLING A CABLE). ATT IE REPORT PI F CONCENTR	ACH THE LAB ANAL' ERIOD IN THE SPACE ATION WAS BELOW I O&G	YSIS WHICH SHOWS PROVIDED BELOW.	A MAXIMUM; TABULATE AI	LL THE
Max Measured	DAF Filtration Other None THE INDUSTRIAL USER MUNCILLARY(AFTER TREATM NALYTICAL DATA COLLECT CCEPTABLE; LIST THE DETER	JST PERFORM S IENT, IF APPLIC TED DURING TH CTION LIMIT IF	SAMPLING A CABLE). ATT IE REPORT PI F CONCENTR	ACH THE LAB ANAL' ERIOD IN THE SPACE ATION WAS BELOW I O&G (SGT-HEM	YSIS WHICH SHOWS PROVIDED BELOW.	A MAXIMUM; TABULATE AI	LL THE
	DAF Other None THE INDUSTRIAL USER MUNCILLARY(AFTER TREATM NALYTICAL DATA COLLECT CCEPTABLE; LIST THE DETERMORALY (mg/l)	JST PERFORM SIENT, IF APPLICED DURING THE CTION LIMIT IF	SAMPLING A CABLE). ATT HE REPORT PI F CONCENTR Hg	ACH THE LAB ANAL' ERIOD IN THE SPACE ATION WAS BELOW I O&G (SGT-HEM Method)	YSIS WHICH SHOWS PROVIDED BELOW.	A MAXIMUM; TABULATE AI	LL THE
	DAF Filtration Other None THE INDUSTRIAL USER MUNCILLARY(AFTER TREATM NALYTICAL DATA COLLECT CCEPTABLE; LIST THE DETERMINATION OF THE	JST PERFORM SIENT, IF APPLICED DURING THE CTION LIMIT IF	SAMPLING A CABLE). ATT HE REPORT PI F CONCENTR Hg	ACH THE LAB ANAL' ERIOD IN THE SPACE ATION WAS BELOW I O&G (SGT-HEM Method)	YSIS WHICH SHOWS PROVIDED BELOW.	A MAXIMUM; TABULATE AI	LL THE
	DAF Filtration Other None THE INDUSTRIAL USER MUNCILLARY(AFTER TREATM NALYTICAL DATA COLLECT CCEPTABLE; LIST THE DETERMINATION OF THE	JST PERFORM SIENT, IF APPLICED DURING THE CTION LIMIT IF	SAMPLING A CABLE). ATT HE REPORT PI F CONCENTR Hg	ACH THE LAB ANAL' ERIOD IN THE SPACE ATION WAS BELOW I O&G (SGT-HEM Method)	YSIS WHICH SHOWS PROVIDED BELOW.	A MAXIMUM; TABULATE AI	LL THE
	DAF Filtration Other None THE INDUSTRIAL USER MUNCILLARY(AFTER TREATM NALYTICAL DATA COLLECT CCEPTABLE; LIST THE DETERMINATION (Mg/l) Max for 1 day	JST PERFORM SIENT, IF APPLICED DURING THE CTION LIMIT IF	SAMPLING A CABLE). ATT HE REPORT PI F CONCENTR Hg	ACH THE LAB ANAL' ERIOD IN THE SPACE ATION WAS BELOW I O&G (SGT-HEM Method)	YSIS WHICH SHOWS PROVIDED BELOW.	A MAXIMUM; TABULATE AI	LL THE

My commission expires _____

40CFR442 SEMI-ANNUAL REPORT CON'D FACILITY NAME: PJ'S TANK WASH

POLLUTION PREVENTION ACT OF 1990 [42 U.S.C. 131]	

§6602 [42 U.S.C. 13101] Findings and Policy para (b) Policy.—The Congress hereby declares it to be the national policy of the United States that pollution should be prevented or reduced at the source whenever feasible; pollution that cannot be prevented should be recycled in an environmentally safe manner whenever feasible; and disposal or other release into the environment should be employed only as a last resort and should be conducted in an environmentally safe manner.

The User may list any new or ongoing Pollution Prevention practices:

(8) GENERAL COMMENTS

FACILITY IS NOT DISCHARGING WASTE WATER AT THIS TIME. PJ'S IS UPDATING TREATMENT SYSTEM AND PLANS TO COMMENCE DISCHARGING TO POTW IN THE FUTURE.

(9) SIGNATORY REQUIREMENTS [40CFR403.12(1)]

I certify under penalty of law that I have personally examined and am familiar with the information in this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME OF CORDOR ATE OFFICER OR AUTHORIZED DEDRESENTATIVE

DIRECTOR OF OPERATIONS

SIGNATURE

DATE SIGNED