

From: [Gilliam, Allen](#)
To: [Kristopher Sherman](#)
Cc: [Randy Coats](#); [Burrow, Kealey](#)
Subject: AR0001210_PJs Tank Wash Oct 2015 no discharge Semi Annual Pretreatment report_20151016
Date: Friday, October 16, 2015 11:36:53 AM
Attachments: [image2015-10-08-114433.pdf](#)

Kris,

PJ's Tank Wash October 2015 semi-annual Pretreatment report was electronically received with the certification statement that no process water regulated under the Transportation Equipment Cleaning standards (40 CFR 442.16) was discharged to the City of Crossett.

Please provide adequate notice to this office and appropriate Crossett officials when you plan to finish "updating [treatment] system" and prior to discharge to the City sewage collection system per 403.12(j).

Thank you for your timely report.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

E/NPDES/NPDES/Pretreatment/Reports

From: Kristopher Sherman [mailto:kristophers@sbht.com]
Sent: Thursday, October 08, 2015 11:03 AM
To: Gilliam, Allen
Cc: Randy Coats
Subject: Semi- Annual report

Allen,

Attached is our semi-annual report for PJ's tank wash. As stated, we are still not discharging wastewater at this time. Let me know if you have any questions.

Thank you,

Kris Sherman



Terminal Manager
Office (870) 862-5477
Cell (541) 729-9943
Fax (870) 862-4170

SEMI-ANNUAL REPORT FOR INDUSTRIAL USERS REGULATED BY 40CFR442

Use of this form is not an EPA/ADEQ requirement. Attn: Water Div/NPDES Pretreatment

(1) IDENTIFYING INFORMATION

A. LEGAL NAME & MAILING ADDRESS

PJ's Tank Wash DBA
Sherman Bros. Trucking
PO Box 706
Harrisburg, OR 97446

B. FACILITY & LOCATION ADDRESS

PJ's Tank Wash
2201 Hwy 82 West
Crossett, AR 71635

C. FACILITY CONTACT: Clark Reed

TELEPHONE NUMBER: 870-364-7020

(2) REPORTING PERIOD--FISCAL YEAR From April 1st to March 31st (Both Semi-Annual Reports must cover Fiscal Year)

A. MONTHS WHICH REPORTS ARE DUE

____ October ____ & ____ April ____

B. PERIOD COVERED BY THIS REPORT

FROM: 04/1/15 TO: 9/31/15

(3) DESCRIPTION OF OPERATION

A. REGULATED PROCESSES

Subparts

CHECK EACH APPLICABLE BLOCK

Tank Trucks/Chemical & Petroleum Cargo

Rail Tank Cars/Chemical & Petroleum Cargo

Barges & Ocean/Sea Tankers/Chem & Petro Cargo

Tanks/Food Grade Cargos

Comments:

B. CHANGES: SUMMARIZE ANY CHANGES IN THE REGULATED PROCESSES SINCE THE LAST REPORT. ATTACH AN ADDITIONAL SHEET IF THE SPACE BELOW IS INADEQUATE. PROVIDE A NEW SCHEMATIC IF APPROPRIATE.

C. Number of Regular Employees at this Facility 8

D. [Reserved]

40CFR442 SEMI-ANNUAL REPORT CON'D FACILITY NAME:

(4) FLOW MEASUREMENT

INDIVIDUAL & TOTAL PROCESS FLOWS DISCHARGED TO POTW IN GALLONS PER DAY

Process	Average	Maximum	Type of Discharge
Regulated			
§403.6(e) Unregulated*			
§403.6(e) Dilute			
Cooling Water			
Sanitary			
Total Flow to POTW			

*"Unregulated" has a precise legal meaning; see 40CFR403.6(e).

(5) MEASUREMENT OF POLLUTANTS

A. TYPE OF TREATMENT SYSTEM

CHECK EACH APPLICABLE BLOCK

- Neutralization
- Chemical Precipitation and Sedimentation
- DAF
- Filtration
- Other _____
- X None

B. COMMENTS ON TREATMENT SYSTEM

No treatment at this time

C. THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSES--CORE & ANCILLARY--(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE ANALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT ACCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT.

Pollutant(mg/l)	Cu	Hg	O&G (SGT-HEM Method)
Max for 1 day	0.84	0.0031	26
Max Measured			

Sample Location _____

Sample Type (Grab or Composite) _____

Number of Samples and Frequency Collected _____

40CFR136 Preservation and Analytical Methods Use: Yes No

(7) POLLUTION PREVENTION ACT OF 1990 [42 U.S.C. 13101 et seq.]

§6602 [42 U.S.C. 13101] Findings and Policy para (b) Policy.--The Congress hereby declares it to be the national policy of the United States that pollution should be prevented or reduced at the source whenever feasible; pollution that cannot be prevented should be recycled in an environmentally safe manner, whenever feasible; pollution that cannot be prevented or recycled should be treated in an environmentally safe manner whenever feasible; and disposal or other release into the environment should be employed only as a last resort and should be conducted in an environmentally safe manner.

The User may list any new or ongoing Pollution Prevention practices:

(8) GENERAL COMMENTS

Facility is not discharging at this moment, PJ's will be updating system to discharge in the upcoming year.

(9) SIGNATORY REQUIREMENTS [40CFR403.12(l)]


I certify under penalty of law that I have personally examined and am familiar with the information in this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kris Sherman

NAME OF CORPORATE OFFICER OR AUTHORIZED REPRESENTATIVE

Terminal Manager

OFFICIAL TITLE



SIGNATURE

10-8-15

DATE SIGNED