

Gilliam, Allen

From: Gilliam, Allen
Sent: Tuesday, December 27, 2011 9:29 AM
To: Kevin Campbell (KCampbell@ezloader.com)
Cc: mt. home alma clark
Subject: AR0021211_EZ Boat Loader (ARP001055) Dec 2011 semi annual Pretreatment Report analytical results reply_20111220

Kevin,

The electronic submittal of your December 2011 semi-annual Pretreatment report results (Arkansas Analytical's) was received and reviewed. As per our phone conversations on 12/20 your Zinc level (4.37 mg/l) violated the Metal Finishing Standards in 40 CFR 433.17 (1.48 mg/l). This is quite an aberration from your previous semi-annual reports typically showing Zinc levels from ~0.2 to 1.2 mg/l (from 8/07 to present).

[Please electronically provide a full semi-annual report on the form you previously use with a cover letter and the signatory authority's (Gary Potter?) legible signature below the appropriate certification statements.]

Your reporting requirements under 40 CFR 403.12(g)(2), "If sampling performed by [EZ Boat] indicates a violation, [EZ Boat] shall notify [ADEQ] within 24 hours of becoming aware of the violation. [EZ Boat] shall also repeat the sampling and analysis and submit the results of the repeat analysis to [ADEQ] within 30 days after becoming aware of the violation." has been and will be met per your below correspondence and per our phone conversation today.

Looking at the City's potable water levels of Zinc (0.205 mg/l), it is doubtful your subsequent Zinc analysis will bring your December monthly average below the Metal Finishing Monthly Average not to exceed of 1.48 mg/l. Even two more samples during December of just tap water might not bring your Zinc numbers below the "monthly avg. not to exceed" if the City's Zinc levels remain near 0.205 mg/l.

Please keep this office apprised of any new information you might discover from your internal investigation of any recent changes in raw material or chemicals.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

ec: Alma Clark, Director, Water & Sewer Services, City of Mountain Home

From: Kevin Campbell [<mailto:KCampbell@ezloader.com>]
Sent: Tuesday, December 20, 2011 11:04 AM
To: Gilliam, Allen
Subject: FW: WW Results (12/7/11)

Mr. Gilliam,

Below are the last set of samples I collected on 12/07/11. I received the results via email on 12/13/11, but was working on another project and did not view them until Monday, December 19, 2011. The level of Zinc in the effluent is above the monthly average set in the Pretreatment standard. I will perform resampling starting today and will resample tomorrow as well to provide more information. I will forward the results of these samples to you as I receive them. I will resample until I am able to show compliance. Please let me know anything else I need to do to satisfy your department.

*Kevin Campbell
Compliance Manager
EZ Loader Custom Boat Trailers, Inc.
800-553-7855 ext. 259
870-404-4629 cellular
870-481-5150 fax
kcampbell@ezloader.com*

-----Original Message-----

From: Sydney James [<mailto:sjames@arkansasanalytical.com>]
Sent: Tuesday, December 13, 2011 1:45 PM
To: Kevin Campbell
Subject: [NEWSENDER] - WW Results (12/7/11)

Thanks,
Sydney James Randles



11701 Interstate 30
Bldg. 1, Ste. 115
Little Rock, AR 72209
501-455-3233
501-455-6118 (fax)

Business Hours - Mon-Thur - 8am-5pm, Fri - 8am-4pm

This e-mail and any attachments are confidential. If you receive this message in error or are not the intended recipient, you should not retain, distribute, disclose or use any of this information and you should destroy the e-mail and any attachments or copies.