

Gilliam, Allen

From: Gilliam, Allen
Sent: Wednesday, February 01, 2012 7:52 AM
To: Kevin Campbell (KCampbell@ezloader.com)
Cc: mt. home alma clark; Henderson, Katie
Subject: AR0021211_EZ Boat Loader ARP001055 Jan 2012 repeat analysis still showing Zn violation reply_20120201
Attachments: 1201254.pdf

Kevin,

I'm at wit's end also. Looking at the lab's QA/QC report (attached), it doesn't appear there is any Zinc contamination coming from them.

Continue with your corrective action plan. You mentioned over the phone your holding tanks and sump were completely cleaned out and subsequent regulated wastewater discharged was measured at 5 mg/l Zinc? Please keep this office apprised of the analyticals after you've installed the filter unit. I have my reservations about the success of a 50 micron filter eliminating your Zinc excursions, but if that is what your contact insinuated would work to reduce your Zinc, we'll have to see.

I'll be expecting to hear from you later in the week or early next week regarding what you discover about any new chemical changes (powder coat too?) and/or metallurgical make-up of your various raw material (metals) alloys.

As long as you are following the rough corrective action plan submitted electronically on 1/17/12, ADEQ will continue "working" with you on this problem. If the filter doesn't work and you have not discovered the source, a modification ("plan C") will have to be submitted to your corrective action plan.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

ec: Alma Clark, Director, Water and Sewer Services, City of Mountain Home

From: Kevin Campbell [<mailto:KCampbell@ezloader.com>]
Sent: Monday, January 30, 2012 6:40 AM
To: Gilliam, Allen
Subject: RE: AR0021211_EZ Boat Loader ARP001055 Dec 2011 semi annual Pretreatment Report with Zn violations and corrective action plan_20120118

Allen,

Got my latest set of test results back and our Zinc is now even higher, got a 5.0 reading this time. We will be moving forward with our filtration plan. I will sample as soon as the filter is installed and make you aware of the results. Is there anything else your department requires at this time? Also, is there a time limit on how long we have to correct the problem?

Thank you,
Kevin

*Kevin Campbell
Compliance Manager
EZ Loader Custom Boat Trailers, Inc.
800-553-7855 ext. 259
870-404-4629 cellular
870-481-5150 fax*