

Gilliam, Allen

From: Gilliam, Allen
Sent: Tuesday, January 04, 2011 9:08 AM
To: 'Kevin Campbell'
Cc: Fuller, Kim; 'normajames@sbcglobal.net'; Hurley, Jane; 'aclark@cityofmountainhome.com'
Subject: AR0021211_EZ Loader (ARP001055) Dec '10 Semi Annual Pretreatment Report Reply_20110106

Mr. Campbell,

Your December semi-annual report was received via e-mail on 1/3/11, reviewed, deemed compliant with the the Metal Finishing standards in 40 CFR 433. There are no further actions deemed necessary at this time.

One caveat regarding pH analysis: There is virtually no "holding time" (15 minutes) for analysis of pH per 40 CFR 136.3. Your regulated wastewater/potable water sampling time indicated ~3:00 p.m. on 12/2/10. Arkansas Analytical's report indicated their pH analysis was conducted on 12/3/10 at around 2:00 p.m. Their pH results are null and void for your reporting results. Your certified lab should have made note of this on their report to you.

If you wish to analyze for pH immediately upon discharge of your regulated wastewater, you must obtain an accurate pH meter with calibration records on file. More information regarding pH sampling/calibration can be obtained from ADEQ's lab person, Jane Hurley (cc'd above) at 501.682.0938.

Thank you for your timely Pretreatment reporting.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

ec: Norma James - Arkansas Analytical/Jane Hurley - ADEQ Lab/Alma Clark - City of Mountain Home, Director of Water & Sewer

-----Original Message-----

From: Kevin Campbell [mailto:KCampbell@ezloader.com]
Sent: Monday, January 03, 2011 2:18 PM
To: Gilliam, Allen
Subject: EZ Loader Bi-Annual Report

Hello Allen,

Sorry for the delay in getting this to you. Thought I had it out last week, but it doesn't seem to have worked.

I have attached our report which is due in June and December of each year, please review and let me know if it is acceptable as our final submission for December 2010. Let me know if you have any questions or suggestions.

Thank you,

Kevin Campbell
Compliance Manager
EZ Loader Custom Boat Trailers, Inc.
800-553-7855 ext. 259
870-404-4629 cellular
870-481-5150 fax
kcampbell@ezloader.com

<<Semi annual water report form Dec 2010.doc>>
<<wastewater test results.pdf>>
<<PLANT LAYOUT, 2010.PDF>>