


**PRETREATMENT PERFORMANSC SUMMARY (PPS)
ATTACHMENT C**

NOTE: ALL QUESTIONS REFER TO THE INDUSTRIAL PRETREATMENT PROGRAM AS APPROVED BY THE EPA. THE PERMITTEE SHOULD NOT ANSWER THE QUESTIONS BASED ON CHANGES MADE TO THE APPROVED PROGRAM WITHOUT DEPARTMENT AUTHORIZATION.

I. General Information

Control Authority Name CITY OF DE QUEEN
 Address PO BOX 730 (670 South 9th Wastewater Plant)
 City DE QUEEN State / Zip ARKANSAS 71832
 Contact Person MICHAEL SIMS WASTEWATER SUPT.
 (Position)
 Contact Telephone (870) 642-5231



NPDES Permit Nos. AR0021733

Reporting Period AUGUST 2005 JULY 2006
 (Beginning Month and Year) (Ending Month and Year)

Total Number of Categorical Ius 0

Total Number of Significant Noncategorical Ius 1

NPDES PERMIT FILE

NPDES # _____

AFIN # _____

Permit PN _____

Correspondence _____

Technical Backup _____

Date Scanned _____

SIGNIFICANT INDUSTRIAL USERS

Categorical Noncategorical

| | | |
|--|--------------|------------|
| 1) No. of SIUs Submitting BMRs / Total No. Required----- | <u>0 / 0</u> | <u>N/A</u> |
| 2) No. of SIUs Submitting 90-Day Compliance Reports / No. Required----- | <u>0 / 0</u> | <u>N/A</u> |
| 3) No. of SIUs Submitting Semiannual Reports / Total No. Required----- | <u>0 / 0</u> | <u>0</u> |
| 4) No. of SIUs Meeting Compliance Schedule / Total No. Required to Meet Schedule----- | <u>0 / 0</u> | <u>0</u> |
| 5) No. of SIUs in Significant Noncompliance / Total No. of SIUs----- | <u>0 / 0</u> | <u>0</u> |
| 6) Rate of Significant Noncompliance for all SIUs (categorical and noncategorical)----- | <u>0 / 0</u> | |

III. Compliance Monitoring Program


| | <u>SIGNIFICANT INDUSTRIAL USERS</u> | |
|--|-------------------------------------|-----------------------|
| | <u>Categorical</u> | <u>Noncategorical</u> |
| 1) No. of Control Documents Issued / Total No. Required----- | <u>0 / 0</u> | <u>1 / 1</u> |
| 2) No. of Nonsampling Inspections Conducted ----- | <u>0</u> | <u>1</u> |
| 3) No. of Sampling Visits Conducted ----- | <u>0</u> | <u>365</u> |
| 4) No. of Facilities Inspected (nonsampling)----- | <u>0</u> | <u>1</u> |
| 5) No. of Facilities Sampled ----- | <u>0</u> | <u>1</u> |

IV. Enforcement Action

| | | |
|---|--------------|--------------|
| 1) No. of Compliance Schedules Issued / No. of Schedules Required----- | <u>0 / 0</u> | <u>0 / 0</u> |
| 2) No. of Notices of Violations Issued to SIUs----- | <u>0</u> | <u>9</u> |
| 3) No. of Administrative Orders Issued to SIUs----- | <u>0</u> | <u>0</u> |
| 4) No. of Civil Suits Filed----- | <u>0</u> | <u>0</u> |
| 5) No. of Criminal Suits Filed ----- | <u>0</u> | <u>0</u> |
| 6) No. of Significant Violators (attach newspaper pub.)---- | <u>0</u> | <u>0</u> |
| 7) Amount of Penalties Collected (total dollars/ius assessed) | <u>0</u> | <u>0</u> |
| 8) Other Actions (sewer bans , etc..)----- | <u>0</u> | <u>0</u> |

The following certification must be signed in order for this form to be considered complete :

I certify that the information contained herein is complete and accurate to the best of my knowledge.



8-29-06

Authorized Representative

Date

SIGNIFICANT VIOLATORS - ENFORCEMENT ACTIONS TAKEN

| INDUSTRIAL USER | NATURE OF VIOLATIONS | REPORTS LIMITS | N.O.V. | A.O. | CIVIL CRIMINAL OTHER | NUMBER OF ACTIONS TAKEN | COMPLIANCE SCHEDULE | | | | |
|-----------------|----------------------|----------------|--------|------|----------------------|-------------------------|---------------------|-------------|------------------|-----------|---------|
| | | | | | | | PENALTIES COLLECTED | DATE ISSUED | DATE CURRENT DUE | STATUS | COMMENT |
| PILGRIM'S PRIDE | OIL & GREASE | | 7 | | | | | | | COMPLIANT | C |
| PILGRIM'S PRIDE | pH | | 2 | | | | | | | COMPLIANT | C |
| PILGRIM'S PRIDE | BOD | | 17 | | | | | | | COMPLIANT | C |
| PILGRIM'S PRIDE | TSS | | 17 | | | | | | | COMPLIANT | C |

PRETREATMENT PROGRAM STATUS REPORT UPDATED SIGNIFICANT INDUSTRIAL USERS LIST

| | | CONTROL DOCUMENT | COMPLIANCE STATUS REPORTS | | | | | | | |
|-----------------|----------|-------------------------|------------------------------|------------------|-----------------|---------------|------------------|----------------|----------|---|
| INDUSTRIAL USER | SIC CODE | CATERGORICAL DETERMINA. | Y/N | LAST ACTION USER | TIMES INSPECTED | TIMES SAMPLED | 90-DAY BMR COMPL | SEMI ANNUL MON | SELF MON | EFFLUENT LIMITS |
| PILGRIM'S PRIDE | 2015 | | Y | 9/01/05 | 1 | 84 | | | | BOD 450(30day avg) 550(day max) TSS 200(30day avg) 300(day max) O&G 100((30day avg) 150(day max) pH 6 - 9 FLOW 2mgd(30day avg) 2.5mgd(day max) TKN/NH3 Report only |

| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | <u>NH3</u> |
|-----------------|--------------------|--------------|--------------|------------------|-------------|-----------------|-------------|--------------|
| | 8/23-24/05 | 389 | 364 | 21 | 7.07 | 1.80058 | 51.7 | 7.80 |
| | 8/24-25/05 | 356 | 260 | 27 | 7.19 | 1.8101 | 51.2 | 7.70 |
| | 8/25-26/05 | 226 | 172 | 24 | 7.2 | 1.09849 | 41.3 | 10.50 |
| | 8/26-27/05 | 657 | 316 | 300 | 6.69 | 1.44153 | 58.7 | 9.75 |
| | 8/27-28/05 | 484 | 152 | 13 | 6.23 | 0.0789 | 64.1 | 27.50 |
| | 8/28-29/05 | 210 | 104 | 12 | 7.46 | 0.36073 | 36.7 | 12.10 |
| | 8/29-30/05 | 414 | 288 | 19 | 6.9 | 1.74063 | 49.5 | 4.37 |
| AVERAGE | | 390.9 | 236.6 | 59.4 | | 1.19014 | 50.5 | 11.4 |
| MIN | | | | | 6.23 | | | |
| MAX | | 657 | 364 | 300 | 7.46 | 1.8101 | 64.1 | 27.5 |
| 90% FLOW | | | | | | 1.026853 | | |
| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | <u>NH3</u> |
| | 9/19-20/05 | 533.5 | 248 | 14 | 7.22 | 1.72071 | 50.9 | 11.00 |
| | 9/20-21/05 | 306 | 180 | 13 | 7.29 | 1.71212 | 42.7 | 12.25 |
| | 9/21-22/05 | 306 | 88 | 33 | 7.05 | 1.65784 | 40.1 | 19.00 |
| | 9/22-23/05 | 290 | 200 | 11 | 6.86 | 1.86184 | 42.4 | 23.75 |
| | 9/23-24/05 | 232 | 96 | 240 | 6.59 | 1.5096 | 42.2 | 19.12 |
| | 9/24-25/05 | 157 | 124 | 8.6 | 6.17 | 0.209 | 28 | 12.13 |
| | 9/25-26/05 | 144 | 68 | 17 | 7.14 | 0.42228 | 51.1 | 23.50 |
| AVERAGE | | 281.2 | 143.4 | 48.1 | | 1.29906 | 42.5 | 17.3 |
| MIN | | | | | 6.17 | | | |
| MAX | | 533.5 | 248 | 240 | 7.29 | 1.86184 | 51.1 | 23.75 |
| 90% FLOW | | | | | | 0.7755 | | |
| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | <u>NH3</u> |
| | 10/17-18/05 | 452 | 200 | 8.4 | 7.19 | 1.63584 | 51.6 | 15.50 |
| | 10/18-19/05 | 905 | 184 | 2.4 | 7.16 | 1.66988 | 39.2 | 14.82 |
| | 10/19-20/05 | 575 | 184 | 31 | 6.98 | 1.71016 | 37.3 | 17.50 |
| | 10/20-21/05 | 469 | 140 | 250 | 6.00 | 1.94777 | 40.5 | 16.25 |
| | 10/21-22/05 | 593 | 188 | 290 | 6.71 | 1.54701 | 42.1 | 16.75 |
| | 10/22-23/05 | 222 | 40 | 25 | 6.29 | 0.07399 | 25.6 | 17.00 |
| | 10/23-24/05 | 122 | 72 | 15 | 6.93 | 0.35991 | | |
| AVERAGE | | 476.9 | 144.0 | 88.8 | | 1.27779 | 39.4 | 16.3 |
| MIN | | | | | 6.00 | | | |
| MAX | | 905 | 200 | 290 | 7.19 | 1.94777 | 51.6 | 17.5 |
| 90% FLOW | | | | | | 1.00679 | | |

| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | <u>NH3</u> |
|-----------------|--------------------|--------------|--------------|------------------|-------------|-----------------|-------------|--------------|
| | 11/4-5/05 | 642 | 144 | 210 | 7.11 | 1.53221 | 39.1 | 9.50 |
| | 11/5-6/05 | 345 | 68 | 53 | 6.63 | 0.08241 | 18 | 10.00 |
| | 11/6-7/05 | 80.4 | 120 | 26 | 6.99 | 0.29745 | 42.4 | 18.25 |
| | 11/7-8/05 | 87.7 | 92 | 39 | 7.16 | 1.67993 | 47.2 | 19.75 |
| | 11/8-9/05 | 368 | 212 | 7.3 | 6.89 | 1.72179 | 56.4 | 10.75 |
| | 11/9-10/05 | 616 | 396 | 34 | 7.22 | 1.77173 | 51.1 | 12.00 |
| | 11/10-11/05 | 388 | 220 | 21 | 7.36 | 1.66856 | 50 | 14.75 |
| AVERAGE | | 361.0 | 178.9 | 55.8 | | 1.25058 | 43.5 | 13.6 |
| MIN | | | | | 6.63 | | | |
| MAX | | 642 | 396 | 210 | 7.36 | 1.77173 | 56.4 | 19.75 |
| 90% FLOW | | | | | | 1.12587 | | |
| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | <u>NH3</u> |
| | 12/5-6/05 | 374 | 152 | 94 | 6.93 | 1.65529 | 47.9 | 23.75 |
| | 12/7-8/05 | 128 | 80 | 15 | 7.22 | 1.73497 | 46 | 18.50 |
| | 12/8-9/05 | 326 | 104 | 34 | 7.29 | 1.68165 | 52.4 | 12.00 |
| | 12/9-10/05 | 233 | 104 | 150 | 7.15 | 1.61828 | 47.1 | 21.50 |
| | 12/10-11/05 | 160 | 72 | 520 | 5.82 | 0.40965 | 13.4 | 5.23 |
| | 12/11-12/05 | 339 | 80 | 12 | 6.99 | 0.52515 | 18.2 | 17.31 |
| | 12/12-13/05 | 368 | 88 | 8.4 | 7.2 | 1.69575 | 46.1 | 17.50 |
| AVERAGE | | 275.4 | 97.1 | 119.1 | | 1.33153 | 38.7 | 16.5 |
| MIN | | | | | 5.82 | | | |
| MAX | | 374 | 152 | 520 | 7.29 | 1.73497 | 52.4 | 23.75 |
| 90% FLOW | | | | | | 1.11175 | | |
| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | <u>NH3</u> |
| | 1/17-18/06 | | 160 | 73 | 6.95 | 1.65684 | 57 | 27.25 |
| | 1/18-19/06 | 248 | 208 | 22 | 6.86 | 1.70393 | 56.8 | 13.75 |
| | 1/19-20/06 | 287 | 172 | 100 | 6.97 | 1.97764 | 45.1 | 9.75 |
| | 1/20-21/06 | 276 | 148 | 11 | 7.27 | 1.64682 | 41.9 | 16.50 |
| | 1/21-22/06 | 373 | 136 | 48 | 6.48 | 1.42456 | 41.1 | 17.00 |
| | 1/22-23/06 | 100 | 124 | 26 | 6.99 | 0.37578 | 10.9 | 8.50 |
| | 1/23-24/06 | 380 | 176 | 16 | 7.21 | 1.60468 | 49.9 | 11.75 |
| AVERAGE | | 277.3 | 160.6 | 42.3 | | 1.48432 | 43.2 | 14.9 |
| MIN | | | | | 6.48 | | | |
| MAX | | 380 | 208 | 100 | 7.27 | 1.97764 | 57 | 27.25 |
| 90% FLOW | | | | | | 1.078296 | | |

| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | <u>NH3</u> |
|-----------------|--------------------|--------------|--------------|------------------|-------------|----------------|-------------|--------------|
| | 2/13-14/06 | 359 | 132 | 15 | 6.82 | 1.65065 | 47.3 | 10.00 |
| | 2/14-15/06 | 307 | 108 | 13 | 7.11 | 1.73981 | 44.3 | 3.75 |
| | 2/15-16/06 | 230 | 104 | 14 | 7.04 | 1.51092 | 42.7 | 14.50 |
| | 2/16-17/06 | 221 | 76 | 19 | 6.99 | 1.723 | 34.5 | 17.75 |
| | 2/17-18/06 | 246 | 96 | 120 | 6.92 | 1.67063 | 43.2 | 17.25 |
| | 2/18-19/06 | 70 | 32 | 6 | 6.71 | 0.3402 | 8.2 | 7.50 |
| | 2/19-20/06 | 73.1 | 48 | 25 | 6.98 | 0.56735 | 9.8 | 9.50 |
| AVERAGE | | 215.2 | 85.1 | 30.3 | | 1.31465 | 32.9 | 11.5 |
| MIN | | | | | 6.71 | | | |
| MAX | | 359 | 132 | 120 | 7.11 | 1.73981 | 47.3 | 17.75 |
| 90% FLOW | | | | | | 1.23294 | | |
| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | |
| | 3/13-14/06 | 272 | 108 | 22 | 7.07 | 1.76143 | 43.2 | |
| | 3/14-15/06 | 310 | 188 | 170 | 7.32 | 1.82826 | 47.5 | |
| | 3/15-16/06 | 385 | 164 | 84 | 7.37 | 1.7104 | 20.3 | |
| | 3/16-17/06 | 253 | 112 | 220 | 6.55 | 1.7577 | 52.4 | |
| | 3/17-18/06 | 195 | 68 | 9.9 | 6.91 | 1.60128 | 46.6 | |
| | 3/18-19/06 | 73 | 52 | 13 | 7.18 | 1.6125 | 15.9 | |
| | 3/19-20/06 | 393 | 136 | 28 | 7.21 | 0.39865 | 46.9 | |
| AVERAGE | | 268.7 | 118.3 | 78.1 | | 1.52432 | 39.0 | |
| MIN | | | | | 6.55 | | | |
| MAX | | 393 | 188 | 220 | 7.37 | 1.82826 | 52.4 | |
| 90% FLOW | | | | | | 1.24774 | | |
| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | <u>NH3</u> |
| | 4/17-18/06 | 284 | 188 | 32 | 7.3 | 1.72592 | 46.8 | 20.87 |
| | 4/18-19/06 | 348 | 176 | 25 | 7.27 | 1.72649 | 47.5 | 20.00 |
| | 4/19-20/06 | 248 | 112 | 24 | 7.3 | 1.76056 | 43.1 | 19.25 |
| | 4/20-21/06 | 323 | 196 | 51 | 6.41 | 1.76763 | 43.3 | 20.25 |
| | 4/21-22/06 | 192 | 96 | 97 | 6.93 | 1.57759 | 53.8 | 19.75 |
| | 4/22-23/06 | 320 | 300 | 16 | 5.86 | 0.25771 | 85.7 | 22.00 |
| | 4/23-24/06 | 193 | 84 | 28 | 7.18 | 0.34574 | 67.4 | 20.00 |
| AVERAGE | | 272.6 | 164.6 | 39.0 | | 1.30881 | 55.4 | 20.3 |
| MIN | | | | | 5.86 | | | |
| MAX | | 348 | 300 | 97 | 7.30 | 1.76763 | 85.7 | 22 |
| 90% FLOW | | | | | | 1.15043 | | |

| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | <u>NH3</u> |
|-----------------|--------------------|--------------|--------------|------------------|-------------|----------------|-------------|-------------|
| | 5/15-16/06 | 638 | 372 | 70 | 7.07 | 1.77101 | 35.3 | 4.90 |
| | 5/16-17/06 | 261 | 184 | 23 | 6.99 | 1.73599 | 30.3 | 16.00 |
| | 5/17-18/06 | 425 | 268 | 20 | 7.19 | 1.73768 | 30.9 | 3.88 |
| | 5/18-19/06 | 475 | 244 | 29 | 7.21 | 1.75642 | 25.4 | 7.25 |
| | 5/19-20/06 | 546 | 416 | 23 | 7.21 | 1.74274 | 24.9 | 16.00 |
| | 5/20-21/06 | 545 | 412 | 56 | 6.87 | 1.53291 | 25 | 2.00 |
| | 5/21-22/06 | 230 | 116 | 11 | 7.07 | 0.39175 | 18 | 10.00 |
| AVERAGE | | 445.7 | 287.4 | 33.1 | | 1.52407 | 27.1 | 8.6 |
| MIN | | | | | 6.87 | | | |
| MAX | | 638 | 416 | 70 | 7.21 | 1.77101 | 35.3 | 16 |
| 90% FLOW | | | | | | 1.24269 | | |
| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | <u>NH3</u> |
| | 6/19-20/06 | 380 | 228 | 20 | 6.91 | 1.92632 | 39.7 | 14.50 |
| | 6/20-21/06 | 478 | 352 | 9.6 | 7.12 | 1.83294 | 39 | 18.30 |
| | 6/21-22/06 | 528 | 536 | 14 | 6.93 | 1.78724 | 42.1 | 21.30 |
| | 6/22-23/06 | 600 | 332 | 27 | 6.91 | 1.74405 | 46.4 | 21.00 |
| | 6/23-24/06 | 1190 | 456 | 120 | 6.77 | 1.58864 | 54.1 | 24.80 |
| | 6/24-25/06 | 840 | 88 | 36 | 6.32 | 0.09971 | 70.8 | 35.50 |
| | 6/25-26/06 | 354 | 284 | 61 | 6.87 | 0.38154 | 35.9 | 18.30 |
| AVERAGE | | 624.3 | 325.1 | 41.1 | | 1.33721 | 46.9 | 22.0 |
| MIN | | | | | 6.32 | | | |
| MAX | | 1190 | 536 | 120 | 7.12 | 1.92632 | 70.8 | 35.5 |
| 90% FLOW | | | | | | 1.45143 | | |
| | <u>SAMPLE DATE</u> | <u>BOD</u> | <u>TSS</u> | <u>O & G</u> | <u>PH</u> | <u>FLOW</u> | <u>TKN</u> | <u>NH3</u> |
| | 7/17-18/06 | 716 | 280 | 40 | 6.88 | 1.79925 | 44.7 | 17.00 |
| | 7/18-19/06 | 655 | 324 | 13 | 6.94 | 1.735 | 62.4 | 22.00 |
| | 7/19-20/06 | 684 | 320 | 18 | 7.25 | 1.70877 | 46.4 | 21.30 |
| | 7/20-21/06 | 572 | 296 | 19 | 7.23 | 1.74639 | 46.6 | 15.80 |
| | 7/21-22/06 | 792 | 496 | 51 | 7.28 | 1.71939 | 60.9 | 19.50 |
| | 7/22-23/06 | 153 | 188 | 5.9 | 6.94 | 0.50603 | 28.5 | 8.30 |
| | 7/23-24/06 | 166 | 228 | 18 | 7.25 | 0.38194 | 20.5 | 7.80 |
| AVERAGE | | 534.0 | 304.6 | 23.6 | | 1.37097 | 44.3 | 16.0 |
| MIN | | | | | 6.88 | | | |
| MAX | | 792 | 496 | 51 | 7.28 | 1.79925 | 62.4 | 22 |
| 90% FLOW | | | | | | 1.16940 | | |

| | <i>30 day ave.</i> | <i>daily max</i> | <i>daily min</i> | | | | | |
|------------------|--------------------|------------------|------------------|--|--|--|--|--|
| BOD | 450 mg/l | 550 mg/l | | | | | | |
| TSS | 200 mg/l | 300 mg/l | | | | | | |
| O & G | 100 mg/l | 150 mg/l | | | | | | |
| FLOW | 2.00 mg/d | 2.5 mg/d | | | | | | |
| Ph | | 9.00 su | 6.00 su | | | | | |
| TKN | report only | | | | | | | |
| NH3 | report only | | | | | | | |

data entry done 9/14/06

REPORTING YEAR Aug - 05 TO July - 06
 TREATMENT PLANT: Darjeen NPDES PERMIT #A00 21733
 AVERAGE POTW FLOW: 2.80 MGD % IU FLOW: 60 %

| METALS, CYANIDE and PHENOLS | Maximum Allowable Residual Level (4) | Influent (2) Dates Sampled | | | WQ Level/Limit (3) | Effluent (2) Dates Sampled | | |
|-----------------------------|--------------------------------------|----------------------------|--------|------|--------------------|----------------------------|---------|------|
| | | 12-13-05 | 7-6-06 | | | 12-13-05 | 7-31-06 | |
| Antimony (Total) | | <60 | <60 | ug/L | | 79 | <60 | ug/L |
| Arsenic (Total) | | <10 | <10 | .. | | <10 | <10 | .. |
| Beryllium (Total) | | <5 | <5 | .. | | <5 | <5 | .. |
| Cadmium (Total) | | <1 | <1 | .. | | <1 | <1 | .. |
| Chromium (Total) | | <10 | <10 | .. | | <10 | <10 | .. |
| Copper (Total) | | <10 | 12.1 | .. | | <10 | 15.8 | .. |
| Lead (Total) | | <5 | <5 | .. | | <5 | <5 | .. |
| Mercury (Total) | | <0.2 | <0.2 | .. | | <0.2 | <0.2 | .. |
| Molybdenum (Total) | | | | | | | | |
| Nickel (Total) | | <40 | <40 | .. | | <40 | <40 | .. |
| Selenium (Total) | | <5 | <5 | .. | | <5 | <5 | .. |
| Silver (Total) | | <2 | <2 | .. | | <2 | <2 | .. |
| Thallium (Total) | | <10 | <10 | .. | | <10 | <10 | .. |
| Zinc (Total) | 0.113 | 113 | 84.6 | mg/L | | <20 | <20 | .. |
| Cyanide (Total) | ug/L | <20 | 0.02 | mg/L | ug/L | <20 | 0.02 | mg/L |
| Phenols (Total) | ug/L | 31.8 | 0.017 | mg/L | ug/L | <5 | 0.005 | mg/L |
| (5) | | | | | | | | |

- (1) It is advised that the influent and effluent samples are collected considering flow detention time through each plant. Analytical MQLs should be used so that the data can also be used for Local Limits assessment and NPDES application purpose.
- (2) Indicate reported unit of measurement.
- (3) This value was calculated during development of TBLL and based on State Water Quality Standards and implementation procedures.
- (4) This can be reported in ppm (mg/L), ppb (ug/l) or Rsd/day.
- (5) Record the named of any pollutants [40 CFR 122, Appendix D, Table II and/or Table V] detected any the quantity in which they were detected.

CODE SHEET

Annual Report

| | | <u>CODE</u> |
|-------------------------------|------------------|-------------|
| Auditor's Name | <u>Gilliam</u> | |
| Permit Number | <u>AR0021733</u> | |
| Period Report Covers End Date | <u>7/31/06</u> | PSED |
| Start Date | <u>8/1/05</u> | PSSD |

PPETS WENDB DATA ELEMENTS

| | | |
|--|----------|------|
| Significant IUs in Significant Noncompliance with Pretreatment Compliance Schedule | <u>0</u> | SSNC |
| NOV's and A.O.'s Issued Against Significant IUs | <u>9</u> | FENF |
| Civil and/or Criminal Judicial Actions Against Significant IUs | <u>0</u> | JUDI |
| Significant IUs with Significant Violations published in Newspaper | <u>0</u> | SVPU |
| IUs from which penalties have been collected | <u>0</u> | IUPN |

COMMENTS:

