

Henderson, Katie

From: Gilliam, Allen
Sent: Tuesday, April 13, 2010 1:17 PM
To: nashville ed carlyle
Cc: Henderson, Katie; Garner, Cindy
Subject: Nashville's (AR0021766) 2009 Annual Pretreatment Report Review

Ed,

Your Pretreatment Annual Report was received (~3/1/10), reviewed, deemed complete and compliant with 40 CFR 403.12(i). No further action is required at this time.

Comments:

Elevated Hg levels in your effluent may be a cause for concern. '08 calculated water quality levels not to exceed for Hg was 0.02 ug/l. One of your quarterly values exceeded and two others were close to exceeding this level. You may want to consider beginning a source identification program as resources allow. Once true sources are identified, Hg reduction information may be made available to them.

Thank you for the timely report.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

Cc: Katie Henderson/E-drive/Pretreatment Reports
Cindy Garner/NPDES Enforcement Manager