

Gilliam, Allen

From: Gilliam, Allen
Sent: Friday, July 29, 2011 11:53 AM
To: 'Blanton, Chuck'
Cc: 'wynnewater@yahoo.com'; Fuller, Kim
Subject: AR0021903_ Mueller Copper Tube Products (ARP000036) June 2011 Semi-Annual Pretreatment Report Response_20110729

Chuck,

Your semi-annual Pretreatment Report was electronically received, reviewed, deemed complete and compliant with the National Pretreatment Regulations in 40 CFR 403 and more specifically with the Pretreatment Standards in 40 CFRs 464 and 468 (Metal Molding & Casting and Copper Forming, respectively). No further action is deemed necessary at this time.

Comment: Please discontinue having your dissolved metals analyzed. They are of no relevance to the Pretreatment Standards referenced above. Correspondence with the City's Wastewater Treatment Manager, Don O'Neal, concurred with this observation as he knew of no City requirements for Mueller to do so.

Thank you for your timely report and remaining in compliance with the National Pretreatment Regulations.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

cc: Don O'Neal/City of Wynne Wastewater Treatment Plant Manager

E:\NPDES\NPDES\Pretreatment\Reports

From: Blanton, Chuck [<mailto:CBlanton@MuellerIndustries.com>]
Sent: Thursday, June 30, 2011 6:10 AM
To: Gilliam, Allen
Subject: Semi-Annual BMR for Mueller Copper Tube Products, Inc.

Allen:

Attached please find the Semi-annual BMR for Mueller Copper Tube Products, Inc. I believe I have attached/updated all files as we have discussed. Please let me know if further information is needed. I thank you for your patience and assistance in this matter.

Sincerely,

Chuck Blanton
Corporate Director E&HS
Mueller Industries, Inc.