

Gage, Hannah

From: Gilliam, Allen
Sent: Monday, May 02, 2016 11:33 AM
To: 'Denise Bosnick'
Cc: Gage, Hannah; Farmer, Sandra; Healey, Richard; Leamons, Bryan; Walker, Brent; Ramsey, David; Kaelin, Cynthia
Subject: AR0022039_West Memphis April 2016 annual Pretreatment Program report denoting City in SNC_20160502
Attachments: 2015-2016 Yearly report-resubmit.pdf

Denise,

West Memphis' April 2016 annual Pretreatment Program report was electronically received and reviewed.

Attachment C, Part II indicates you received four (4) BMRs (Baseline Monitoring Reports) for your last Pretreatment year. This office cannot see this increase in Categoricals from last year's annual report. Please note these annual reports are meant to only cover your last Pretreatment year. I believe the "1) No. of SIU submitting BMRs/Total No. Required" should read "0 / 0". Same applies to "2) No. of SIU Submitting 90-Day Compliance Reports/No. Required" which should read "0 / 0" as these two types of reports are only required from Categoricals which began discharging to your collection system within your last pretreatment year. "N/A" should be entered for those two (2) reports under the "NonCategorical" column.

5) of that same Section indicates 5 of the City's 6 significant industrial users (SIUs) were in significant non-compliance (83%). The reported 54 notices of violation indicates to this office the City is not following its Enforcement Response Plan to bring its non-compliant SIUs back into compliance in a timely fashion by not escalating enforcement options for the same violations.

Section III, item 2) indicates only 1 of the City's 6 SIUs were inspected (17%).

Per the criteria on page 11 of EPA's "Guidance for Reporting and Evaluating POTW Noncompliance with Pretreatment Implementation Requirements" @ https://www3.epa.gov/npdes/pubs/1990_potw_noncompliance_guidance.pdf the City meets two (2) of the Level II Criteria causing the City to meet the Significant Non-Compliance (SNC) criteria: "2. Failure to Inspect...at least 80% of the SIUs..." and "3) Failure to Enforce Pretreatment Standards...".

If you believe this office has misread your annual report, have comments or a rebuttal, please "reply to all" in writing referencing this email within ten (10) days from the date on this correspondence.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

E/NPDES/NPDES/Pretreatment/Reports

From: Denise Bosnick [<mailto:dbosnick@citywm.com>]


Sent: Thursday, April 28, 2016 7:54 AM

To: Gilliam, Allen

Subject: Yearly report

Here it is again. Let me know if I need to do something else.

Thanks Tina



WEST MEMPHIS UTILITY COMMISSION
604 East Cooper PO Box 1868
West Memphis, Arkansas 72301
Phone (870) 735-3355 Fax (870) 732-7623

April 20, 2016

Allen Gilliam
NPDES Pretreatment Coordinator
Arkansas Department of Environmental Quality
5301 Northshore Drive
Little Rock, AR 72118-5317

Dear Mr. Gilliam,

In order to comply with 40 CFR part 403, the General Pretreatment Regulation, and our NPDES permit (AR00022039) the following is submitted to you:

- 1) Pretreatment Performance Summary,
- 2) Monitoring results for the annual pretreatment report,
- 3) Copy of the statement to be submitted to the largest newspaper in the municipality (Evening Times) for publication during the month April and;
- 4) The following statement: For this reporting period March 2015 - February 2016 there were three significant violators for this reporting period.

Automated Conveyors
3850 Southland Drive
West Memphis, AR 72301

This was due to Chronic violations and Technical Review Criteria (TRC) violation.

Qualawash Services
400 Mound City Road
West Memphis, AR 72301

This was due to Technical Review Criteria (TRC) violation.

Stateside Steel
304 Wyanoke Road
West Memphis, AR 72301

This was due to Technical Review Criteria (TRC) violation.

Wastewater Solutions
408 Mound City Road
West Memphis, AR 72301

This was due to Technical Review Criteria (TRC) violations.

Warren Unilube
915 East Jefferson
West Memphis, AR 72301

This was due to a spill at the facility causing harm to POTW.

I trust this fulfills the requirements. Please let me know if further information is required.

Sincerely,

Denise Bosnick
Director of Environmental Quality

ATTACHMENT C

PRETREATMENT PERFORMANCE SUMMARY (PPS)

NOTE: ALL QUESTIONS REFER TO THE INDUSTRIAL PRETREATMENT PROGRAM AS APPROVED BY ADEQ.
THE PERMITTEE SHOULD NOT ANSWER THE QUESTIONS BASED ON CHANGES MADE TO THE APPROVED PROGRAM WITHOUT DEPARTMENT AUTHORIZATION.

I. General Information

Control Authority Name West Memphis Utility Commission

Address 604 East Cooper / P O Box 1868

City West Memphis State/Zip Arkansas / 72301

Contact Person Denise Bosnick Position Director of Environmental Quality

Contact Telephone 870-702-5141 NPDES Permit Nos. AR0022039

Reporting Period March 2015 February 2016
(Beginning Month and Year) (Ending Month and Year)

Total Number of Categorical IUs Five

Total Number of Significant Noncategorical IUs One

Total Number of Non-Significant (yet permitted) IUs Three

II. Significant Industrial User Compliance

	<u>SIGNIFICANT INDUSTRIAL USERS</u>	
	<u>Categorical</u>	<u>NonCategorical</u>
1) No. of SIUs Submitting BMRs/Total		
No. Required.	<u>4 / 4</u>	<u>0 / 0</u>
2) No. of SIUs Submitting 90-Day Compliance		
Reports/No. Required.	<u>1 / 1</u>	<u>1 / 1</u>
3) No. of SIUs Submitting Semiannual Reports/		
Total No. Required.	<u>0 / 0</u>	<u>0 / 0</u>
4) No. of SIUs Meeting Compliance Schedule/		
Total No. Required to Meet Schedule	<u>1 / 1</u>	<u>0 / 1</u>
5) No. of SIUs in Significant Noncompliance/		
Total No. of SIUs	<u>4 / 5</u>	<u>1 / 1</u>

6) Rate of Significant Noncompliance for all
 SIUs (categorical and noncategorical) 5 / 6

III. Compliance Monitoring Program

	<u>SIGNIFICANT</u> <u>Categorical</u>	<u>INDUSTRIAL USERS</u> <u>NonCategorical</u>
1) No. of Control Documents Issued/Total No. Required.	<u>5 / 5</u>	<u>1 / 1</u>
2) No. of Nonsampling Inspections Conducted.	<u>1 / 5</u>	<u>0 / 1</u>
3) No. of Sampling Visits Conducted.	<u>361</u>	<u>157</u>
4) No. of Facilities Inspected (nonsampling)	<u>1 / 5</u>	<u>0 / 1</u>
5) No. of Facilities Sampled	<u>5 / 5</u>	<u>1 / 1</u>

IV. Enforcement Actions

	<u>SIGNIFICANT</u> <u>Categorical</u>	<u>INDUSTRIAL USERS</u> <u>NonCategorical</u>
1) No. of Compliance Schedules Issued/No. of Schedules Required	<u>1 / 1</u>	<u>1 / 1</u>
2) No. of Notices of Violations Issued to SIUs	<u>38</u>	<u>16</u>
3) No. of Administrative Orders Issued to SIUs	<u>0</u>	<u>0</u>
4) No. of Civil Suits Filed.	<u>0</u>	<u>0</u>
5) No. of Criminal Suits Filed	<u>0</u>	<u>0</u>
6) No. of Significant Violators (attach newspaper publication).	<u>4</u>	<u>1</u>
7) Amount of Penalties (not surcharges) Collected (total dollars/IUs assessed)	<u>0 / 5</u>	<u>20,344.32 / 1</u>
8) Other Actions (sewer bans, etc.).	<u>0</u>	<u>0</u>

The following certification must be signed in order for this form to be considered complete:

I certify that the information contained herein is complete and accurate to the best of my knowledge.

Dennis Borrero
 Authorized Representative

Date 4/22/16

MONITORING RESULTS FOR THE ANNUAL PRETREATMENT REPORT
REPORTING YEAR: March 1, 2015 TO February 28, 2016
TREATMENT PLANT: City of West Memphis NPDES PERMIT #AR0022039
AVERAGE POTW FLOW: 4.6 MGD % IU FLOW: 14%

METALS, CYANIDE and PHENOLS	MAHC (Total) (µg/l) (2)	INFLUENT DATES SAMPLED (µg/l) Once/quarter				WQ level/ limit (µg/l) (2)	EFFLUENT DATES SAMPLED (µg/l) Once/quarter				LABORATORY ANALYSIS		
		Date	Date	Date	Date		Date	Date	Date	Date	EPA MQL (µg/l) (1)	EPA Method Used (1)	Detection Level Achieved (µg/l)
		6/26/2015	9/25/2015	12/8/2015	2/23/2016		6/26/2015	9/25/2015	12/8/2015	2/23/2016			
Antimony	N/A	2.28	1.59	<1.00	<1.00	N/A	1.64	<1.00	<1.00	1.10	60	EPA-200.8	1.00
Cadmium	12.2	0.346	0.230	0.253	0.220	6510.0	<0.100	<0.100	<0.100	0.190	0.5	EPA-200.8	0.100
Copper	517.0	53.7	65.1	31.7	37.9	21200.0	6.76	4.16	8.52	28.4	0.5	EPA-200.8	0.500
Lead	132.3	2.99	2.05	2.12	1.89	30630.0	<0.500	<0.500	0.670	2.06	0.5	EPA-200.8	0.500
Mercury	0.0091	0.0109	0.0462	0.00805	0.035	0.034	0.00397	0.00168	0.00299	0.00286	0.005	EPA-1631E	0.0025
Nickel	96.1	6.69	2.66	4.76	3.03	829050.0	4.18	2.04	3.30	3.59	0.5	EPA-200.8	0.500
Selenium	19.2	<1.00	<1.00	<1.00	<1.00	10910.0	<1.00	<1.00	<1.00	<1.00	5	EPA-200.8	1.00
Silver	250.0	<0.100	0.339	0.120	<0.100	4260.0	<0.100	<0.100	<0.100	0.157	0.5	EPA-200.8	0.100
Zinc	429.0	139	104	158	98	174030.0	143	123	104	159	20	EPA-200.8	5.00
Chromium	351.7	9.06	2.96	3.29	3.82	1230840.0	1.94	1.52	1.75	7.19	10	EPA-200.8	1.00
Cyanide	100.0	<5	<5	<5	<5	12200.0	<5	<5	<5	<5	10	SM-4500CNE-2011	5
Arsenic	16.0	2.52	1.40	2.63	2.04	361640.0	2.92	0.935	3.67	1.92	0.5	EPA-200.8	0.500
Molybdenum	14.4	16.6	2.26	<0.005	1.53	N/A	2.47	1.02	<0.005	1.34	-	EPA-200.8	1.00
Phenols	N/A	1627	23.4	8	209.1	N/A	<5	<5	<5	6	5	EPA-420.1	5
Beryllium	100.0	<0.500	<0.500	<0.500	<0.500	15200.0	<0.500	<0.500	<0.500	<0.500	0.5	EPA-200.8	0.500
Thallium	N/A	<0.100	<0.100	<0.100	<0.100	N/A	<0.100	<0.100	<0.100	<0.100	0.5	EPA-200.8	0.100
Flow, MGD	N/A					N/A							
⁽³⁾ Phosphorus		5020	4480	3650	3140		625	756	2220	2730		SM-4500PE-2011	250
Chloroform					1.90							EPA-624	1.00
4,4'-DDD					0.01655							EPA-608	.00408
4,4'-DDT										0.01521		EPA-608	.00408
Dieldrin										0.00547		EPA-608	.00408
Endosulfan II										0.01231		EPA-608	.00408
Endrin					0.04146					0.00955		EPA-608	.00408

Endrin Aldehyde										0.00655		EPA-608	.00408
Ethylbenzene				4.07							1.00	EPA-624	1.00
Aluminum				630								EPA-200.8	100
Barium				51.4						930		EPA-200.8	100
Boron				118						49.8		EPA-200.8	1.00
Iron				1120						161		EPA-200.8	5.00
Magnesium				3390						1200		EPA-200.8	100
Manganese				102						3470		EPA-200.8	100
Tin				15.2						106		EPA-200.8	1.00
Titanium										12.2		EPA-200.8	5.00
Thallium				24.1						60.6		EPA-200.8	1.00
												EPA-200.8	0.100

(1) It is advised that the influent and effluent samples are collected considering flow detention time through each plant. **Analytical MQLs must be met for the effluent (and SHOULD be met for the influent) so the data can also be used for Local Limits assessment and NPDES application purposes.**

(2) This value was calculated during the development of TBLL based on State WQ criteria, EPA guidance and either ADEQ Pretreatment staff Excel spreadsheets or the Permittee's consultant with concurrence from Pretreatment staff.

(3) Record the name of any pollutant [40 CFR 122, Appendix D, Table II and/or Table V] detected and the concentration at which they were detected.

MAHL - Maximum Allowable Headworks Level / MAHC – Maximum Allowable Headworks Concentration

WQ - "Water Quality Levels not to exceed" OR actual permit limit.

ATTACHMENT A
PRETREATMENT PROGRAM STATUS REPORT
UPDATED SIGNIFICANT INDUSTRIAL USERS LIST

Industrial User Name	SIC/NAICS Code	40 CFR XXX or N/A	Control Document		New User	Times Inspected	Times Sampled	Compliance Status (N/A, C, NC, or SNC)				Permit Limits (denote parameter violated & number of times)
			Y/N	Last Action				Reports				
								BMR	90-day Compliance	Semi Annual	Self Monitoring	
Automated Conveyors <i>**Only discharge to the city Sewer when they clean their equipment</i>	3535/ 333922	40 CFR 433.15	Y	6/1/2014- 5/31/2017	N	0	2	C	N/A	N/A	N/A	SNC - Copper-3 Silver-3 Zinc-2
Grace Trailer	7699/ 811192	40 CFR 442.15	Y	6/1/2014- 5/31/2017	N	0	161	C	N/A	N/A	N/A	NC - TPH O&G-4 Mercury-2 Copper-1
Quala Services	7699/ 811192	40 CFR 442.15	Y	6/1/2014- 5/31/2017	N	0	80	C	C	N/A	N/A	SNC - Copper-11 THP O&G-1 Mercury-1
Stateside Steel	3315/ 331222	40 CFR 433.15	Y	7/1/2013- 6/30/2016	N	0	28	C	N/A	N/A	N/A	SNC - Zinc-11 Chromium-1
Waste Water Solutions, LLC	4212/ 562211	40 CFR 437.47	Y	9/1/2014- 8/31/2017	N	1	90	N/A	N/A	N/A	N/A	SNC - Zinc-10 p-Cresol-13 O&G-1 TPH O&G-1 Cobalt-2

												o-Cresol-1 n- Octadecane -1 Arsenic-1
Warren Unilube	2992 / 324191	N/A	Y	11/1/2015 - 10/31/2018	N	0	157	N/A	NC	N/A	N/A	SNC- Spill at their plant causing harm - volume unknown TPH O&G 3

- Automated Conveyors - No 90-day compliance issued and city does all testing so no semi annual or self monitoring.
- Grace Trailer - No 90-day compliance issued and city does all testing so no semiannual or self monitoring.
- Quala Services - City does all testing so no semi annual or self monitoring.
- Stateside Steel - No 90-day compliance issued and city does all testing so no semi annual or self monitoring.
- WasteWater Solutions, LLC - Does not require a BMR, no 90-day compliance issued and city does all testing so no semi annual or self monitoring..
- Warren Unilube - They are Non-Categorical so no CFR category, no BMR is required, city does all testing so no semi annual or self monitoring.

Include NAICS code(s)

3rd column - include the CFR # only if the Category has Pretreatment Standards (numeric or narrative)

Please footnote N/A reason

ATTACHMENT A-2
PRETREATMENT PROGRAM STATUS REPORT
UPDATED NON-SIGNIFICANT (yet permitted) INDUSTRIAL USERS LIST

Industrial User Name	SIC/NAICS Code	40 CFR XXX or N/A	Control Document		New User	Times Inspected	Times Sampled	Compliance Status (C, NC, or SNC)				Permit Limits
			Y/N	Last Action				Reports				
								BMR	90-day Compliance	Semi Annual	Self Monitoring	
Coca-Cola Bottling	2086/312111	N/A	Y	6/1/2014-5/31/2017	N	0	52	N/A	N/A	N/A	N/A	C
Langston Bag	2674/322224	N/A	Y	6/1/2014-5/31/2017	N	1	62	N/A	N/A	N/A	N/A	NC-O&G-2 Copper-3
Nu-Way	2842/325612	N/A	Y	6/1/2014-5/31/2017	N	0	2	N/A	N/A	N/A	N/A	C

- *All three of the above industries are Non-Categorical so no CFR category, no BMR is required, no 90-day compliance was issued, city does all testing so no semi annual or self monitoring.



WEST MEMPHIS UTILITY COMMISSION

PO Box 1868 604 East Cooper
Telephone (501) 735-3355 Fax (501) 732-7623
West Memphis, Arkansas 72301

The West Memphis Utility Commission and the City of West Memphis is required in its National Pollutant Discharge Elimination System Permit (NPDES) to list significant violators to the industrial pretreatment program. This is a requirement by the United States Environmental Protection Agency and the State of Arkansas Department of Environmental Quality.

For this reporting period March 2015 - February 2016 there were five significant violators for this reporting period.

Automated Conveyors

**3850 Southland Drive
West Memphis, AR 72301**

This was due to Chronic violations and Technical Review Criteria (TRC) violations.

Qualawash Services

**400 Mound City Road
West Memphis, AR 72301**

This was due to Technical Review Criteria (TRC) violation.

Stateside Steel

**304 Wyanoke Road
West Memphis, AR 72301**

This was due to Technical Review Criteria (TRC) violation.

Wastewater Solutions

**408 Mound City Road
West Memphis, AR 72301**

This was due to Technical Review Criteria (TRC) violations.

Warren Unilube

**915 East Jefferson
West Memphis, AR 72301**

This was due to a spill at the facility causing harm to POTW.

501 N. 27th Street
West Memphis, AR 72301

You are hereby notified that the State of Arkansas, Plaintiff, whose attorney is Thomas A. Young, Deputy Prosecuting Attorney, whose address is 66 Mound City Road, Marion, Arkansas 72364, has filed a Complaint herein against you, a copy of which Complaint and Summons shall be delivered to you or to your attorney upon request. You are also notified that you must appear and defend by filing your answer or other responsive pleading within thirty (30) days of the date of the first publication of this Warning Order; and in the event of your failure to do so, Judgment by Default will be entered against you for the relief demanded in the Complaint as circumscribed by the laws of this State.

IN WITNESS WHEREFOR, I have hereunto set my hand and seal as Clerk of the Court on this 14th day of April, 2016.

Terry Hawkins, Clerk
By: Sarah Traugh, D.C.
22,29

IN THE CIRCUIT COURT OF CRITTENDEN COUNTY, ARKANSAS CIVIL DIVISION

STATE OF ARKANSAS PLAINTIFF
VS. CV-2016-153

1996 FORD CROWN VIC VIN#2FALP74WITX114861 DEFENDANT

MORRELL STEWART CLAIMANT

WARNING ORDER

TO: MORRELL STEWART
1201 Wingate
West Memphis, Arkansas
72301

You are hereby notified that the State of Arkansas, Plaintiff, whose attorney is Thomas A. Young, Deputy Prosecuting Attorney, whose address is 66 Mound City Road, Marion, Arkansas 72364, has filed a Complaint herein against you, a copy of which Complaint and Summons shall be delivered to you or to your attorney upon request. You are also notified that you must appear and defend by filing your answer or other responsive pleading within thirty (30) days of the date of the first publication of this Warning Order; and in the event of your failure to do so, Judgment by Default will be entered against you for the relief demanded in the Complaint as circumscribed by the laws of this State.

IN WITNESS WHEREFOR, I have hereunto set my hand and seal as Clerk of the Court on this 14th day of April, 2016.

Terry Hawkins, Clerk
By: Sarah Traugh, D.C.
22,29

IN THE CIRCUIT COURT OF CRITTENDEN COUNTY CIVIL DIVISION

MICHAEL BUTLER and ALICE BUTLER PLAINTIFFS

VS. CV-2016-225

past; and, that the undersigned has never been convicted of violating the laws of this State, or any other State, relative to the sale of controlled beverages.

Belal Kaid
Name of Applicant

7th St. Food Mart
Name of Business

Sworn to before me this 7th day of April, 2016.

Christina A. Baioni
Notary Public

My Commission Expires: June 4, 2018
15,22

NOTICE OF PUBLIC SALE

In accordance with Act 576 of 1987 of the Acts of Arkansas, and pursuant to the security agreements between DSB of West Memphis, LLC dba The Storage Depot, and the following tenants occupying space numbers:

H029 MICHAEL A. PATTERSON
A035 MARK CASSELL
A121 JEVON JAMES
A044 DEMETRIC THORNTON
A060 CAROLYN ROBINSON
D074 PAPITOS GRILL/ARLETTE AVILA

The collateral securing the above named Tenants' obligations to The Storage Depot, will be sold at a public sale to be held on the 4th day of MAY, 2016 at 1:00 P.M. The location of the sale is 701 Hwy 77, West Memphis, AR., telephone (870)733-1100. The collateral security to be sold consists of numerous types of household goods, and other items of personal property including furniture, housewares, recreational goods, tools, appliances, and clothing. The sale shall be in parcels, each parcel being the contents of a storage unit. The collateral being sold and sale terms may be viewed at the time of sale.

22,29

NOTICE OF SALE

PURSUANT TO ACT 576 OF 1987 A.C.A. SECTION 18-16-407 ARKANSAS LAW, A PUBLIC SALE BE HELD ON: April 27th 2016, AT 8:00AM AT SECURITY MINI STORAGE LOCATED AT 110 WEST POLK, WEST MEMPHIS, ARKANSAS. AT SAID SALE IN ORDER TO SATISFY A STORAGE LIEN AND OTHER ACCRUED CHARGES, THE CONTENTS OF MINI STORAGE SPACE LEASED TO: CHRISTOPHER THOMAS UNIT #37, NATASHA LESUEUR UNIT #A04, CASTER ENGINEERING UNIT #B16, HELLENIA SOCTT UNIT #B24, ANDRE WHITAKER UNIT #C10, GREGORY MASENGALE UNIT #C25, TRENSA WATKINS UNIT #D25, CADERIA WATKINS UNIT #E14, PAUL NYHUS

ANNOUNCEMENT:

The West Memphis Metropolitan Organization (MPO) is soliciting public comments concerning the upcoming FY 2017 Unified Planning Work Program (UPWP). This final comment period will end on May 5, 2016. The purpose of the UPWP is to identify all transportation related planning activities that will be undertaken during the project year July 1, 2016 to June 30, 2017. Through this program, the local transportation planning process provides a series of work tasks and relates these to the overall comprehensive planning process. Please contact the MPO at 796 West Broadway, West Memphis, AR 72301 if you would like to review the draft FY 2017 UPWP or if you have comments or questions concerning the transportation planning process. Telephone

NOTICE OF SALE

PURSUANT TO ACT 576 OF 1987 A.C.A. SECTION 18-16-407 ARKANSAS LAW, A PUBLIC SALE BE HELD ON: April 27, 2016, AT 9:30AM AT SECURITY MINI STORAGE #2 LOCATED AT 4900 I-55 EAST SERVICE ROAD, MARION, ARKANSAS. AT SAID SALE IN ORDER TO SATISFY A STORAGE LIEN AND OTHER ACCRUED CHARGES, THE CONTENTS OF MINI STORAGE SPACE LEASED TO: Tyrone Gamble, Unit 104; Larry Sims, Units 105 and 73; Brenda F Temples, Unit 133; Raymond Siggers, Unit 136; Jack Carter, Unit 169; April Terry, Unit 213; Waylon Thomason, Unit 230; Lakeshia Hulum, Unit 234; John Nunes, Unit 5; Avery Willis, Unit 913; WILL BE SOLD, INCLUDING BUT NOT LIMITED TO: CONTENTS OF STORAGE UNITS. ALL CONTENTS OF MAILBOXES WILL BE RETURNED TO POST OFFICE ON SAID DATE.

TENANT: CUSTOMER HAS THE LEGAL RIGHT AND PRIVILEGE TO PAY THE TOTAL PAST DUE AMOUNT AND VACATE THE PROPERTY BEFORE THE STATED SALE DATE.

SECURITY MINI STORAGE #2
4900 I-55 EAST SERVICE ROAD
MARION, AR 72364
TELEPHONE: (870)739-1555
22

ORDER OF PUBLICATION

No. CH-16-0523-1 IN THE CHANCERY COURT OF SHELBY COUNTY, TENNESSEE

IN THE MATTER OF: ROYALTY MARIE SIMON (DOB: February 1, 2016), A Minor,

BETHANY CHRISTIAN SERVICES OF WEST TENNESSEE, INC., Petitioner,

vs. TARINO "LAST NAME UNKNOWN" and ANY UNKNOWN FATHER, Respondents.

It appearing from the sworn petition for termination of parental rights filed in this cause that the whereabouts of the Respondents, Tarino "Last Name Unknown" and Any Unknown Father, are unknown and cannot be ascertained upon diligent inquiry. It further appearing that Respondent, Tarino "Last Name Unknown" is an African-American male, approximately 5'7" tall, with dark hair and a medium brown complexion. Conception of the minor child occurred at a hotel in West Memphis, Crittenden County, Arkansas

(870)732-9100
15,22

EEOE/AAP
866-326-2679
www.drive4marten.com

The West Memphis Utility Commission and the City of West Memphis is required in its National Pollutant Discharge Elimination System Permit (NPDES) to list significant violators to the Industrial pretreatment program. This is a requirement by the United States Environmental Protection Agency and the State of Arkansas Department of Environmental Quality.

For this reporting period March 2015 - February 2016 there were five significant violators for this reporting period.

Automated Conveyors
3850 Southland Drive
West Memphis, AR 72301
This was due to Chronic violations and Technical Review Criteria (TRC) violations.

Qualawash Services
400 Mound City Road
West Memphis, AR 72301
This was due to Technical Review Criteria (TRC) violation.

Stateside Steel
304 Wyanoke Road
West Memphis, AR 72301
This was due to Technical Review Criteria (TRC) violations.

Wastewater Solutions
408 Mound City Road
West Memphis, AR 72301
This was due to Technical Review Criteria (TRC) violations.

Warren Unilube
915 East Jefferson
West Memphis, AR 72301
This was due to a spill at the facility causing harm to POTW.

25

WMSD is accepting bids for a new pick-up truck. Bids are due to the Supt's office by noon on Tuesday, May 10, 2016. Contact Bill Cook, Business Mgr for specs. 870-735-1915.

22,29

021 CEMETERY LOTS

BURIAL PLOTS (2) - Crittenden Memorial Park, section 14, lot 79, plots 1 and 3. \$975 each. Call 901-489-4140.

MAUSOLEUM - Crittenden Memorial Park, Level A, double, crypt 15. \$4,225. Call 901-219-7504 or 901-581-4757.

070 EMPLOYMENT

EXPERIENCED COOK Needed - Nights and weekends. Apply in person, Fun-kee's Cafe, 2895 Highway 77, Suites 2 and 3, Marion.

CDL CLASS A DRIVERS

Local Drivers w/1 year Flatbed Exp Home Every Night/M-F Only/No Overnights

Dental, Vision, Health Insurance/EST min \$40K per year Paid Vac., Holidays and 401 K

Contact Bee Matthew, 870-733-8911 or Fax Resume 870-733-0243 or email bee.matthews@wmsteel.com

MAINTENANCE SUPERVISOR

Are you well versed in electronics & electrical equipment? Is installing, maintaining & troubleshooting industrial machinery something you enjoy? If you have a "hands on" leadership style and would like to engineer & implement changes that will improve performance & eliminate problems, then you are just the kind of person for our Maintenance Supervisor!

Qualifications - preventive/predictive maintenance; implement & execute all safety procedures; oversee all troubleshooting, PM's, planning and scheduled repairs; prefer a technical degree; 5 plus years' experience with maintenance & supervision; PLC, VFD, process controls, etc, multi-voltage experience.

Please apply by sending an updated resume with salary requirements to hresources915@gmail.com
Must pass pre-employment drug test & background check.
EOE/M/V/F/D

Oakridge Behavioral Care, a 54 bed inpatient behavioral health facility in West Memphis AR, is looking for individuals with patient centered care and behavioral health experience to come and be a part of our treatment team.

Teacher

Arkansas Special Education Certification preferred. Tuition reimbursement for SPED coursework.


We offer a competitive salary commensurate with experience.

INSTR AUBREY State II C# 901
LONNIE IMPRO
Carpentry, R...
Flooring, Pr...
Replaceme...
Insu...
Stat...
Cell 670...

Reed's RAMOND
Bathrooms
Drywall, Roc...
Patios,
Vinyl Siding, F...
Licensed
870-
reedsremodelir

1
7
1/Wic
Full
Buck
Chip
Stun
Grap
Se
87

Fill in the bla
column and
level ranges
4 1
6
2 7
5



WEST MEMPHIS UTILITY COMMISSION

P O Box 1868 604 East Cooper

West Memphis, AR 72303

Phone (870) 735-3355 Fax (870) 732-7623

Industrial Users For West Memphis, Arkansas

Automated Conveyors Systems Inc.

3850 Southland Drive

West Memphis, AR 72301

Categorical Industry

Standard Industrial Classification - 3535

North American Industry Classification System - 333922

Industrial Waste Discharge Permit Number - 02

Permit Issued – June 1, 2014 Expires – May 31, 2017

This industry only discharges into the city's wastewater system once or twice yearly to clean their equipment.

In a twelve month period there has been a total of 2 sampling visits made.

Compliance Status – SNC – 3 Copper violation, 3 Silver violation and 2 Zinc violation.

Coca-Cola Bottling Company

1400 Rainer Road

West Memphis, Arkansas 72301

Non-Significant Non-Categorical Industry

Standard Industrial Classification -

North American Industry Classification System - 312111

Industrial Waste Discharge Permit Number - 08

Permit Issued – June 1, 2014 Expires – May 31, 2017

Samples are taken on a monthly basis for permit reporting and a grab sample is pulled when possible.

In a twelve month period there has been a total of 52 sampling visits made.

Compliance Status – Complaint – No violations.



Department of Environmental Quality

Grace Trailer Service

615 Petro Cove
West Memphis, Arkansas 72301

Categorical Industry

Standard Industrial Classification - 7699
North American Industry Classification System – 811192
Industrial Waste Discharge Permit Number - 24
Permit Issued – June 1, 2014 Expires – May 31, 2017

Samples are taken on a monthly basis for permit reporting this is done twice a month. A grab sample is pulled when possible.

In a twelve month period there has been a total of 161 sampling visits made.
Compliance Status - NC- 6 pH violations and 4 TPH O&G violations, 1 Copper violation & 2 Mercury violations.

Langston Bag

1100 North 7th
West Memphis, Arkansas 72301

Non-Significant Non-Categorical Industry

Standard Industrial Classification - 2674
North American Industry Classification System – 322224
Industrial Waste Discharge Permit Number - 10
Permit Issued – June 1, 2014 Expires – May 31, 2017

Samples are taken on a monthly basis for permit reporting and a grab sample is pulled when possible.

In a twelve month period there has been a total of 62 sampling visits made.
Compliance Status – NC – 2 O&G violations and 2 Copper violations.

Nu-Way Products

220 Garrison (213 Front)
West Memphis, Arkansas 72301

Non-Significant Non-Categorical Industry

Standard Industrial Classification - 2842
North American Industry Classification System – 325612
Industrial Waste Discharge Permit Number - 11
Permit Issued – June 1, 2014 Expires – May 31, 2017

This industry is batch discharge only and must notify us before they discharge.
There are no daily grab samples pulled.

In a twelve month period there has been a total of 2 sampling visits made.
Compliance Status – Compliant - no violations.



Quala Services

400 Mound City Road
West Memphis, AR 72301

Categorical Industry

Standard Industrial Classification - 7699

North American Industry Classification System – 811192

Industrial Waste Discharge Permit Number - 24

Permit Issued – June 1, 2014 Expires – May 31, 2017

Samples are taken on a monthly basis for permit reporting this is done twice a month. A grab sample is pulled when possible.

In a twelve month period there has been a total of 80 sampling visits made.

Compliance Status – SNC - 9 pH violations, 11 Copper violations, 1 Mercury violation and 2 TPH O&G violations, Compliance Order.

Stateside Steel and Wire, LLC

304 Wyanoke Road
West Memphis, AR 72301

Categorical Industry

Standard Industrial Classification - 3315

North American Industry Classification System - 331222

Industrial Waste Discharge Permit Number - 25

Permit Issued – July 1, 2013 Expires – June 30, 2016

Samples are taken on a monthly basis for permit reporting and a grab sample is pulled when possible.

In a twelve month period there has been a total of 28 sampling visits made.

Compliance Status – SNC –1 Chromium violation and 11 Zinc violations.

Warren Unilube

915 East Jefferson
West Memphis, AR 72301

Non-Significant Non-Categorical Industry

Standard Industrial Classification – 2992

North American Industry Classification System -

Industrial Waste Discharge Permit Number - 27

Permit Issued – June 1, 2011 Expires – May 31, 2014

Samples are taken on a monthly basis for permit reporting. This industry is batch discharge only and must notify us before they discharge.

In a twelve month period there has been a total of 157 sampling visits made.

Compliance Status – SNC – 1 pH violation and 2 TPH O&G violations,
Compliance Order.



Waste Water Solutions, LLC

408 Mound City Road

West Memphis, AR 72301

Categorical Industry

Standard Industrial Classification –

North American Industry Classification System - 562211

Industrial Waste Discharge Permit Number - 28

Permit Issued – September 1, 2014 Expires – August 31, 2017

Samples are taken on a monthly basis for permit reporting and a grab sample is pulled when possible.

In a twelve month period there has been a total of 90 sampling visits made.

Compliance Status – SNC – 2 pH violations, 10 Zinc violations, 1 O&G violation, 1 TPH O&G violation, 2 Cobalt violations, 1 o-Cresol violation, 1 Arsenic violation, 1 n-Octadecane violation and 13 p-Cresol violations.

