

## Henderson, Katie

---

**From:** Gilliam, Allen  
**Sent:** Tuesday, March 23, 2010 2:21 PM  
**To:** 'clarksville pam crow'  
**Cc:** Henderson, Katie  
**Subject:** Clarksville 2009 Annual Pretreatment Report (AR0022187) Review

Pam,

Your 2009 Annual Pretreatment Report was reviewed and deemed complete and compliant with 40 CFR 403.12(i).

The effluent sample taken from your POTW on 4/29/09 exceeded the calculated copper "WQ level not to exceed". This event may have been caused by contamination, lab error, etc. If this occurs again, you might want to immediately conduct an investigation of its source. If enough sample is saved at your contract lab, you might consider asking them to re-analyze to verify levels such as this.

Any activity at your drinking water plant (corrosion inhibition problems?) that might be asked about?

Other than the above observation and comment, no further action is required.

Thank you for your timely submittal.

Sincerely,

Allen Gilliam  
ADEQ State Pretreatment Coordinator  
501.682.0625

cc: Katie Henderson/E-drive/Pretreatment Reports