

## Jamie Belcourt (adpce.ad)

---

**From:** Jamie Belcourt (adpce.ad)  
**Sent:** Tuesday, February 21, 2023 10:44 AM  
**To:** 'Porsha.Russell@clarksvilleconnected.net'; 'Rainey, Gregg'  
**Cc:** Stacie Wassell (adpce.ad); Richard Healey (adpce.ad); David Ramsey (adpce.ad)  
**Subject:** Clarksville Connected Utilities January 2022 - December 2022 Pretreatment Program Annual Report (NPDES Permit AR0022187)

Hello,

Clarksville Connected Utilities' January 1, 2022 – December 31, 2022 Pretreatment Program Annual Report (NPDES Permit AR0022187) was received, reviewed, and deemed complete and compliant according to the reporting requirements of 40 C.F.R. § 403.12(i).

Thank you for your timely submittal. If you have any questions or concerns on this matter, please feel free to contact me.

Best,

Jamie Belcourt | State Pretreatment Coordinator  
Division of Environmental Quality | Office of Water Quality  
Policy and Administration

5301 Northshore Drive | North Little Rock, AR 72118

t: 501.682.0858 | e: [jamie.belcourt@adeq.state.ar.us](mailto:jamie.belcourt@adeq.state.ar.us)



**ARKANSAS**  
ENERGY & ENVIRONMENT

**ATTACHMENT C**  
**PRETREATMENT PERFORMANCE SUMMARY (PPS)**

**NOTE:** ALL QUESTIONS REFER TO THE INDUSTRIAL PRETREATMENT PROGRAM AS APPROVED BY ADEQ. THE PERMITTEE SHOULD NOT ANSWER THE QUESTIONS BASED ON CHANGES MADE TO THE APPROVED PROGRAM WITHOUT DEPARTMENT AUTHORIZATION.

I. General Information

Control Authority Name Clarksville Connected Utilities

Address P.O. Box 1807

City Clarksville State/Zip AR 72830

Contact Person Porsha Russell Position Pretreatment Coord.

Contact Telephone (479) 754-3148  
Ext 304 NPDES Permit Nos. AR 0022187

Reporting Period January 1, 2022 December 31, 2022  
 (Beginning Month, Day and Year) (Ending Month, Day and Year)

Total Number of Categorical IUs 1

Total Number of Significant Noncategorical IUs 2

Total Number of Non-Significant (yet permitted) IUs 0

II. Significant Industrial User Compliance

	<u>SIGNIFICANT INDUSTRIAL USERS</u>	
	<u>Categorical</u>	<u>NonCategorical</u>
1) No. of SIUs Submitting BMRs/Total No. Required. . . . .	<u>0/0</u>	<u>N/A*</u>
2) No. of SIUs Submitting 90-Day Compliance Reports/No. Required. . . . .	<u>0/0</u>	<u>N/A*</u>
3) No. of SIUs Submitting Semiannual Reports/ Total No. Required. . . . .	<u>1/1</u>	<u>2/2</u>
4) No. of SIUs Meeting Compliance Schedule/ Total No. Required to Meet Schedule . . . . .	<u>0/0</u>	<u>0/0</u>
5) No. of SIUs in Significant Noncompliance/ Total No. of SIUs . . . . .	<u>0/1</u>	<u>0/2</u>
6) Rate of Significant Noncompliance for all SIUs (categorical and noncategorical) . . .	<u>0</u>	

III. Compliance Monitoring Program

	<u>SIGNIFICANT INDUSTRIAL USERS</u>	
	<u>Categorical</u>	<u>NonCategorical</u>
1) No. of Control Documents Issued/Total No. Required. . . . .	<u>1/1</u>	<u>2/2</u>
2) No. of Nonsampling Inspections Conducted. . . . .	<u>1/1</u>	<u>2/2</u>
3) No. of Sampling Visits Conducted. . . . .	<u>2/1</u>	<u>4/2</u>
4) No. of Facilities Inspected (nonsampling) . . . . .	<u>0/0</u>	<u>0/0</u>
5) No. of Facilities Sampled . . . . .	<u>1/1</u>	<u>2/2</u>

IV. Enforcement Actions

	<u>SIGNIFICANT INDUSTRIAL USERS</u>	
	<u>Categorical</u>	<u>NonCategorical</u>
1) No. of Compliance Schedules Issued/No. of Schedules Required . . . . .	<u>0/0</u>	<u>0/0</u>
2) No. of Notices of Violations Issued to SIUs	<u>0</u>	<u>0</u>
3) No. of Administrative Orders Issued to SIUs	<u>0</u>	<u>0</u>
4) No. of Civil Suits Filed. . . . .	<u>0</u>	<u>0</u>
5) No. of Criminal Suits Filed . . . . .	<u>0</u>	<u>0</u>
6) No. of Significant Violators (attach newspaper publication). . . . .	<u>0</u>	<u>0</u>
7) Amount of Penalties (not surcharges) Collected (total dollars/IUs assessed) . . . . .	<u>0/0</u>	<u>\$18,000/1</u>
8) Other Actions (sewer bans, etc.). . . . .	<u>0</u>	<u>0</u>

The following certification must be signed in order for this form to be considered complete:

I certify that the information contained herein is complete and accurate to the best of my knowledge.



Authorized Representative

Date 1-23-2023





MONITORING RESULTS FOR THE ANNUAL PRETREATMENT REPORT

REPORTING YEAR: Jan-22 TO Dec-22  
 TREATMENT PLANT: CITY OF CLARKSVILLE NPDES PERMIT WA00022187  
 AVERAGE POTW FLOW: 1.4202 MGD % IU FLOW: 16.8%

METALS CYANIDE and PHENOLS (Total)	MAHC ug/l	Influent Dates Sampled (ug/l)					WQ level/ limit ug/l	Effluent Dates Sampled (ug/l)					Laboratory Analysis (See Attachment PPS)		
		Once/Quarter						Once/Quarter					EPA Method Used	Detection Level Achieved (ug/l)	
		1/24/2022	5/16/2022	7/25/2022	10/18/2022	11/2/2022		1/25/2022	5/17/2022	6/13/2022	7/26/2022	8/25/2022			10/20/2022
Antimony	N/A	ND	ND	ND	ND	N/A	ND	ND	ND	ND	ND	ND	ND	200.7	15
Cadmium	5.35	ND	ND	ND	ND	5.29	ND	ND	ND	ND	5.29	ND	ND	200.7	5
Copper	134	15.8	ND	26.4	34.4	45.75	ND	ND	ND	ND	45.75	ND	ND	200.7	10
Lead	55.3	ND	ND	ND	ND	20.04	ND	ND	ND	ND	20.04	ND	ND	200.7	10
Mercury	0.27	0.0151	0.0109	0.0257	0.0267	0.013	0.00298	0.00225	0.00442	0.0131	0.00798	0.00798	1631E	0.0005	
Nickel	49.2	ND	ND	ND	ND	514	ND	ND	ND	ND	514	ND	ND	200.7	5
Selenium	6.43	ND	ND	ND	ND	5.58	ND	ND	ND	ND	5.58	ND	ND	200.7	15
Silver	36.1	ND	ND	ND	ND	14.44	ND	ND	ND	ND	14.44	ND	ND	200.7	7
Zinc	500	84.5	48.5	81.6	91.1	444	41.3	27	52.8	23.1	23.1	23.1	200.7	20	
Chromium	154	ND	ND	ND	38.6	1192	ND	ND	ND	ND	1192	ND	ND	200.7	5
Cyanide	18.7	ND	6.3	ND	ND	5.8	ND	7.2	12	ND	ND	ND	ND	SM4500	5
Arsenic	5.45	ND	ND	ND	ND	411.00000	ND	ND	ND	ND	411.00000	ND	ND	200.7	10
Molybdenum	8.1	ND	ND	ND	ND	N/A	ND	ND	ND	ND	N/A	ND	ND	200.7	20
Phenols	N/A	ND	1000	310	ND	N/A	ND	420	280	ND	N/A	ND	ND	420.1	50
Beryllium	11.8	ND	ND	ND	ND	5.91000	ND	ND	ND	ND	5.91000	ND	ND	200.7	1
Thallium	N/A	ND	ND	ND	ND	N/A	ND	ND	ND	ND	N/A	ND	ND	200.7	20
Flow, MGD	N/A	1.442	1.631	0.949	1.21	0.754	1.164	1.481	0.903	1.156	1.022	1.275	1.156	1.022	1.275