

# Clarksville 2019 Pretreatment Program Annual Report

Yates, Adam

Wed 5/27/2020 11:47 AM

To: pam.smith@clarksvilleconnected.net <pam.smith@clarksvilleconnected.net>;

Cc: Healey, Richard <HEALEYR@adeq.state.ar.us>; Ramsey, David <RAMSEY@adeq.state.ar.us>; Allen-Daniel, Leslie <ALLEN-DANIEL@adeq.state.ar.us>; Gray, Gavin <Gavin.Gray@adeq.state.ar.us>;

Pam,

City of Clarksville's Feb 2020 Pretreatment Program Annual Report was received, reviewed, and deemed complete and compliant according to the reporting requirements of 40 CFR 403.12(i).

Thank you for your timely submittal. If you have any questions or concerns on this matter, please feel free to contact me.

Kindly,

**Adam Yates** | State Pretreatment Coordinator  
**Division of Environmental Quality | Office of Water Quality**  
5301 Northshore Drive | North Little Rock, AR 72118  
t: (501) 682-0617 | e: [yates@adeq.state.ar.us](mailto:yates@adeq.state.ar.us)



February 18, 2020

Mr. Yates

RE: Annual Report

Dear Mr. Yates

Please find enclosed our 13th annual list – violator's industrial users as required by our permit. I have included our MAHL as required. If you have any questions please feel free to give us a call 479-754-6241 ext 304.

Sincerely

A handwritten signature in black ink that reads "Gregg Rainey". The signature is written in a cursive style with a large initial "G".

Gregg Rainey  
Superintendent

A handwritten signature in black ink that reads "Pam Smith". The signature is written in a cursive style with a large initial "P".

Pam Smith  
Pretreatment Coordinator

ATTACHMENT A  
 PRETREATMENT PROGRAM STATUS REPORT  
 UPDATED SIGNIFICANT INDUSTRIAL USERS LIST

Industrial User Name	SIC/NAICS Code	40 CFR XXX or N/A	Control Document		New User	Times Inspected	Times Sampled	Compliance Status (N/A, C, NC, or SNC)				Permit Limits (denote parameter violated & number of times)
			Y/N	Last Action				Reports				
								BMR	90-day Compliance	Semi Annual	Self Monitoring	
Greenville Tube	3356/3317 333149/ 331210	433.17	Y	2-1-19	N	1	1	N/A	N/A	C	C	
Hanesbread	2251/ 313310	403	Y	9-1-16	N	1	1	N/A	N/A	C	C	
Petsweet	2037/ 311411	403	Y	6-1-18	N	1	1	N/A	N/A	C	WC	6 BOD 3 pH

Include NAICS code(s)  
 3<sup>rd</sup> column - include the CFR # only if the Category has Pretreatment Standards (numeric or narrative)  
 Please footnote N/A reason



ATTACHMENT C  
PRETREATMENT PERFORMANCE SUMMARY (PPS)

NOTE: ALL QUESTIONS REFER TO THE INDUSTRIAL PRETREATMENT PROGRAM AS APPROVED BY ADEQ. THE PERMITTEE SHOULD NOT ANSWER THE QUESTIONS BASED ON CHANGES MADE TO THE APPROVED PROGRAM WITHOUT DEPARTMENT AUTHORIZATION.

I. General Information

Control Authority Name Clarksville Connected Utilities  
 Address P.O. Box 1807  
 City Clarksville State/Zip AR 72830  
 Contact Person Pam Smith Position Pretreatment Coordinator  
                                 Ext. 304  
 Contact Telephone 478-754-6241 NPDES Permit Nos. AR0022187  
 Reporting Period January, 2019                    December 31, 2019  
                                 (Beginning Month, day and Year)                    (Ending Month, day and Year)  
 Total Number of Categorical IUs 1  
 Total Number of Significant Noncategorical IUs 2  
 Total Number of Non-Significant (yet permitted) IUs 0

II. Significant Industrial User Compliance

	<u>SIGNIFICANT INDUSTRIAL USERS</u>	
	<u>Categorical</u>	<u>NonCategorical</u>
1) No. of SIUs Submitting BMRs/Total No. Required. . . . .	<u>1/1</u>	<u>N/A*</u>
2) No. of SIUs Submitting 90-Day Compliance Reports / No. Required. . . . .	<u>0/0</u>	<u>N/A*</u>
3) No. of SIUs Submitting Semiannual Reports / Total No. Required. . . . .	<u>1/1</u>	<u>2/2</u>
4) No. of SIUs Meeting Compliance Schedule / Total No. Required to Meet Schedule . . . . .	<u>0/0</u>	<u>0/0</u>
5) No. of SIUs in Significant Noncompliance / Total No. of SIUs . . . . .	<u>0/1</u>	<u>0/2</u>
6) Rate (%) of Significant Noncompliance for all SIUs (categorical and noncategorical) . . . . .	<u>0</u>	

III. Compliance Monitoring Program

SIGNIFICANT INDUSTRIAL USERS  
Categorical                    NonCategorical

1) No. of Control Documents Issued / Total No. Required. . . . .	<u>11</u>	<u>2/2</u>
2) No. of Non-sampling Inspections Conducted / Total No. Required. . . . .	<u>1</u>	<u>2</u>
3) No. of Sampling Visits Conducted / Total No. Required. . . . .	<u>11</u>	<u>2/2</u>
4) No. of Facilities Inspected (nonsampling) / Total No. Required. . . . .	<u>0</u>	<u>0/0</u>
5) No. of Facilities Sampled / Total No. Required. . . . .	<u>11</u>	<u>2/2</u>

IV. Enforcement Actions

	<u>SIGNIFICANT INDUSTRIAL USERS</u>	
	<u>Categorical</u>	<u>NonCategorical</u>
1) No. of Compliance Schedules Issued/No. of Schedules Required . . . . .	<u>0</u>	<u>0</u>
2) No. of Notices of Violations Issued to SIUs	<u>0</u>	<u>9</u>
3) No. of Administrative Orders Issued to SIUs	<u>0</u>	<u>0</u>
4) No. of Civil Suits Filed. . . . .	<u>0</u>	<u>0</u>
5) No. of Criminal Suits Filed . . . . .	<u>0</u>	<u>0</u>
6) No. of Significant Violators (attach newspaper publication). . . . .	<u>0</u>	<u>0</u>
7) Amount of Penalties (not surcharges) Collected (total dollars/IUs assessed) . . . .	<u>0</u>	<u>0</u>
8) Other Actions (sewer bans, etc.). . . . .	<u>0</u>	<u>0</u>

The following certification must be signed in order for this form to be considered complete:

I certify that the information contained herein is complete and accurate to the best of my knowledge.

Alex Raimy

Authorized Representative

Date 2-18-2020

**MONITORING RESULTS (1) FOR THE ANNUAL PRETREATMENT REPORT**

REPORTING YEAR: Jan-19 TO Dec-19  
 TREATMENT PLANT: CITY OF CLARKSVILLE NPDES PERMIT #AR0022187  
 AVERAGE POTW FLOW: 1.358 % IU FLOW 8.87 %

METALS CYANIDE and PHENOLS (Total)	MAHC ug/l	Influent Dates Sampled (ug/l) Once/Quarter				WQ level/ limit ug/l	Effluent Dates Sampled (ug/l) Once/Quarter				Laboratory Analysis (See Attachment PPS)	
		1/30/2019	4/23/2019	9/3/2019	11/19/2019		1/31/2019	4/24/2019	9/4/2019	11/20/2019	EPA Method Used	Detection Level Achieved (ug/l)
Antimony	N/A	0	0	0	0	N/A	0	0	0	0	200.8	60
Cadmium	5.35	0	0	0	0	5.29	0	0	0	0	200.8	0.5
Copper	134	13.6	13.3	21.1	18.6	45.75	0	0	0	0	200.8	0.5
Lead	55.3	0	0	0	0	20.04	0	0	0	0	200.8	0.5
Mercury	0.27	0.0144	0.0206	0.0374	0.056	0.013	0.0032	0.00643	0.0189	0.00566	1631E	0.005
Nickel	49.2	0	0	0	0	514	0	0	0	0	200.8	0.5
Selenium	8.43	0	0	0	0	5.58	0	0	0	0	200.8	5
Silver	36.1	0	0	0	0	14.44	0	0	0	0	200.8	0.5
Zinc	500	42.7	69.4	67.8	93.4	444	35.1	27.6	66.7	31.9	200.8	20
Chromium	154	0	8.5	5.6	5	1192	0	0	0	0	200.8	10
Cyanide	18.7	0	0	0	0	5.8	0	0	12	0	SM4500	10
Arsenic	5.45	0	0	0	0	411.00000	0	0	0	0	200.8	0.5
Molybdenum	8.1	0	0	0	0	N/A	0	0	0	0	200.8	8
Phenols	N/A	0	0	0	0	N/A	0	0	0	0	420.1	5
Beryllium	11.8	0	0	0	0	5.91000	0	0	0	0	200.8	0.5
Thallium	N/A	0	0	0	0	N/A	0	0	0	0	200.8	0.5
Flow, MGD	N/A	1.589	0.853	1.584	0.977	N/A	1.218	1.186	1.712	0.997		