



P.O. Box 1807 • Phone (479) 754-3148 • Clarksville, Arkansas 72830

February 8, 2011

Mr. Gene Little

RE: AR0022187 AFIN # 36-00038

Dear Mr. Little

*2010 Annual Report complete/compliant
AF*

Please find enclosed our 6th annual list – violator's industrial users as required by our permit. Please note the violations on attachment A. I have included our MAHL as required by our permit. If you have any questions please feel free to call me at 479-754-7929.

Sincerely

Gregg Rainey
Superintendent

Pam Smith
Pretreatment Coordinator

ATTACHMENT C
 PRETREATMENT PERFORMANCE SUMMARY (PPS)

NOTE: ALL QUESTIONS REFER TO THE INDUSTRIAL PRETREATMENT PROGRAM AS APPROVED BY ADEQ. THE PERMITTEE SHOULD NOT ANSWER THE QUESTIONS BASED ON CHANGES MADE TO THE APPROVED PROGRAM WITHOUT DEPARTMENT AUTHORIZATION.

I. General Information

Control Authority Name Clarksville Light & Water

Address P.O. Box 1807

City Clarksville State/Zip AR. 72830

Contact Person Dan Smith Position Pretreatment

Contact Telephone 479-754-1929 NPDES Permit Nos. AR0022187

Reporting Period Jan. 2010 Dec. 2010
 (Beginning Month and Year) (Ending Month and Year)

Total Number of Categorical IUs one

Total Number of Significant Noncategorical IUs TWO

Total Number of Non-Significant (yet permitted) IUs 0
Permitted yet no discharge one

II. Significant Industrial User Compliance

	<u>SIGNIFICANT INDUSTRIAL USERS</u>	
	<u>Categorical</u>	<u>NonCategorical</u>
1) No. of SIUs Submitting BMRs/Total No. Required.	<u>0/0</u>	<u>N/A*</u>
2) No. of SIUs Submitting 90-Day Compliance Reports/No. Required.	<u>0/0</u>	<u>N/A*</u>
3) No. of SIUs Submitting Semiannual Reports/ Total No. Required.	<u>1/1</u>	<u>2/2</u>
4) No. of SIUs Meeting Compliance Schedule/ Total No. Required to Meet Schedule	<u>0/0</u>	<u>0/0</u>
5) No. of SIUs in Significant Noncompliance/ Total No. of SIUs	<u>0/1</u>	<u>0/2</u>
6) Rate of Significant Noncompliance for all SIUs (categorical and noncategorical)		<u>0/</u>

III. Compliance Monitoring Program

	<u>SIGNIFICANT INDUSTRIAL USERS</u>	
	<u>Categorical</u>	<u>NonCategorical</u>
1) No. of Control Documents Issued/Total No. Required.	<u>1/1</u>	<u>2/2</u>
2) No. of Nonsampling Inspections Conducted.	<u>2/1</u>	<u>2/1</u>
3) No. of Sampling Visits Conducted.	<u>4/1</u>	<u>8/1</u>
4) No. of Facilities Inspected (nonsampling)	<u>0/1</u>	<u>0/1</u>
5) No. of Facilities Sampled	<u>2/1</u>	<u>2/1</u>

IV. Enforcement Actions

	<u>SIGNIFICANT INDUSTRIAL USERS</u>	
	<u>Categorical</u>	<u>NonCategorical</u>
1) No. of Compliance Schedules Issued/No. of Schedules Required	<u>0/0</u>	<u>0/0</u>
2) No. of Notices of Violations Issued to SIUs	<u>0</u>	<u>12</u>
3) No. of Administrative Orders Issued to SIUs	<u>0</u>	<u>0</u>
4) No. of Civil Suits Filed.	<u>0</u>	<u>0</u>
5) No. of Criminal Suits Filed	<u>0</u>	<u>0</u>
6) No. of Significant Violators (attach newspaper publication).	<u>0</u>	<u>0</u>
7) Amount of Penalties (not surcharges) Collected (total dollars/IUs assessed)	<u>0/0</u>	<u>0/0</u>
8) Other Actions (sewer bans, etc.).	<u>0</u>	<u>0</u>

The following certification must be signed in order for this form to be considered complete:

I certify that the information contained herein is complete and accurate to the best of my knowledge.

Drew Rainey
 Authorized Representative Date 2-7-2011

MONITORING RESULTS (1) FOR THE ANNUAL PRETREATMENT REPORT

REPORTING YEAR: Jan-10 TO Dec-10
 TREATMENT PLANT: CITY OF CLARKSVILLE NPDES PERMIT #AR0022187
 AVERAGE POTW FLOW 1.156 %
IJ FLOW 8.52 %

METALS CYANIDE and PHENOLS (Total)	MAHC ug/l	Influent Dates Sampled (ug/l) Once/Quarter				WQ level/ limit ug/l	Effluent Dates Sampled (ug/l) Once/Quarter		
		2/17/2010	5/18/2010	8/11/2010	11/16/2010		2/18/2010	5/19/2010	8/13/2010
Antimony	N/A	0	0	0	0	N/A	0	0	0
Cadmium	5.4	0	0	0	0	5.3	0	0	0
Copper	158	34	39	43	83	45.7	4.2	6.4	8.6
Lead	51.4	1.4	1.9	2.4	5.4	20	0	0	0
Mercury	0.27	0.0518	0.102	0.181	0.288	0.013	0.0116	0.01449	0.01085
Nickel	42.1	4.9	4.8	5.9	13	514	2.1	3.4	4.3
Selenium	8.4	0	0	0	0	5.6	0	0	0
Silver	57.8	13	0.62	1.4	3.8	14.4	0	0	9.1
Zinc	500	55	86	160	230	444	22	34	28
Chromium	154	0	0	0	20	1192	0	0	0
Cyanide	18.7	0	0	0	0	5.8	0	0	0
Arsenic	7	0	0	0	0	411.00000	0	0	0
Molybdenum	8	0	0	0	0	N/A	0	0	0
Phenols	N/A	27	52	33	48	N/A	22	18	0
Beryllium	11.8	0	0	0	0	5.90000	0	0	0
Thallium	N/A	0	0	0	0	N/A	0	0	0
Flow, MGD	N/A	1.236	0.8	1.347	0.681	N/A	1.232	0.968	1.008

Laboratory Analysis (See Attachment PPS)		EPA Method Used	Detection Level Achieved (ug/l)
11/17/2010	0	200.8	60
	0	200.8	0.5
	8.2	200.8	0.5
	0	200.8	0.5
	0.00472	1631E	0.0005
	3.2	200.8	0.5
	0	200.8	5
	0	200.8	0.5
	36	200.8	20
	0	200.8	10
	0	SM4500	10
	0	200.8	0.5
	0	200.8	8
	0	420.1	5
0	200.8	0.5	
0	200.8	0.5	
0.704	200.8	0.5	

7003 2260 0002 2247 4382




CLARKSVILLE LIGHT & WATER CO.
 400 WEST MAIN • P.O. BOX 1807
 CLARKSVILLE, AR 72830
 PHONE (479) 754-3148

TO:
 ADEQ
 5301 Northshore Drive
 North Little Rock, AR 72118-5317
 ATTN: Allen Gilliam



UNITED STATES POSTAGE

 02 1M
 000 4255 430
 MAILED FROM ZIP CODE 72830
\$ 06.15⁰⁰
 FEB 08 2011
 RINET BOWES



PPS Program Report

* NPDES ID: 120022187Permittee's Name Clarksville* Report Received/Event Date: 2/11/11Date 3/1/11**Report Type**

Select a Program Report to add

- Biosolids Program Report
- CAFO Annual Report
- CSO Event Report
- Local Limits Report
- MS4 Program Report

- Pretreatment Performance Summary Report
- SSO Annual Report
- SSO Event Report
- SSO Monthly Event Report
- Storm Water Event Report

Report Information* Pretreatment Performance Summary Start Date: 1/1/10**Significant Industrial Users (SIUs)**

- SIUs: 3
- SIUs Without Control Mechanism: 0
- SIUs Not Inspected: 0
- SIUs Not Sampled: 0
- SIUs in SNC with Pretreatment Standards: 0
- SIUs in SNC with Reporting Requirements: 0
- SIUs in SNC with Pretreatment Schedule: 0
- SIUs in SNC Published in Newspaper: 0
- SIUs Schedules: 0
- Violation Notices Issued to SIUs: 12
- Administrative Orders Issued to SIUs: 0
- Civil Suits Filed Against SIUs: 0
- Criminal Suits Filed Against SIUs: 0

Categorical Industrial Users (CIUs)

- CIUs: 1
- CIUs in SNC: 0

Penalties

Dollar Amount of Penalties Collected: \$ _____

Industrial Users (IUs) from which Penalties have been collected: _____

Other Information

- SUO Reference: _____
- SUO Date: _____
- Annual Pretreatment Budget: \$ _____
- Pass-Through/Interference Indicator:
- Notification of IU Schedule for Remedial Measures: No
- Local Response to Violation of IU Schedule for Remedial Measures:

Local Limits

Date of Most Recent Technical Evaluation & or Local Limits: _____

Date of Most Recent Adoption of Technically Based Local Limits: _____

Local Limit Pollutants: _____

ADD / REMOVE

Removal Credits

Removal Credits Application Status: Not Applicable

Date of Most Recent Removal Credits Approval: _____

Removal Credits: _____

ADD / REMOVE

Acceptance of Waste

Acceptance of Hazardous Waste: No

Acceptance of Non-Hazardous Industrial Waste: No

Acceptance of Hauled Domestic Wastes: No

Deficiencies

Deficiencies Identified During IU File Review: No

Control Mechanism Deficiencies: No

Legal Authority Deficiencies: No

Deficiencies in Data Management and Public Participation: No

Deficiencies in Interpretation and Application of Pretreatment Standards: No

Inadequacy of Sampling and Inspections: No

Adequacy of Pretreatment Resources: Yes

Annual Frequency

Annual Frequency of Influent Toxicant Sampling: _____

Annual Frequency of Effluent Toxicant Sampling: _____

Annual Frequency of Sludge Toxicant Sampling: _____