

June 27, 2007

Allen Gilliam
ADEQ, Water Division
P.O. Box 8913
Little Rock, AR72219

Dear Mr. Gilliam,

Please find enclosed the closure inspection for Fujicolor Bentonville, Inc. performed yesterday June 26th.

If you have any questions regarding the closure please contact me at (479)-271-3160.

Approximately August 1, 2007 3M Company will be opening a small plant in Bentonville producing toothpaste & mouthwash. The expected discharge which will be categorical (SIC codes 2834 and 5122) is expected to be released in batch dumps of 60 gallons every other day. They will begin their BMR when production begins.

If you have any suggestions regarding this industry they would be most welcome.

Sincerely,

Nancy Busen
Nancy Busen
City of Bentonville, WWTF
Lab/Pretreatment Supervisor

NPDES PERMIT FILE
NPDES # _____
AFIN # _____
_____ Permit PN
_____ ✓ Correspondence
_____ ✓ Technical Backup
7-2-07 su Date Scanned



June 27, 2007

Closure Inspection Report;

Bill Thompson
Operations Manager
Fujicolor Processing, Inc.
1107 S.E. 10th St.
Bentonville, AR 72712

Dear Mr. Thompson,

Those present for the inspection on June 26, 2007 1:00pm were:

Bill Thompson, Operations Manager, Fujicolor - Bentonville
Jim Johnson, Jim Johnson, Technical Manager, Fujicolor - Bentonville
Jerry Burris, Chemical Technician, Fujicolor - Bentonville
Nancy Busen, Lab/ Pretreatment Supervisor, City of Bentonville
Román Rios, Laboratory Technician, City of Bentonville

All industrial cleaning has been completed at the Fujicolor photo processing facility in Bentonville. The trench drain running through the facility is clean and dry. No processing chemicals remain on the property or in the building. Some remaining equipment & metal shelving is currently being dismantled and scrapped or recycled. Some sold equipment (dry) still remains to be crated for shipping to other photo processing destinations.

The "V" notch weir in the sampling pit was removed. Accumulated sludge from behind this structure was contained and shipped to a silver recycling firm.

The property and building will return to Wal-Mart on or around August 1, 2007.

City of Bentonville, WWTF
Industrial Pretreatment Division


1901 N.E. "A" Street
Bentonville, AR 72712

479-271-3160
FAX: 479-271-3163

Intended use is non production. The sampling pit will be filled with concrete. I have contact Dean Button, Water Utilities Manager (479-271-31472) for direction about sealing the 8" discharge line.

Closure and cleanup of a facility such as Fujicolor is certainly no small project. Pretreatment and laboratory personnel sampled Monday thru Friday from March 7th thru June 19th, 2007. Random Silver samples were analyzed and pH was monitored continuously with no violations noted. This accomplishment is a testament to the continued diligence of staff and management at this facility.

I would like to thank you and your staff for your excellent record of environmental stewardship in Bentonville. I wish all of you the very best in your future endeavors.

A handwritten signature in cursive script that reads "Nancy Busen". The signature is written in black ink and is positioned above a solid horizontal line.

Nancy Busen
Pretreatment Supervisor
City of Bentonville WWTF
1901 N.E. 'A' Street
Bentonville, AR 72712

Fujicolor Bentonville Closure Inspection



8" discharge pipe to city sewer from Fujicolor Bentonville Plant ↑



Start of trench drain that runs throughout the plant. ↑

Fujicolor Bentonville Closure Inspection



End section of trench drain that runs throughout the plant. ↑



Floor section removed for soil sampling.
Results were satisfactory. ↑