

# ADEQ

ARKANSAS  
Department of Environmental Quality

September 10, 2008

James Yankee  
Pretreatment Coordinator  
Blytheville Wastewater Department  
Blytheville, AR 72316

Re: Blytheville (NPDES# AR0022560; AFIN# 47-00544) '07 - '08 Annual Report Review

Dear Mr. Yankee,

Per the e-mails this office has sent the Pretreatment Cities in the State, you should be aware of the new EPA required effluent MQL reporting requirements. The new analytical reporting requirements went into effect via this office's e-mail on 3/11/08.

Upon review of your three (3) wastewater plants' influent/effluent summary sheets, it was found your lab's analytical methods did not meet the required MQLs after that date; therefore, your 8/29/08 annual report is deemed incomplete. You will want to contact your lab and inform them of EPA's new MQLs requirement.

Please resample and re-submit within thirty (30) day to bring your reporting requirements back into compliance.

Sincerely,



Allen Gilliam  
ADEQ State Pretreatment Coordinator

cc: Anne Roberts / NPDES Enforcement

NPDES PERMIT FILE  
NPDES # AR0022560  
AFIN # 47-00544  
\_\_\_\_\_  
Permit PN  
\_\_\_\_\_  
Correspondence  
\_\_\_\_\_  
Technical Backup  
9/10/08 vlt Date Scanned