


MAYOR:
James Sanders

CITY COUNCIL:
John Musgraves
Stan Parks
R.L. Jones
Kevin Snow
Tommy Abbott
Missy Langston

Blytheville Wastewater Dept.
P.O. Box 1784
Blytheville, AR 72316-1784



Phone: (870) 763-4961
Fax: (870) 763-8541

ATTORNEY:
Mike Bearden

**PUBLIC UTILITIES
DIRECTOR:**
Marvin Crawford

SUPERINTENDENT:
Kenneth Ellis

August 1, 2014

Ms. Deborah Gerst
ADEQ
Water Division/Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118-5317

RE: Permit No: AR0022560 AFIN: 47-00544

Dear Ms. Gerst,

The Blytheville Wastewater Department is submitting a Final Compliance and Status/Progress report for its West Treatment Plant on mercury discharges.

The last 12 months mercury tests results are as follows beginning July 2013 for your review.

7/13	0.263 ug/l
8/13	0.560 ug/l
9/13	0.320 ug/l
10/13	0.078 ug/l
11/13	0.535 ug/l
12/13	0.186 ug/l
1/14	0.265 ug/l
2/14	0.100 ug/l
3/14	0.013 ug/l
4/14	0.142 ug/l
5/14	0.215 ug/l
6/14	0.052 ug/l

The Blytheville Wastewater Department will possibly begin issuing wastewater discharge permits to facilities that tested positive for mercury in their discharge to the City. Our

focus is on our dental offices to determine if they have a properly operating amalgam separator installed at their facility. There are no industries discharging to this treatment plant only residential and light commercial facilities.

If you need more information or have any questions, please contact me at (870)763-4961.

Sincerely,

A handwritten signature in cursive script that reads "James Yankee". The signature is written in black ink and is positioned above a horizontal line.

James Yankee
Pretreatment Coordinator
Blytheville Wastewater Department

Blytheville Wastewater

PO Box 1784

Blytheville, AR 72316-1784

MEMPHIS TN 380

01 AUG 2014 PM 3 L



Ms. Deborah Gerst
ADEQ
Water Division/Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118-5317

72118531799

