

MAYOR:
Barrett Harrison

CITY COUNCIL:
Ray Jones
Shirley Conneally
Shirley Overman
John White
Mylas Jeffers
James Sanders


ATTORNEY:
Mike Bearden

**PUBLIC UTILITIES
DIRECTOR:**
Rick Mosley

SUPERINTENDENT:
Kenneth Ellis

Blytheville Wastewater Dept.

P.O. Box 1784
Blytheville, AR 72316-1784



Phone: (870) 763-4961

Fax: (870) 763-8541

July 3, 2007

Allen Gilliam
A.D.E.Q. State Pretreatment Coordinator
P.O. Box 8913
Little Rock, AR 72219-8913

Re: NPDES # AR0022560 Pretreatment Program Audit/
Municipal Pollution Prevention (P2) Assessment

Dear Mr. Gilliam,

Please find enclosed the finished response to the required audit findings and our proposed corrective actions.

B) Summary of Findings with Required Actions:

- 1) Motor Technologies Group permit limits will be modified to reflect production based standards for the aluminum die casting operation or reuse the small quantity discharge as makeup water in its process(s).
- 2.a) Industry inspections will include more information about the facilities discharges, wastewater processes, chemical handling, P2 activities, and will include a representatives signature.
- 2.b) The sampling site at Motor Appliance Corporation has been moved to sample only their regulated waste stream.
- 3) Language in the Pretreatment Ordinance and I.U. permits will be changed to eliminate a re-application requirement for existing users.
- 4) Measurements and/or water usage for each I.U.s regulated process will be recorded on all monitoring days.

- 5) Comprehensive industry/non-domestic survey users list is being conducted and placed in a file for determination of waste streams and audits from ADEQ.
- 6) Each permitted I.U. will be assessed for slug potential and required to submit to the City a control plan if deemed necessary. The City will enforce the P2 assessment requirements.
- 7) Hazardous waste generators along with hospitals, dentists, and other healthcare facilities as well as photofinishers will be notified of this requirement and documented.
- 8) All I.U.s will be updated with current schematics, process flows, and general layouts of their facility.
- 9) 2.a) Operators are being trained to properly troubleshoot and maintain treatment plants.
2.b) Operators will also be trained in lab work.
2.c) (see 2.a. above) Should require less supervision.
2.d) Calls were from Industry batch dischargers, suppliers, engineers and operators because of aeration upgrades to each treatment plant. All upgrades have been completed.
- 3) We will begin cross training select individuals for pretreatment purposes.
- 4) We now have a clerical/secretarial assistant.

The City of Blytheville Wastewater Department will make every effort possible to remedy the non-compliance items listed above. We value the help and guidance from ADEQ in bringing our Pretreatment Program up to today's standards.

If you have any questions, or need more information, please contact me at (870) 763-4961.

Sincerely,



James Yankee
Pretreatment Coordinator